

Facility Summary in Lewis and Clark County in the City of Augusta

Location: AUGUSTA GAS STATION LLC
 130 Main St
 Augusta, MT 59410 Lewis and Clark

Legacy ID:25-02114

Facility ID: 23462
Last Inspected On: 08/18/2020
Operating Permit Renewal Date: 08/22/2023

Owner Operator Contact: Augusta Service Station LLP;Ben Arps;Exxon Service Station **4065623477**

Operator Contact: Susan Carlstrom **4065623377**

Owner/Operator: Augusta Service Station LLP

Susan Carlstrom, UST Class A Operator
 Susan Carlstrom, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
06	32	06/06/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3950	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		07/08/2008	Statistical Inventory Reconciliation	Not Listed	No
1,500					No
05	32	06/06/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3951	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		07/08/2008	Statistical Inventory Reconciliation	Not Listed	No
750					No
04	32	06/06/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3952	No			None	Yes

Currently in Use		Not Required	Safe Suction	Non-corrodible
Gasoline	07/08/2008	Statistical Inventory Reconciliation	Not Listed	No
750				No

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 1
 US Hwy 287
 Augusta, MT 59410 Lewis and Clark

Legacy ID:50-09030

Facility ID: 28877
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	59	06/02/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
303	No	05/23/2018	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		04/30/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 5
 MT Hwy 21
 Augusta, MT 59410 Lewis and Clark

Legacy ID:25-09034

Facility ID: 23808
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	05/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
247	No	05/23/2018	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 6
US Hwy 287
Augusta, MT 59410 Lewis and Clark

Legacy ID:25-09035

Facility ID: 23809
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator

William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	05/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
248	No	08/19/2018	Double-Walled	Double Walled	Yes
Currently in Use		08/19/2018	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 7
 Road 434
 Augusta, MT 59410 Lewis and Clark

Legacy ID:25-09036

Facility ID: 23810
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	06/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm

249	No	09/25/2018	Double-Walled	Double Walled	Yes
Currently in Use		09/25/2018	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB G 10
 US Hwy 287
 Augusta, MT 59410 Lewis and Clark

Legacy ID:25-09050

Facility ID: 23816
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/23/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	06/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
255	No	04/26/2018	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB G 9
 US Hwy 287
 Augusta, MT 59410 Lewis and Clark

Legacy ID:25-09049

Facility ID: 23815
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/23/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	30	10/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
254	No	04/26/2018	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of East Helena

Location: CANYON FERRY MINI BASKET
 3012 Canyon Ferry Rd
 East Helena, MT 59635-3025 Lewis and Clark

Legacy ID:25-03122

Facility ID: 23511
Last Inspected On: 11/15/2018
Operating Permit Renewal Date: 03/30/2022

Owner Operator Contact: Big Sky Food and Fuel Inc Helena;Ervin Hotz;Canyon Ferry Mini Basket Inc East Helena **4062278506;4064433608**

Operator Contact: Robert Merzlak **4064433608**

Owner/Operator: Big Sky Food and Fuel Inc Helena

Owner/Operator: Robert J Merzlak

Robert J Merzlak, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2319	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/13/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000		03/30/2006	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	14	10/16/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5151	No		Double-Walled	Double Walled	Yes
Currently in Use		02/19/2007	Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; MLLD Line Tightness Testing	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
05	14	10/16/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5152	No		Double-Walled	Double Walled	Yes
Currently in Use		02/19/2007	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP EAST HELENA 2
116 S Lane Ave
East Helena, MT 59635 Lewis and Clark

Legacy ID:56-13915

Facility ID: 30585
Last Inspected On: 06/04/2021
Operating Permit Renewal Date: 06/08/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: East Helena 2 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4028	No		Double-Walled	Double Walled	Yes
Currently in Use		06/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
02	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4029	No		Double-Walled	Double Walled	Yes
Currently in Use		06/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
03	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4030	No		Double-Walled	Double Walled	Yes
Currently in Use		06/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
04	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4031	No		Double-Walled	Double Walled	Yes
Currently in Use		06/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
05	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4032	No		Double-Walled	Double Walled	Yes
Currently in Use		06/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
06	22	03/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4033	No		Double-Walled	Double Walled	Yes
Currently in Use		06/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
07	18	08/18/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4861	No		Double-Walled	Double Walled	Yes
Currently in Use		06/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP INC EAST HELENA
418 W Main St
East Helena, MT 59635 Lewis and Clark

Legacy ID:25-08697

Facility ID: 23791
Last Inspected On: 08/11/2021
Operating Permit Renewal Date: 08/20/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: East Helena 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	53	04/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4672	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
02	53	04/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4673	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No

12,000			Gilbarco-Veeder Root/TLS-350		No
03	53	04/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4674	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
04	53	04/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4675	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
3,000			Gilbarco-Veeder Root/TLS-350		No
05	53	04/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4676	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
4,000			Gilbarco-Veeder Root/TLS-350		No
06	44	04/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4677	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No

07	44	04/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4678	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Fort Harrison

Location: VETERANS HEALTH ADMINISTRATION
3687 Veterans Dr Bldg 141
Fort Harrison, MT 59636 Lewis and Clark

Legacy ID:25-05908

Facility ID: 23656
Last Inspected On: 09/11/2020
Operating Permit Renewal Date: 02/03/2024

Owner Operator Contact: US Dept of Veterans Affairs

Operator Contact: Kailen Collette;Michael Harris

4064477382

Owner/Operator: US Dept of Veterans Affairs

Kailen Collette, UST Class A Operator
Michael Harris, UST Class A Operator
Steven Felter, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	28	12/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2214	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Deferred	No
1,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	28	12/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm

2216	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
4,000		06/13/2013	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
13	11	10/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5278	No	07/01/2011	Double-Walled	Double Walled	Yes
Currently in Use		04/26/2011	Not Required	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
8,000		06/13/2013	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
14	9	05/01/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
5366	No	05/24/2012	Double-Walled	Double Walled	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
10,000		03/30/2015	Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes

Facility Summary in Lewis and Clark County in the City of Helena

Location: ARMY AVIATION SUPPORT FACILITY
3333 Skyway Dr
Helena, MT 59602 Lewis and Clark

Legacy ID:56-13821

Facility ID: 30507
Last Inspected On: 11/29/2018
Operating Permit Renewal Date: 02/09/2022

Owner Operator Contact: US Dept of Military Affairs Helena

4063243000

Operator Contact: Adel Johnson;Thad Waples

Owner/Operator: US Dept of Military Affairs Helena

Adel Johnson, UST Class A Operator
Adel Johnson, UST Class B Operator
Braiden Burns, UST Class B Global Operator
James Grigsby, UST Class B Operator

Mark Hall, UST Class B Operator
 Michael Muir, UST Class B Operator
 Thad Waples, UST Class A Operator
 William Norberg, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	03/01/1997	Fiberglass Reinforced Plastic	No Piping	Ball Float Valve;High Level Alarm
827	No		Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	
Aviation Gas			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring		No
25,000			Gilbarco-Veeder Root/Other		No
02	24	03/01/1997	Fiberglass Reinforced Plastic	No Piping	Ball Float Valve;High Level Alarm
828	No		Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	
Aviation Gas			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring		No
25,000			Gilbarco-Veeder Root/Other		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: BOBS VALLEY SERVICE INC UST
 7507 N Montana Ave
 Helena, MT 59602-9389 Lewis and Clark

Legacy ID:25-07404

Facility ID: 23734
Last Inspected On: 11/06/2020
Operating Permit Renewal Date: 03/26/2024

Owner Operator Contact: Bobs Valley Market;Steve Bartmess;Bobs Valley Market

4064585140;4064585140;4064585140

Operator Contact: Dylan Pizzini

Owner/Operator: Bobs Valley Market

Craig Sprankle, UST Class B Operator

Dylan Pizzini, UST Class A Operator
Dylan Pizzini, UST Class B Global Operator
Stephen Bartmess, UST Class B Global Operator
Steve Nummerdor, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	33	03/27/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
474	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	33	03/27/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
475	No			Double Walled	Yes
Currently in Use		05/14/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	29	06/01/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
476	No			Double Walled	Yes
Currently in Use		05/14/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	23	11/15/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

477	No		Double Walled	Yes
Currently in Use	05/14/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	09/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: CEDAR STREET CONOCO
1701 Cedar St
Helena, MT 59601-1109 Lewis and Clark

Legacy ID:25-03466

Facility ID: 23531
Last Inspected On: 04/30/2021
Operating Permit Renewal Date: 06/11/2024

Owner Operator Contact: Michael Salois; Tray LLC

4064506297

Operator Contact: Michael Salois

Owner/Operator: Cedar Street Conoco

Owner/Operator: Michael J Salois

Daren Griffeth, UST Class B Operator
Michael Salois, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	23	09/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2228	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000			Veeder Root/TLS-300		No
06	23	09/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2229	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000			Veeder Root/TLS-300		No
07	23	09/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2230	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Veeder Root/TLS-300		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: COMBINED CRIMINAL JUSTICE FACILITY
221 Breckenridge St
Helena, MT 59601-4230 Lewis and Clark

Legacy ID:25-00945

Facility ID: 23395
Last Inspected On: 02/07/2019
Operating Permit Renewal Date: 05/03/2022

Owner Operator Contact: Lewis and Clark County Jail

4064478299

Operator Contact: David Schmitz;Kirk Ketchum;Robert McCarley

4064478299

Owner/Operator: Lewis and Clark County Jail

David Schmitz, UST Class A Operator
David Schmitz, UST Class B Global Operator
Kirk Ketchum, UST Class A Operator
Kirk Ketchum, UST Class B Global Operator
Robert McCarley, UST Class A Operator
Robert McCarley, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	04/21/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4060	No	05/03/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		02/07/2019	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
3,000			Gilbarco/EMC Basic		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: COSTCO GASOLINE 633
2195 E Custer Ave
Helena, MT 59602 Lewis and Clark

Legacy ID:60-15051

Facility ID: 30825
Last Inspected On: 02/18/2020
Operating Permit Renewal Date: 02/24/2023

Owner Operator Contact:

Operator Contact: Andrew Erdahl;Dan Martinez;Daniel Manibusan;Dave Preston;Teresa Gonzales

4064492381;4064957042

Owner/Operator: Costco Wholesale

Andrew Erdahl, UST Class A Operator

Andrew Erdahl, UST Class B Global Operator
 Andrew Erdahl, UST Class B Operator
 Dan Martinez, UST Class A Operator
 Daniel Manibusan, UST Class A Operator
 Daniel Manibusan, UST Class B Operator
 Dave Preston, UST Class A Operator
 Dave Preston, UST Class B Operator
 Teresa Gonzales, UST Class A Operator
 Teresa Gonzales, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	15	10/05/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5095	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
30,000		12/15/2016	Gilbarco-Veeder Root/TLS-350		No
02	15	10/05/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5096	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
30,000		12/15/2016	Gilbarco-Veeder Root/TLS-350		No
03	15	10/05/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5097	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
30,000		12/15/2016	Gilbarco-Veeder Root/TLS-350		No
04	10	04/12/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5281	No		Double-Walled	Double Walled	Yes
Currently in Use		10/25/2010	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Hazardous Substance			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
1,500		12/15/2016	Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Lewis and Clark County in the City of Helena

Location: DAVES EXPRESS LUBE
4990 N Montana Ave
Helena, MT 59602-7268 Lewis and Clark

Legacy ID:56-13828

Facility ID: 30514
Last Inspected On: 06/27/2019
Operating Permit Renewal Date: 07/27/2022

Owner Operator Contact: Dave's Express Lube Inc **4064499667**

Operator Contact: Dave Clemens **4064499667**

Owner/Operator: Dave's Express Lube Inc

Dave Clemens, UST Class A Operator
Dave Clemens, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	23	01/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
372	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No

02	23	01/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
373	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No
03	23	01/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
374	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
04	23	01/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
375	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: ECS 6 ARMY RESERVE
2150 Williams St
Helena, MT 59602-9233 Lewis and Clark

Legacy ID:25-00217

Facility ID: 23365
Last Inspected On:
Operating Permit Renewal Date:

Owner Operator Contact: US Dept of the Army ECS 6

4064421112

Operator Contact:

Owner/Operator: US Dept of the Army ECS 6

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	10/01/1992	Fiberglass Reinforced Plastic	Steel	
	No		Double-Walled	None	No
Temporarily Out of Use				Gravity Feed	
Oil, Waste			Not Listed	Not Listed	No
200					No

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXEC AIR MONTANA INC 1
2430 Airport Rd
Helena, MT 59601-1234 Lewis and Clark

Legacy ID:25-00642

Facility ID: 23382
Last Inspected On: 04/01/2021
Operating Permit Renewal Date: 04/14/2024

Owner Operator Contact: David Coon;West Air LLC;Exec Air Montana Inc

4064422190;4064434543

Operator Contact: John Maxness

4064222190

Owner/Operator: Exec Air Montana Inc

Owner/Operator: John Maxness

John Maxness, UST Class A Operator
John Maxness, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
05	30	06/01/1991	Cathodically Protected Steel	No Piping	High Level Alarm
3344	No		Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Aviation Gas	09/13/2017		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Deferred	No
12,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
06	30	06/01/1991	Cathodically Protected Steel	No Piping	High Level Alarm
3345	No		Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Jet Fuel (Jet-A, Jet-A1, JP5)	09/13/2017		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Deferred	No
12,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
07	4	09/10/2017	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5765	No		Double-Walled	None	No
Currently in Use	09/10/2017		Not Required	Not Listed	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Deferred	No
30,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXXONMOBIL HELENA PRODUCTS TERMINAL
3120 E US Hwy 12
Helena, MT 59601-9701 Lewis and Clark

Legacy ID:25-08728

Facility ID: 23795
Last Inspected On: 09/28/2021
Operating Permit Renewal Date: 05/25/2022

Owner Operator Contact: Exxon Mobil Corporation Helena

8326257781

Operator Contact: Bry Joaillier Allen;Christopher Martin;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein

4065866927;4066575404;4357647049;8326247774;8326247876

Owner/Operator: Exxon Mobil Corporation Helena

Bry Joaillier Allen, UST Class A Operator
 Bry Joaillier Allen, UST Class B Global Operator
 Christopher Martin, UST Class A Operator
 Christopher Martin, UST Class B Operator
 James Vokral, UST Class A Operator
 James Vokral, UST Class B Global Operator
 Janie Lee, UST Class A Operator
 Janie Lee, UST Class B Global Operator
 Jim Gullon, UST Class B Global Operator
 M Martin, UST Class A Operator
 M Martin, UST Class B Global Operator
 Marc Larson, UST Class B Global Operator
 Michael Bailey, UST Class A Operator
 Michael Bailey, UST Class B Global Operator
 Michael James, UST Class A Operator
 Michael James, UST Class B Global Operator
 Robert Ochsenbein, UST Class A Operator
 Robert Ochsenbein, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
14	34	01/01/1987	Cathodically Protected Steel	Steel	High Level Alarm
2767	No		Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Mixture		11/18/2015	Continuous Interstitial Monitoring	Terminal Piping Annual Line Test	No
2,000		12/08/2015			No
S01	71	01/01/1950	Bare Steel	Steel - Terminal Piping	

2768	Yes			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		11/18/2015	Deferred	Terminal Piping Annual Line Test	No
603,330		12/08/2015			No
S03	71	01/01/1950	Bare Steel	Steel - Terminal Piping	
2770	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Gasoline		11/18/2015	Deferred	Terminal Piping Annual Line Test	No
604,000		12/08/2015			No
S05	71	01/01/1950	Bare Steel	Steel - Terminal Piping	
2772	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Gasoline		11/18/2015	Deferred	Terminal Piping Annual Line Test	No
1,200,000		12/08/2015			No
S07	71	01/01/1950	Bare Steel	Steel - Terminal Piping	
2774	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		11/18/2015	Deferred	Terminal Piping Annual Line Test	No
638,000		12/08/2015			No
S11	71	01/01/1950	Bare Steel	Steel - Terminal Piping	
2778	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		11/18/2015	Deferred	Terminal Piping Annual Line Test	No

633,000		12/08/2015			No
S15	34	01/01/1987	Bare Steel	Steel	
2780	Yes	12/21/2016		Secondary Containment Chase	Yes
Currently in Use		01/11/2017	Continuous Interstitial Monitoring	Pressurized	
Hazardous Substance			Deferred	Continuous Interstitial Monitoring	No
10,000					No
S18	34	01/01/1987	Bare Steel	Flexible Plastic	
2783	Yes			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Hazardous Substance			Deferred	Continuous Interstitial Monitoring	No
3,000					No
S21	34	01/01/1987	Bare Steel	Flexible Plastic	
2786	Yes			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Hazardous Substance			Deferred	Continuous Interstitial Monitoring	No
1,000					No

Facility Summary in Lewis and Clark County in the City of Helena

Location: FEDERAL RESERVE BANK HELENA
100 Neill Ave
Helena, MT 59601-3329 Lewis and Clark

Legacy ID:25-11291

Facility ID: 23861
Last Inspected On: 07/21/2020
Operating Permit Renewal Date: 01/09/2024

Owner Operator Contact: Federal Reserve Bank

Operator Contact: Ronald Hicks

Owner/Operator: Federal Reserve Bank

Ronald Hicks, UST Class A Operator
Ronald Hicks, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	32	10/01/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2322	No			Double Walled	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Heating Oil		07/24/2017	Automatic Tank Gauging 0.2	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
4,000		08/25/2015	Gilbarco-Veeder Root/TLS-300		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: FRIENDLYS SINCLAIR
1831 11th Ave
Helena, MT 59601-4769 Lewis and Clark

Legacy ID:25-01314

Facility ID: 23408
Last Inspected On: 06/24/2020
Operating Permit Renewal Date: 07/26/2023

Owner Operator Contact: Barbara Leland;Shirley Allen;Friendlys Sinclair

4064424410;4064424865;4064424865

Operator Contact: Barbara Leland;Edward Dimock;Ginny Helfert

4064424865

Owner/Operator: Barbara Leland

Owner/Operator: Ron Leland

Barbara Leland, UST Class A Operator
Edward Dimock, UST Class A Operator
Edward Dimock, UST Class B Operator
Ginny Helfert, UST Class A Operator
Scott Leland, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	19	01/02/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4611	No			Double Walled	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000		06/06/2017	Veeder Root/TLS-300		No
06	19	01/02/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4612	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		06/06/2017	Veeder Root/TLS-300		No
07	19	01/02/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4613	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
20,000		06/06/2017	Veeder Root/TLS-300		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: GATES OF THE MOUNTAINS INC
3106 Gates of The Mountains Rd
Helena, MT 59604-4478 Lewis and Clark

Legacy ID:25-06619

Facility ID: 23697
Last Inspected On: 04/24/2019
Operating Permit Renewal Date: 04/30/2022

Owner Operator Contact: Gates of The Mountains Inc

4064585241

Operator Contact: Timothy Crawford

4064585241

Owner/Operator: Gates of The Mountains Inc

Timothy Crawford, UST Class A Operator

Timothy Crawford, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	35	04/29/1986	Cathodically Protected Steel	Steel	Flapper Valve
1202	No		Double-Walled	None	Yes
Currently in Use		03/12/2007	Mechanical Line Leak Detector	Pressurized	Galvanic;Impressed Current
Gasoline		04/06/2016	Manual Interstitial Monitoring	MLLD Line Tightness Testing	No
5,000		04/06/2016			No
04	35	04/29/1986	Cathodically Protected Steel	Steel	Flapper Valve
1203	No		Double-Walled	None	Yes
Currently in Use		03/12/2007	Mechanical Line Leak Detector	Pressurized	Galvanic;Impressed Current
Diesel		04/06/2016	Manual Interstitial Monitoring	MLLD Line Tightness Testing	No
1,000		04/06/2016			No

Facility Summary in Lewis and Clark County in the City of Helena

Location: GREEN MEADOW MARKET
3300 Green Meadow Dr
Helena, MT 59602-7707 Lewis and Clark

Legacy ID:25-05688

Facility ID: 23648
Last Inspected On: 07/31/2019
Operating Permit Renewal Date: 08/13/2022

Owner Operator Contact: JTA Inc

4064427095

Operator Contact: Todd Adams

Owner/Operator: JTA Inc

John Rule, UST Class B Global Operator

Todd Adams, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	42	10/01/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3243	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		04/14/2016	Gilbarco/EMC Basic		No
02	42	10/01/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3244	No		Lined Interior/Impressed Current	None	Yes
Currently in Use		07/11/2014	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		04/14/2016	Gilbarco/EMC Basic		No
03	14	08/08/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5135	No			Double Walled	Yes
Currently in Use		07/11/2014	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		04/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		04/14/2016	Gilbarco/EMC Basic		No
04	14	08/08/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

5136	No		Double Walled	Yes
Currently in Use	07/11/2014	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel	04/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
7,000	04/14/2016	Gilbarco/EMC Basic		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: HELENA MAIN CENTRAL OFFICE
441 N Park Ave
Helena, MT 59601-5020 Lewis and Clark

Legacy ID:25-08775

Facility ID: 23796
Last Inspected On: 07/23/2020
Operating Permit Renewal Date: 10/18/2023

Owner Operator Contact:

Operator Contact: Kevin Robison;Stephanie Miller

5016808141;8015983020

Owner/Operator: Qwest Corporation/Century Link

Kevin Robison, UST Class A Operator
Kevin Robison, UST Class B Global Operator
Stephanie Miller, UST Class A Operator
Stephanie Miller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	01/01/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
1728	No		Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
2,500		06/06/2017	Veeder Root/TLS-300		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: HELENA SERVICE CENTER
1315 N Last Chance Gulch
Helena, MT 59601-2909 Lewis and Clark

Legacy ID:25-01183

Facility ID: 23405
Last Inspected On: 03/24/2020
Operating Permit Renewal Date: 08/12/2023

Owner Operator Contact: Bill Thompson;Northwestern Energy
Butte;Northwestern Energy Butte

4064434150;4066552521;4066552521

Operator Contact: John Habeger;Kellen Gilreath;Phil Hatfield

4062390025;4064438951

Owner/Operator: Northwestern Energy Butte

John Habeger, UST Class A Operator
Kellen Gilreath, UST Class A Operator
Kellen Gilreath, UST Class B Global Operator
Phil Hatfield, UST Class A Operator
Phil Hatfield, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1678	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
05	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1679	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: HOLIDAY STATIONSTORE 270
401 Euclid Ave
Helena, MT 59601 Lewis and Clark

Legacy ID:25-08067

Facility ID: 23766
Last Inspected On: 07/01/2020
Operating Permit Renewal Date: 09/09/2023

Owner Operator Contact:

Operator Contact: Brent Johnson;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries;Veronica Rivera

9528308028;9528308721

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
 Brent Johnson, UST Class A Operator
 Brent Johnson, UST Class B Global Operator
 Julie Cordie, UST Class B Global Operator
 Patrick Patnaude, UST Class A Operator
 Stephen Reckinger, UST Class A Operator
 Todd White, UST Class B Global Operator
 Travis Struckman, UST Class B Global Operator
 Valeria Jeffries, UST Class A Operator
 Veronica Rivera, UST Class A Operator
 Veronica Rivera, UST Class B Global Operator
 William George, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	05/01/1987	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve;Flapper Valve
3017	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
02	34	05/01/1987	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve;Flapper Valve
3018	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
03	34	11/01/1987	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve;Flapper Valve
3019	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
04	34	11/01/1987	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve;Flapper Valve
3020	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Lewis and Clark County in the City of Helena

Location: HOLIDAY STATIONSTORE 723
606 N Fee St
Helena, MT 59601-3148 Lewis and Clark

Legacy ID:56-13956

Facility ID: 30624
Last Inspected On: 11/06/2018
Operating Permit Renewal Date: 03/30/2022

Owner Operator Contact:

Operator Contact: Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Robert Deninno;Stephen Reckinger;Valeria Jeffries;Veronica Rivera **4063210938;9528308028;9528308721;9528308722**

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Craig Hagmeier, UST Class B Operator
- Cynthia Hellwitz, UST Class B Operator
- Julie Cordie, UST Class B Global Operator
- Kegan Krueger, UST Class A Operator
- Patrick Patnaude, UST Class A Operator
- Robert Deninno, UST Class A Operator
- Ryan Coey, UST Class B Operator
- Stephen Reckinger, UST Class A Operator
- Stephen Reckinger, UST Class B Global Operator

Todd White, UST Class B Global Operator
 Valeria Jeffries, UST Class A Operator
 Veronica Rivera, UST Class A Operator
 Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	22	10/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
4128	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000		09/05/2018	Veeder Root/TLS-450		No
02	22	10/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
4129	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		04/23/2018	Veeder Root/TLS-450		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: JOLLY OS GAS N GO
 1200 Cedar St
 Helena, MT 59601 Lewis and Clark

Legacy ID:25-04966

Facility ID: 23600
Last Inspected On: 03/07/2019
Operating Permit Renewal Date: 03/26/2019

Owner Operator Contact: Dan Stockton;Stockton Oil Co Billings;Jim
 Phillips;Stockton Oil Co Billings

Operator Contact: Michael Stockton

4062456376

Owner/Operator: Stockton Oil Co Billings

Joseph Stockton, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	03/26/1985	Cathodically Protected Steel	Steel	Flapper Valve
4784	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/11/2018	Statistical Inventory Reconciliation	MLLD Line Tightness Testing; Statistical Inventory Reconciliation	No
8,000					No
02	36	03/26/1985	Cathodically Protected Steel	Steel	Flapper Valve
4785	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/11/2018	Statistical Inventory Reconciliation	MLLD Line Tightness Testing; Statistical Inventory Reconciliation	No
8,000					No
04	30	09/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4786	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/11/2018	Statistical Inventory Reconciliation	MLLD Line Tightness Testing; Statistical Inventory Reconciliation	No
4,000					No

Facility Summary in Lewis and Clark County in the City of Helena

Location: KIMS MARINA and RESORT
 8015 Canyon Ferry Rd
 Helena, MT 59602-8509 Lewis and Clark

Legacy ID:25-01091

Facility ID: 23401
Last Inspected On: 03/28/2020
Operating Permit Renewal Date: 05/10/2023

Owner Operator Contact:

Operator Contact:

Owner/Operator: Greg Axtman

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	28	05/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3516	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
3,782		05/05/2014	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: LAKESIDE MARKET AND GAS
5330 York Rd
Helena, MT 59602 Lewis and Clark

Legacy ID:25-13657

Facility ID: 23950
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/30/2024

Owner Operator Contact:

Operator Contact: Sandra Gast;Shari Winters

4062278157

Owner/Operator: Sandra Gast

Owner/Operator: Sunflower LLC

Jessica Minetti, UST Class B Operator
Sandra Gast, UST Class A Operator
Sandra Gast, UST Class B Operator
Shari Winters, UST Class A Operator
Trisha Huston, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	26	07/24/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4552	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible	
Diesel		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
5,000	02/08/2018	Veeder Root/TLS-300		No	
01	26	07/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4553	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible	
Gasoline		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
8,000	02/08/2018	Veeder Root/TLS-300		No	

Facility Summary in Lewis and Clark County in the City of Helena

Location: LAST CHANCE RENTAL and LEASING LLP
3122 Airport Rd
Helena, MT 59601 Lewis and Clark

Legacy ID:25-12834

Facility ID: 23905
Last Inspected On: 05/18/2020
Operating Permit Renewal Date: 08/19/2023

Owner Operator Contact:

Operator Contact: John Maxness;Ted Beck

4064222190;4064498668

Owner/Operator: Last Chance Rental & Leasing LLP

Owner/Operator: Ted Beck Md

Henry Weitz, UST Class B Operator
John Maxness, UST Class A Operator
John Maxness, UST Class B Global Operator
Ted Beck, UST Class A Operator
Ted Beck, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	29	09/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4444	No		Double Walled	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible	
Gasoline		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
12,000	11/01/2016	Incon/TS-1000		No	

Facility Summary in Lewis and Clark County in the City of Helena

Location: LITHIA CHRYSLER JEEP DODGE RAM OF HELENA
3401 US Hwy 12 E
Helena, MT 59601-9708 Lewis and Clark

Legacy ID:25-13687

Facility ID: 23952
Last Inspected On: 08/26/2020
Operating Permit Renewal Date: 08/28/2023

Owner Operator Contact: Lithia Chrysler Jeep Dodge Ram of Helena

4064429994

Operator Contact: Amanda Stewart;Deann Horning

4064425810;4064953203

Owner/Operator: Lithia Chrysler Jeep Dodge Ram of Helena

Amanda Stewart, UST Class A Operator
Deann Horning, UST Class A Operator
Howard Reed, UST Class B Operator
Justin Smith, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	25	03/15/1996	Cathodically Protected Steel	Steel	
1244	No		Double-Walled	Secondary Containment Chase	Yes
Currently in Use		Not Required	U.S. Suction	Galvanic	
Oil, Waste		08/04/2017	Manual Interstitial Monitoring	3-Year Line Tightness Test;Manual Interstitial Monitoring	No

8,000

08/04/2017

No

Facility Summary in Lewis and Clark County in the City of Helena

Location: MDOT HELENA HEADQUARTERS
2701 Prospect Ave
Helena, MT 59601-9746 Lewis and Clark

Legacy ID:25-06849

Facility ID: 23715
Last Inspected On: 07/01/2020
Operating Permit Renewal Date: 11/19/2023

Owner Operator Contact: MDOT Helena

4064446163

Operator Contact: Jeff Gleason;Joe Radonich;Mike Murolo;Walt Kerttula

Owner/Operator: MDOT Helena

- Douglas Robbins, UST Class B Global Operator
- Jeff Gleason, UST Class A Operator
- Jim Adolph, UST Class B Global Operator
- Joe Radonich, UST Class A Operator
- Joe Radonich, UST Class B Global Operator
- Mike Murolo, UST Class A Operator
- Tim Clark, UST Class B Operator
- Walt Kerttula, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
04	25	03/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2911	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		01/27/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	25	03/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2912	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline		Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000	01/17/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: MDT EQUIPMENT DEVELOPMENT BUILDING
490 18th St
Helena, MT 59601 Lewis and Clark

Legacy ID:60-15139

Facility ID: 30883
Last Inspected On: 03/30/2020
Operating Permit Renewal Date: 05/15/2023

Owner Operator Contact: Montana Dept of Administration

4064443060

Operator Contact: Ed Sivils

Owner/Operator: Montana Dept of Administration

Daniel Messerli, UST Class B Operator
David Spradlin, UST Class B Operator
Ed Sivils, UST Class A Operator
Ed Sivils, UST Class B Operator
James Simmons, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	12	10/01/2009	Aboveground Tank	Flexible Plastic	
5214	Yes	06/20/2016		Double Walled	No
Currently in Use		07/08/2009	Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
4,000					Yes
S2	9	10/01/2012	Aboveground Tank	Flexible Plastic	
5386	Yes	06/20/2016		Double Walled	No
Currently in Use		07/31/2012	Auto Dialer	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
4,000					Yes

Facility Summary in Lewis and Clark County in the City of Helena

Location: MERGENTHALER TRANSFER and STORAGE
CARTER DR
1430 Carter Dr
Helena, MT 59601-6429 Lewis and Clark

Legacy ID:56-13831

Facility ID: 30515
Last Inspected On: 12/10/2020
Operating Permit Renewal Date: 03/19/2024

Owner Operator Contact: Mergenthalers Transfer and Storage

4064429470

Operator Contact: Dave Gardner

Owner/Operator: Mergenthalers Transfer and Storage

Dave Gardner, UST Class A Operator

Dave Gardner, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	11/01/1997	Cathodically Protected Steel	Flexible Plastic	
1609	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Oil, Waste		12/18/2017	Manual Interstitial Monitoring	3-Year Line Tightness Test;Manual Interstitial Monitoring	No
3,000		03/06/2018			No

Facility Summary in Lewis and Clark County in the City of Helena

Location: MONROES HIGH COUNTRY TRAVEL PLAZA
3122 E US Hwy 12
Helena, MT 59601 Lewis and Clark

Legacy ID:25-08659

Facility ID: 23790
Last Inspected On: 02/07/2020
Operating Permit Renewal Date: 03/15/2023

Owner Operator Contact: Kary Tonjum;City Service Inc

4067554321;4067554321

Operator Contact: Debra Monroe;Marvin Monroe;William Monroe

4064596633;4064618357

Owner/Operator: Monroes High Country Travel Plaza LLC

Debra Monroe, UST Class A Operator

Debra Monroe, UST Class B Operator

Marvin Monroe, UST Class A Operator

Marvin Monroe, UST Class B Global Operator

William Monroe, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	31	06/19/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4526	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		09/12/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000		10/16/2016	Gilbarco/EMC Basic		No
06	31	06/19/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4527	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000		10/16/2016	Gilbarco/EMC Basic		No
12	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4528	No			Double Walled	Yes
Currently in Use		08/23/2011	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		10/16/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		10/16/2016	Gilbarco/EMC Basic		No
13	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4529	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible

Gasoline		10/16/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		10/16/2016	Gilbarco/EMC Basic		No
14	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4530	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		10/16/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		10/16/2016	Gilbarco/EMC Basic		No
15	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4531	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		10/16/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
15,000		10/15/2016	Gilbarco/EMC Basic		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: MOUNTAIN VIEW COOP HELENA
720 Custer Ave
Helena, MT 59602 Lewis and Clark

Legacy ID:60-15323

Facility ID: 31020
Last Inspected On: 04/21/2020
Operating Permit Renewal Date: 06/21/2023

Owner Operator Contact:

Operator Contact: David Douglas

Owner/Operator: Mountain View Coop Black Eagle

Cody Tripp, UST Class B Global Operator
David Douglas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	3	11/19/2018	Steel Clad	Flexible Plastic	Positive Shutoff
5841	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
30,000			Incon/TS-550 EVO		Yes
02	3	11/19/2018	Steel Clad	Flexible Plastic	Positive Shutoff
5842	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
9,000			Incon/TS-550 EVO		Yes
03	3	11/19/2018	Steel Clad	Flexible Plastic	Positive Shutoff
5843	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
9,000			Incon/TS-550 EVO		Yes
04	3	11/19/2018	Steel Clad	Flexible Plastic	Positive Shutoff
5844	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Incon/TS-550 EVO		Yes

Facility Summary in Lewis and Clark County in the City of Helena

Location: PHILLIPS 66 HELENA TERMINAL
3180 E US Hwy 12
Helena, MT 59601-9701 Lewis and Clark

Legacy ID:25-01846

Facility ID: 23445
Last Inspected On: 05/04/2021
Operating Permit Renewal Date: 06/28/2024

Owner Operator Contact: Steve Thomas

Operator Contact: Brian Buckley;Ryan Norwood	4064414752
---	-------------------

Owner/Operator: Phillips 66 Helena Terminal

- Brian Buckley, UST Class A Operator
- Brian Buckley, UST Class B Operator
- Clifford Pearce, UST Class B Operator
- Dane Whittaker, UST Class B Global Operator
- Jeb Pedrazzi, UST Class B Global Operator
- Ryan Norwood, UST Class A Operator
- Ryan Norwood, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
39	28	01/01/1993	Fiberglass Reinforced Plastic	Steel	High Level Alarm
4919	No		Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	
Mixture		05/05/2017	Continuous Interstitial Monitoring	3-Year Line Tightness Test	No
10,000		05/15/2018	Other/Other		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: QUEEN CITY EXXON LLC
1721 Cedar St
Helena, MT 59601-1109 Lewis and Clark

Legacy ID:25-07848

Facility ID: 23755
Last Inspected On: 06/04/2021
Operating Permit Renewal Date: 08/27/2024

Owner Operator Contact: Queen City Exxon LLC

Operator Contact: Timothy Hornbacher;Vaughn Ogle	4064394469
---	-------------------

Owner/Operator: Queen City Exxon LLC

Owner/Operator: Timothy C Hornbacher

Jacob Ogle, UST Class B Operator
 Mike Bakker, UST Class B Operator
 Timothy C Hornbacher, UST Class A Operator
 Timothy C Hornbacher, UST Class B Operator
 Vaughn Ogle, UST Class A Operator
 Vaughn Ogle, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	34	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve
1396	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/26/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		09/01/2004	Gilbarco/EMC Basic		No
05	34	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve
1397	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		07/26/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		09/01/2004	Gilbarco/EMC Basic		No
06	34	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve
1398	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/26/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No

10,000		09/01/2004	Gilbarco/EMC Basic		No
08	31	11/01/1990	Cathodically Protected Steel	No Piping	
1399	No			None	Yes
Currently in Use		04/24/2009	Not Required	Gravity Feed	Galvanic
Oil, Waste		07/26/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000		09/01/2004	Gilbarco/EMC Basic		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: SAFEWAY GASOLINE HELENA
611 N Montana Ave
Helena, MT 59601-3827 Lewis and Clark

Legacy ID:56-14000

Facility ID: 30661
Last Inspected On: 12/13/2019
Operating Permit Renewal Date: 01/29/2023

Owner Operator Contact: Safeway Stores Inc

Operator Contact: Rachel Jones

2083953269

Owner/Operator: Safeway Stores Inc

Page Rost, UST Class B Global Operator
Rachel Jones , UST Class A Operator
Rachel Jones , UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	06/01/2001	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
4330	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

02	20	06/01/2001	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
4331	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
03	20	06/01/2001	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
4332	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: SOUTHS COUNTRY STORE
3105 York Rd
Helena, MT 59602-8816 Lewis and Clark

Legacy ID:25-07353

Facility ID: 23731
Last Inspected On: 09/19/2019
Operating Permit Renewal Date: 09/23/2022

Owner Operator Contact:

Operator Contact: Lonnie Bennett	4064434833
---	-------------------

Owner/Operator: Lonnie Bennett

Lonnie Bennett, UST Class A Operator
Lonnie Bennett, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	28	05/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3562	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		07/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		07/26/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	28	05/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3563	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		07/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		07/26/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: SPRINT HELENA POP
1100 Phoenix Ave
Helena, MT 59601 Lewis and Clark

Legacy ID:56-14011

Facility ID: 30671
Last Inspected On: 06/09/2020
Operating Permit Renewal Date: 08/08/2023

Owner Operator Contact: Sprint Communications Co LLP **9137625957**

Operator Contact: Brian Wiedower

9133158631

Owner/Operator: Sprint Communications Co LLP

Brandon Hyde, UST Class B Operator
Brian Wiedower, UST Class A Operator
Doug Dickinson, UST Class B Operator
Matt Santee, UST Class B Global Operator
Nikki Lattin, UST Class B Global Operator
Scott Hallesy, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
4322	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
2,500		02/20/2017	Gilbarco-Veeder Root/TLS-300		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: THRIFTWAY SUPER STOP 9
1405 Euclid Ave
Helena, MT 59601-2052 Lewis and Clark

Legacy ID:25-07931

Facility ID: 23761
Last Inspected On: 02/20/2019
Operating Permit Renewal Date: 06/12/2022

Owner Operator Contact: Sutey Oil Co Inc

4064942305

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey

4064915808;4064942305

Owner/Operator: Sutey Oil Co Inc

Bryan Kelsey, UST Class B Operator
Douglas Bond, UST Class B Operator
Jack Hook, UST Class A Operator
Jack Hook, UST Class B Global Operator
Jack Hook, UST Class B Operator
Kirsten Jakubec, UST Class B Global Operator

Kirsten Jakubec, UST Class B Operator
 Linda Otonicar, UST Class A Operator
 Louis Sutey, UST Class A Operator
 Louis Sutey, UST Class B Global Operator
 Peggy Johnson, UST Class B Operator
 Ruth Coladonato, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2056	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2057	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2058	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA #3
3161 N Sanders
Helena, MT 59602 Lewis and Clark

Legacy ID:60-15210

Facility ID: 30930
Last Inspected On: 06/22/2021
Operating Permit Renewal Date: 09/28/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Helena 3 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	9	05/01/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5367	No		Double-Walled	Double Walled	Yes
Currently in Use		02/04/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes
02	9	05/01/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5369	No		Double-Walled	Double Walled	Yes
Currently in Use		02/04/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-350		Yes
03	9	05/01/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve

5370	No		Double-Walled	Double Walled	Yes
Currently in Use		02/04/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-350		Yes
04	9	05/01/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5371	No		Double-Walled	Double Walled	Yes
Currently in Use		02/04/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes
05	9	05/01/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5372	No		Double-Walled	Double Walled	Yes
Currently in Use		02/04/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 1
1240 Prospect Ave
Helena, MT 59601 Lewis and Clark

Legacy ID:25-08706

Facility ID: 23792
Last Inspected On: 07/15/2021
Operating Permit Renewal Date: 07/20/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Helena PTRCB 1231 **4064976948**

Operator Contact: Trent Biggers

Owner/Operator: Helena 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	38	04/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2506	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
02	38	04/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2507	No			Double Walled	Yes
Currently in Use		06/27/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
03	38	04/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2508	No			Double Walled	Yes
Currently in Use		06/27/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/25/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
07	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2509	No		Double-Walled	Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel	09/25/2014		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
08	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2510	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel	09/25/2014		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 2
1140 Euclid Ave
Helena, MT 59601 Lewis and Clark

Legacy ID:25-08707

Facility ID: 23793
Last Inspected On: 06/03/2021
Operating Permit Renewal Date: 06/08/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Helena PTRCB 1231 **4064976948**

Operator Contact: Trent Biggers

Owner/Operator: Helena 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	37	04/14/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4832	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Gasoline		04/24/2013	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
04	30	07/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4833	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/29/2005	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
05	30	07/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4834	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/29/2005	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
06	30	07/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4835	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 4
2900 N Montana Ave
Helena, MT 59601-0549 Lewis and Clark

Legacy ID:56-13846

Facility ID: 30528
Last Inspected On: 05/26/2021
Operating Permit Renewal Date: 05/26/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Helena 4 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	23	06/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2680	No		Double-Walled	Double Walled	Yes
Currently in Use		06/11/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
02	23	06/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2681	No		Double-Walled	Double Walled	Yes
Currently in Use		06/11/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
03	23	06/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2682	No		Double-Walled	Double Walled	Yes
Currently in Use		06/11/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No

04	23	06/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2683	No		Double-Walled	Double Walled	Yes
Currently in Use		06/11/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
05	23	07/24/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2684	No		Double-Walled	Double Walled	Yes
Currently in Use		06/11/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
06	20	09/07/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4671	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 5
1822 E Custer Ave
Helena, MT 59602-1206 Lewis and Clark

Legacy ID:60-15029

Facility ID: 30813
Last Inspected On: 08/11/2021
Operating Permit Renewal Date: 06/19/2022

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Helena 5 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	15	12/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
5064	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000		12/07/2006	Gilbarco-Veeder Root/TLS-350		No
02	15	12/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
5065	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
10,000		12/07/2006	Gilbarco-Veeder Root/TLS-350		No
03	15	12/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5066	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000		12/11/2006	Gilbarco-Veeder Root/TLS-350		No
04	15	12/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve

5067	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		12/11/2006	Gilbarco-Veeder Root/TLS-350		No
05	15	12/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5068	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000		12/15/2006	Gilbarco-Veeder Root/TLS-350		No
06	15	12/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5074	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		12/15/2006	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 6
2401 N Montana Ave
Helena, MT 59601-0876 Lewis and Clark

Legacy ID:56-13818

Facility ID: 30505
Last Inspected On: 05/25/2021
Operating Permit Renewal Date: 05/26/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Helena 6 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	24	10/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
3443	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-350		No
01	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4610	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: UNITED PARCEL SERVICES HELENA
3029 Airport Rd
Helena, MT 59601 Lewis and Clark

Legacy ID:25-04538

Facility ID: 23584
Last Inspected On: 04/03/2019
Operating Permit Renewal Date: 06/01/2022

Owner Operator Contact: Thomas McKenna;United Parcel Service Inc Billings **4066986391;4066568964**

Operator Contact: Kaytee Villafrancaa;Paul Vandehey;Robert Counts;Russell Stott;Trear Smith **2066216286;2066216380;5039787678**

Owner/Operator: United Parcel Service Inc Seattle

- Kaytee Villafrancaa, UST Class A Operator
- Kaytee Villafrancaa, UST Class B Global Operator
- Paul Vandehey, UST Class A Operator
- Paul Vandehey, UST Class B Global Operator
- Robert Counts, UST Class A Operator
- Robert Counts, UST Class B Operator

Russell Stott, UST Class A Operator
 Russell Stott, UST Class B Operator
 Treair Smith, UST Class A Operator
 Treair Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	28	12/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4446	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		04/14/2015	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: ZIP TRIP 42
 3100 N Montana Ave
 Helena, MT 59602-7812 Lewis and Clark

Legacy ID:25-12353

Facility ID: 23889
Last Inspected On: 12/29/2020
Operating Permit Renewal Date: 03/02/2024

Owner Operator Contact:

Operator Contact: Jim Alford;Sean Hurley;Tom Savas

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
 Jim Alford, UST Class B Global Operator
 Karina Serrano, UST Class B Global Operator
 Luci Tuttle, UST Class B Operator
 Sean Hurley, UST Class A Operator
 Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	30	06/07/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
559	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	07/14/2016		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000	08/11/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	30	06/07/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
560	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	07/14/2016		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000	08/11/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	30	06/07/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
561	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel	07/14/2016		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000	08/11/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Helena

Location: ZIP TRIP 43
1318 Euclid Ave
Helena, MT 59601-2169 Lewis and Clark

Legacy ID:25-05774

Facility ID: 23652
Last Inspected On: 12/29/2020
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula

4065420384

Operator Contact: Jim Alford;Tom Savas

5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Luci Tuttle, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	37	04/26/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
4518	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/06/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		08/11/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
01	38	04/26/1983	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
4519	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/06/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		08/11/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	24	04/23/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4520	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		06/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		08/11/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Lincoln

Location: MOUNTAIN VIEW COOP LINCOLN
525 Main St
Lincoln, MT 59639 Lewis and Clark

Legacy ID:25-03995

Facility ID: 23557
Last Inspected On: 09/10/2020
Operating Permit Renewal Date: 10/16/2023

Owner Operator Contact: Mountain View Coop Black Eagle

4064535900

Operator Contact: David Douglas

Owner/Operator: Mountain View Coop Black Eagle

David Douglas, UST Class A Operator
 David Douglas, UST Class B Global Operator
 Ranae Brown, UST Class B Global Operator
 Ranae Brown, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2252	No	04/11/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/18/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2253	No	04/11/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/18/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2254	No	04/11/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Diesel		08/18/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2255	No	04/11/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/18/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lewis and Clark County in the City of Wolf Creek

Location: BOAT LOFT
1460 Beartooth Rd
Wolf Creek, MT 59648-8743 Lewis and Clark

Legacy ID:25-05921

Facility ID: 23657
Last Inspected On: 01/07/2021
Operating Permit Renewal Date: 01/08/2024

Owner Operator Contact: Driftwood Enterprises LLC

4062354435

Operator Contact: Marshall Trainor

Owner/Operator: Driftwood Enterprises LLC

Chris Ryan, UST Class B Operator
Marshall Trainor, UST Class A Operator
Marshall Trainor, UST Class B Global Operator
Mike Liggett, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	04/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
473	No		Double-Walled	Double Walled	Yes
Currently in Use		11/13/2002	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/EMC Basic		No

Facility Summary in Lewis and Clark County in the City of Wolf Creek

Location: CANYON STORE EXXON
175 Recreation Rd
Wolf Creek, MT 59648 Lewis and Clark

Legacy ID:25-04132

Facility ID: 23568
Last Inspected On: 03/05/2021
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: Paul Beister;Canyon Store Exxon

4062354111

Operator Contact: Shawn Otheim

7755274507

Owner/Operator: Otheim Family LLC

Owner/Operator: Paul D and Cheryl D Beister

Shawn Otheim, UST Class A Operator
Shawn Otheim, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3483	No			Double Walled	Yes
Currently in Use			Auto Dialer;Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
3,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	23	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3484	No			Double Walled	Yes
Currently in Use			Auto Dialer;Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
7,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	23	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3946	No			Double Walled	Yes
Currently in Use			Auto Dialer;Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No