

Facility Summary in Liberty County in the City of Chester

Location: AG AIR INC
Liberty County Airport
Chester, MT 59522-0670 Liberty

Legacy ID:26-02182

Facility ID: 23979
Last Inspected On: 10/08/2019
Operating Permit Renewal Date: 09/24/2022

Owner Operator Contact: Ag Air Inc

4063554257

Operator Contact: Dana Ness

4063554257

Owner/Operator: Ag Air Inc

Dana Ness, UST Class A Operator
Dana Ness, UST Class B Global Operator
James Briden, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	27	05/01/1994	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
358	No			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Non-corrodible
Aviation Gas			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		04/14/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Liberty County in the City of Chester

Location: CHESTER SUPERMARKET
1278 US Hwy 2
Chester, MT 59522 Liberty

Legacy ID:26-13532

Facility ID: 24091
Last Inspected On: 11/03/2020
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact: MPR Inc

Operator Contact: Manjit Maan

4067595538

Owner/Operator: MPR Inc

Manjit Maan, UST Class A Operator
Pardeep Kumar, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	26	09/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
3223	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-450		No
02	26	09/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
3224	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-450		No
03	26	09/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
3225	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
7,000			Gilbarco-Veeder Root/TLS-450		No

Facility Summary in Liberty County in the City of Chester

Location: FRASER OIL INC CHESTER
119 Washington Ave
Chester, MT 59522 Liberty

Legacy ID:26-13006

Facility ID: 24087
Last Inspected On: 11/02/2020
Operating Permit Renewal Date: 03/17/2024

Owner Operator Contact: Fraser Oil Inc;Walt Laas

Operator Contact: Cory Fraser

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator
 Cory Fraser, UST Class B Operator
 Craig Fraser, UST Class B Operator
 Jesse Kuegler, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1123	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/23/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		10/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1124	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/23/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
1,000		10/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1125	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/23/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
1,000		10/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Liberty County in the City of Chester

Location: ROOSEVELT SERVICE INC
219 Washington Ave
Chester, MT 59522 Liberty

Legacy ID:26-06061

Facility ID: 24034
Last Inspected On: 04/25/2019
Operating Permit Renewal Date: 09/29/2022

Owner Operator Contact: Robert Nordstrom;Roosevelt Service Station

4067595278;4067595278

Operator Contact:

Owner/Operator: Roosevelt Service Inc

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	30	06/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1752	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		04/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		09/15/2015	OPW/EECO 1500		No
07	30	06/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1753	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		04/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		09/15/2015	OPW/EECO 1500		No

Facility Summary in Liberty County in the City of Chester

Location: TIBER MARINA
669 Tiber Marina Rd
Chester, MT 59522 Liberty

Legacy ID:26-03877

Facility ID: 24011
Last Inspected On: 04/18/2019
Operating Permit Renewal Date: 09/29/2022

Owner Operator Contact:

Operator Contact: Eric Kleinsasser

Owner/Operator: Bureau of Reclamation Billings

Eric Kleinsasser, UST Class A Operator

Eric Kleinsasser, UST Class B Global Operator

Eric Kleinsasser, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	35	05/01/1986	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3997	No			None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		06/02/2016	Automatic Tank Gauging 0.2	Deferred	No
1,000			EMCO Electronics/EECO 1500		No