

Facility Summary in Liberty County in the City of Chester

Location: AG AIR INC
 Liberty County Airport
 Chester, MT 59522-0670 Liberty

System Facility ID:26-02182

Facility Code: 23979
Last Inspected On: 06/24/2025
Operating Permit Renewal Date: 09/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ag Air Inc

(406) 759-5191

Operator Contact:

Owner/Operator: Ag Air Inc

(406) 759-5191

James Briden, UST Class B Operator

jdbriden@itstriangle.com

Tank Code	05	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	358	Spill Test Date	07/30/2021	Piping Installed Date	07/30/2021	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/24/2025	Line Tightness Test Date	10/03/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/24/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Liberty County in the City of Chester

Location: CHESTER SUPERMARKET
1278 US Hwy 2
Chester, MT 59522 Liberty

System Facility ID:26-13532

Facility Code: 24091
Last Inspected On: 03/08/2024
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MPR Inc (406) 750-2250 chestersupermarket@gmail.com

Operator Contact: Harinder Singh;Manjit Maan (209) 647-8034;(406) 868-2062 nder4030@yahoo.com;mcpshelby@gmail.com

Owner/Operator: MPR Inc (406) 750-2250 chestersupermarket@gmail.com

Charnjit Maan, UST Class B Operator
Harinder Singh, UST Class A Operator
Manjit Maan, UST Class A Operator
Pardeep Kumar, UST Class B Operator

inder4030@yahoo.com
mcpshelby@gmail.com
pardeep.k51@yahoo.com

Tank Code	01	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3223	Spill Test Date	03/08/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/08/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/08/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3224	Spill Test Date	03/08/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/08/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	5000	ATG Test Date	03/08/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3225	Spill Test Date	03/08/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/08/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7000	ATG Test Date	03/08/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Liberty County in the City of Chester

Location: FRASER OIL INC CHESTER
119 Washington Ave
Chester, MT 59522 Liberty

System Facility ID:26-13006

Facility Code: 24087
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 03/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fraser Oil Inc

(406) 292-3833

Operator Contact: Cory Fraser

frasfuel@yahoo.com

Owner/Operator: Fraser Oil Inc

(406) 292-3833

Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator
Craig Fraser, UST Class B Operator
Jesse Kuegler, UST Class B Operator

frasfuel@yahoo.com
frasfuel@yahoo.com
fraser_46@hotmail.com
kealohakuegler@gmail.com

Tank Code	04	Tank Age	32	Tank Installed Date	10/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1123	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/16/2023	Line Tightness Test Date	11/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	32	Tank Installed Date	10/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1124	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	11/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	32	Tank Installed Date	10/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1125	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	11/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Liberty County in the City of Chester

Location: ROOSEVELT SERVICE INC
219 Washington Ave
Chester, MT 59522 Liberty

System Facility ID:26-06061

Facility Code: 24034
Last Inspected On: 08/07/2025
Operating Permit Renewal Date: 09/29/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Roosevelt Service Inc (406) 759-5278

Operator Contact: Dan Davis;Matthew Meyers;Roosevelt Service Inc (406) 945-2905;(406) 759-5278 dan@rooseveltservice.com;station@rooseveltservice.com

Owner/Operator: Roosevelt Service Inc (406) 759-5278

Dan Davis, UST Class A Operator
Dan Davis, UST Class B Global Operator
Matthew Meyers, UST Class A Operator
Matthew Meyers, UST Class B Operator

dan@rooseveltservice.com
dan@rooseveltservice.com
station@rooseveltservice.com
station@rooseveltservice.com

Tank Code	06	Tank Age	35	Tank Installed Date	06/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1752	Spill Test Date	08/07/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/07/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/07/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/07/2025	Line Tightness Test Date	08/07/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/07/2025			ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	35	Tank Installed Date	06/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1753	Spill Test Date	08/07/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/07/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/07/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/07/2025	Line Tightness Test Date	08/07/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/07/2025			ATG Type	Veeder Root/TLS-300				

Facility Summary in Liberty County in the City of Chester

Location: TIBER MARINA
669 Tiber Marina Rd
Chester, MT 59522 Liberty

System Facility ID:26-03877

Facility Code: 24011
Last Inspected On: 05/14/2025
Operating Permit Renewal Date: 09/29/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bureau of Reclamation Billings (406) 247-7310

Operator Contact: Eric Kleinsasser;Kenneth Scheffler EKleinsasser@usbr.gov;kscheffler@usbr.gov

Owner/Operator: Bureau of Reclamation Billings (406) 247-7310

Eric Kleinsasser, UST Class A Operator

EKleinsasser@usbr.gov

Eric Kleinsasser, UST Class B Global Operator

EKleinsasser@usbr.gov

Eric Kleinsasser, UST Class B Operator

EKleinsasser@usbr.gov

Kenneth Scheffler, UST Class A Operator

kscheffler@usbr.gov

Kenneth Scheffler, UST Class B Operator

kscheffler@usbr.gov

Tank Code	04	Tank Age	40	Tank Installed Date	05/01/1986	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3997	Spill Test Date	05/14/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/28/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	05/14/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/14/2025			ATG Type	EMCO Electronics/EECO 1500				