

Facility Summary in Lincoln County in the City of Eureka

Location: BIG SKY TIRE and AUTO
495 US Hwy 93 N
Eureka, MT 59917 Lincoln

Legacy ID:27-02343

Facility ID: 24114
Last Inspected On: 03/17/2021
Operating Permit Renewal Date: 03/21/2024

Owner Operator Contact: EJ Properties LLC

4062972623

Operator Contact: Joey Burgess

4062972623

Owner/Operator: EJ Properties LLC

Owner/Operator: Ernie Roo

Joey Burgess, UST Class A Operator

Joey Burgess, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	41	05/06/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1851	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/24/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		09/16/2017	Gilbarco/EMC Basic		No
06	41	05/06/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1852	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/24/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		08/11/2017	Gilbarco/EMC Basic		No
07	41	05/06/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1853	No		Lined Interior/Impressed Current	None	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/24/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		09/16/2017	Gilbarco/EMC Basic		No
08	39	05/06/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1854	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		01/24/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		11/03/2017	Gilbarco/EMC Basic		No
09	32	05/06/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1855	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/25/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
15,000		08/23/2017	Gilbarco/EMC Basic		No
10	28	10/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1856	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic;Impressed Current
Diesel		02/16/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		08/21/2017	Gilbarco/EMC Basic		No

Facility Summary in Lincoln County in the City of Eureka

Location: EUREKA MIDDLE SCHOOL
335 6th St E
Eureka, MT 59917 Lincoln

Legacy ID:27-04550

Facility ID: 24154
Last Inspected On: 03/24/2020
Operating Permit Renewal Date: 05/20/2023

Owner Operator Contact: Eureka Public Schools LCHS;Lora Johnson;Eureka Public Schools LCHS

4062652525

Operator Contact:

Owner/Operator: Eureka Public Schools LCHS

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	24	08/01/1997	Fiberglass Reinforced Plastic	Copper	Flapper Valve
1540	No	04/28/2017		Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Heating Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Incon/TS-1000		No

Facility Summary in Lincoln County in the City of Eureka

Location: Ksanka Store
1835 Hwy 93 N
Eureka, MT 59917 Lincoln

Legacy ID:27-05303

Facility ID: 24175
Last Inspected On: 08/24/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact:

Operator Contact: Andre Hofstee

Owner/Operator: AR93, LLC

Owner/Operator: HARJ93, LLC

Andre Hofstee, UST Class A Operator
Andre Hofstee, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	31	04/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3308	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Gasoline		04/20/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		04/20/2017	Veeder Root/TLS-350		No
05	31	04/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3309	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/20/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		04/20/2017	Veeder Root/TLS-350		No

Facility Summary in Lincoln County in the City of Eureka

Location: RANCH HAND INC
1000 US Hwy 93 N
Eureka, MT 59917-9555 Lincoln

Legacy ID:27-12713

Facility ID: 24484
Last Inspected On: 10/09/2018
Operating Permit Renewal Date: 03/19/2022

Owner Operator Contact: Michael Stoken;Mike Stoken and Pat Stoken

4062962342

Operator Contact: Dorothy Bickel

4062972342

Owner/Operator: AJR LLC

Dorothy Bickel, UST Class A Operator
Dorothy Bickel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	23	05/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2960	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
20,000		10/04/2018	Gilbarco/EMC Basic		No
09	23	05/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve

2961	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
15,000		10/04/2018	Gilbarco/EMC Basic		No
10	23	05/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2962	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
15,000		10/04/2018	Gilbarco/EMC Basic		No
11	23	05/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2963	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		10/04/2018	Gilbarco/EMC Basic		No
12	23	05/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2964	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		10/04/2018	Gilbarco/EMC Basic		No
13	23	05/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2965	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No

2,000

10/04/2018

Gilbarco/EMC Basic

No

Facility Summary in Lincoln County in the City of Eureka

Location: TOWN PUMP INC EUREKA
10 Dewey Ave
Eureka, MT 59917 Lincoln

Legacy ID:27-08699

Facility ID: 24240
Last Inspected On: 06/30/2021
Operating Permit Renewal Date: 07/20/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Eureka 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
04	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2517	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		03/25/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
05	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2518	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		03/25/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
06	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve

2519	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		03/25/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
07	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2520	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		03/25/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
08	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2521	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		03/25/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
09	21	11/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4251	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		03/25/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
10	21	11/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4252	No			Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		03/25/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
11	7	03/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5467	No	03/19/2014	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
8,000			Gilbarco-Veeder Root/TLS-350		Yes
12	7	03/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5468	No	03/19/2014	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-350		Yes
13	7	03/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5469	No	03/19/2014	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Lincoln County in the City of Fortine

Location: CRYSTAL LAKES RESORT INC
Crystal Lakes Rd
Fortine, MT 59918 Lincoln

Legacy ID:27-03824

Facility ID: 24145
Last Inspected On: 12/17/2018
Operating Permit Renewal Date: 04/02/2022

Owner Operator Contact: James Smith

4068824432

Operator Contact: James Smith

4068824432

Owner/Operator: James E Smith

James E Smith, UST Class A Operator

James E Smith, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	35	06/01/1986	Cathodically Protected Steel	Steel	Flapper Valve
3892	No			Single Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Jet Fuel (Jet-A, Jet-A1, JP5)		12/06/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/06/2018	Incon/TS-1000		No
02	35	06/01/1986	Cathodically Protected Steel	Steel	Flapper Valve
3893	No			Single Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Aviation Gas		12/06/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/06/2018	Incon/TS-1000		No

Facility Summary in Lincoln County in the City of Fortine

Location: FORTINE MERCANTILE US 93
12000 US Hwy 93 S
Fortine, MT 59918 Lincoln

Legacy ID:27-13725

Facility ID: 24537
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/26/2024

Owner Operator Contact: Betty Stinger

4068824446

Operator Contact: Debbie Peterson

Owner/Operator: Betty Stinger

Debbie Peterson, UST Class A Operator

Debbie Peterson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	04/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4705	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/24/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/03/2018	Gilbarco/EMC Basic		No
02	25	04/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4706	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/24/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		12/03/2018	Gilbarco/EMC Basic		No
03	25	04/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4707	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		01/24/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		12/03/2018	Gilbarco/EMC Basic		No

Facility Summary in Lincoln County in the City of Libby

Location: ASA WOOD SCHOOL
700 Idaho Ave
Libby, MT 59923-1706 Lincoln

Legacy ID:27-05434

Facility ID: 24184
Last Inspected On: 03/01/2021
Operating Permit Renewal Date: 03/04/2024

Owner Operator Contact: School Dist 4 Libby

4062932791

Operator Contact: David Nadolny

Owner/Operator: School Dist 4 Libby

David Nadolny, UST Class A Operator
David Nadolny, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	28	10/01/1993	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1528	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Diesel		01/23/2018	Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
10,000		01/23/2018	Other/Other		No

Facility Summary in Lincoln County in the City of Libby

Location: Bears Quick Stop
36175 US Hwy 2 W
Libby, MT 59923 Lincoln

Legacy ID:27-10863

Facility ID: 24368
Last Inspected On: 03/23/2021
Operating Permit Renewal Date: 03/31/2024

Owner Operator Contact: Kary Tonjum;City Service Inc

4067554321;4067554321

Operator Contact: Elzhon Anderson

4062831345

Owner/Operator: AJAM2, LLC

Elzhon Anderson, UST Class A Operator
Elzhon Anderson, UST Class B Global Operator
Keeli Anderson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	30	04/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
676	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic	
Diesel	11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
17,000	02/13/2019	Veeder Root/EMC Basic		No	
05	30	04/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
677	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic	
Diesel	11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
17,000	02/13/2019	Veeder Root/EMC Basic		No	
06	30	04/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
678	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic	
Diesel	11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
10,000	02/13/2019	Veeder Root/EMC Basic		No	
07	30	04/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
679	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic	
Gasoline	11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
10,000	02/13/2019	Veeder Root/EMC Basic		No	

08	30	04/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
680	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		02/13/2019	Veeder Root/EMC Basic		No

Facility Summary in Lincoln County in the City of Libby

Location: CABINET PEAKS MEDICAL CENTER
209 Health Park Dr
Libby, MT 59923 Lincoln

Legacy ID:60-15252

Facility ID: 30969
Last Inspected On: 08/24/2020
Operating Permit Renewal Date: 12/19/2023

Owner Operator Contact: Cabinet Peaks Medical Center

4062837000

Operator Contact: Tony Rebo

Owner/Operator: Cabinet Peaks Medical Center

Tony Rebo, UST Class A Operator
Tony Rebo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	8	11/29/2013	Bare Steel	Flexible Plastic	High Level Alarm
5414	Yes	05/03/2017	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000					No

Facility Summary in Lincoln County in the City of Libby

Location: HAPPY'S INN LLC
72576 US Hwy 2
Libby, MT 59923-8518 Lincoln

Legacy ID:27-05998

Facility ID: 24198
Last Inspected On: 02/12/2020
Operating Permit Renewal Date: 03/18/2023

Owner Operator Contact: Happy's Inn LLC

4063343783

Owner/Operator: Happy's Inn LLC

Brandy Kraft, UST Class A Operator
 Brandy Kraft, UST Class B Operator
 Carry Mick, UST Class A Operator
 Deb Steinke, UST Class A Operator
 Deb Steinke, UST Class B Operator
 Kristopher Cole, UST Class A Operator
 Kristopher Cole, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	03/23/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
1282	No			None	Yes
Currently in Use		09/29/2006	Not Required	Safe Suction	Impressed Current
Diesel		02/20/2017	Automatic Tank Gauging 0.2	Deferred	No
8,000			Incon/TS-1000		No
02	37	03/23/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
1283	No			None	Yes
Currently in Use		09/29/2006	Not Required	Safe Suction	Impressed Current
Gasoline		02/20/2017	Automatic Tank Gauging 0.2	Deferred	No
8,000			Incon/TS-1000		No

Facility Summary in Lincoln County in the City of Libby

Location: HARLOWS SCHOOL BUS SERVICE INC LIBBY
 30772 US Hwy 2
 Libby, MT 59923 Lincoln

Legacy ID:27-07523

Facility ID: 24224
Last Inspected On: 11/02/2020
Operating Permit Renewal Date: 12/17/2023

Owner Operator Contact:

Operator Contact: Hugh Taylor;Wesley Tangen

4062398845;4062938845

Owner/Operator: HJJ Properties LLC

Hugh Taylor, UST Class A Operator

Hugh Taylor, UST Class B Operator

Wesley Tangen, UST Class A Operator

Wesley Tangen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	28	02/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3101	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Deferred	No
2,000			Veeder Root/TLS-300		No
04	28	02/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3102	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Deferred	No
2,000			Veeder Root/TLS-300		No

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY CENTRAL OFFICE 9080 B01
114 E 4th St
Libby, MT 59923-2030 Lincoln

Legacy ID:27-07386

Facility ID: 24219
Last Inspected On: 07/13/2020
Operating Permit Renewal Date: 07/31/2023

Owner Operator Contact: Citizens Communications Company

9166863499

Operator Contact: Alan Kelly;Brian McGuinness

4062930010

Owner/Operator: Citizens Communications Company

Alan Kelly, UST Class A Operator
 Alan Kelly, UST Class B Operator
 Brian McGuinness, UST Class A Operator
 Brian McGuinness, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	30	08/01/1991	Fiberglass Reinforced Plastic	Steel	High Level Alarm
4307	No	07/09/2014	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	Gravity Feed	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
600			Gilbarco-Veeder Root/TLS-250		No

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY HIGH SCHOOL DIST 4
 150 Education Way
 Libby, MT 59923-2816 Lincoln

Legacy ID:27-05437

Facility ID: 24187
Last Inspected On: 03/01/2021
Operating Permit Renewal Date: 03/04/2024

Owner Operator Contact: School Dist 4 Libby

4062932791

Operator Contact: David Nadolny;Louie Mysse

Owner/Operator: School Dist 4 Libby

David Nadolny, UST Class A Operator
 David Nadolny, UST Class B Operator
 Louie Mysse, UST Class A Operator
 Louie Mysse, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

S2	31	02/05/1990	Unknown	Copper	Positive Shutoff
1531	Yes	07/31/2018		Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Non-corrodible
Heating Oil			Deferred	Continuous Interstitial Monitoring	No
2,000					No
S3	31	02/05/1990	Unknown	Copper	Positive Shutoff
1532	Yes	07/31/2018		Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Non-corrodible
Heating Oil			Deferred	Continuous Interstitial Monitoring	No
2,000					No
S4	27	07/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1533	No	07/31/2018	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Heating Oil		01/24/2018	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
10,000		05/28/2015	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY QUIK STOP
120 W 9th St
Libby, MT 59923-1965 Lincoln

Legacy ID:27-08831

Facility ID: 24249
Last Inspected On: 10/09/2018
Operating Permit Renewal Date: 03/02/2022

Owner Operator Contact: Travis Tammaro **4063964804**

Operator Contact: Jeffrey Aitken **4068474080**

Owner/Operator: Travis Tammaro

Jeffrey Aitken, UST Class A Operator
Jeffrey Aitken, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	47	11/21/1974	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1274	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		11/20/2018	Veeder Root/TLS-300		No
05	47	11/21/1974	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1276	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		05/09/2012	Veeder Root/TLS-300		No
04	47	11/21/1974	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4881	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		11/20/2018	Veeder Root/TLS-300		No

Facility Summary in Lincoln County in the City of Libby

Location: MACS PLACE
1427 MT Hwy 37
Libby, MT 59923-9309 Lincoln

Legacy ID:27-10660

Facility ID: 24354
Last Inspected On: 06/20/2019
Operating Permit Renewal Date: 10/11/2022

Owner Operator Contact:

Operator Contact: Ann Siefke

4062932784

Owner/Operator: Northside Enterprises LLC

Ann Siefke, UST Class A Operator
Ann Siefke, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	46	03/23/1975	Cathodically Protected Steel	Steel	Flapper Valve
1272	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		08/17/2016	Automatic Tank Gauging 0.2	Deferred	No
4,000		12/30/2005	Veeder Root/TLS-300		No
02	46	03/23/1975	Cathodically Protected Steel	Steel	Flapper Valve
1273	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		08/17/2016	Automatic Tank Gauging 0.2	Deferred	No
12,000		12/30/2005	Veeder Root/TLS-300		No

Facility Summary in Lincoln County in the City of Libby

Location: MCGRADE SCHOOL UST
933 Farm to Market Rd Ste C
Libby, MT 59923-8282 Lincoln

Legacy ID:27-05435

Facility ID: 24185
Last Inspected On: 03/01/2021
Operating Permit Renewal Date: 03/04/2024

Owner Operator Contact: Kirby Maki;School Dist 4 Libby;School Dist 4 Libby **4062932791**

Operator Contact: David Nadolny

Owner/Operator: School Dist 4 Libby

David Nadolny, UST Class A Operator
David Nadolny, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
S2	26	08/01/1995	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
1529	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil	01/23/2018		Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
4,000	01/23/2018		OPW / EMCO/EECO 1500		No

Facility Summary in Lincoln County in the City of Libby

Location: MOORE OIL INC KARDGUARD
206 E 1st St
Libby, MT 59923 Lincoln

Legacy ID:27-10130

Facility ID: 24291
Last Inspected On: 06/20/2019
Operating Permit Renewal Date: 06/24/2022

Owner Operator Contact: Bary Moore;Moore Oil Inc Thompson Falls;Moore Oil Inc Thompson Falls **4068273498;4068274314;4068274314**

Operator Contact: Larry Kelly

Owner/Operator: Moore Oil Inc Thompson Falls

Larry Kelly, UST Class A Operator
Larry Kelly, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
S1	37	12/19/1984	Bare Steel	Flexible Plastic	
1700	Yes	11/22/2016		Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;Manual Interstitial Monitoring	No
20,000					No

S2	37	12/19/1984	Bare Steel	Flexible Plastic	
1701	Yes	11/22/2016		Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; Manual Interstitial Monitoring	No
20,000					No
S4	47	07/01/1974	Bare Steel	Flexible Plastic	
1702	Yes	11/22/2016		Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; Manual Interstitial Monitoring	No
12,000					No

Facility Summary in Lincoln County in the City of Libby

Location: PLUMMER ELEMENTARY SCHOOL
247 Indian Head Rd
Libby, MT 59923-2982 Lincoln

Legacy ID:27-05436

Facility ID: 24186
Last Inspected On: 02/17/2021
Operating Permit Renewal Date: 02/19/2024

Owner Operator Contact: School Dist 4 Libby

4062932791

Operator Contact: David Nadolny

Owner/Operator: School Dist 4 Libby

David Nadolny, UST Class A Operator
David Nadolny, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	25	08/01/1996	Cathodically Protected Steel	Steel	Flapper Valve
1530	No	07/20/2015	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		01/23/2018	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lincoln County in the City of Libby

Location: SAVE RITE SOUTH
33934 US Hwy 2
Libby, MT 59923-9011 Lincoln

Legacy ID:27-01240

Facility ID: 24106
Last Inspected On: 03/28/2019
Operating Permit Renewal Date: 04/01/2022

Owner Operator Contact: Golden State Oil;Jesse Knapp;Robert Uithof;Golden State Oil

Operator Contact: Jesse Knapp;Lloyd Holcomb

4062831352

Owner/Operator: Golden State Oil

Owner/Operator: Robert Uithof

Jesse Knapp, UST Class A Operator
Jesse Knapp, UST Class B Operator
Lloyd Holcomb, UST Class A Operator
Lloyd Holcomb, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	32	05/01/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2167	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/18/2007	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000		11/18/2010	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
07	32	05/01/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2168	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/18/2007	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000		11/18/2010	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
08	32	05/01/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2169	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/18/2007	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No

4,000		11/18/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
16	26	06/03/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2170	No	10/03/2016		Double Walled	Yes
Currently in Use		08/31/2012	Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000		07/18/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
17	26	06/03/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2171	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		07/18/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
18	26	06/03/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2172	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000		07/18/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
19	26	06/23/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2173	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000		07/18/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

20	26	06/23/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2174	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000		07/18/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
21	26	06/23/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2175	No	10/03/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000		07/18/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lincoln County in the City of Libby

Location: SAVE RITE WEST
31978 US Hwy 2
Libby, MT 59923-3026 Lincoln

Legacy ID:27-01239

Facility ID: 24105
Last Inspected On: 03/28/2019
Operating Permit Renewal Date: 04/01/2022

Owner Operator Contact: Golden State Oil;Robert Uithof;Golden State Oil

Operator Contact: Jesse Knapp;Lloyd Holcomb

4062831352

Owner/Operator: Golden State Oil

Owner/Operator: Robert Uithof

Jesse Knapp, UST Class A Operator
Jesse Knapp, UST Class B Operator
Lloyd Holcomb, UST Class A Operator
Lloyd Holcomb, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

13	27	03/01/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2158	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		05/18/2007	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000			Incon/TS-1000		No
14	27	03/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2159	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		05/20/2010	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000			Incon/TS-1000		No
15	27	03/01/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2160	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		05/20/2010	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000			Incon/TS-1000		No
16	24	06/01/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2161	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		09/12/2013	Gilbarco/EMC Basic		No
17	24	06/01/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve

2162	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000		09/12/2013	Gilbarco/EMC Basic		No
18	24	06/01/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2163	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		09/12/2013	Gilbarco/EMC Basic		No
19	24	06/01/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2164	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000		09/12/2013	Gilbarco/EMC Basic		No
20	24	06/01/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2165	No	09/16/2013		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000		09/12/2013	Gilbarco/EMC Basic		No
21	24	06/01/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2166	No	09/16/2013		Double Walled	Yes

Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel	08/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
3,000	09/12/2013	Gilbarco/EMC Basic		No

Facility Summary in Lincoln County in the City of Libby

Location: SEWER PLANT
750 City Service Rd
Libby, MT 59923 Lincoln

Legacy ID:27-03164

Facility ID: 24131
Last Inspected On: 03/01/2021
Operating Permit Renewal Date: 03/12/2024

Owner Operator Contact: City of Libby

Operator Contact: Lucas Backen;Mike Voorhies

4062934684

Owner/Operator: City of Libby

Lucas Backen, UST Class A Operator
Mike Voorhies, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	35	12/01/1986	Fiberglass Reinforced Plastic	Steel	Flapper Valve
4089	No			None	Yes
Currently in Use			Not Required	U.S. Suction	
Diesel		11/07/2017	Manual Tank Gauging	3-Year Line Tightness Test	No
550		11/18/2014			No

Facility Summary in Lincoln County in the City of Libby

Location: ST JOHNS LUTHERAN HOSPITAL
350 Louisiana Ave
Libby, MT 59923-2198 Lincoln

Legacy ID:27-01695

Facility ID: 24110
Last Inspected On: 08/24/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact:

Operator Contact: Tony Rebo

Owner/Operator: Cabinet Peaks Medical Center

Tony Rebo, UST Class A Operator

Tony Rebo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	23	07/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1952	No	07/29/2014	Double-Walled	Double Walled	Yes
Currently in Use		02/15/2013	Auto Dialer	U.S. Suction	Non-corrodible
Heating Oil			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-300		Yes

Facility Summary in Lincoln County in the City of Libby

Location: ST JOSEPH PARISH
719 Utah Ave
Libby, MT 59923-2115 Lincoln

Legacy ID:27-07289

Facility ID: 24218
Last Inspected On: 09/02/2021
Operating Permit Renewal Date: 12/11/2024

Owner Operator Contact: Diocese of Helena

4062934322

Operator Contact: Lauri Youso;Richard Kluk

4062933216;4062934322

Owner/Operator: Diocese of Helena

Lauri Youso, UST Class A Operator
Lauri Youso, UST Class B Operator
Richard Kluk, UST Class A Operator
Richard Kluk, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	28	11/30/1993	Fiberglass Reinforced Plastic	Copper	Flapper Valve

833	No	10/09/2018	Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Heating Oil			Continuous Interstitial Monitoring	Manual Interstitial Monitoring	No
1,000			Pneumercator/Other		No

Facility Summary in Lincoln County in the City of Libby

Location: TOWN PUMP INC LIBBY 2
1315 Minnesota Ave
Libby, MT 59923 Lincoln

Legacy ID:56-14121

Facility ID: 30762
Last Inspected On: 07/01/2021
Operating Permit Renewal Date: 07/20/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Libby 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	17	06/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4922	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		No
02	17	06/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4923	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
03	17	06/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4924	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
04	17	06/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4925	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		No
05	17	06/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4927	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
06	17	06/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4928	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lincoln County in the City of Troy

Location: CENEX TROY MINI MART
217 E Missoula Ave
Troy, MT 59935 Lincoln

Legacy ID:27-03253

Facility ID: 24134
Last Inspected On: 09/05/2019
Operating Permit Renewal Date: 09/11/2022

Owner Operator Contact: Barry Beatty;Troy Mini Mart;Frederick Haaland;Frederick R Haaland;Joseph Lapham

2082637606

Operator Contact: Joseph Lapham;Kayla Eberly;Mark Roesler-Begalke;Mike DuPerault;Paula Paasch;Valerie Brown

2082637606;2086101110;4062954285;4062954933

Owner/Operator: Joseph Lapham

- Brittany Savage, UST Class B Global Operator
- Brittany Savage, UST Class B Operator
- Joseph Lapham, UST Class A Operator
- Joseph Lapham, UST Class B Operator
- Kayla Eberly, UST Class A Operator
- Mark Roesler-Begalke, UST Class A Operator
- Mike DuPerault, UST Class A Operator
- Mike DuPerault, UST Class B Operator
- Paula Paasch, UST Class A Operator
- Paula Paasch, UST Class B Operator
- Valerie Brown, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	28	04/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3129	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No

8,000		08/15/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	28	04/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3130	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/15/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	28	04/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3131	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		12/29/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000		08/15/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	28	04/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3132	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		12/29/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000		08/15/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lincoln County in the City of Troy

Location: LINCOLN COUNTY SHOP TROY
1210 E Missoula Ave
Troy, MT 59935-9640 Lincoln

Legacy ID:27-06716

Facility ID: 24202
Last Inspected On: 01/04/2019
Operating Permit Renewal Date: 07/02/2022

Owner Operator Contact: Lincoln County Road Dept

4062954420

Operator Contact: Dave Kyriss

4062954420

Owner/Operator: Lincoln County Road Dept

Dave Kyriss, UST Class A Operator

Dave Kyriss, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	05/01/1990	Cathodically Protected Steel	Steel	Flapper Valve
1538	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		05/16/2016	Continuous Interstitial Monitoring	Deferred	No
2,000			Other/Other		No
04	31	05/01/1990	Cathodically Protected Steel	Steel	Flapper Valve
1539	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		05/16/2016	Continuous Interstitial Monitoring	Deferred	No
2,000			Other/Other		No

Facility Summary in Lincoln County in the City of Troy

Location: TOWN PUMP INC TROY
112 E Missoula Ave
Troy, MT 59935 Lincoln

Legacy ID:27-08722

Facility ID: 24241
Last Inspected On: 07/03/2021
Operating Permit Renewal Date: 07/20/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Troy 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	49	04/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2522	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/27/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
02	49	04/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2523	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/27/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
03	41	04/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2524	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/27/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lincoln County in the City of Troy

Location: TROY CENTRAL OFFICE 9140 B01
402 N 2nd St
Troy, MT 59935 Lincoln

Legacy ID:27-08082

Facility ID: 24235
Last Inspected On: 05/16/2019
Operating Permit Renewal Date: 06/01/2022

Owner Operator Contact: Citizens Communications Company

9166863499

Operator Contact: Brian McGuinness;John Jones

Owner/Operator: Citizens Communications Company

Alan Kelly, UST Class B Operator
Brian McGuinness, UST Class A Operator
Brian McGuinness, UST Class B Global Operator
John Jones, UST Class A Operator
John Jones, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	30	08/01/1991	Unknown	Steel	
3272	Yes	04/28/2016		Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
500					No

Facility Summary in Lincoln County in the City of Troy

Location: TROY ELEMENTARY SCHOOL
318 Kalispell Ave
Troy, MT 59935 Lincoln

Legacy ID:27-00764

Facility ID: 24102
Last Inspected On: 12/17/2018
Operating Permit Renewal Date: 03/02/2022

Owner Operator Contact: School Dist 1 Troy

4062954606

Operator Contact: John Daniel;Keith Haggerty

4062931170;4062931693

Owner/Operator: School Dist 1 Troy

John Daniel, UST Class A Operator
John Daniel, UST Class B Global Operator

Keith Haggerty, UST Class A Operator
 Keith Haggerty, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	34	08/01/1987	Cathodically Protected Steel	Copper	Flapper Valve
2149	No			PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		01/06/2016	Manual Interstitial Monitoring	Manual Interstitial Monitoring	No
10,000					No

Facility Summary in Lincoln County in the City of Troy

Location: TROY HIGH SCHOOL MISSOULA AVE
 204 Missoula Ave
 Troy, MT 59935 Lincoln

Legacy ID:27-00763

Facility ID: 24101
Last Inspected On: 12/17/2018
Operating Permit Renewal Date: 03/02/2022

Owner Operator Contact: School Dist 1 Troy

4062954606

Operator Contact: John Daniel;Keith Haggerty

4062931170;4062931693

Owner/Operator: School Dist 1 Troy

John Daniel, UST Class A Operator
 John Daniel, UST Class B Global Operator
 Keith Haggerty, UST Class A Operator
 Keith Haggerty, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	34	08/01/1987	Cathodically Protected Steel	Copper	Flapper Valve

2147	No			PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		01/06/2016	Manual Interstitial Monitoring	Manual Interstitial Monitoring	No
10,000					No
S3	34	08/01/1987	Cathodically Protected Steel	Copper	Flapper Valve
2148	No		Double-Walled	PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		01/06/2016	Manual Interstitial Monitoring	Manual Interstitial Monitoring	No
10,000					No