

Facility Summary in Lincoln County in the City of Eureka

Location: KSANKA STORE
1835 Hwy 93 N
Eureka, MT 59917 Lincoln

System Facility ID:27-05303

Facility Code: 24175
Last Inspected On: 06/06/2023
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: AR93, LLC;HARJ93, LLC

(206) 834-5349;(914) 433-7643

sheragroupllc@gmail.com;shergroupllc@gmail.com

Operator Contact: Rahul Kumar

tharejallc@gmail.com

Owner/Operator: AR93, LLC

(914) 433-7643

shergroupllc@gmail.com

Owner/Operator: HARJ93, LLC

(914) 433-7643

shergroupllc@gmail.com

Rahul Kumar, UST Class A Operator

Rahul Kumar, UST Class B Operator

tharejallc@gmail.com

tharejallc@gmail.com

Tank Code	04	Tank Age	36	Tank Installed Date	04/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3308	Spill Test Date	01/23/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/06/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/02/2023	Line Tightness Test Date	06/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/02/2023			ATG Type	Veeder Root/TLS-250				
Tank Code	05	Tank Age	36	Tank Installed Date	04/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3309	Spill Test Date	06/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/06/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/02/2023	Line Tightness Test Date	06/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/02/2023			ATG Type	Veeder Root/TLS-250				

Facility Summary in Lincoln County in the City of Eureka

Location: RANCH HAND INC
1000 US Hwy 93 N
Eureka, MT 59917-9555 Lincoln

System Facility ID:27-12713

Facility Code: 24484
Last Inspected On: 10/07/2024
Operating Permit Renewal Date: 03/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: AJR LLC

(509) 953-9787

sheragroupllc@gmail.com

Operator Contact: Rahul Kumar

tharejallc@gmail.com

Owner/Operator: AJR LLC

(509) 953-9787

sheragroupllc@gmail.com

Rahul Kumar, UST Class A Operator

tharejallc@gmail.com

Rahul Kumar, UST Class B Operator

tharejallc@gmail.com

Tank Code	08	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2960	Spill Test Date	10/07/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	10/07/2024	Line Tightness Test Date	10/07/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2961	Spill Test Date	03/05/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/07/2024	Line Tightness Test Date	10/07/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	10	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2962	Spill Test Date	10/07/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	10/07/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/07/2024	Line Tightness Test Date	10/07/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	11	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2963	Spill Test Date	05/26/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/04/2022	Line Tightness Test Date	10/04/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/03/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	12	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2964	Spill Test Date	10/07/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/07/2024	Line Tightness Test Date	10/07/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	13	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2965	Spill Test Date	03/28/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	10/07/2024	Line Tightness Test Date	10/07/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Lincoln County in the City of Eureka

Location: TOWN PUMP INC EUREKA
10 Dewey Ave
Eureka, MT 59917 Lincoln

System Facility ID:27-08699

Facility Code: 24240
Last Inspected On: 05/18/2023
Operating Permit Renewal Date: 08/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Eureka 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Eureka 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	04	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2517	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	03/25/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2518	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	03/25/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	06	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2519	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	03/25/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2520	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	03/25/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date	08/27/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2521	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	03/25/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	26	Tank Installed Date	11/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4251	Spill Test Date	06/25/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	03/25/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	26	Tank Installed Date	11/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4252	Spill Test Date	06/25/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	03/25/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	12	Tank Installed Date	03/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5467	Spill Test Date	06/25/2021	Piping Installed Date	02/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	12	Tank Age	12	Tank Installed Date	03/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5468	Spill Test Date	06/25/2021	Piping Installed Date	02/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLL D Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	13	Tank Age	12	Tank Installed Date	03/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5469	Spill Test Date	06/25/2021	Piping Installed Date	02/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lincoln County in the City of Fortune

Location: CRYSTAL LAKES RESORT INC
Crystal Lakes Rd
Fortine, MT 59918 Lincoln

System Facility ID:27-03824

Facility Code: 24145
Last Inspected On: 01/21/2025
Operating Permit Renewal Date: 04/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: James Smith

clsupermt@gmail.com

Operator Contact: James Smith

clsupermt@gmail.com

Owner/Operator: James E Smith

clsupermt@gmail.com

James E Smith, UST Class A Operator

clsupermt@gmail.com

James E Smith, UST Class B Operator

clsupermt@gmail.com

Tank Code	01	Tank Age	40	Tank Installed Date	06/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3892	Spill Test Date	01/21/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/03/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	01/21/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/03/2025	Line Tightness Test Date	12/03/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/21/2025			ATG Type	Incon/TS-1000				
Tank Code	02	Tank Age	40	Tank Installed Date	06/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3893	Spill Test Date	01/21/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/03/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	01/21/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/03/2025	Line Tightness Test Date	12/03/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/21/2025			ATG Type	Incon/TS-1000				

Facility Summary in Lincoln County in the City of Fortune

Location: FORTINE MERC LLC
12000 US Hwy 93 S
Fortine, MT 59918 Lincoln

System Facility ID:27-13725

Facility Code: 24537
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 03/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: FORTINE MERC LLC;Steven Vredenburg

(406) 882-4446;(971) 404-9771

fortinemerc@gmail.com;tessamt@aol.com

Operator Contact: Debbie Peterson

fortinemerc@gmail.com

Owner/Operator: FORTINE MERC LLC

(406) 882-4446

fortinemerc@gmail.com

Owner/Operator: Steven Vredenburg

(406) 882-4446

fortinemerc@gmail.com

Debbie Peterson, UST Class A Operator

Debbie Peterson, UST Class B Operator

fortinemerc@gmail.com

fortinemerc@gmail.com

Tank Code	01	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4705	Spill Test Date	11/13/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/05/2023	Line Tightness Test Date	12/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/05/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4706	Spill Test Date	11/13/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/05/2023	Line Tightness Test Date	12/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/05/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve

Tag Number	4707	Spill Test Date	11/13/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/05/2023	Line Tightness Test Date	12/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/05/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Lincoln County in the City of Libby

Location: CABINET PEAKS MEDICAL CENTER
209 Health Park Dr
Libby, MT 59923 Lincoln

System Facility ID:60-15252

Facility Code: 30969
Last Inspected On: 10/18/2023
Operating Permit Renewal Date: 12/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cabinet Peaks Medical Center

trebo@cabinetpeaks.org

Operator Contact: Tony Rebo

trebo@sjlh.com

Owner/Operator: Cabinet Peaks Medical Center

trebo@cabinetpeaks.org

Tony Rebo, UST Class A Operator

trebo@sjlh.com

Tony Rebo, UST Class B Operator

trebo@sjlh.com

Tank Code	S1	Tank Age	13	Tank Installed Date	11/29/2013	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5414	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lincoln County in the City of Libby

Location: HAPPY'S INN LLC
72576 US Hwy 2
Libby, MT 59923-8518 Lincoln

System Facility ID:27-05998

Facility Code: 24198
Last Inspected On: 11/13/2025
Operating Permit Renewal Date: 03/18/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Happy's Inn LLC (406) 334-3783 coles1222@aol.com

Operator Contact: Brandy Kraft;Carry Mick;Deb Steinke;Kristopher Cole (406) 293-4079;(406) 334-3783 coles1222@aol.com;d.steinke@frontier.com;happysroadhouseinn@gmail.com

Owner/Operator: Happy's Inn LLC (406) 334-3783 coles1222@aol.com

Brandy Kraft, UST Class A Operator
Brandy Kraft, UST Class B Operator
Carry Mick, UST Class A Operator
Deb Steinke, UST Class A Operator
Deb Steinke, UST Class B Operator
Kristopher Cole, UST Class A Operator
Kristopher Cole, UST Class B Operator

happysroadhouseinn@gmail.com
happysroadhouseinn@gmail.com
happysroadhouseinn@gmail.com
d.steinke@frontier.com
d.steinke@frontier.com
coles1222@aol.com
coles1222@aol.com

Tank Code	01	Tank Age	42	Tank Installed Date	03/23/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1282	Spill Test Date	11/13/2025	Piping Installed Date	09/29/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/13/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	11/13/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/13/2025			ATG Type	Incon/TS-1000				
Tank Code	02	Tank Age	42	Tank Installed Date	03/23/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1283	Spill Test Date	11/13/2025	Piping Installed Date	09/29/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/13/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	11/13/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

Overfill Test Date 11/13/2025

ATG Type Incon/TS-1000

Facility Summary in Lincoln County in the City of Libby

Location: HARLOWS SCHOOL BUS SERVICE INC LIBBY
30772 US Hwy 2
Libby, MT 59923 Lincoln

System Facility ID:27-07523

Facility Code: 24224
Last Inspected On: 10/19/2023
Operating Permit Renewal Date: 12/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: HJJ Properties LLC

(701) 224-1767

jeremy.hageness@goharloys.com

Operator Contact: Wesley Tangen

(406) 293-8845

Owner/Operator: HJJ Properties LLC

(701) 224-1767

jeremy.hageness@goharloys.com

Wesley Tangen, UST Class A Operator

Wesley Tangen, UST Class B Operator

Tank Code	03	Tank Age	33	Tank Installed Date	02/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3101	Spill Test Date	10/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	10/19/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/19/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	33	Tank Installed Date	02/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3102	Spill Test Date	10/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	10/19/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/19/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY CENTRAL OFFICE 9080 B01
114 E 4th St
Libby, MT 59923-2030 Lincoln

System Facility ID:27-07386

Facility Code: 24219
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 07/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Citizens Communications Company

(916) 686-3499

legal@zipl.com

Operator Contact: Alan Kelly

(406) 293-0010

alan.kelly@zipl.com

Owner/Operator: Citizens Communications Company

(916) 686-3499

legal@zipl.com

Alan Kelly, UST Class A Operator

alan.kelly@zipl.com

Alan Kelly, UST Class B Operator

alan.kelly@zipl.com

Tank Code	02	Tank Age	35	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	4307	Spill Test Date	10/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Gravity Feed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	600	ATG Test Date	07/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-250				

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY HIGH SCHOOL DIST 4
150 Education Way
Libby, MT 59923-2816 Lincoln

System Facility ID:27-05437

Facility Code: 24187
Last Inspected On: 09/05/2023
Operating Permit Renewal Date: 03/04/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 4 Libby

(406) 293-2791

Operator Contact: David Nadolny;Louie Mysse

myssel@libby.k12.mt.us;nadolnyd@libbyschools.org

Owner/Operator: School Dist 4 Libby

(406) 293-2791

David Nadolny, UST Class A Operator

nadolnyd@libbyschools.org

David Nadolny, UST Class B Operator

nadolnyd@libbyschools.org

Louie Mysse, UST Class A Operator

myssel@libby.k12.mt.us

Louie Mysse, UST Class B Global Operator

myssel@libby.k12.mt.us

Tank Code	S2	Tank Age	36	Tank Installed Date	02/05/1990	Tank Material	Unknown	Piping Material	Copper	Overfill Types	Positive Shutoff
Tag Number	1531	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	03/04/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	36	Tank Installed Date	02/05/1990	Tank Material	Unknown	Piping Material	Copper	Overfill Types	Positive Shutoff
Tag Number	1532	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	03/04/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S4	Tank Age	32	Tank Installed Date	07/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1533	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/04/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	09/05/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/28/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY QUIK STOP
120 W 9th St
Libby, MT 59923-1965 Lincoln

System Facility ID: 27-08831

Facility Code: 24249
Last Inspected On: 10/03/2024
Operating Permit Renewal Date: 03/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: HIMALYAN LLC

(406) 293-7513

LAKESIDEUNITY@GMAIL.COM

Operator Contact:

Owner/Operator: HIMALYAN LLC

(406) 293-7513

LAKESIDEUNITY@GMAIL.COM

Tank Code	03	Tank Age	52	Tank Installed Date	11/21/1974	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1274	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/02/2024	Line Tightness Test Date	05/02/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	52	Tank Installed Date	11/21/1974	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1276	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/09/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	52	Tank Installed Date	11/21/1974	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	4881	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/02/2024	Line Tightness Test Date	05/02/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: MACS PLACE
1427 MT Hwy 37
Libby, MT 59923-9309 Lincoln

System Facility ID:27-10660

Facility Code: 24354
Last Inspected On: 06/23/2025
Operating Permit Renewal Date: 10/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northside Enterprises LLC

(406) 293-7799

Operator Contact: Ann Siefke

(406) 293-2784

a_montgirl@yahoo.com

Owner/Operator: Northside Enterprises LLC

(406) 293-7799

Ann Siefke, UST Class A Operator

a_montgirl@yahoo.com

Ann Siefke, UST Class B Operator

a_montgirl@yahoo.com

Tank Code	01	Tank Age	51	Tank Installed Date	03/23/1975	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1272	Spill Test Date	06/23/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/04/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	06/23/2025	Line Tightness Test Date	12/30/2005	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/23/2025			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	51	Tank Installed Date	03/23/1975	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1273	Spill Test Date	06/23/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/23/2025	Line Tightness Test Date	12/30/2005	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/23/2025			ATG Type	Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: MCGRADE SCHOOL UST
933 Farm to Market Rd Ste C
Libby, MT 59923-8282 Lincoln

System Facility ID:27-05435

Facility Code: 24185
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 03/04/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 4 Libby

(406) 293-2791

Operator Contact: David Nadolny

nadolnyd@libbyschools.org

Owner/Operator: School Dist 4 Libby

(406) 293-2791

David Nadolny, UST Class A Operator

David Nadolny, UST Class B Operator

nadolnyd@libbyschools.org

nadolnyd@libbyschools.org

Tank Code	S2	Tank Age	31	Tank Installed Date	08/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1529	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	09/05/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/05/2023	Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date	09/05/2023			ATG Type	Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Libby

Location: PLUMMER ELEMENTARY SCHOOL
247 Indian Head Rd
Libby, MT 59923-2982 Lincoln

System Facility ID:27-05436

Facility Code: 24186
Last Inspected On: 09/05/2023
Operating Permit Renewal Date: 02/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 4 Libby

(406) 293-2791

Operator Contact: David Nadolny

nadolnyd@libbyschools.org

Owner/Operator: School Dist 4 Libby

(406) 293-2791

David Nadolny, UST Class A Operator

David Nadolny, UST Class B Operator

nadolnyd@libbyschools.org

nadolnyd@libbyschools.org

Tank Code	S2	Tank Age	30	Tank Installed Date	08/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1530	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/03/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	09/05/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Libby

Location: QUICK STOP
36175 US Hwy 2 W
Libby, MT 59923 Lincoln

System Facility ID:27-10863

Facility Code: 24368
Last Inspected On: 11/28/2023
Operating Permit Renewal Date: 03/31/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: AJR LLC

(509) 953-9787

sheragroupllc@gmail.com

Operator Contact: Jessica Parker

bearscountrystore2017@gmail.com

Owner/Operator: AJR LLC

(509) 953-9787

sheragroupllc@gmail.com

Jessica Parker, UST Class A Operator

bearscountrystore2017@gmail.com

Jessica Parker, UST Class B Operator

bearscountrystore2017@gmail.com

Tank Code	04	Tank Age	35	Tank Installed Date	04/29/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	676	Spill Test Date	04/21/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	17000	ATG Test Date	11/28/2023	Line Tightness Test Date	11/28/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/28/2023			ATG Type	Veeder Root/EMC Basic				
Tank Code	05	Tank Age	35	Tank Installed Date	04/29/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	677	Spill Test Date	11/28/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	17000	ATG Test Date	11/28/2023	Line Tightness Test Date	11/28/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/28/2023			ATG Type	Veeder Root/EMC Basic				
Tank Code	06	Tank Age	35	Tank Installed Date	04/29/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	678	Spill Test Date	04/21/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	11/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/28/2023	Line Tightness Test Date	11/28/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/28/2023			ATG Type	Veeder Root/EMC Basic				
Tank Code	07	Tank Age	35	Tank Installed Date	04/29/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	679	Spill Test Date	04/21/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/28/2023	Line Tightness Test Date	11/28/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/28/2023			ATG Type	Veeder Root/EMC Basic				
Tank Code	08	Tank Age	35	Tank Installed Date	04/29/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	680	Spill Test Date	04/21/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/28/2023	Line Tightness Test Date	11/28/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/28/2023			ATG Type	Veeder Root/EMC Basic				

Facility Summary in Lincoln County in the City of Libby

Location: SAVE RITE SOUTH
33934 US Hwy 2
Libby, MT 59923-9011 Lincoln

System Facility ID:27-01240

Facility Code: 24106
Last Inspected On: 01/05/2025
Operating Permit Renewal Date: 04/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Robert Uithof	(406) 293-4119	gsoil@frontiernet.net
--	----------------	-----------------------

Operator Contact: Jesse Knapp;Lloyd Holcomb	(406) 283-1352;(406) 293-4119	knapp539@gmail.com;lazyway@montanasky.tv
--	-------------------------------	--

Owner/Operator: Robert Uithof	(406) 293-4119	gsoil@frontiernet.net
Jesse Knapp, UST Class A Operator		knapp539@gmail.com
Jesse Knapp, UST Class B Operator		knapp539@gmail.com
Lloyd Holcomb, UST Class A Operator		lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Global Operator		lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Operator		lazyway@montanasky.tv

Tank Code	06	Tank Age	37	Tank Installed Date	05/01/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2167	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/18/2007	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	37	Tank Installed Date	05/01/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2168	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLL Test Date		Tank/Piping CP Test Date	05/18/2007	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	37	Tank Installed Date	05/01/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2169	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLL Test Date		Tank/Piping CP Test Date	05/18/2007	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	16	Tank Age	31	Tank Installed Date	06/03/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2170	Spill Test Date	10/03/2024	Piping Installed Date	08/31/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLL Test Date		Tank/Piping CP Test Date	12/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Manual Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	17	Tank Age	31	Tank Installed Date	06/03/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2171	Spill Test Date	04/10/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Diesel	PLL Test Date		Tank/Piping CP Test Date	12/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Manual Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	18	Tank Age	31	Tank Installed Date	06/03/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2172	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLL Test Date		Tank/Piping CP Test Date	12/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Manual Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	19	Tank Age	31	Tank Installed Date	06/23/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2173	Spill Test Date	04/10/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/04/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLL Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/03/2024	Line Tightness Test Date	12/04/2021	Secondary Tank Leak Detection	Manual Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	20	Tank Age	31	Tank Installed Date	06/23/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2174	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLL Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Manual Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No

		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	21	Tank Age	31	Tank Installed Date	06/23/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2175	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date	10/03/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection	Manual Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lincoln County in the City of Libby

Location: SAVE RITE WEST
31978 US Hwy 2
Libby, MT 59923-3026 Lincoln

System Facility ID:27-01239

Facility Code: 24105
Last Inspected On: 01/05/2025
Operating Permit Renewal Date: 04/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Robert Uithof (406) 293-4119 gsoil@frontiernet.net

Operator Contact: Jesse Knapp;Lloyd Holcomb (406) 283-1352;(406) 293-4119 knapp539@gmail.com;lazyway@montanasky.tv

Owner/Operator: Robert Uithof (406) 293-4119 gsoil@frontiernet.net

Jesse Knapp, UST Class A Operator

knapp539@gmail.com

Jesse Knapp, UST Class B Operator

knapp539@gmail.com

Lloyd Holcomb, UST Class A Operator

lazyway@montanasky.tv

Lloyd Holcomb, UST Class B Operator

lazyway@montanasky.tv

Tank Code	13	Tank Age	32	Tank Installed Date	03/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2158	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/18/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	14	Tank Age	32	Tank Installed Date	03/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2159	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/20/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	15	Tank Age	32	Tank Installed Date	03/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2160	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/20/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	16	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2161	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	17	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2162	Spill Test Date	11/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	18	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2163	Spill Test Date	04/09/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	12000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	19	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2164	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	20	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2165	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	21	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2166	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	10/03/2024	Line Tightness Test Date	10/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco/TLS-350				

Facility Summary in Lincoln County in the City of Libby

Location: ST JOHNS LUTHERAN HOSPITAL
350 Louisiana Ave
Libby, MT 59923-2198 Lincoln

System Facility ID:27-01695

Facility Code: 24110
Last Inspected On: 05/04/2023
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cabinet Peaks Medical Center

trebo@cabinetpeaks.org

Operator Contact: Tony Rebo

trebo@sjlh.com

Owner/Operator: Cabinet Peaks Medical Center

trebo@cabinetpeaks.org

Tony Rebo, UST Class A Operator

trebo@sjlh.com

Tony Rebo, UST Class B Operator

trebo@sjlh.com

Tank Code	S3	Tank Age	28	Tank Installed Date	07/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1952	Spill Test Date	05/04/2023	Piping Installed Date	02/15/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	05/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: ST JOSEPH PARISH
719 Utah Ave
Libby, MT 59923-2115 Lincoln

System Facility ID:27-07289

Facility Code: 24218
Last Inspected On: 09/03/2024
Operating Permit Renewal Date: 12/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Diocese of Helena (406) 293-4322 stjosephlibby@gmail.com

Operator Contact: Lauri Youso;Richard Kluk (406) 293-3216;(406) 293-4322 stjosephlibby@gmail.com

Owner/Operator: Diocese of Helena (406) 293-4322 stjosephlibby@gmail.com

Lauri Youso, UST Class A Operator

stjosephlibby@gmail.com

Lauri Youso, UST Class B Operator

stjosephlibby@gmail.com

Richard Kluk, UST Class A Operator

stjosephlibby@gmail.com

Richard Kluk, UST Class B Operator

stjosephlibby@gmail.com

Tank Code	S3	Tank Age	33	Tank Installed Date	11/30/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	833	Spill Test Date	09/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Manual Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	09/03/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/03/2024			ATG Type	Pneumercator/Other				

Facility Summary in Lincoln County in the City of Libby

Location: TOWN PUMP INC LIBBY 2
1315 Minnesota Ave
Libby, MT 59923 Lincoln

System Facility ID: 56-14121

Facility Code: 30762
Last Inspected On: 11/05/2025
Operating Permit Renewal Date: 09/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Libby 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Libby 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	22	Tank Installed Date	06/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4922	Spill Test Date	08/15/2022	Piping Installed Date	06/09/2004	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	02/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	22	Tank Installed Date	06/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4923	Spill Test Date	08/15/2022	Piping Installed Date	06/09/2004	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	22	Tank Installed Date	06/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4924	Spill Test Date	12/07/2022	Piping Installed Date	06/09/2004	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	22	Tank Installed Date	06/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4925	Spill Test Date	08/15/2022	Piping Installed Date	06/09/2004	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	02/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	22	Tank Installed Date	06/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4927	Spill Test Date	12/07/2022	Piping Installed Date	06/09/2004	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	02/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	22	Tank Installed Date	06/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4928	Spill Test Date	08/15/2022	Piping Installed Date	06/09/2004	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date	02/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Troy

Location: CENEX TROY MINI MART
217 E Missoula Ave
Troy, MT 59935 Lincoln

System Facility ID:27-03253

Facility Code: 24134
Last Inspected On: 07/16/2025
Operating Permit Renewal Date: 09/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Joseph Lapham

(208) 263-7606

Operator Contact: Mike DuPerault

(208) 610-1110

2holidaymotel2@gmail.com.

Owner/Operator: Joseph Lapham

(208) 263-7606

Mike DuPerault, UST Class A Operator

2holidaymotel2@gmail.com.

Mike DuPerault, UST Class B Operator

2holidaymotel2@gmail.com.

Tank Code	07	Tank Age	33	Tank Installed Date	04/12/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3129	Spill Test Date	07/16/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/16/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/16/2025	Line Tightness Test Date	07/16/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/16/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	33	Tank Installed Date	04/12/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3130	Spill Test Date	07/16/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/16/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/16/2025	Line Tightness Test Date	07/16/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/16/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	33	Tank Installed Date	04/12/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	3131	Spill Test Date	07/16/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/16/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/16/2025	Line Tightness Test Date	07/16/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/16/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	33	Tank Installed Date	04/12/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3132	Spill Test Date	07/16/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/16/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/16/2025	Line Tightness Test Date	07/16/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/16/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lincoln County in the City of Troy

Location: LINCOLN COUNTY SHOP TROY
1210 E Missoula Ave
Troy, MT 59935-9640 Lincoln

System Facility ID:27-06716

Facility Code: 24202
Last Inspected On: 04/28/2025
Operating Permit Renewal Date: 07/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lincoln County Road Dept

(406) 295-4420

Operator Contact: DJ Welch

road2@libby.org

Owner/Operator: Lincoln County Road Dept

(406) 295-4420

DJ Welch, UST Class A Operator

DJ Welch, UST Class B Operator

road2@libby.org

road2@libby.org

Tank Code	03	Tank Age	36	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1538	Spill Test Date	04/28/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/28/2025	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	04/28/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/28/2025			ATG Type	OPW / EMCO/Auto Stik JR				
Tank Code	04	Tank Age	36	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1539	Spill Test Date	04/28/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/28/2025	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	04/28/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/28/2025			ATG Type	OPW / EMCO/Auto Stik JR				

Facility Summary in Lincoln County in the City of Troy

Location: TOWN PUMP TROY
107 E Missoula Ave
Troy, MT 59935 Lincoln

System Facility ID:00-32472

Facility Code: 32472
Last Inspected On: 09/08/2024
Operating Permit Renewal Date: 09/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Troy Town Pump, Inc.

(406) 497-6700

arnoldo@townpump.com

Operator Contact: Trent Biggers;Town Pump

Trentb@townpump.com;environmental@townpump.com

Owner/Operator: Troy Town Pump, Inc.

(406) 497-6700

arnoldo@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Operator

environmental@townpump.com

environmental@townpump.com

Tank Code	01	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6066	Spill Test Date	08/10/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/10/2022	Line Tightness Test Date	02/14/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/10/2022			ATG Type					
Tank Code	02	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6067	Spill Test Date	08/10/2022	Piping Installed Date	03/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	6000	ATG Test Date	08/10/2022	Line Tightness Test Date	02/14/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	08/10/2022			ATG Type					
Tank Code	03	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6068	Spill Test Date	08/10/2022	Piping Installed Date	03/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/10/2022	Line Tightness Test Date	02/14/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/10/2022			ATG Type					
Tank Code	04	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6069	Spill Test Date	08/10/2022	Piping Installed Date	03/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/10/2022	Line Tightness Test Date	02/14/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/10/2022			ATG Type					
Tank Code	05	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6070	Spill Test Date		Piping Installed Date	03/01/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes

	Overfill Test Date				ATG Type					
Tank Code	06	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6071	Spill Test Date	08/10/2023	Piping Installed Date	03/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	6000	ATG Test Date	08/10/2023	Line Tightness Test Date	02/15/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	08/10/2023			ATG Type				
Tank Code	07	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6072	Spill Test Date	08/10/2023	Piping Installed Date	03/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	16000	ATG Test Date	08/10/2023	Line Tightness Test Date	02/15/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	08/10/2023			ATG Type				
Tank Code	08	Tank Age	3	Tank Installed Date	03/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6073	Spill Test Date	08/10/2023	Piping Installed Date	03/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	8000	ATG Test Date	08/10/2023	Line Tightness Test Date	02/15/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act

		Overfill Test Date	08/10/2023			ATG Type				
Tank Code	09	Tank Age	4	Tank Installed Date	06/20/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6077	Spill Test Date	08/17/2022	Piping Installed Date	03/01/2023	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	15000	ATG Test Date	05/09/2024	Line Tightness Test Date	05/15/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	08/17/2022			ATG Type				
Tank Code	10	Tank Age	4	Tank Installed Date	06/20/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6078	Spill Test Date	08/17/2022	Piping Installed Date	03/01/2023	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	10000	ATG Test Date	05/09/2024	Line Tightness Test Date	05/15/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	08/17/2022			ATG Type				
Tank Code	11	Tank Age	4	Tank Installed Date	06/20/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6079	Spill Test Date	08/17/2022	Piping Installed Date	03/01/2023	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	25000	ATG Test Date	05/09/2024	Line Tightness Test Date	05/15/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	08/17/2022			ATG Type				

Facility Summary in Lincoln County in the City of Troy

Location: TROY CENTRAL OFFICE 9140 B01
402 N 2nd St
Troy, MT 59935 Lincoln

System Facility ID:27-08082

Facility Code: 24235
Last Inspected On: 05/29/2025
Operating Permit Renewal Date: 06/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Citizens Communications Company

(916) 686-3499

legal@zipl.com

Operator Contact: Scott Kerzman;Citizens Communications Company

(406) 293-1479;(916) 686-3499

scott.kerzman@zipl.com;legal@zipl.com

Owner/Operator: Citizens Communications Company

(916) 686-3499

legal@zipl.com

Scott Kerzman, UST Class A Operator

legal@zipl.com

Scott Kerzman, UST Class B Operator

legal@zipl.com

Tank Code	S2	Tank Age	35	Tank Installed Date	08/01/1991	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	3272	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	500	ATG Test Date	05/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Troy

Location: TROY ELEMENTARY SCHOOL
318 Kalispell Ave
Troy, MT 59935 Lincoln

System Facility ID:27-00764

Facility Code: 24102
Last Inspected On: 11/14/2024
Operating Permit Renewal Date: 03/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 Troy (406) 295-4606

Operator Contact: John Daniel;Keith Haggerty (406) 293-1170 khaggerty@troyk12.org

Owner/Operator: School Dist 1 Troy (406) 295-4606

John Daniel, UST Class A Operator

John Daniel, UST Class B Global Operator

Keith Haggerty, UST Class A Operator

Keith Haggerty, UST Class B Global Operator

khaggerty@troyk12.org

khaggerty@troyk12.org

Tank Code	S1	Tank Age	39	Tank Installed Date	08/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	2149	Spill Test Date	11/14/2024	Piping Installed Date		Tank Construction		Piping Construction	PVC	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	11/14/2024	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Manual Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/14/2024			ATG Type					

Facility Summary in Lincoln County in the City of Troy

Location: TROY HIGH SCHOOL MISSOULA AVE
204 Missoula Ave
Troy, MT 59935 Lincoln

System Facility ID:27-00763

Facility Code: 24101
Last Inspected On: 11/14/2024
Operating Permit Renewal Date: 03/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 Troy (406) 295-4606

Operator Contact: John Daniel;Keith Haggerty (406) 293-1170 khaggerty@troyk12.org

Owner/Operator: School Dist 1 Troy (406) 295-4606

John Daniel, UST Class A Operator

John Daniel, UST Class B Global Operator

Keith Haggerty, UST Class A Operator

Keith Haggerty, UST Class B Global Operator

khaggerty@troyk12.org

khaggerty@troyk12.org

Tank Code	S1	Tank Age	39	Tank Installed Date	08/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	2147	Spill Test Date	11/14/2024	Piping Installed Date		Tank Construction		Piping Construction	PVC	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	11/14/2024	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Manual Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/14/2024			ATG Type					
Tank Code	S3	Tank Age	39	Tank Installed Date	08/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	2148	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	PVC	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	11/14/2024	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Manual Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					