

**Facility Summary in Madison County in the City of Alder**

**Location:** ALDER MARKET LLC  
2325 Hwy 287  
Alder, MT 59710 Madison

Legacy ID:28-04167

**Facility ID:** 24625  
**Last Inspected On:** 04/13/2021  
**Operating Permit Renewal Date:** 05/15/2024

**Owner Operator Contact:** Alder Market LLC

**4068425679**

**Operator Contact:** William Caldwell

**4062932711**

**Owner/Operator:** Alder Market LLC

**Owner/Operator:** Brian Beal

William Caldwell, UST Class A Operator

William Caldwell, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	33	07/01/1988	Unknown	Flexible Plastic	
385	Yes	11/02/2017		Double Walled	No
Currently in Use		11/14/2017	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
3,000		11/14/2017			No
S4	33	07/01/1988	Unknown	Flexible Plastic	
386	Yes	11/02/2017		Double Walled	No
Currently in Use		11/14/2017	Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
2,900		11/14/2017			No

**Facility Summary in Madison County in the City of Cameron**

**Location:** WARREN MILLER LODGE  
Seven Bears Trl  
Cameron, MT 59720 Madison

Legacy ID:60-15020

**Facility ID:** 30806  
**Last Inspected On:** 04/01/2021  
**Operating Permit Renewal Date:** 04/08/2024

**Owner Operator Contact:****Operator Contact:** Joe Robillard**Owner/Operator:** Yellowstone Club

Dan Nitsche, UST Class B Global Operator

Joe Robillard, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	4	08/14/2017	Steel Clad	Flexible Plastic	Flapper Valve
5766	No	09/18/2017	Double-Walled	Double Walled	Yes
Currently in Use		08/14/2017	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
2,000		09/18/2017	OPW/EECO 1500		Yes

**Facility Summary in Madison County in the City of Ennis****Location:** ROCKY MOUNTAIN SUPPLY INC ENNIS  
4997 US Hwy 287 N  
Ennis, MT 59729 Madison

Legacy ID:56-13826

**Facility ID:** 30512  
**Last Inspected On:** 09/02/2020  
**Operating Permit Renewal Date:** 11/29/2023**Owner Operator Contact:** Brad Gjermeo;Rocky Mountain Supply Inc;Rocky Mountain Supply Inc**4063884009****Operator Contact:** Greg Stearman;Jason Rorabaugh**4063884008****Owner/Operator:** Rocky Mountain Supply Inc

Greg Stearman, UST Class A Operator

Greg Stearman, UST Class B Operator

Jason Rorabaugh, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	07/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>1768</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		07/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	24	07/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>1769</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
5,000		07/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	24	07/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>1770</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		07/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	24	07/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>1771</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
5,000		07/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	24	07/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>1772</b>	No			Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		07/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	24	07/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1773	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		07/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Madison County in the City of Ennis**

**Location:** TOWN PUMP INC ENNIS  
116 W Main St  
Ennis, MT 59729 Madison

Legacy ID:28-08698

**Facility ID:** 24722  
**Last Inspected On:** 07/15/2021  
**Operating Permit Renewal Date:** 10/27/2024

**Owner Operator Contact:** Don Edmisten; Town Pump Inc Ennis

**4064976948**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Ennis 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	41	04/14/1980	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2529	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/23/2018	Approved Remote Monitoring; Statistical Inventory Reconciliation	Approved Remote Monitoring; Statistical Inventory Reconciliation	No

12,000			Gilbarco-Veeder Root/TLS-350		No
04	29	04/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2530</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		07/13/2015	Gilbarco-Veeder Root/TLS-350		No
05	29	04/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2531</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		07/13/2015	Gilbarco-Veeder Root/TLS-350		No
06	29	04/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2532</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
07	19	10/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4734</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/03/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No

08	19	10/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4735</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Madison County in the City of Norris**

**Location:** MCLEOD MERCANTILE SW CORNER  
6533 US Hwy 287  
Norris, MT 59745 Madison

Legacy ID:56-14138

**Facility ID:** 30774  
**Last Inspected On:** 01/24/2019  
**Operating Permit Renewal Date:** 02/28/2022

**Owner Operator Contact:** A M Welles Inc;Tim Hokanson;AM Welles Inc dba McLeod Merc

**4066853372;4066853372**

**Operator Contact:** Katie Burtchett;Marvena Rice;Patricia Lehman

**4065803664;4066853372**

**Owner/Operator:** A M Welles Inc

- Katie Burtchett, UST Class A Operator
- Katie Burtchett, UST Class B Operator
- Marvena Rice, UST Class A Operator
- Marvena Rice, UST Class B Operator
- Patricia Lehman, UST Class A Operator
- Patricia Lehman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2712</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/02/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No

2,000		11/02/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2713</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/02/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
2,000		11/02/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2714</b>	No			None	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Diesel		10/02/2018	Automatic Tank Gauging 0.2	Deferred	No
2,000		11/02/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2715</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/02/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000		11/02/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
<b>2716</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/02/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000		11/02/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
<b>2717</b>	No			None	Yes

Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/02/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000		11/02/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
14	17	07/02/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4892</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		07/17/2015	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		11/02/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Madison County in the City of Sheridan**

**Location:** A M WELLES  
95 Tuke Ln  
Sheridan, MT 59749 Madison

Legacy ID:60-15002

**Facility ID:** 30796  
**Last Inspected On:** 09/05/2019  
**Operating Permit Renewal Date:** 09/09/2022

**Owner Operator Contact:** A M Welles Inc

**Operator Contact:** Sandy Flager;Tim Nicholls

**Owner/Operator:** A M Welles Inc

Sandy Flager, UST Class A Operator  
Sandy Flager, UST Class B Operator  
Tim Nicholls, UST Class A Operator  
Tim Nicholls, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	16	09/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>5007</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No



15,000		12/09/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	16	09/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>5008</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000		12/09/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	16	09/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>5009</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
7,000		12/09/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	16	09/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>5010</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000		12/09/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	16	09/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>5011</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		12/09/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
01	16	09/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>5044</b>	No			Double Walled	Yes

Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000	12/09/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Madison County in the City of Sheridan**

**Location:** MCLEOD MERCANTILE 2802043  
202 S Main St  
Sheridan, MT 59749 Madison

Legacy ID:28-02043

**Facility ID:** 24575  
**Last Inspected On:** 03/10/2021  
**Operating Permit Renewal Date:** 06/09/2024

**Owner Operator Contact:** Larrie Else; Elser Oil Co; Tim Hokanson; McLeod Mercantile

**4066853372;4066853379;4068425478**

**Operator Contact:** Sandy Flager

**Owner/Operator:** AM Welles Inc dba McLeod Merc

Sandy Flager, UST Class A Operator  
Sandy Flager, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

13	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve; High Level Alarm
<b>5999</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	Yes
12,000					Yes

14	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve; High Level Alarm
<b>6000</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No

12,000				Yes
15	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>6001</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
6,000				Yes
16	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>6002</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel, Dyed		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000				Yes

**Facility Summary in Madison County in the City of Twin Bridges**

**Location:** BOS CHEVRON AND TIRE SERVICE  
100 S Main St  
Twin Bridges, MT 59754 Madison

Legacy ID:28-07478

**Facility ID:** 24698  
**Last Inspected On:** 10/01/2019  
**Operating Permit Renewal Date:** 11/08/2022

**Owner Operator Contact:** Bo Mailey;Bo Mailey;Bo Mailey

**4066845611**

**Operator Contact:** Bo Mailey

**4066845611**

**Owner/Operator:** Bo Mailey

Bo Mailey, UST Class A Operator

Bo Mailey, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	22	01/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
<b>3913</b>	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Deferred	No
1,000					No
06	22	01/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
<b>3914</b>	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Deferred	No
1,000					No

**Facility Summary in Madison County in the City of Twin Bridges**

**Location:** THREE RIVERS QUICK STOP  
325 S Main St  
Twin Bridges, MT 59754-9740 Madison

Legacy ID:28-10708

**Facility ID:** 24759  
**Last Inspected On:** 04/11/2019  
**Operating Permit Renewal Date:** 09/09/2022

**Owner Operator Contact:** Danny Hanson

**4066845733**

Operator Contact: Danny Hanson;Gena Nordquist

4066845733

**Owner/Operator:** Danny Hanson

Danny Hanson, UST Class A Operator

Gena Nordquist, UST Class A Operator

Gena Nordquist, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1816	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/06/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
3,000			Gilbarco/EMC Basic		No
05	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1817	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/06/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No

**Facility Summary in Madison County in the City of Virginia City**

**Location:** VILLAGE PUMP and INFORMATION CENTER  
221 E Wallace St  
Virginia City, MT 59755-0338 Madison

Legacy ID:28-05399

**Facility ID:** 24653  
**Last Inspected On:** 06/11/2019  
**Operating Permit Renewal Date:** 01/07/2023

**Owner Operator Contact:** Elijah Allen;Montana Heritage Preservation and  
Development Commission Virginia City;Montana  
Heritage Preservation and Development Commission  
Virginia City

4068435247;4068435655;4068435655

**Operator Contact:** Becky DiGiovanna

4066602195

**Owner/Operator:** Montana Heritage Preservation and  
 Development Commission Virginia City  
 Becky DiGiovanna, UST Class A Operator  
 Becky DiGiovanna, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	2	02/05/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
<b>5860</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		02/05/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
6,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
05	2	02/05/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
<b>5861</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		02/05/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes