

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: BERG GARAGE INC
11 W Main St
White Sulphur Springs, MT 59645-0000 Meagher

System Facility ID:30-07694

Facility Code: 24982
Last Inspected On: 09/16/2022
Operating Permit Renewal Date: 12/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Berg Garage Inc4065473514

Operator Contact: Jay Berg4065472150

Owner/Operator: Berg Garage Inc

Jay Berg, UST Class A Operator

Jay Berg, UST Class B Operator

Tank Code	03	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	434	Spill Test Date	09/06/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type					
Tank Code	04	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	435	Spill Test Date	09/06/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type					
Tank Code	05	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	436	Spill Test Date	09/06/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type					
Tank Code	06	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	437	Spill Test Date	09/06/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type					

Facility Summary in Meagher County in the City of White Sulphur Springs

Location:

TOWN PUMP WHITE SULPHUR SPRINGS
309 E Main St
White Sulphur Springs, MT 59645 Meagher

Facility Code:

24989

Last Inspected On:

10/20/2022

Operating Permit Renewal Date:

08/13/2022

System Facility ID:

30-08724

Note:

Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town Pump Inc White Sulphur Springs;White Sulphur Springs 4064976700
1 Town Pump LLC

Operator Contact: Trent Biggers

Owner/Operator: Town Pump Inc White Sulphur Springs

Owner/Operator: White Sulphur Springs 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	52	Tank Installed Date	05/10/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2533	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/01/2018	Tank/Piping CP Test Date	05/15/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	02	Tank Age	52	Tank Installed Date	05/10/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2534	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/01/2018	Tank/Piping CP Test Date	05/15/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/EMC Basic				

Tank Code	03	Tank Age	44	Tank Installed Date	05/10/1980	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2535	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/01/2018	Tank/Piping CP Test Date	05/15/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	04	Tank Age	35	Tank Installed Date	05/10/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2536	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	02/06/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/01/2018	Tank/Piping CP Test Date	05/15/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	05	Tank Age	32	Tank Installed Date	10/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2537	Spill Test Date	05/19/2021	Piping Installed Date	08/16/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	02/05/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/14/2022	Line Tightness Test Date	11/04/2019	Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	05/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	25	Tank Installed Date	09/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4119	Spill Test Date	05/19/2021	Piping Installed Date	08/16/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	02/05/2010	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/14/2022	Line Tightness Test Date	11/04/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	05/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	25	Tank Installed Date	09/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4120	Spill Test Date	05/19/2021	Piping Installed Date	08/16/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	02/05/2010	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/14/2022	Line Tightness Test Date	11/04/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	05/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	5	Tank Installed Date	08/02/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5875	Spill Test Date	05/19/2021	Piping Installed Date	08/02/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	24000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/16/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	5	Tank Installed Date	08/02/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5876	Spill Test Date	05/19/2021	Piping Installed Date	08/02/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes

Capacity	6000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/16/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	5	Tank Installed Date	08/02/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5877	Spill Test Date	05/19/2021	Piping Installed Date	08/02/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/16/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	12	Tank Age	5	Tank Installed Date	08/02/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5878	Spill Test Date	05/19/2021	Piping Installed Date	08/02/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/16/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	13	Tank Age	5	Tank Installed Date	08/02/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5916	Spill Test Date	05/19/2021	Piping Installed Date	08/02/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/16/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/19/2021			ATG Type					

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: VAN OIL CO 12 W MAIN ST
12 W Main St
White Sulphur Springs, MT 59645 Meagher

System Facility ID:30-00478

Facility Code: 24943
Last Inspected On: 01/25/2022
Operating Permit Renewal Date: 01/25/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Marga Johnson4065473636

Operator Contact:

Owner/Operator: Marga Johnson

Tank Code	06	Tank Age	33	Tank Installed Date	06/06/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2211	Spill Test Date		Piping Installed Date	04/16/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/17/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-250				
Tank Code	07	Tank Age	33	Tank Installed Date	06/06/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2212	Spill Test Date		Piping Installed Date	04/16/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/17/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-250				
Tank Code	08	Tank Age	33	Tank Installed Date	06/06/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2213	Spill Test Date		Piping Installed Date	04/16/2007	Tank Construction		Piping Construction	None	AST	No

Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/17/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-250				

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: WHITE SULPHUR SPRINGS SCHOOL DIST 8
405 Central Ave S
White Sulphur Springs, MT 59645 Meagher

System Facility ID:30-04720

Facility Code: 24962
Last Inspected On: 10/12/2023
Operating Permit Renewal Date: 12/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 8 White Sulphur Springs

Operator Contact: John Michaelson;School Dist 8 White Sulphur Springs

Owner/Operator: School Dist 8 White Sulphur Springs

John Michaelson, UST Class A Operator

John Michaelson, UST Class B Operator

Tank Code	S7	Tank Age	26	Tank Installed Date	08/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2262	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				