

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: BERG GARAGE INC
 11 W Main St
 White Sulphur Springs, MT 59645-0000 Meagher

Legacy ID:30-07694

Facility ID: 24982
Last Inspected On: 10/15/2019
Operating Permit Renewal Date: 12/19/2022

Owner Operator Contact: Berg Garage Inc;Jay Berg;Berg Garage Inc

4065472150;4065473514;4065473514

Operator Contact: Jay Berg

4065472150

Owner/Operator: Berg Garage Inc

Jay Berg, UST Class A Operator

Jay Berg, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
434	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/26/2016	Manual Tank Gauging	Deferred	No
500					No
04	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
435	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/26/2016	Manual Tank Gauging	Deferred	No
500					No
05	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
436	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Gasoline		10/26/2016	Manual Tank Gauging	Deferred	No
500					No
06	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
437	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/26/2016	Manual Tank Gauging	Deferred	No
500					No

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: TOWN PUMP WHITE SULPHUR SPRINGS
309 E Main St
White Sulphur Springs, MT 59645 Meagher

Legacy ID:30-08724

Facility ID: 24989
Last Inspected On: 05/19/2021
Operating Permit Renewal Date: 05/19/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc White Sulphur Springs;Town Pump Inc White Sulphur Springs

4064976948

Operator Contact: Trent Biggers

Owner/Operator: Town Pump Inc White Sulphur Springs

Owner/Operator: White Sulphur Springs 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	29	10/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2537	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		02/05/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	No

12,000			Gilbarco-Veeder Root/TLS-450		No
07	22	09/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4119	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		02/05/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		Yes
08	22	09/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4120	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		02/05/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-450		No
09	2	08/02/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5875	No		Double-Walled	Double Walled	No
Currently in Use		08/02/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	Yes
24,000			Gilbarco-Veeder Root/TLS-450		Yes
10	2	08/02/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5876	No		Double-Walled	Double Walled	No
Currently in Use		08/02/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	Yes

6,000			Gilbarco-Veeder Root/TLS-450		Yes
11	2	08/02/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5877	No		Double-Walled	Double Walled	No
Currently in Use		08/02/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		Yes
12	2	08/02/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5878	No		Double-Walled	Double Walled	No
Currently in Use		08/02/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	Yes
10,000			Gilbarco-Veeder Root/TLS-450		Yes
13	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5916	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel, Dyed			Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;Statistical Inventory Reconciliation	No
6,000					Yes

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: VAN OIL CO 12 W MAIN ST
12 W Main St
White Sulphur Springs, MT 59645 Meagher

Legacy ID:30-00478

Facility ID: 24943
Last Inspected On: 11/02/2021
Operating Permit Renewal Date: 01/25/2022

Owner Operator Contact: N/A ZZZ - TBL_OWN : 1088;Van Oil Co

4065473636

Operator Contact: Gary Walter

Owner/Operator: Marga Johnson

Gary Walter, UST Class A Operator
Gary Walter, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	30	06/06/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2211	No			None	Yes
Temporarily Out of Use		04/16/2007	Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/17/2015	Veeder Root/TLS-250		No
07	30	06/06/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2212	No			None	Yes
Temporarily Out of Use		04/16/2007	Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/17/2015	Veeder Root/TLS-250		No
08	30	06/06/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2213	No			None	Yes
Temporarily Out of Use		04/16/2007	Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/17/2015	Veeder Root/TLS-250		No

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: WHITE SULPHUR SPRINGS SCHOOL DIST 8
209 & 405 Central Ave S
White Sulphur Springs, MT 59645 Meagher

Legacy ID:30-04720

Facility ID: 24962
Last Inspected On: 07/07/2020
Operating Permit Renewal Date: 12/16/2023

Owner Operator Contact: Jim Palmer;School Dist 8 White Sulphur Springs;School Dist 8 White Sulphur Springs

Operator Contact: Hal Haugan

4065473822

Owner/Operator: School Dist 8 White Sulphur Springs

Hal Haugan, UST Class A Operator

Hal Haugan, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S7	23	08/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
2262	No			Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Heating Oil			Automatic Tank Gauging 0.2	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
10,000		07/17/2017	Gilbarco/EMC Basic		No