

**Facility Summary in Mineral County in the City of Alberton**

**Location:** REYNCO LLC  
415 Railroad Ave  
Alberton, MT 59820-9488 Mineral

Legacy ID:56-13785

**Facility ID:** 30473  
**Last Inspected On:** 12/27/2018  
**Operating Permit Renewal Date:** 04/30/2022

**Owner Operator Contact:** Reynco LLC

**4062189940**

**Operator Contact:** Bob Westin;Dave Otto;John Thompson;Will Dukart

**4063708176;4066651728;4067557427;4068808169**

**Owner/Operator:** Reynco LLC

- Bob Westin, UST Class A Operator
- Dave Otto, UST Class A Operator
- Dave Otto, UST Class B Global Operator
- John Thompson, UST Class A Operator
- John Thompson, UST Class B Global Operator
- John Thompson, UST Class B Operator
- Mike Dunlon, UST Class B Operator
- Will Dukart, UST Class A Operator
- Will Dukart, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
S1	24	08/01/1997	Bare Steel	Fiberglass Reinforced Plastic	
<b>3858</b>	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
12,000		04/30/2018			No
S2	24	08/01/1997	Bare Steel	Fiberglass Reinforced Plastic	
<b>3859</b>	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No

12,000		04/30/2018			No
S3	24	08/01/1997	Bare Steel	Fiberglass Reinforced Plastic	
<b>3860</b>	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
10,000		04/30/2018			No
S4	24	08/01/1997	Bare Steel	Fiberglass Reinforced Plastic	
<b>3861</b>	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
4,000		04/30/2018			No

**Facility Summary in Mineral County in the City of Haugan**

**Location:** SILVER EXPRESS EXXON  
Exit 16 & I-90  
Haugan, MT 59842 Mineral

Legacy ID:31-13289

**Facility ID:** 25141  
**Last Inspected On:** 08/07/2019  
**Operating Permit Renewal Date:** 08/28/2022

**Owner Operator Contact:** Brooke Lincoln;Silver Express Exxon;Geri Lincoln;Silver Dollar Ventures Inc;Silver Dollar Ventures Inc

**4065445880;4066784242**

**Operator Contact:** Brooke Lincoln

**4065445880**

**Owner/Operator:** Brooke Lincoln

**Owner/Operator:** Silver Dollar Ventures Inc

Brooke Lincoln, UST Class A Operator  
Brooke Lincoln, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	27	04/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
----	----	------------	-------------------------------	-------------------------------	------------------

<b>3161</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		05/22/2018	Gilbarco-Veeder Root/TLS-450		No
02	27	04/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3162</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		05/22/2018	Gilbarco-Veeder Root/TLS-450		No
03	27	04/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3163</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		05/22/2018	Gilbarco-Veeder Root/TLS-450		No
04	27	04/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3164</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		05/22/2018	Gilbarco-Veeder Root/TLS-450		No

**Facility Summary in Mineral County in the City of Saint Regis**

**Location:** SAINT REGIS EXXON  
6 Old US Hwy 10 E  
Saint Regis, MT 59866 Mineral

Legacy ID:31-05827

**Facility ID:** 25073  
**Last Inspected On:** 05/11/2020  
**Operating Permit Renewal Date:** 06/03/2020

**Owner Operator Contact:** Gary Bullock;Lincoln Development Co Inc;Lincoln Development Co Inc

**Operator Contact:** Gary Bullock

**Owner/Operator:** Lincoln Development Co Inc

Gary Bullock, UST Class A Operator

Gary Bullock, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	48	01/01/1973	Bare Steel	Steel	Flapper Valve
<b>3630</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		12/13/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
8,000					No
02	39	04/22/1982	Bare Steel	Steel	Flapper Valve
<b>3631</b>	No			None	Yes
Temporarily Out of Use		04/30/2007	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/13/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000					No
03	39	04/22/1982	Bare Steel	Steel	Flapper Valve
<b>3632</b>	No			None	Yes
Temporarily Out of Use		04/30/2007	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/13/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000					No

04	48	04/23/1973	Bare Steel	Steel	Flapper Valve
<b>3633</b>	No			None	Yes
Temporarily Out of Use		04/30/2007	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/13/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
6,000					No

**Facility Summary in Mineral County in the City of Saint Regis**

**Location:** SAINT REGIS TRAVEL CENTER  
100 Mullan Rd W  
Saint Regis, MT 59866 Mineral

Legacy ID:31-07690

**Facility ID:** 25085  
**Last Inspected On:** 01/24/2020  
**Operating Permit Renewal Date:** 03/28/2023

**Owner Operator Contact:** Lindevco Inc;Maureen Bullock;Lindevco Inc

**4066492407**

**Operator Contact:** Gary Bullock

**Owner/Operator:** Lindevco Inc

Gary Bullock, UST Class A Operator  
Gary Bullock, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	36	04/22/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>3813</b>	No	04/15/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		09/17/2016	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/13/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		04/18/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	36	04/22/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>3814</b>	No	04/15/2016	Lined Interior/Impressed Current	Double Walled	Yes

Currently in Use		09/17/2016	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/13/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		04/18/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	36	04/22/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>3815</b>	No	04/15/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		09/17/2016	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/13/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000		04/18/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Mineral County in the City of Saint Regis**

**Location:** STANGS FOOD CITY  
85 Old US Hwy 10 E  
Saint Regis, MT 59866-9715 Mineral

Legacy ID:31-07503

**Facility ID:** 25082  
**Last Inspected On:** 07/15/2019  
**Operating Permit Renewal Date:** 09/07/2022

**Owner Operator Contact:** Stangs Inc

**4066492414**

**Operator Contact:** Janice Hoskins;Robert Buss

**4063211168**

**Owner/Operator: Stangs Inc**

Janice Hoskins, UST Class A Operator  
Janice Hoskins, UST Class B Operator  
Robert Buss, UST Class A Operator  
Robert Buss, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	22	08/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4105</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

6,000			Gilbarco/EMC Basic		No
06	22	08/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4106</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco/EMC Basic		No
07	22	08/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4107</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco/EMC Basic		No

**Facility Summary in Mineral County in the City of Saltese**

**Location:** TAFT SUBSTATION  
 Randolph Creek Rd  
 Saltese, MT 59867 Mineral

Legacy ID:31-07747

**Facility ID:** 25086  
**Last Inspected On:** 09/29/2021  
**Operating Permit Renewal Date:** 08/18/2022

**Owner Operator Contact:** Bonneville Power Administration Kalispell **4067517800**

**Operator Contact:** Dustin Gordon;Emery Barnhill **2082702925**

**Owner/Operator:** Bonneville Power Administration Kalispell

Dustin Gordon, UST Class A Operator  
 Dustin Gordon, UST Class B Global Operator  
 Emery Barnhill, UST Class A Operator  
 Emery Barnhill, UST Class B Operator  
 Raymond Lawrence, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	10/01/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
478	No	06/28/2016	Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Mineral County in the City of Superior**

**Location:** DURANGOS INC  
 204 4th Ave E  
 Superior, MT 59872 Mineral

Legacy ID:31-07433

**Facility ID:** 25081  
**Last Inspected On:** 04/22/2021  
**Operating Permit Renewal Date:** 04/26/2024

**Owner Operator Contact:** Jo-Joe Investments **4068224967**

**Operator Contact:** Jolie Skelton

**Owner/Operator:** Jo-Joe Investments

Jolie Skelton, UST Class A Operator  
 Jolie Skelton, UST Class B Operator



Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	37	04/23/1984	Cathodically Protected Steel	Steel	Positive Shutoff
<b>3816</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/04/2017	Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
10,000		12/04/2017			No
02	37	04/23/1984	Cathodically Protected Steel	Steel	Positive Shutoff
<b>3817</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/04/2017	Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
10,000		12/04/2017			No

**Facility Summary in Mineral County in the City of Superior**

**Location:** MINERAL COUNTY COURTHOUSE UST  
300 River St  
Superior, MT 59872 Mineral

Legacy ID:31-02302

**Facility ID:** 25033  
**Last Inspected On:** 12/11/2020  
**Operating Permit Renewal Date:** 01/24/2024

**Owner Operator Contact:** Mineral County Health Dept

**Operator Contact:** Norman Naef

**Owner/Operator:** Mineral County Health Dept

Norman Naef, UST Class A Operator  
Norman Naef, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
S2	27	05/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4450	No	01/23/2018	Double-Walled	Double Walled	Yes
Currently in Use		Auto Dialer	U.S. Suction	Galvanic	
Heating Oil	01/23/2018	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No	
5,000		Gilbarco-Veeder Root/ILS-350		No	

**Facility Summary in Mineral County in the City of Superior**

**Location:** MOUNTAIN WEST CO OP SUPERIOR  
211 River St  
Superior, MT 59872-9673 Mineral

Legacy ID:31-08916

**Facility ID:** 25094  
**Last Inspected On:** 12/27/2018  
**Operating Permit Renewal Date:** 04/30/2022

**Owner Operator Contact:**

**Operator Contact:** Bob Westin;Dusty Smith;John Thompson;Will Dukart **4066651728;4067557427;4068808169**

**Owner/Operator:** CHS Inc Inver Grove Heights

- Bob Westin, UST Class A Operator
- Bob Westin, UST Class B Global Operator
- Dusty Smith, UST Class A Operator
- Dusty Smith, UST Class B Global Operator
- John Thompson, UST Class A Operator
- John Thompson, UST Class B Operator
- Will Dukart, UST Class A Operator
- Will Dukart, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	35	05/01/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1063	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Diesel		11/16/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		11/06/2018	Gilbarco/EMC Basic		No
02	35	05/01/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>1064</b>	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/16/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		11/06/2018	Gilbarco/EMC Basic		No
03	35	05/01/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>1065</b>	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/16/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		11/06/2018	Gilbarco/EMC Basic		No

**Facility Summary in Mineral County in the City of Superior**

**Location:** S and S FOODS  
205 4th Ave E  
Superior, MT 59872 Mineral

Legacy ID:31-12870

**Facility ID:** 25138  
**Last Inspected On:** 08/29/2019  
**Operating Permit Renewal Date:** 09/25/2022

**Owner Operator Contact:** Gary Bullock;C Store Inc St Regis

**Operator Contact:** Dale Bullock;Gary Bullock

**4068223342**

**Owner/Operator:** D and T Properties LLC

Dale Bullock, UST Class A Operator  
Dale Bullock, UST Class B Operator  
Gary Bullock, UST Class A Operator  
Gary Bullock, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	29	10/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1968</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		07/20/2016	Veeder Root/TLS-300		No
02	29	10/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1969</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		07/20/2016	Veeder Root/TLS-300		No
03	29	10/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1970</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		07/20/2016	Veeder Root/TLS-300		No
04	29	10/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1971</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
3,000		07/20/2016	Veeder Root/TLS-300		No

### **Facility Summary in Mineral County in the City of Superior**

**Location:** TOWN PUMP INC SUPERIOR  
3961 Diamond Match Rd  
Superior, MT 59872-9407 Mineral

Legacy ID:31-08719

**Facility ID:** 25093  
**Last Inspected On:** 02/14/2019  
**Operating Permit Renewal Date:** 05/14/2022

**Owner Operator Contact:** Don Edmisten;Town Pump Inc Superior

**4064976948**

Operator Contact:

**Owner/Operator:** Superior 1 Town Pump LLC

Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
01	51	01/22/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2538</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use		04/22/2011	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/29/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
02	51	01/22/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2539</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use		04/22/2011	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/29/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
03	35	01/01/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>2540</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		04/22/2011	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/29/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No

04	49	01/01/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2541</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use		04/22/2011	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/29/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
06	32	01/01/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2543</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		02/20/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
05	40	01/01/1981	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4840</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/29/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
07	32	01/01/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4841</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		02/20/2010	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No

08	18	06/09/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4842</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		02/20/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
09	18	06/09/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4843</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		02/20/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
3,000			Gilbarco-Veeder Root/TLS-350		No