

Facility Summary in Missoula County in the City of Bonner

Location: POTOMAC BAR AND COUNTRY STORE
29344 MT Hwy 200 E
Bonner, MT 59823-9526 Missoula

System Facility ID:32-12400

Facility Code: 25677
Last Inspected On: 03/04/2023
Operating Permit Renewal Date: 04/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kenney Brown;Potomac Bar and Country Store, Inc;Potomac Bar and Country Store, Inc

(406) 240-3863;(406) 240-3863;(406) 240-3863

kennybrown@blackfoot.net;kennybrown@blackfoot.net;kennybrown@blackfoot.net

Operator Contact: Christine Yednick

potomacbar@outlook.com

Owner/Operator: Kenney Brown,Potomac Bar and Country Store, Inc

(406) 240-3863

kennybrown@blackfoot.net

Owner/Operator: Potomac Bar and Country Store, Inc

(406) 240-3863

kennybrown@blackfoot.net

Christine Yednick, UST Class A Operator

potomacbar@outlook.com

Christine Yednick, UST Class B Operator

potomacbar@outlook.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 35 | Tank Installed Date | 05/28/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 3488 | Spill Test Date | 06/10/2020 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/09/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/04/2023 | Line Tightness Test Date | 11/06/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/10/2020 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 02 | Tank Age | 35 | Tank Installed Date | 05/28/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 3489 | Spill Test Date | 06/10/2020 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/09/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/04/2023 | Line Tightness Test Date | 11/06/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/10/2020 | | | ATG Type | Gilbarco/EMC Basic | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|--------------------------------|
| Tank Code | 03 | Tank Age | 35 | Tank Installed Date | 05/28/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 3490 | Spill Test Date | 06/10/2020 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/09/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/04/2023 | Line Tightness Test Date | 11/06/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/10/2020 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 04 | Tank Age | 35 | Tank Installed Date | 05/28/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 3491 | Spill Test Date | 06/10/2020 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/09/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 3000 | ATG Test Date | | Line Tightness Test Date | 10/20/2010 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/10/2020 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Clinton

Location: BEARMOUTH EXPRESS
16595 US Hwy 10 E
Clinton, MT 59825-9678 Missoula

System Facility ID:32-01572

Facility Code: 25223
Last Inspected On: 09/04/2025
Operating Permit Renewal Date: 11/12/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gene Tripp (406) 825-4000

Operator Contact: Bryan Tripp;Jeff Tripp (406) 825-4000 bearmouth66@blackfoot.net;bryan.tripp44@gmail.com

Owner/Operator: Gene Tripp (406) 825-4000

Bryan Tripp, UST Class A Operator
Bryan Tripp, UST Class B Operator
Jeff Tripp, UST Class A Operator
Jeff Tripp, UST Class B Operator

bryan.tripp44@gmail.com
bryan.tripp44@gmail.com
bearmouth66@blackfoot.net
bearmouth66@blackfoot.net

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 47 | Tank Installed Date | 04/29/1979 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 1205 | Spill Test Date | 09/02/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 09/02/2025 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/02/2025 | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Clinton

Location: CLINTON MARKET
20500 Hwy 10 E
Clinton, MT 59825 Missoula

System Facility ID:56-14040

Facility Code: 30695
Last Inspected On: 11/19/2024
Operating Permit Renewal Date: 04/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: RR Investments of Montana (406) 546-4940 roy.handley6543@gmail.com

Operator Contact: Roy Handley (406) 546-4940 roy.handley6543@gmail.com

Owner/Operator: RR Investments of Montana (406) 546-4940 roy.handley6543@gmail.com

Roy Handley, UST Class A Operator

roy.handley6543@gmail.com

Roy Handley, UST Class B Global Operator

roy.handley6543@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 24 | Tank Installed Date | 05/16/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4651 | Spill Test Date | 05/17/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/17/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/19/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/19/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/17/2024 | | | ATG Type | Gilbarco/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 24 | Tank Installed Date | 05/16/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4652 | Spill Test Date | 05/17/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/19/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/19/2024 | Line Tightness Test Date | 02/26/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 03 | Tank Age | 24 | Tank Installed Date | 05/16/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4653 | Spill Test Date | 05/17/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/17/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/19/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 11/19/2024 | Line Tightness Test Date | 02/28/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 04 | Tank Age | 17 | Tank Installed Date | 10/29/2009 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5223 | Spill Test Date | 05/17/2024 | Piping Installed Date | 10/14/2009 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/17/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/19/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/19/2024 | Line Tightness Test Date | 02/26/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 05 | Tank Age | 8 | Tank Installed Date | 08/28/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5851 | Spill Test Date | 05/17/2024 | Piping Installed Date | 08/28/2018 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/17/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/19/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 11/19/2024 | Line Tightness Test Date | 02/26/2019 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 05/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Clinton

Location: ROCK CREEK LODGE
7 Rock Creek Rd
Clinton, MT 59825 Missoula

System Facility ID:32-11093

Facility Code: 25616
Last Inspected On: 01/05/2024
Operating Permit Renewal Date: 01/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nicholas Caras;SEVEN ROCK LLC (406) 203-4467;(406) 203-4467 nickcaras@gmail.com;sjw@cararealestate.com

Operator Contact:

Owner/Operator: Nicholas Caras,SEVEN ROCK LLC (406) 203-4467 nickcaras@gmail.com

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 32 | Tank Installed Date | 05/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4572 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 04 | Tank Age | 32 | Tank Installed Date | 05/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4573 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | 09/20/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Condon

Location: MISSION MOUNTAINS MERCANTILE
7217 MT Hwy 83
Condon, MT 59826 Missoula

System Facility ID:32-01619

Facility Code: 25226
Last Inspected On: 04/12/2023
Operating Permit Renewal Date: 06/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Leonard Kobylenski (406) 754-2387 len@swanvalley.com

Operator Contact: Leonard Kobylenski (406) 754-2387 len@swanvalley.com

Owner/Operator: Len Kobylenski (406) 754-2387 len@swanvalley.com

Len Kobylenski, UST Class A Operator

len@swanvalley.com

Len Kobylenski, UST Class B Operator

len@swanvalley.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-----------------------------|----------------|------------------|
| Tank Code | 04 | Tank Age | 34 | Tank Installed Date | 05/20/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 1495 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 04/12/2023 | Line Tightness Test Date | 04/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 34 | Tank Installed Date | 05/20/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 1496 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 04/12/2023 | Line Tightness Test Date | 04/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 34 | Tank Installed Date | 05/20/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-----------------------------|----------------|----------|
| Tag Number | 1497 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 04/12/2023 | Line Tightness Test Date | 04/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Frenchtown

Location: BRONCS GROCERIES INC
16640 Beckwith St
Frenchtown, MT 59834-9747 Missoula

System Facility ID:32-05767

Facility Code: 25384
Last Inspected On: 11/28/2023
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeremy Louvar (406) 546-3656 jeremylouvar@yahoo.com

Operator Contact:

Owner/Operator: Jeremy Louvar (406) 546-3656 jeremylouvar@yahoo.com
Jeremy Louvar, UST Class B Operator jeremylouvar@yahoo.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 04 | Tank Age | 28 | Tank Installed Date | 05/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 2702 | Spill Test Date | 05/30/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/06/2024 | Line Tightness Test Date | 05/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/06/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 05 | Tank Age | 28 | Tank Installed Date | 05/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 2703 | Spill Test Date | 05/30/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/06/2024 | Line Tightness Test Date | 05/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/06/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Frenchtown

Location: FRENCHIES
16875 Beckwith St
Frenchtown, MT 59834-9646 Missoula

System Facility ID:32-11177

Facility Code: 25623
Last Inspected On: 05/13/2025
Operating Permit Renewal Date: 11/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc lss@gwpetrol.com

Operator Contact: Joe Heuchert;Karly Shafer (406) 396-2206 dahoyk@yahoo.com;karly@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc lss@gwpetrol.com
Joe Heuchert, UST Class A Operator dahoyk@yahoo.com
Karly Shafer, UST Class A Operator karly@gwpetrol.com
Karly Shafer, UST Class B Global Operator karly@gwpetrol.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 06/25/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4372 | Spill Test Date | 11/09/2023 | Piping Installed Date | 11/20/2023 | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/18/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/14/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/14/2024 | Line Tightness Test Date | 12/30/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 11/09/2023 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 06/25/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4373 | Spill Test Date | 11/09/2023 | Piping Installed Date | 11/20/2023 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/18/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/14/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/14/2024 | Line Tightness Test Date | 12/30/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 11/09/2023 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 06/25/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4374 | Spill Test Date | 11/09/2023 | Piping Installed Date | 11/20/2023 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/18/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/14/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/14/2024 | Line Tightness Test Date | 12/30/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/18/2022 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 06/25/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4375 | Spill Test Date | 11/09/2023 | Piping Installed Date | 11/20/2023 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/18/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 11/14/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/14/2024 | Line Tightness Test Date | 12/30/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/18/2022 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 09 | Tank Age | 3 | Tank Installed Date | 11/16/2023 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 6209 | Spill Test Date | 11/09/2023 | Piping Installed Date | 11/20/2023 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/14/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 11/14/2024 | Line Tightness Test Date | 12/30/2023 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 11/09/2023 | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Greenough

Location: CLEARWATER STOP N GO
44676 MT Hwy 200 E
Greenough, MT 59823-9557 Missoula

System Facility ID:32-07114

Facility Code: 25422
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 06/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|-----------------------------|----------------|--|
| Owner Operator Contact: | The Cow Group | (406) 396-8431 | jjross9185@msn.com |
| Operator Contact: | Jeff Stavish;Sherri Housley | (406) 244-5598 | clearwaterstopngo@gmail.com;jjross9185@msn.com |

| | | | |
|-----------------|---|----------------|-----------------------------|
| Owner/Operator: | The Cow Group | (406) 396-8431 | jjross9185@msn.com |
| | Jeff Stavish, UST Class A Operator | | clearwaterstopngo@gmail.com |
| | Jeff Stavish, UST Class B Global Operator | | clearwaterstopngo@gmail.com |
| | Sherri Housley, UST Class A Operator | | jjross9185@msn.com |
| | Sherri Housley, UST Class B Operator | | jjross9185@msn.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 04 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4474 | Spill Test Date | 03/28/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | 03/27/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 03/28/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 05 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4475 | Spill Test Date | 03/28/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | 03/27/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 03/28/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 06 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4476 | Spill Test Date | 03/27/2024 | Piping Installed Date | 03/19/2018 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | 03/27/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | MLLD Line Tightness Testing | Energy Act | No |
| | | Overfill Test Date | 03/27/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Lolo

Location: LOLO SUPERSTOP
12011 US Hwy 93 S
Lolo, MT 59847-9666 Missoula

System Facility ID:56-13795

Facility Code: 30482
Last Inspected On: 08/21/2025
Operating Permit Renewal Date: 10/03/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|----------------------------------|---|
| Owner Operator Contact: | Tabish Brothers Distributors Inc | lss@gwpetrol.com |
| Operator Contact: | Bri Mader;Karly Shafer | (406) 396-2206 |
| | | karly@gwpetrol.com;knotts.brianna@yahoo.com |

| | | |
|-----------------|---|--------------------------|
| Owner/Operator: | Tabish Brothers Distributors Inc | lss@gwpetrol.com |
| | Bri Mader, UST Class A Operator | knotts.brianna@yahoo.com |
| | Bri Mader, UST Class B Operator | knotts.brianna@yahoo.com |
| | Karly Shafer, UST Class A Operator | karly@gwpetrol.com |
| | Karly Shafer, UST Class B Global Operator | karly@gwpetrol.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 05 | Tank Age | 28 | Tank Installed Date | 01/15/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2086 | Spill Test Date | 11/25/2025 | Piping Installed Date | 12/01/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/07/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 04/27/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 28 | Tank Installed Date | 01/15/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2087 | Spill Test Date | 11/25/2025 | Piping Installed Date | 12/01/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/07/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 05/01/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| | | Overfill Test Date | 07/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 28 | Tank Installed Date | 01/15/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2088 | Spill Test Date | 11/25/2025 | Piping Installed Date | 12/01/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/07/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 07/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 05/07/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 28 | Tank Installed Date | 01/15/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2089 | Spill Test Date | 07/23/2025 | Piping Installed Date | 12/01/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/07/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 05/07/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 28 | Tank Installed Date | 01/15/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2090 | Spill Test Date | 07/23/2025 | Piping Installed Date | 12/01/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/07/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 07/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 05/01/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 1
10955 US Hwy 93 S
Lolo, MT 59847 Missoula

System Facility ID:32-09414

Facility Code: 25493
Last Inspected On: 03/31/2023
Operating Permit Renewal Date: 10/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lolo 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Lolo 1 Town Pump LLC (406) 497-6700 environmental@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 05 | Tank Age | 5 | Tank Installed Date | 04/20/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6029 | Spill Test Date | 07/19/2022 | Piping Installed Date | 04/20/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/19/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/24/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | 03/24/2023 | Line Tightness Test Date | 05/04/2021 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/19/2022 | | | ATG Type | | | | | |
| Tank Code | 06 | Tank Age | 5 | Tank Installed Date | 04/20/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6030 | Spill Test Date | 07/19/2022 | Piping Installed Date | 04/20/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/19/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/24/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 15000 | ATG Test Date | 03/24/2023 | Line Tightness Test Date | 05/04/2021 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/19/2022 | | | ATG Type | | | | | |
| Tank Code | 07 | Tank Age | 5 | Tank Installed Date | 04/20/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tag Number | 6031 | Spill Test Date | 07/19/2022 | Piping Installed Date | 04/20/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/19/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/24/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 7000 | ATG Test Date | 03/24/2023 | Line Tightness Test Date | 05/04/2021 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/19/2022 | | | ATG Type | | | | | |
| Tank Code | 08 | Tank Age | 5 | Tank Installed Date | 04/20/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6032 | Spill Test Date | 07/19/2022 | Piping Installed Date | 04/20/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/19/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/24/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 03/24/2023 | Line Tightness Test Date | 05/04/2021 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/19/2022 | | | ATG Type | | | | | |
| Tank Code | 09 | Tank Age | 5 | Tank Installed Date | 04/20/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6033 | Spill Test Date | 03/10/2021 | Piping Installed Date | 04/20/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 7000 | ATG Test Date | | Line Tightness Test Date | 05/04/2021 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 03/02/2021 | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 2
11880 US HWY 93 S, STE 1
Lolo, MT 59847 Missoula

System Facility ID:32-01639

Facility Code: 25228
Last Inspected On: 03/31/2023
Operating Permit Renewal Date: 10/22/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lolo 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Lolo 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 13 | Tank Age | 29 | Tank Installed Date | 09/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2545 | Spill Test Date | 07/20/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | 12/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 14 | Tank Age | 29 | Tank Installed Date | 09/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2546 | Spill Test Date | 07/20/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | 12/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 17 | Tank Age | 29 | Tank Installed Date | 09/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2549 | Spill Test Date | 07/20/2022 | Piping Installed Date | 08/11/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | 12/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 18 | Tank Age | 29 | Tank Installed Date | 09/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2550 | Spill Test Date | 07/20/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | 12/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 15 | Tank Age | 29 | Tank Installed Date | 09/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4289 | Spill Test Date | 07/20/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | 12/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 16 | Tank Age | 29 | Tank Installed Date | 09/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4290 | Spill Test Date | 07/20/2022 | Piping Installed Date | 08/11/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | 12/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 20 | Tank Age | 22 | Tank Installed Date | 09/15/2004 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4942 | Spill Test Date | 07/20/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 21 | Tank Age | 22 | Tank Installed Date | 09/15/2004 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4943 | Spill Test Date | 07/20/2022 | Piping Installed Date | 08/11/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/03/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Lolo

Location: TRAVELERS REST
10565 Lolo Creek Rd
Lolo, MT 59847-9471 Missoula

System Facility ID:32-11303

Facility Code: 25632
Last Inspected On: 09/26/2024
Operating Permit Renewal Date: 12/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|-------------------------|----------------|---|
| Owner Operator Contact: | Manpreet Singh | (509) 994-6599 | sbsm065@gmail.com |
| Operator Contact: | Emily Day;Jeffrey Toole | | histar.jeff@gmail.com;Travelersrestlolo@gmail.com |

| | | | |
|-----------------|-------------------------------------|----------------|-----------------------------|
| Owner/Operator: | Manpreet Singh | (509) 994-6599 | sbsm065@gmail.com |
| | Emily Day, UST Class A Operator | | Travelersrestlolo@gmail.com |
| | Jeffrey Toole, UST Class A Operator | | histar.jeff@gmail.com |
| | Jeffrey Toole, UST Class B Operator | | histar.jeff@gmail.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | S4 | Tank Age | 23 | Tank Installed Date | 08/13/2003 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4854 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 09/26/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 09/26/2024 | Line Tightness Test Date | 09/26/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | S5 | Tank Age | 23 | Tank Installed Date | 08/13/2003 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4855 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 09/26/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 09/26/2024 | Line Tightness Test Date | 09/26/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | S6 | Tank Age | 23 | Tank Installed Date | 06/23/2003 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4856 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 09/26/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 09/26/2024 | Line Tightness Test Date | 09/26/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | S7 | Tank Age | 23 | Tank Installed Date | 06/23/2003 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4857 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 09/26/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 09/26/2024 | Line Tightness Test Date | 09/26/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | S8 | Tank Age | 23 | Tank Installed Date | 06/23/2003 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4858 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 09/26/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 09/26/2024 | Line Tightness Test Date | 09/26/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Milltown

Location: TOWN PUMP INC BONNER-MILLTOWN
7985 MT Hwy 200 E
Milltown, MT 59851 Missoula

System Facility ID:32-13629

Facility Code: 25772
Last Inspected On: 03/30/2023
Operating Permit Renewal Date: 11/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bonner Town Pump and Casino Inc(406) 497-6700environmental@townpump.com

Operator Contact: Trent BiggersTrentb@townpump.com

Owner/Operator: Bonner Town Pump and Casino Inc(406) 497-6700environmental@townpump.com
Trent Biggers, UST Class A OperatorTrentb@townpump.com
Trent Biggers, UST Class B Global OperatorTrentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2564 | Spill Test Date | 06/06/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 05 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2568 | Spill Test Date | 06/06/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 07 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2570 | Spill Test Date | 06/06/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 08 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2571 | Spill Test Date | 06/06/2022 | Piping Installed Date | 10/17/2016 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 09 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2572 | Spill Test Date | 06/06/2022 | Piping Installed Date | 10/17/2016 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 11 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2574 | Spill Test Date | 06/06/2022 | Piping Installed Date | 10/17/2016 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 10000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 02 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4260 | Spill Test Date | 06/06/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 03 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4261 | Spill Test Date | 06/06/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 04 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4262 | Spill Test Date | 06/06/2022 | Piping Installed Date | 10/13/2006 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Capacity | 12000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 06 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4263 | Spill Test Date | 06/06/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 12 | Tank Age | 23 | Tank Installed Date | 12/03/2003 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4871 | Spill Test Date | 06/06/2022 | Piping Installed Date | 10/17/2016 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 13 | Tank Age | 23 | Tank Installed Date | 12/03/2003 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4872 | Spill Test Date | 06/06/2022 | Piping Installed Date | 10/17/2016 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|---|----------------|------------------|
| Tank Code | 10 | Tank Age | 31 | Tank Installed Date | 09/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4889 | Spill Test Date | 06/06/2022 | Piping Installed Date | 10/17/2016 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 14 | Tank Age | 13 | Tank Installed Date | 06/01/2013 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5363 | Spill Test Date | | Piping Installed Date | 07/12/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Pressurized | CP Met Types | |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring;Deferred | Primary Pipe Detection | Continuous Interstitial Monitoring;Deferred | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 15 | Tank Age | 8 | Tank Installed Date | 01/01/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Positive Shutoff |
| Tag Number | 5802 | Spill Test Date | 06/06/2022 | Piping Installed Date | 12/22/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/09/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 30000 | ATG Test Date | 03/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 06/06/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: 3RD STREET MART
2340 S 3rd St W
Missoula, MT 59801 Missoula

System Facility ID:32-02179

Facility Code: 25246
Last Inspected On: 07/22/2025
Operating Permit Renewal Date: 08/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|--|-------------------------------|---|
| Owner Operator Contact: | Jays Corporation | (406) 549-1750 | polsonbay@yahoo.com |
| Operator Contact: | Jagpreet Ghuman;Jaspal Sandhu;Jays Corporation | (406) 549-1750;(406) 880-7677 | jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com |

| | | | |
|-----------------|---------------------------------------|----------------|-------------------------|
| Owner/Operator: | Jays Corporation | (406) 549-1750 | polsonbay@yahoo.com |
| | Jagpreet Ghuman, UST Class A Operator | | jaysfood08@outlook.com |
| | Jagpreet Ghuman, UST Class B Operator | | jays1stop21@outlook.com |
| | Jaspal Sandhu, UST Class A Operator | | polsonbay@yahoo.com |
| | Jaspal Sandhu, UST Class B Operator | | polsonbay@yahoo.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 50 | Tank Installed Date | 04/23/1976 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3624 | Spill Test Date | 07/22/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 02/03/2025 | Tank/Piping CP Test Date | 06/04/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 02/04/2025 | Line Tightness Test Date | 04/01/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 02/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 50 | Tank Installed Date | 04/23/1976 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3625 | Spill Test Date | 07/22/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 02/03/2025 | Tank/Piping CP Test Date | 06/04/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 02/04/2025 | Line Tightness Test Date | 04/07/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| | | Overfill Test Date | 02/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 03 | Tank Age | 50 | Tank Installed Date | 04/23/1976 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3626 | Spill Test Date | 07/22/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 02/03/2025 | Tank/Piping CP Test Date | 06/04/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 02/04/2025 | Line Tightness Test Date | 10/11/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 02/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: 70 MILE SUPER STOP 2
930 N Russell St
Missoula, MT 59808 Missoula

System Facility ID:32-13472

Facility Code: 25751
Last Inspected On: 01/04/2024
Operating Permit Renewal Date: 01/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Operator Contact:

Owner/Operator: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 32 | Tank Installed Date | 06/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1450 | Spill Test Date | 10/23/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/04/2011 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/15/2025 | Line Tightness Test Date | 10/23/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 02/28/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 32 | Tank Installed Date | 06/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1451 | Spill Test Date | 02/28/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 08/04/2011 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/15/2025 | Line Tightness Test Date | 10/23/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/23/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 32 | Tank Installed Date | 06/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-----------------------------|----------------|----------------|
| Tag Number | 1452 | Spill Test Date | 02/28/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/04/2011 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 04/15/2025 | Line Tightness Test Date | 10/23/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 02/28/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

| | | | | | | | | |
|--|--|--|---|--|--|--|--|--|
| Location: AIRWAY FLEET FUEL 5355 W Harrier Missoula, MT 59808 Missoula | | | System Facility ID:56-14133 | | | Facility Code: 30771 Last Inspected On: 11/17/2025 Operating Permit Renewal Date: 02/18/2026 | | |
| Owner Operator Contact: Finest Oil Co | | | (406) 543-6969 | | | finestoil@finest-oil.com | | |
| Operator Contact: Christopher Glasser;James Brady;John Stordahl;Justin Gaudot;Stephen Hanson | | | (406) 218-1563;(406) 543-6969;(406) 544-1005;(714) 333-8926 | | | chrisglasser@hotmail.com;finestoil@finest-oil.com;fireman2201@msn.com;jeeplin247.jb@gmail.com;justgaudot@yahoo.com | | |
| Owner/Operator: Finest Oil Co | | | (406) 543-6969 | | | finestoil@finest-oil.com | | |
| Christopher Glasser, UST Class A Operator | | | | | | chrisglasser@hotmail.com | | |
| James Brady, UST Class A Operator | | | | | | jeeplin247.jb@gmail.com | | |
| John Stordahl, UST Class A Operator | | | | | | fireman2201@msn.com | | |
| Joseph McClain, UST Class B Operator | | | | | | jgmcclain25@gmail.com | | |
| Justin Gaudot, UST Class A Operator | | | | | | justgaudot@yahoo.com | | |
| Justin Gaudot, UST Class B Global Operator | | | | | | justgaudot@yahoo.com | | |
| Stephen Hanson, UST Class A Operator | | | | | | finestoil@finest-oil.com | | |
| Stephen Hanson, UST Class B Operator | | | | | | finestoil@finest-oil.com | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 21 | Tank Installed Date | 04/05/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4904 | Spill Test Date | 01/16/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 12/19/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 12/20/2022 | Line Tightness Test Date | 06/12/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 12/19/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 21 | Tank Installed Date | 04/05/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4905 | Spill Test Date | 12/19/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Product | Gasoline | PLLD Test Date | 12/19/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 12/20/2022 | Line Tightness Test Date | 06/12/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 12/19/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 21 | Tank Installed Date | 04/05/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4906 | Spill Test Date | 12/19/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 12/19/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 12/20/2022 | Line Tightness Test Date | 06/12/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 12/19/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 04 | Tank Age | 21 | Tank Installed Date | 04/05/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4907 | Spill Test Date | 12/19/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/19/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 12/20/2022 | Line Tightness Test Date | 06/12/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 12/19/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 21 | Tank Installed Date | 04/05/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5038 | Spill Test Date | 12/19/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/19/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 12/20/2022 | Line Tightness Test Date | 06/12/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|--|--|--------------------|------------|--|--|----------|--|--|--|--|--|
| | | Overfill Test Date | 12/19/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |
|--|--|--------------------|------------|--|--|----------|--|--|--|--|--|

Facility Summary in Missoula County in the City of Missoula

Location: BEACH TRANSPORTATION CO
825 Mount Ave
Missoula, MT 59801-5607 Missoula

System Facility ID:32-11904

Facility Code: 25660
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 05/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Beach Transportation

Operator Contact: Carlin Cavill;Shawnae Stanton;Beach Transportation (406) 549-6121 ccavill@beachtrans.com;sstanton@beachtrans.com

Owner/Operator: Beach Transportation

Carlin Cavill, UST Class A Operator
Carlin Cavill, UST Class B Operator
Shawnae Stanton, UST Class A Operator
Shawnae Stanton, UST Class B Operator

ccavill@beachtrans.com
ccavill@beachtrans.com
sstanton@beachtrans.com
sstanton@beachtrans.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 29 | Tank Installed Date | 09/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2361 | Spill Test Date | 04/01/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/01/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | 03/03/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | Gilbarco-Veeder Root/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: BIG SKY GAS N SHOP LLC
318 S Orange St
Missoula, MT 59801-1811 Missoula

System Facility ID:32-08715

Facility Code: 25471
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BIG SKY GAS N SHOP LLC (510) 714-5045

Operator Contact:

Owner/Operator: BIG SKY GAS N SHOP LLC (510) 714-5045

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tank Code | 04 | Tank Age | 36 | Tank Installed Date | 05/24/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2552 | Spill Test Date | 10/04/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 05/12/2023 | Tank/Piping CP Test Date | 05/04/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 06/20/2023 | Line Tightness Test Date | 05/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/04/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 05/29/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2553 | Spill Test Date | 07/11/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 05/12/2023 | Tank/Piping CP Test Date | 05/04/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 06/20/2023 | Line Tightness Test Date | 05/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/11/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 05/29/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|---------------|----------------|----|
| Tag Number | 2554 | Spill Test Date | 07/11/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 05/12/2023 | Tank/Piping CP Test Date | 05/04/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 06/20/2023 | Line Tightness Test Date | 05/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/11/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: BNSF MISSOULA YARD
101 International Dr
Missoula, MT 59808-1549 Missoula

System Facility ID:32-11226

Facility Code: 25626
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BNSF Railway Helena yueh.chuang@bnsf.com

Operator Contact: Devin Clary;Montana Rail Link Inc Missoula;Michael DeLozier;BNSF Railway Helena;Robert Mantle;BNSF Railway Helena (406) 841-5044;(406) 523-1415 bobmantle@hotmail.com;yueh.chuang@bnsf.com;michael.delozier@bnsf.com;yueh.chuang@bnsf.com;rshelley@mtrail.com

Owner/Operator: BNSF Railway Helena yueh.chuang@bnsf.com
Devin Clary, UST Class A Operator rshelley@mtrail.com
Devin Clary, UST Class B Operator yueh.chuang@bnsf.com
Michael DeLozier, UST Class A Operator yueh.chuang@bnsf.com
Robert Mantle, UST Class A Operator yueh.chuang@bnsf.com

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|--------------|--------------------------|----------------------------------|----------------|-----|
| Tank Code | S5 | Tank Age | 36 | Tank Installed Date | 11/01/1990 | Tank Material | Unknown | Piping Material | Steel | Overfill Types | |
| Tag Number | 3872 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | Yes |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/01/2023 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | | Line Tightness Test Date | 11/17/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: CHS MISSOULA PETROLEUM TERMINAL
3576 Grant Creek Rd
Missoula, MT 59808 Missoula

System Facility ID:60-15296

Facility Code: 31000
Last Inspected On: 10/08/2025
Operating Permit Renewal Date: 01/17/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Laurel (406) 628-5200

Operator Contact: Matthew Mill Matt.Mill@chsinc.com

Owner/Operator: CHS Inc Laurel (406) 628-5200

Matthew Mill, UST Class A Operator
Matthew Mill, UST Class B Operator

Matt.Mill@chsinc.com
Matt.Mill@chsinc.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|----|--------------------------|------------|-------------------------------|--------------|--------------------------|----------------------------------|----------------|-----|
| Tank Code | 01 | Tank Age | 18 | Tank Installed Date | 02/01/2008 | Tank Material | Not Listed | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 5708 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Mixture | PLLD Test Date | | Tank/Piping CP Test Date | 11/19/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 7750 | ATG Test Date | | Line Tightness Test Date | 04/18/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746278
403 S Russell St
Missoula, MT 59801-2311 Missoula

System Facility ID:32-08072

Facility Code: 25460
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 04/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|------------------------|----------------|---------------------------|
| Owner Operator Contact: | Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
| Operator Contact: | Veronica Rivera | | ESS-WestCoast@circlek.com |

| | | | |
|-----------------|--|----------------|--------------------------------|
| Owner/Operator: | Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
| | Brad Lee, UST Class B Global Operator | | brad.lee@holidaycompanies.com |
| | Jeff Reed, UST Class B Global Operator | | jeff.reed@holidaycompanies.com |
| | Veronica Rivera, UST Class A Operator | | ESS-WestCoast@circlek.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 06 | Tank Age | 31 | Tank Installed Date | 07/31/1995 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3024 | Spill Test Date | 07/07/2025 | Piping Installed Date | 06/10/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 01/06/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 01/06/2025 | Line Tightness Test Date | 07/25/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/07/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 31 | Tank Installed Date | 07/31/1995 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3025 | Spill Test Date | 01/06/2025 | Piping Installed Date | 06/10/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 01/06/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 8000 | ATG Test Date | 01/06/2025 | Line Tightness Test Date | 07/27/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|----------------|
| | | Overfill Test Date | 01/06/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 31 | Tank Installed Date | 07/31/1995 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3026 | Spill Test Date | 01/06/2025 | Piping Installed Date | 06/10/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 01/06/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 8000 | ATG Test Date | 01/06/2025 | Line Tightness Test Date | 08/02/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/06/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 31 | Tank Installed Date | 07/31/1995 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4700 | Spill Test Date | 01/06/2025 | Piping Installed Date | 06/10/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 01/06/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 01/06/2025 | Line Tightness Test Date | 10/13/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/06/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746282
605 S Higgins Ave
Missoula, MT 59801-2733 Missoula

System Facility ID:32-09733

Facility Code: 25517
Last Inspected On: 05/03/2023
Operating Permit Renewal Date: 08/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|------------------------|----------------|---------------------------|
| Owner Operator Contact: | Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
| Operator Contact: | Veronica Rivera | | ESS-WestCoast@circlek.com |

| | | | |
|-----------------|--|----------------|--------------------------------|
| Owner/Operator: | Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
| | Brad Lee, UST Class B Global Operator | | brad.lee@holidaycompanies.com |
| | Jeff Reed, UST Class B Global Operator | | jeff.reed@holidaycompanies.com |
| | Veronica Rivera, UST Class A Operator | | ESS-WestCoast@circlek.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 38 | Tank Installed Date | 08/01/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3028 | Spill Test Date | 05/03/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/27/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 06/27/2022 | Line Tightness Test Date | 06/27/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/27/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 38 | Tank Installed Date | 08/01/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3029 | Spill Test Date | 05/03/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/27/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 06/27/2022 | Line Tightness Test Date | 06/27/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/27/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|---------------|
| Tank Code | 03 | Tank Age | 38 | Tank Installed Date | 08/01/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3030 | Spill Test Date | 05/03/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/27/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 06/27/2022 | Line Tightness Test Date | 06/27/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/27/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746283
2325 S Reserve St
Missoula, MT 59801-6446 Missoula

System Facility ID:32-09694

Facility Code: 25512
Last Inspected On: 10/17/2023
Operating Permit Renewal Date: 02/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|------------------------|----------------|---------------------------|
| Owner Operator Contact: | Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
| Operator Contact: | Veronica Rivera | | ESS-WestCoast@circlek.com |

| | | | |
|-----------------|--|----------------|--------------------------------|
| Owner/Operator: | Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
| | Brad Lee, UST Class B Global Operator | | brad.lee@holidaycompanies.com |
| | Jeff Reed, UST Class B Global Operator | | jeff.reed@holidaycompanies.com |
| | Veronica Rivera, UST Class A Operator | | ESS-WestCoast@circlek.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 39 | Tank Installed Date | 08/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3706 | Spill Test Date | 11/21/2024 | Piping Installed Date | 04/10/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/03/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 06/07/2023 | Tank/Piping CP Test Date | 06/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 06/07/2023 | Line Tightness Test Date | 07/06/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 06/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 39 | Tank Installed Date | 08/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3707 | Spill Test Date | 11/21/2024 | Piping Installed Date | 04/10/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/03/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 06/07/2023 | Tank/Piping CP Test Date | 06/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 10000 | ATG Test Date | 06/07/2023 | Line Tightness Test Date | 06/14/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-------------------|
| | | Overfill Test Date | 06/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 39 | Tank Installed Date | 08/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3708 | Spill Test Date | 04/11/2022 | Piping Installed Date | 04/10/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/03/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 06/07/2023 | Tank/Piping CP Test Date | 06/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 10000 | ATG Test Date | 06/07/2023 | Line Tightness Test Date | 06/17/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 06/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 04 | Tank Age | 39 | Tank Installed Date | 08/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3709 | Spill Test Date | 06/22/2021 | Piping Installed Date | 04/10/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/03/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 06/07/2023 | Tank/Piping CP Test Date | 06/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 06/07/2023 | Line Tightness Test Date | 06/13/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 06/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: COMMUNITY MEDICAL CENTER
2827 Fort Missoula Rd
Missoula, MT 59804 Missoula

System Facility ID:32-11740

Facility Code: 25652
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 03/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: RCHP Billings - Missoula LLCcclark@communitymed.org

Operator Contact: Randy Allen;Community Medical Center(406) 327-4029rallen6261@gmail.com

Owner/Operator: RCHP Billings - Missoula LLCcclark@communitymed.org

Randy Allen, UST Class A Operator

rallen6261@gmail.com

Randy Allen, UST Class B Operator

rallen6261@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 04 | Tank Age | 32 | Tank Installed Date | 07/01/1994 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2353 | Spill Test Date | 11/28/2023 | Piping Installed Date | 06/03/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/05/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 11/28/2023 | Line Tightness Test Date | 11/28/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | 3-Year Line Tightness Test | Energy Act | No |
| | | Overfill Test Date | 11/28/2023 | | | ATG Type | Franklin Fueling Systems/S940 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: CORNER QWIK STOP
2480 39th St
Missoula, MT 59803-1123 Missoula

System Facility ID:32-09690

Facility Code: 25511
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 08/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Operator Contact: Jagpreet Ghuman;Manpreet Singh (406) 880-7677;(509) 994-6599 jaysfood08@outlook.com;sbsm065@gmail.com

Owner/Operator: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com
Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
Jaspal Sandhu, UST Class B Global Operator jas_sandhu75@hotmail.com
Manpreet Singh, UST Class A Operator sbsm065@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 01 | Tank Age | 44 | Tank Installed Date | 11/03/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1360 | Spill Test Date | 04/27/2021 | Piping Installed Date | 04/27/2018 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/27/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/08/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 06/22/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 44 | Tank Installed Date | 11/03/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1361 | Spill Test Date | 04/27/2021 | Piping Installed Date | 04/27/2018 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/27/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 12/03/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------|----------------|--------------------------------------|
| | | Overfill Test Date | 06/22/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 44 | Tank Installed Date | 11/03/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1362 | Spill Test Date | 04/27/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/08/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/22/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: COSTCO WHOLESALE FUELING MSLA
3220 N Reserve St
Missoula, MT 59808-1556 Missoula

System Facility ID:56-13977

Facility Code: 30639
Last Inspected On: 07/11/2024
Operating Permit Renewal Date: 07/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Operator Contact: Brandon Krause;Sean Davis;Costco Wholesale Corporation w067gas@costco.com;w067ops@costco.com
Missoula;Shawn Willis

Owner/Operator: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Brandon Krause, UST Class A Operator
Sean Davis, UST Class A Operator
Sean Davis, UST Class B Operator
Shawn Willis, UST Class A Operator
Shawn Willis, UST Class B Global Operator
Shawn Willis, UST Class B Operator

w067gas@costco.com
w067ops@costco.com
w067ops@costco.com
w067gas@costco.com
w067gas@costco.com
w067gas@costco.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 26 | Tank Installed Date | 05/15/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4189 | Spill Test Date | 07/10/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/01/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/11/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 07/10/2024 | Line Tightness Test Date | 07/10/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 26 | Tank Installed Date | 05/15/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4190 | Spill Test Date | 07/10/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/01/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/11/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Capacity | 20000 | ATG Test Date | 07/10/2024 | Line Tightness Test Date | 07/10/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 03 | Tank Age | 26 | Tank Installed Date | 05/15/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4191 | Spill Test Date | 07/10/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/01/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/11/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 07/10/2024 | Line Tightness Test Date | 07/10/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 04 | Tank Age | 15 | Tank Installed Date | 08/01/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5283 | Spill Test Date | 07/10/2024 | Piping Installed Date | 10/25/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/11/2024 | Sump Tightness Test Date | 06/01/2022 | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Hazardous Substance | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 1500 | ATG Test Date | 07/10/2024 | Line Tightness Test Date | 07/10/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | MLLD Line Tightness Testing | Energy Act | Yes |
| | | Overfill Test Date | 07/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: DEMAROIS, INC
3115 W Broadway St
Missoula, MT 59808-1613 Missoula

System Facility ID:32-10552

Facility Code: 25588
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 01/08/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: DeMarois Inc (406) 721-4000

Operator Contact: Jack DeMarois (406) 721-4000 jack@demarois.com

Owner/Operator: DeMarois Inc (406) 721-4000

Jack DeMarois, UST Class A Operator
Jack DeMarois, UST Class B Operator

jack@demarois.com
jack@demarois.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 28 | Tank Installed Date | 11/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2188 | Spill Test Date | 11/08/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 12/13/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/13/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: FAST TRIP CONOCO
2730 S Reserve St
Missoula, MT 59801-7641 Missoula

System Facility ID:56-13914

Facility Code: 30584
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 07/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Scott Worster scottoej@gmail.com

Operator Contact: Deb Privett (406) 529-7771 fasttripinc@gmail.com

Owner/Operator: Scott Worster scottoej@gmail.com

Deb Privett, UST Class A Operator

fasttripinc@gmail.com

Deb Privett, UST Class B Operator

fasttripinc@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 01 | Tank Age | 27 | Tank Installed Date | 08/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4913 | Spill Test Date | 06/24/2024 | Piping Installed Date | 06/03/2020 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/24/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 10/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 10/23/2025 | Line Tightness Test Date | 12/02/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 27 | Tank Installed Date | 08/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4914 | Spill Test Date | 06/24/2024 | Piping Installed Date | 06/03/2020 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/24/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 10/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/23/2025 | Line Tightness Test Date | 11/14/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-----------------------------------|
| | | Overfill Test Date | 10/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 27 | Tank Installed Date | 08/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4915 | Spill Test Date | 06/24/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/24/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 10/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/23/2025 | Line Tightness Test Date | 10/25/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: FINEST OIL CO MISSOULA NORTHGATE

3665 Grant Creek Rd

Missoula, MT 59808-1431 Missoula

System Facility ID:32-02295

Facility Code: 25257

Last Inspected On: 06/14/2023

Operating Permit Renewal Date: 08/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Finest Oil Co

(406) 543-6969

finestoil@finest-oil.com

Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson

(406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926

chrisglasser@hotmail.com;finestoil@finest-oil.com;jepin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com

Owner/Operator: Finest Oil Co

(406) 543-6969

finestoil@finest-oil.com

chrisglasser@hotmail.com

jepin247.jb@gmail.com

rivban22@gmail.com

jgmcclain25@gmail.com

justgaudot@yahoo.com

justgaudot@yahoo.com

finestoil@finest-oil.com

finestoil@finest-oil.com

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-------------------------------|----------------|--------------------------------|
| Tank Code | 06 | Tank Age | 35 | Tank Installed Date | 07/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1066 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 07 | Tank Age | 35 | Tank Installed Date | 07/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1067 | Spill Test Date | 06/14/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |

Report Created: 1/13/2026

Page [54] of [171]

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-------------------------------|----------------|--------------------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 06/14/2023 | Tank/Piping CP Test Date | 06/14/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 08 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1068 | Spill Test Date | 06/14/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 06/14/2023 | Tank/Piping CP Test Date | 06/14/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 09 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1069 | Spill Test Date | 06/14/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 06/14/2023 | Tank/Piping CP Test Date | 06/14/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 10 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1070 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 06/14/2023 | Tank/Piping CP Test Date | 04/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-------------------------------|----------------|--------------------------------|
| Capacity | 12000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 11 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1071 | Spill Test Date | 08/04/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 06/14/2023 | Tank/Piping CP Test Date | 04/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 12 | Tank Age | 32 | Tank Installed Date | 05/01/1994 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1072 | Spill Test Date | 08/04/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 06/14/2023 | Tank/Piping CP Test Date | 04/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 13 | Tank Age | 32 | Tank Installed Date | 05/01/1994 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1073 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 06/14/2023 | Tank/Piping CP Test Date | 04/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 06/18/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Missoula County in the City of Missoula

| | | | | | | | | |
|--|--|--|--|--|--|---|--|--|
| Location: FINEST OIL EASTGATE 940 E Broadway St Missoula, MT 59802-4915 Missoula | | | System Facility ID:32-10284 | | | Facility Code: 25565 Last Inspected On: 08/27/2025 Operating Permit Renewal Date: 09/17/2028 | | |
| Owner Operator Contact: Finest Oil Co | | | (406) 543-6969 | | | finestoil@finest-oil.com | | |
| Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson | | | (406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926 | | | chrisglasser@hotmail.com;finestoil@finest-oil.com;jeeplin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com | | |
| Owner/Operator: Finest Oil Co | | | (406) 543-6969 | | | finestoil@finest-oil.com | | |
| Christopher Glasser, UST Class A Operator | | | | | | chrisglasser@hotmail.com | | |
| David Peyton, UST Class A Operator | | | | | | | | |
| David Peyton, UST Class B Global Operator | | | | | | | | |
| James Brady, UST Class A Operator | | | | | | jeeplin247.jb@gmail.com | | |
| James DeWaters, UST Class A Operator | | | | | | rivban22@gmail.com | | |
| John Stordahl, UST Class B Global Operator | | | | | | fireman2201@msn.com | | |
| Joseph McClain, UST Class B Operator | | | | | | jgmccclain25@gmail.com | | |
| Justin Gaudot, UST Class A Operator | | | | | | justgaudot@yahoo.com | | |
| Justin Gaudot, UST Class B Global Operator | | | | | | justgaudot@yahoo.com | | |
| Stephen Hanson, UST Class A Operator | | | | | | finestoil@finest-oil.com | | |
| Stephen Hanson, UST Class B Operator | | | | | | finestoil@finest-oil.com | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 07 | Tank Age | 29 | Tank Installed Date | 10/27/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1074 | Spill Test Date | 08/27/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 08/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/27/2025 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 08 | Tank Age | 29 | Tank Installed Date | 10/27/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1075 | Spill Test Date | 08/27/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 08/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/27/2025 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 09 | Tank Age | 29 | Tank Installed Date | 10/27/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1076 | Spill Test Date | 05/04/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 08/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/27/2025 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: GREAT WESTERN PETROLEUM
1002 E Broadway St
Missoula, MT 59802-4930 Missoula

System Facility ID:32-07431

Facility Code: 25437
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/30/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc lss@gwpetrol.com

Operator Contact: Heather Stiles hstiles@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc lss@gwpetrol.com

Heather Stiles, UST Class A Operator hstiles@gwpetrol.com
Heather Stiles, UST Class B Global Operator hstiles@gwpetrol.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 10 | Tank Age | 28 | Tank Installed Date | 06/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1432 | Spill Test Date | 10/17/2024 | Piping Installed Date | 08/26/2006 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 05/01/2024 | Line Tightness Test Date | 05/01/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/01/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | S11 | Tank Age | 28 | Tank Installed Date | 06/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 1433 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 17000 | ATG Test Date | 10/07/2021 | Line Tightness Test Date | 05/01/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|-----|
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S12 | Tank Age | 28 | Tank Installed Date | 06/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 1434 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 11000 | ATG Test Date | 10/07/2021 | Line Tightness Test Date | 05/01/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S13 | Tank Age | 28 | Tank Installed Date | 06/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 1435 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 14600 | ATG Test Date | 10/07/2021 | Line Tightness Test Date | 05/01/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S14 | Tank Age | 28 | Tank Installed Date | 06/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 1436 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 11000 | ATG Test Date | 10/07/2021 | Line Tightness Test Date | 05/01/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: HEATING PLANT
Physical Plant Bldg #32
Missoula, MT 59812 Missoula

System Facility ID:32-00505

Facility Code: 25184
Last Inspected On: 10/01/2025
Operating Permit Renewal Date: 02/22/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: University of Montana (406) 243-2190

Operator Contact: Anthony Ey anthony.ey@mso.umt.edu>

Owner/Operator: University of Montana (406) 243-2190

Anthony Ey, UST Class A Operator
Anthony Ey, UST Class B Operator

anthony.ey@mso.umt.edu>
anthony.ey@mso.umt.edu>

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 09 | Tank Age | 28 | Tank Installed Date | 11/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4221 | Spill Test Date | 01/27/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 09/30/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/30/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE CONOCO SERVICE CENTER
711 E Broadway St
Missoula, MT 59802-4609 Missoula

System Facility ID:32-00144

Facility Code: 25156
Last Inspected On: 06/12/2023
Operating Permit Renewal Date: 06/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hellgate Conoco Service Center;Ross Grenfell;Hellgate Conoco Service Center (406) 728-9966;(406) 728-9966;(406) 728-9966 hellgateconoco@gmail.com

Operator Contact: Ross Grenfell;Hellgate Conoco Service Center (406) 728-9966;(406) 728-9966 hellgateconoco@gmail.com

Owner/Operator: Hellgate Conoco Service Center (406) 728-9966
Owner/Operator: Ross Grenfell,Hellgate Conoco Service Center (406) 728-9966
Ross Grenfell, UST Class A Operator hellgateconoco@gmail.com
Ross Grenfell, UST Class B Global Operator hellgateconoco@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 60 | Tank Installed Date | 03/31/1966 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3765 | Spill Test Date | 06/12/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 06/12/2023 | Sump Tightness Test Date | 06/12/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | 06/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 06/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 60 | Tank Installed Date | 03/31/1966 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3766 | Spill Test Date | 06/12/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 06/12/2023 | Sump Tightness Test Date | 06/12/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | 06/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|-------------------|
| | | Overfill Test Date | 06/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 03 | Tank Age | 60 | Tank Installed Date | 03/31/1966 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3767 | Spill Test Date | 06/12/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 06/12/2023 | Sump Tightness Test Date | 06/12/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | 06/12/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 08 | Tank Age | 16 | Tank Installed Date | 12/16/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5279 | Spill Test Date | 06/12/2023 | Piping Installed Date | 12/16/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 06/12/2023 | Sump Tightness Test Date | 06/12/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/15/2017 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 8000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | 06/12/2023 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 06/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE TRADING POST INC
6265 Mullan Rd
Missoula, MT 59808-5650 Missoula

System Facility ID:32-00211

Facility Code: 25173
Last Inspected On: 03/12/2025
Operating Permit Renewal Date: 06/03/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc lss@gwpetrol.com

Operator Contact: Karly Shafer (406) 396-2206 karly@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc lss@gwpetrol.com
Heather Stiles, UST Class B Global Operator hstiles@gwpetrol.com
Karly Shafer, UST Class A Operator karly@gwpetrol.com
Karly Shafer, UST Class B Global Operator karly@gwpetrol.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 03 | Tank Age | 32 | Tank Installed Date | 09/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1425 | Spill Test Date | 03/12/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/12/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/12/2025 | Line Tightness Test Date | 03/12/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/12/2025 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 04 | Tank Age | 32 | Tank Installed Date | 09/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1426 | Spill Test Date | 03/12/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/12/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/12/2025 | Line Tightness Test Date | 03/12/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/12/2025 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORES 400
540 E Broadway St
Missoula, MT 59802-4614 Missoula

System Facility ID:32-03614

Facility Code: 25304
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 08/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JACKSONS FOOD STORES INC (208) 888-6061 compliance@jacksons.com

Operator Contact: Earl Allen

Owner/Operator: JACKSONS FOOD STORES INC (208) 888-6061 compliance@jacksons.com

Earl Allen, UST Class A Operator

Earl Allen, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 05 | Tank Age | 11 | Tank Installed Date | 04/28/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5573 | Spill Test Date | 04/09/2024 | Piping Installed Date | 04/28/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/09/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/03/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 18000 | ATG Test Date | 05/03/2023 | Line Tightness Test Date | 02/13/2021 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 07/31/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 11 | Tank Installed Date | 04/28/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5574 | Spill Test Date | 04/09/2024 | Piping Installed Date | 04/28/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/09/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/03/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/03/2023 | Line Tightness Test Date | 02/13/2021 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|------------------|
| | | Overfill Test Date | 07/31/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 11 | Tank Installed Date | 04/28/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5575 | Spill Test Date | 05/18/2021 | Piping Installed Date | 04/28/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/18/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/18/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 05/18/2021 | Line Tightness Test Date | 02/13/2021 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 07/31/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORES 401
1605 S Russell St
Missoula, MT 59801-5636 Missoula

System Facility ID:32-08863

Facility Code: 25478
Last Inspected On: 10/23/2024
Operating Permit Renewal Date: 02/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: GYPSY LLC (208) 888-6061 compliance@jacksons.com

Operator Contact: Earl Allen

Owner/Operator: GYPSY LLC (208) 888-6061 compliance@jacksons.com

Earl Allen, UST Class A Operator
Earl Allen, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 41 | Tank Installed Date | 06/23/1985 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1357 | Spill Test Date | 10/23/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/25/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 10/23/2024 | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 02 | Tank Age | 41 | Tank Installed Date | 06/23/1985 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1358 | Spill Test Date | 11/26/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/25/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/26/2024 | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 03 | Tank Age | 41 | Tank Installed Date | 06/23/1985 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|--|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tag Number | 1359 | Spill Test Date | 10/23/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/25/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 10/23/2024 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORES 402
1250 39th St
Missoula, MT 59803 Missoula

System Facility ID:32-05763

Facility Code: 25380
Last Inspected On: 09/13/2025
Operating Permit Renewal Date: 12/10/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JACKSONS FOOD STORES INC (208) 888-6061 compliance@jacksons.com

Operator Contact: Earl Allen

Owner/Operator: JACKSONS FOOD STORES INC (208) 888-6061 compliance@jacksons.com

Earl Allen, UST Class A Operator
Earl Allen, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 46 | Tank Installed Date | 01/01/1980 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1348 | Spill Test Date | 04/23/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/23/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/23/2025 | Line Tightness Test Date | 06/14/2010 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 46 | Tank Installed Date | 01/01/1980 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1349 | Spill Test Date | 04/23/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/23/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/23/2025 | Line Tightness Test Date | 06/14/2010 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|-------------------|
| Tank Code | 03 | Tank Age | 46 | Tank Installed Date | 01/01/1980 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1350 | Spill Test Date | 04/23/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/23/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/23/2025 | Line Tightness Test Date | 06/14/2010 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: JAYS 1 STOP
505 Highton St
Missoula, MT 59801-5424 Missoula

System Facility ID:32-06680

Facility Code: 25412
Last Inspected On: 06/24/2025
Operating Permit Renewal Date: 07/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman;Jays 1 Stop;Jaspal Sandhu;Jays Corporation (406) 549-1750;(406) 880-7677;(406) 549-1031 jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com;jays1stop21@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com
Jagpreet Ghuman, UST Class A Operator jays1stop21@outlook.com
Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 36 | Tank Installed Date | 01/10/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2298 | Spill Test Date | 09/03/2024 | Piping Installed Date | 02/21/2025 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/21/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 07/12/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 02/25/2025 | Line Tightness Test Date | 07/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 03/03/2025 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 36 | Tank Installed Date | 01/10/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2299 | Spill Test Date | 09/03/2024 | Piping Installed Date | 02/21/2025 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/21/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 07/12/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 02/25/2025 | Line Tightness Test Date | 07/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 03/03/2025 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 01/10/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2300 | Spill Test Date | 09/03/2024 | Piping Installed Date | 02/21/2025 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/21/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 07/12/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 02/25/2025 | Line Tightness Test Date | 07/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 03/03/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 2 | Tank Installed Date | 08/07/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6252 | Spill Test Date | 09/03/2024 | Piping Installed Date | 02/21/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 02/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 03/03/2025 | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

System Facility ID:32-05760

Facility Code: 25377
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 08/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu (406) 880-7677 jas_sandhu75@hotmail.com;jaysfood08@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com
Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Global Operator jaysfood08@outlook.com
Jaspal Sandhu, UST Class A Operator jas_sandhu75@hotmail.com
Jaspal Sandhu, UST Class B Global Operator jas_sandhu75@hotmail.com
Jaspal Sandhu, UST Class B Operator jas_sandhu75@hotmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 54 | Tank Installed Date | 11/18/1972 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1345 | Spill Test Date | 04/11/2022 | Piping Installed Date | 10/10/2015 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/22/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 12/03/2019 | Tank/Piping CP Test Date | 03/01/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | 10/12/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/11/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 50 | Tank Installed Date | 11/18/1976 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1346 | Spill Test Date | 04/11/2022 | Piping Installed Date | 10/10/2015 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/22/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 12/03/2019 | Tank/Piping CP Test Date | 03/01/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-------------------|
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | 10/14/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/11/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 54 | Tank Installed Date | 11/18/1972 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1347 | Spill Test Date | 04/11/2022 | Piping Installed Date | 10/10/2015 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/22/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 12/03/2019 | Tank/Piping CP Test Date | 03/01/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | 10/14/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/11/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE CARDLOCK
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

System Facility ID:32-05761

Facility Code: 25378
Last Inspected On: 04/18/2025
Operating Permit Renewal Date: 06/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman (406) 880-7677 jaysfood08@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com
Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Global Operator jaysfood08@outlook.com
Jaspal Sandhu, UST Class B Global Operator jas_sandhu75@hotmail.com

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 47 | Tank Installed Date | 11/14/1979 | Tank Material | Bare Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3627 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/28/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 51 | Tank Installed Date | 11/14/1975 | Tank Material | Bare Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3628 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | 06/28/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------|----------------|-------------------|
| Tank Code | 03 | Tank Age | 47 | Tank Installed Date | 11/14/1979 | Tank Material | Bare Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3629 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/28/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: LOVES TRAVEL STOP #753
8077 Hwy 10 W
Missoula, MT 59808 Missoula

System Facility ID:60-15321

Facility Code: 31018
Last Inspected On: 10/01/2024
Operating Permit Renewal Date: 01/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Loves Travel Stops and Country Stores Inc (281) 655-9425 environmental@loves.com

Operator Contact: Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Lowery;Loves Travel Stops and Country Stores Inc (281) 655-9425;(405) 779-3768;(281) 655-9425 environmental@loves.com;environmental@loves.com

Owner/Operator: Loves Travel Stops and Country Stores Inc (281) 655-9425 environmental@loves.com
Eric Bennett, UST Class A Operator environmental@loves.com
Eric Bennett, UST Class B Operator environmental@loves.com
Eric Candelaria, UST Class B Operator environmental@loves.com
Ted Lowery, UST Class A Operator environmental@loves.com
Ted Lowery, UST Class B Operator environmental@loves.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5830 | Spill Test Date | 09/20/2022 | Piping Installed Date | 08/15/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 30000 | ATG Test Date | 01/22/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 09/20/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 02 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5831 | Spill Test Date | 09/20/2022 | Piping Installed Date | 08/15/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|----------------|
| | | Overfill Test Date | 09/20/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 03 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5832 | Spill Test Date | 09/20/2022 | Piping Installed Date | 08/15/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 09/20/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 04 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5833 | Spill Test Date | 09/20/2022 | Piping Installed Date | 08/15/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 09/20/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 05 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5834 | Spill Test Date | 09/20/2022 | Piping Installed Date | 08/15/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 09/20/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 06 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5835 | Spill Test Date | 09/22/2022 | Piping Installed Date | 08/15/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 09/20/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 07 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5836 | Spill Test Date | 09/20/2022 | Piping Installed Date | 08/15/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Biodiesel B99 | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 09/20/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 08 | Tank Age | 7 | Tank Installed Date | 08/15/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | |
| Tag Number | 5837 | Spill Test Date | | Piping Installed Date | 08/15/2019 | Tank Construction | | Piping Construction | | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Pressurized | CP Met Types | |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Not Listed | Primary Pipe Detection | Not Listed | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 11/29/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Not Listed | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 09 | Tank Age | 8 | Tank Installed Date | 10/26/2018 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5863 | Spill Test Date | 10/01/2023 | Piping Installed Date | 12/17/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Oil, Motor | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | 11/24/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 02/24/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 10 | Tank Age | 8 | Tank Installed Date | 10/26/2018 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5864 | Spill Test Date | 10/01/2024 | Piping Installed Date | 12/17/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Oil, Motor | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | 11/24/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 02/24/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 11 | Tank Age | 8 | Tank Installed Date | 10/26/2018 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5865 | Spill Test Date | 10/01/2024 | Piping Installed Date | 12/17/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Oil, Motor | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | 11/24/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 02/24/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 12 | Tank Age | 8 | Tank Installed Date | 10/26/2018 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5866 | Spill Test Date | 10/01/2023 | Piping Installed Date | 12/17/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Oil, Motor | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | 11/24/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 02/24/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 13 | Tank Age | 8 | Tank Installed Date | 10/26/2018 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5867 | Spill Test Date | 10/01/2023 | Piping Installed Date | 12/17/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Safe Suction | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Product | Oil, Motor | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | 11/24/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 02/24/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 14 | Tank Age | 8 | Tank Installed Date | 10/26/2018 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5868 | Spill Test Date | 10/01/2023 | Piping Installed Date | 12/17/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/15/2023 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Oil, Waste | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 7000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | 11/24/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 02/24/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 15 | Tank Age | 8 | Tank Installed Date | 10/26/2018 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5869 | Spill Test Date | 10/01/2023 | Piping Installed Date | 12/17/2019 | Tank Construction | Double-Walled | Piping Construction | Secondary Containment Chase | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/20/2022 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Oil, Motor | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 11/15/2023 | Line Tightness Test Date | 11/24/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 02/24/2022 | | | ATG Type | Incon/TS-550 EVO | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MDOT MISSOULA
8350 Old Hwy 10
Missoula, MT 59808 Missoula

System Facility ID:60-15231

Facility Code: 30948
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 09/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Department of Transportation Helena

Operator Contact: Joe Radonich;Montana Dept of Transportation;Michael Carstensen;MDT 11 3211 Missoula W Broadway (406) 444-9204;(406) 444-7632;(406) 523-5836 jradonich@mt.gov;jradonich@mt.gov;mcarstensen@mt.gov

Owner/Operator: Montana Department of Transportation Helena

Joe Radonich, UST Class A Operator jradonich@mt.gov
Joe Radonich, UST Class B Operator jradonich@mt.gov
Michael Carstensen, UST Class A Operator mcarstensen@mt.gov
Michael Carstensen, UST Class B Operator mcarstensen@mt.gov

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 12 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5438 | Spill Test Date | 11/16/2021 | Piping Installed Date | 08/30/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/16/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 11/16/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 11/16/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 12 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5439 | Spill Test Date | | Piping Installed Date | 08/25/2013 | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring | Primary Pipe Detection | ELLD 0.1;ELLD 0.2 | Vapor Recovery | No |

| | | | | | | | | | | | |
|----------|------|--------------------|--|--------------------------|--|-------------------------------|---|--------------------------|------------|------------|----|
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Not Listed | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA #7 FLYING J
8745 Hwy 93 N
Missoula, MT 59808 Missoula

System Facility ID:60-15158

Facility Code: 30899
Last Inspected On: 06/27/2023
Operating Permit Renewal Date: 10/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Missoula 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5256 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 02 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5257 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5258 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 04 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5259 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 30000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 05 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5260 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 8000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 06 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5261 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 15000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 07 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5262 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 08 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5331 | Spill Test Date | 10/25/2022 | Piping Installed Date | 07/19/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 09 | Tank Age | 16 | Tank Installed Date | 09/01/2010 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5361 | Spill Test Date | | Piping Installed Date | 04/11/2012 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Not Listed | CP Met Types | |

| | | | | | | | | | | | |
|----------|---------------------|--------------------|--|--------------------------|--|-------------------------------|---|--------------------------|---|----------------|-----|
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Approved Remote Monitoring;Continuous Interstitial Monitoring | Primary Pipe Detection | Approved Remote Monitoring;Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA AIRPORT WASHINGTON HANGER
5225 W Broadway St
Missoula, MT 59808-9385 Missoula

System Facility ID:32-07606

Facility Code: 25444
Last Inspected On: 12/13/2025
Operating Permit Renewal Date: 05/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Washington Corporations

Operator Contact: Andrew Ihle;Missoula Airport Washington Hanger;Ryan Opheim (406) 214-8531 aihle@washcorp.com;ropheim@washcorp.com

Owner/Operator: Washington Corporations

Andrew Ihle, UST Class A Operator
Andrew Ihle, UST Class B Operator
Ryan Opheim, UST Class A Operator
Ryan Opheim, UST Class B Operator

aihle@washcorp.com
aihle@washcorp.com
ropheim@washcorp.com
ropheim@washcorp.com

| | | | | | | | | | | | |
|-------------|-------------------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 01 | Tank Age | 42 | Tank Installed Date | 05/07/1984 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 2242 | Spill Test Date | 03/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/17/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Jet Fuel (Jet-A, Jet-A1, JP5) | PLLD Test Date | | Tank/Piping CP Test Date | 02/26/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/17/2024 | Line Tightness Test Date | 03/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/17/2024 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA CHEVROLET
3663 N Reserve St
Missoula, MT 59808-1509 Missoula

System Facility ID:56-14056

Facility Code: 30710
Last Inspected On: 05/13/2023
Operating Permit Renewal Date: 09/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MISSOULA MOTOR COMPANY LLC (406) 721-2438 terryh@missoulamc.com

Operator Contact: Terry Hedrick (406) 532-2437 terryh@missoulamc.com

Owner/Operator: MISSOULA MOTOR COMPANY LLC (406) 721-2438 terryh@missoulamc.com

Terry Hedrick, UST Class A Operator

terryh@missoulamc.com

Terry Hedrick, UST Class B Operator

terryh@missoulamc.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 02 | Tank Age | 24 | Tank Installed Date | 07/22/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4695 | Spill Test Date | 11/17/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 11/17/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/17/2022 | Line Tightness Test Date | 09/20/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/17/2022 | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 03 | Tank Age | 24 | Tank Installed Date | 07/22/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4696 | Spill Test Date | 11/17/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 11/17/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Capacity | 4000 | ATG Test Date | 11/17/2022 | Line Tightness Test Date | 09/20/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/17/2022 | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | S1 | Tank Age | 24 | Tank Installed Date | 07/30/2002 | Tank Material | Aboveground Tank | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4699 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | |
| Product | Oil, Waste | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/17/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA COUNTY DETENTION CENTER
2340 Mullan Rd
Missoula, MT 59808-1830 Missoula

System Facility ID:56-13921

Facility Code: 30591
Last Inspected On: 08/18/2025
Operating Permit Renewal Date: 11/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|--|---|----------------|
| Owner Operator Contact: Missoula County Detention Center | | |
| Operator Contact: | Gary Zinke;Jess Ebel | (406) 531-3627 |
| | gezinke@missoulacounty.us;jebel@missoulacounty.us | |

Owner/Operator: Missoula County Detention Center

Gary Zinke, UST Class A Operator
Gary Zinke, UST Class B Operator
Jess Ebel, UST Class A Operator
Jess Ebel, UST Class B Operator

gezinke@missoulacounty.us
gezinke@missoulacounty.us
jebel@missoulacounty.us
jebel@missoulacounty.us

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|-----|
| Tank Code | S1 | Tank Age | 27 | Tank Installed Date | 06/01/1999 | Tank Material | Unknown | Piping Material | Copper | Overfill Types | |
| Tag Number | 3774 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Secondary Containment Chase | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 3000 | ATG Test Date | 08/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA SERVICE CENTER
1900 S Russell St
Missoula, MT 59801-6624 Missoula

System Facility ID:32-01182

Facility Code: 25203
Last Inspected On: 12/23/2025
Operating Permit Renewal Date: 06/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|---------------------------|----------------|--|
| Owner Operator Contact: | Northwestern Energy Butte | (406) 655-2521 | eric.larson@northwestern.com |
| Operator Contact: | Eric Larson;Jeremy Salle | (406) 565-6871 | eric.larson@northwestern.com;jeremy.salle@northwestern.com |

| | | | |
|-----------------|--|----------------|-------------------------------|
| Owner/Operator: | Northwestern Energy Butte | (406) 655-2521 | eric.larson@northwestern.com |
| | Eric Larson, UST Class A Operator | | eric.larson@northwestern.com |
| | Eric Larson, UST Class B Global Operator | | eric.larson@northwestern.com |
| | Jeremy Salle, UST Class A Operator | | jeremy.salle@northwestern.com |
| | Joe Vigue, UST Class B Operator | | Joseph.Vigue@northwestern.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 04 | Tank Age | 36 | Tank Installed Date | 07/27/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1680 | Spill Test Date | 08/25/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 01/18/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 13000 | ATG Test Date | 07/19/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/25/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 07/27/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1681 | Spill Test Date | 08/25/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 01/18/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 3000 | ATG Test Date | 07/19/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/25/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA URBAN TRANSPORTATION
1221 Shakespeare St
Missoula, MT 59802-2307 Missoula

System Facility ID:32-04427

Facility Code: 25341
Last Inspected On: 12/16/2025
Operating Permit Renewal Date: 06/05/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula Urban Transportation (406) 543-8386

Operator Contact: Jeffrey Logan;John Roseboom (406) 215-2455;(406) 215-2458 jlogan@mountainline.com;john@mountainline.com

Owner/Operator: Missoula Urban Transportation (406) 543-8386

Brian Dildine, UST Class B Operator

Cody Bush, UST Class B Operator

David Loewen, UST Class B Operator

Jacob Nolen, UST Class B Operator

Jeffrey Logan, UST Class A Operator

Jeffrey Logan, UST Class B Operator

John Roseboom, UST Class A Operator

John Roseboom, UST Class B Operator

Kent Russell, UST Class B Operator

bdildine@mountainline.com

cbush@mountainline.com

jnolen@mountainline.com

jlogan@mountainline.com

jlogan@mountainline.com

john@mountainline.com

john@mountainline.com

krussell@mountainline.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 04 | Tank Age | 28 | Tank Installed Date | 04/30/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 1658 | Spill Test Date | 03/24/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/24/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 03/24/2023 | | | ATG Type | Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic | | | | |
| Tank Code | 05 | Tank Age | 28 | Tank Installed Date | 04/30/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1659 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|--|-------------------------------|---|--------------------------|------------------------------------|----------------|----------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Gravity Feed | CP Met Types | Non-corrodible |
| Product | Oil, Waste | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 600 | ATG Test Date | 03/24/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/24/2023 | | | ATG Type | Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MOUNTAIN WEST COOP
4570 N Reserve St
Missoula, MT 59808 Missoula

System Facility ID:32-02437

Facility Code: 25260
Last Inspected On: 03/27/2024
Operating Permit Renewal Date: 06/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|---|--|--|--|
| Owner Operator Contact: CHS Inc Inver Grove Heights | | (651) 355-6343 | Kirsten.Tindall@chsinc.com |
| Operator Contact: | Bob Westin;Dusty Smith;John Thompson;Michael Gourley;CHS Inc Inver Grove Heights;Robin McCurdy;Will Dukart | (406) 370-3920;(651) 355-6343;(406) 541-6800;(406) 543-8383;(406) 546-4885 | chuck.thompson@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;Kirsten.Tindall@chsinc.com;robin.mccurdy@chsinc.com;will.dukart@chsinc.com |

| | | | |
|---|--|----------------|----------------------------|
| Owner/Operator: CHS Inc Inver Grove Heights | | (651) 355-6343 | Kirsten.Tindall@chsinc.com |
| Bill Griffin, UST Class B Operator | | | |
| Bob Westin, UST Class A Operator | | | |
| Bob Westin, UST Class B Global Operator | | | |
| Dusty Smith, UST Class A Operator | | | dusty.smith@chsinc.com |
| Dusty Smith, UST Class B Global Operator | | | dusty.smith@chsinc.com |
| John Thompson, UST Class A Operator | | | chuck.thompson@chsinc.com |
| John Thompson, UST Class B Global Operator | | | chuck.thompson@chsinc.com |
| John Thompson, UST Class B Operator | | | chuck.thompson@chsinc.com |
| Michael Gourley, UST Class A Operator | | | Kirsten.Tindall@chsinc.com |
| Mike Dunlon, UST Class B Operator | | | michael.dunlop@chsinc.com |
| Robin McCurdy, UST Class A Operator | | | robin.mccurdy@chsinc.com |
| Robin McCurdy, UST Class B Operator | | | robin.mccurdy@chsinc.com |
| Will Dukart, UST Class A Operator | | | will.dukart@chsinc.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 16 | Tank Age | 31 | Tank Installed Date | 03/29/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 2859 | Spill Test Date | 10/07/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/07/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 03/26/2024 | Tank/Piping CP Test Date | 03/27/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 02/27/2024 | Line Tightness Test Date | 06/12/2014 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 03/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 17 | Tank Age | 12 | Tank Installed Date | 11/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5554 | Spill Test Date | 10/07/2021 | Piping Installed Date | 01/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/07/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/26/2024 | Tank/Piping CP Test Date | 03/27/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 03/27/2024 | Line Tightness Test Date | 01/16/2015 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 03/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 18 | Tank Age | 12 | Tank Installed Date | 11/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5555 | Spill Test Date | 10/07/2021 | Piping Installed Date | 01/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/07/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/26/2024 | Tank/Piping CP Test Date | 03/27/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 25000 | ATG Test Date | 03/27/2024 | Line Tightness Test Date | 01/16/2015 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 03/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 19 | Tank Age | 12 | Tank Installed Date | 11/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5556 | Spill Test Date | 10/07/2021 | Piping Installed Date | 01/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/07/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/26/2024 | Tank/Piping CP Test Date | 03/27/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/27/2024 | Line Tightness Test Date | 01/16/2015 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 03/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 20 | Tank Age | 12 | Tank Installed Date | 11/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5557 | Spill Test Date | 10/07/2021 | Piping Installed Date | 01/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/07/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/26/2024 | Tank/Piping CP Test Date | 03/27/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/27/2024 | Line Tightness Test Date | 01/16/2015 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 03/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 21 | Tank Age | 12 | Tank Installed Date | 11/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5558 | Spill Test Date | 10/07/2021 | Piping Installed Date | 01/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/07/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/26/2024 | Tank/Piping CP Test Date | 03/27/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/27/2024 | Line Tightness Test Date | 01/16/2015 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 10/07/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 22 | Tank Age | 12 | Tank Installed Date | 11/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5559 | Spill Test Date | 10/07/2021 | Piping Installed Date | 01/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/07/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/26/2024 | Tank/Piping CP Test Date | 03/27/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 10000 | ATG Test Date | 03/27/2024 | Line Tightness Test Date | 09/16/2022 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 03/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: MURALTS TRUCK PLAZA
8800 Truck Stop Rd
Missoula, MT 59808-9708 Missoula

System Facility ID:32-00146

Facility Code: 25157
Last Inspected On: 12/20/2023
Operating Permit Renewal Date: 01/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|---------------------------|----------------|--------------------|
| Owner Operator Contact: | Muralts Inc;Walter Muralt | (406) 728-4700 | walt@muralts.com |
| Operator Contact: | Curtis Wilson | | curtis@muralts.com |

| | | | |
|-----------------|--|----------------|-------------------------|
| Owner/Operator: | Muralts Inc | (406) 728-4700 | |
| Owner/Operator: | Walter Muralt | (406) 728-4700 | |
| | Bonnie Kelley, UST Class B Global Operator | | bonnie@muralts.com |
| | Curtis Wilson, UST Class A Operator | | curtis@muralts.com |
| | Curtis Wilson, UST Class B Operator | | curtis@muralts.com |
| | Kevin Linton, UST Class B Operator | | jesselinton14@gmail.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 10 | Tank Age | 31 | Tank Installed Date | 11/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1734 | Spill Test Date | | Piping Installed Date | 01/12/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 05/19/2009 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 11 | Tank Age | 31 | Tank Installed Date | 11/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1735 | Spill Test Date | | Piping Installed Date | 01/12/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 05/19/2009 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 01 | Tank Age | 58 | Tank Installed Date | 03/26/1968 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3650 | Spill Test Date | | Piping Installed Date | 01/12/2016 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 07/23/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 02 | Tank Age | 58 | Tank Installed Date | 03/26/1968 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3651 | Spill Test Date | | Piping Installed Date | 01/12/2016 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 07/23/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 03 | Tank Age | 58 | Tank Installed Date | 03/26/1968 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3652 | Spill Test Date | | Piping Installed Date | 01/12/2016 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 07/23/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 04 | Tank Age | 58 | Tank Installed Date | 03/26/1968 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|---------------|----------------|-------------------|
| Tag Number | 3653 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 07/23/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 05 | Tank Age | 58 | Tank Installed Date | 03/26/1968 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3654 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 07/23/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 06 | Tank Age | 53 | Tank Installed Date | 03/26/1973 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3655 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 12/17/2020 | Tank/Piping CP Test Date | 07/23/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | 01/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

Facility Summary in Missoula County in the City of Missoula

| | | | | | | | | |
|--|--|--|-----------------------------|--|--|--|--|--|
| Location: OLES COUNTRY STORE 11 1600 S Russell St Missoula, MT 59801-5637 Missoula | | | System Facility ID:32-04620 | | | Facility Code: 25345 Last Inspected On: 10/22/2024 Operating Permit Renewal Date: 03/05/2028 | | |
| Owner Operator Contact: DDJ Investments LLC;Jennifer Louquet | | | (406) 728-7618 | | | olescs11@gmail.com | | |
| Operator Contact: Derek Louquet | | | (406) 369-5855 | | | derek.louquet@gmail.com | | |
| Owner/Operator: DDJ Investments LLC | | | (406) 728-7618 | | | olescs11@gmail.com | | |
| Owner/Operator: Jennifer Louquet | | | (406) 728-7618 | | | olescs11@gmail.com | | |
| Derek Louquet, UST Class A Operator | | | | | | derek.louquet@gmail.com | | |
| Mary Fleming, UST Class B Operator | | | | | | olescs11@gmail.com | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|------------------|
| Tank Code | 04 | Tank Age | 38 | Tank Installed Date | 10/30/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1721 | Spill Test Date | 04/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 02/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 10/23/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 02/06/2024 | Line Tightness Test Date | 02/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 02/06/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 05 | Tank Age | 38 | Tank Installed Date | 10/30/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1722 | Spill Test Date | 10/27/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 02/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 10/23/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 02/06/2024 | Line Tightness Test Date | 02/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 02/06/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 06 | Tank Age | 38 | Tank Installed Date | 10/30/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-----------------------------|----------------|----------|
| Tag Number | 1723 | Spill Test Date | 10/27/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 02/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 10/23/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 02/06/2024 | Line Tightness Test Date | 02/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 02/06/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 12
3705 MT Hwy 200 E
Missoula, MT 59802 Missoula

System Facility ID:32-03190

Facility Code: 25284
Last Inspected On: 10/29/2025
Operating Permit Renewal Date: 02/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tri East Inc (406) 728-7736

Operator Contact: Peggy Wolfe peggy_wlf@yahoo.com

Owner/Operator: Tri East Inc (406) 728-7736

LeeAnn Dean, UST Class B Global Operator
Peggy Wolfe, UST Class A Operator
Peggy Wolfe, UST Class B Operator

peggy_wlf@yahoo.com
peggy_wlf@yahoo.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 62 | Tank Installed Date | 05/01/1964 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1427 | Spill Test Date | 07/24/2025 | Piping Installed Date | 01/11/2018 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/21/2025 | Line Tightness Test Date | 04/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 62 | Tank Installed Date | 05/01/1964 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1428 | Spill Test Date | 07/24/2025 | Piping Installed Date | 01/11/2018 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/21/2025 | Line Tightness Test Date | 04/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 03 | Tank Age | 62 | Tank Installed Date | 05/01/1964 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1429 | Spill Test Date | 07/24/2025 | Piping Installed Date | 01/11/2018 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/21/2025 | Line Tightness Test Date | 04/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 62 | Tank Installed Date | 05/01/1964 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1430 | Spill Test Date | 07/24/2025 | Piping Installed Date | 01/11/2018 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/21/2025 | Line Tightness Test Date | 04/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 47 | Tank Installed Date | 05/02/1979 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1431 | Spill Test Date | 07/24/2025 | Piping Installed Date | 01/11/2018 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/21/2025 | Line Tightness Test Date | 04/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 2
923 N Orange St
Missoula, MT 59802-2927 Missoula

System Facility ID:32-05216

Facility Code: 25359
Last Inspected On: 11/08/2022
Operating Permit Renewal Date: 03/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|----------------------------------|----------------|-----------------------|
| Owner Operator Contact: | Oles Country Stores Inc Missoula | (406) 542-2224 | olesmanager@aol.com |
| Operator Contact: | Casie Schwindt | | rschwindt92@yahoo.com |

| | | | |
|-----------------|--------------------------------------|----------------|-----------------------|
| Owner/Operator: | Oles Country Stores Inc Missoula | (406) 542-2224 | olesmanager@aol.com |
| | Casie Schwindt, UST Class A Operator | | rschwindt92@yahoo.com |
| | Casie Schwindt, UST Class B Operator | | rschwindt92@yahoo.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-----------------------------|----------------|---------------|
| Tank Code | 04 | Tank Age | 36 | Tank Installed Date | 09/25/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2357 | Spill Test Date | 11/08/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Secondary Containment Chase | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/08/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | 08/22/2007 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/09/2022 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 09/25/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2358 | Spill Test Date | 11/08/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Secondary Containment Chase | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/08/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | 10/07/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/09/2022 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 09/25/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-----------------------------|----------------|----------|
| Tag Number | 2359 | Spill Test Date | 11/08/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Secondary Containment Chase | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/08/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 11/08/2022 | Line Tightness Test Date | 08/22/2007 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/09/2022 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED MISSOULA
TERMINAL
3330 Raser Dr
Missoula, MT 59808-1534 Missoula

System Facility ID:32-08732

Facility Code: 25472
Last Inspected On: 01/23/2025
Operating Permit Renewal Date: 06/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | | | | | | | | | |
|---|--|--|--|--|--|---|--|--|--|--|--|
| Owner Operator Contact: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal | | | | | | allen.eggen@p66.com | | | | | |
| Operator Contact: Chris Cote;Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal;Tanner Beadles;Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal | | | | | | chris.r.cote@p66.com;allen.eggen@p66.com;tanner.j.beadles@p66.com;allen.eggen@p66.com | | | | | |
| Owner/Operator: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal | | | | | | allen.eggen@p66.com | | | | | |
| Andrew Snyder, UST Class B Operator | | | | | | andrew.a.snyder@conocophillips.com | | | | | |
| Chris Binder, UST Class B Operator | | | | | | | | | | | |
| Chris Cote, UST Class A Operator | | | | | | allen.eggen@p66.com | | | | | |
| Chris Cote, UST Class B Operator | | | | | | allen.eggen@p66.com | | | | | |
| Dusty Nagel, UST Class B Operator | | | | | | dusty.a.nagel@p66.com | | | | | |
| Orlando Rodriguez, UST Class B Operator | | | | | | orlando.r.rodriquez@conocophillips.com | | | | | |
| Tanner Beadles, UST Class A Operator | | | | | | allen.eggen@p66.com | | | | | |
| Tanner Beadles, UST Class B Operator | | | | | | allen.eggen@p66.com | | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------|--------------------------|----------------------------------|----------------|-----|
| Tank Code | S15 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 2793 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 630000 | ATG Test Date | | Line Tightness Test Date | 09/03/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S18 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 2796 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------|--------------------------|----------------------------------|----------------|-----|
| Capacity | 1260000 | ATG Test Date | | Line Tightness Test Date | 09/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S19 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 2797 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 647892 | ATG Test Date | | Line Tightness Test Date | 08/30/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S23 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 2800 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 847000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S24 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 2801 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 847000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S25 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 2802 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------|--------------------------|----------------------------------|----------------|-----|
| Capacity | 648000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S26 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 2803 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 648000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S13 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 4581 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 630000 | ATG Test Date | | Line Tightness Test Date | 09/04/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S17 | Tank Age | 72 | Tank Installed Date | 06/01/1954 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 4909 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 840000 | ATG Test Date | | Line Tightness Test Date | 08/29/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

| | | |
|--|-----------------------------|--|
| Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL 3330 Raser Dr Missoula, MT 59808-1534 Missoula | System Facility ID:32-03320 | Facility Code: 25289 |
| | | Last Inspected On: 01/23/2025 |
| | | Operating Permit Renewal Date: 06/09/2028 |
| | | Note: Inspection is due 90 days before the Operating Permit Renewal Date. |

| | |
|---|---------------------|
| Owner Operator Contact: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal | allen.eggen@p66.com |
|---|---------------------|

| | |
|--|--|
| Operator Contact: Adam Pfeifer;Dusty Nagel | adam.pfeifer@p66.com;dusty.a.nagel@p66.com |
|--|--|

| | |
|---|--|
| Owner/Operator: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal | allen.eggen@p66.com |
| Adam Pfeifer, UST Class A Operator | adam.pfeifer@p66.com |
| Adam Pfeifer, UST Class B Global Operator | adam.pfeifer@p66.com |
| Andrew Snyder, UST Class B Operator | andrew.a.snyder@conocophillips.com |
| Chris Binder, UST Class B Operator | |
| Dustin Rogers, UST Class B Operator | dustin.w.rogers@conocophilips.com |
| Dusty Nagel, UST Class A Operator | dusty.a.nagel@p66.com |
| Dusty Nagel, UST Class B Operator | dusty.a.nagel@p66.com |
| Marcus Eppard, UST Class B Operator | marcus.k.eppard@p66.com |
| Orlando Rodriguez, UST Class B Operator | orlando.r.rodriquez@conocophillips.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|----------------------------|----------------|------------------|
| Tank Code | 22 | Tank Age | 29 | Tank Installed Date | 11/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Steel - Terminal Piping | Overfill Types | High Level Alarm |
| Tag Number | 738 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Gravity Feed | CP Met Types | |
| Product | Mixture | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 10/22/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S09 | Tank Age | 73 | Tank Installed Date | 01/01/1953 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 739 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------|--------------------------|----------------------------------|----------------|-----|
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 1260000 | ATG Test Date | | Line Tightness Test Date | 09/09/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S11 | Tank Age | 73 | Tank Installed Date | 01/01/1953 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 741 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 840000 | ATG Test Date | | Line Tightness Test Date | 09/09/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S13 | Tank Age | 73 | Tank Installed Date | 01/01/1953 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 743 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Mixture | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 840000 | ATG Test Date | | Line Tightness Test Date | 09/16/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S15 | Tank Age | 73 | Tank Installed Date | 01/01/1953 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 745 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Gasohol/Ethanol | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 840000 | ATG Test Date | | Line Tightness Test Date | 08/27/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S17 | Tank Age | 54 | Tank Installed Date | 01/01/1972 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 747 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------|--------------------------|----------------------------------|----------------|-----|
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 840000 | ATG Test Date | | Line Tightness Test Date | 09/24/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S19 | Tank Age | 52 | Tank Installed Date | 01/01/1974 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 749 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 4200000 | ATG Test Date | | Line Tightness Test Date | 09/24/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S20 | Tank Age | 52 | Tank Installed Date | 01/01/1974 | Tank Material | Cathodically Protected Steel | Piping Material | Steel - Terminal Piping | Overfill Types | |
| Tag Number | 750 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/21/2024 | Primary Tank Leak Detection | | Primary Pipe Detection | Terminal Piping Annual Line Test | Vapor Recovery | No |
| Capacity | 2646000 | ATG Test Date | | Line Tightness Test Date | 09/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: PROVIDENCE CENTER
900 N Orange St
Missoula, MT 59802-2998 Missoula

System Facility ID:32-13405

Facility Code: 25746
Last Inspected On: 11/12/2023
Operating Permit Renewal Date: 04/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|-------------------------|-------------------------|
| Owner Operator Contact: | Saint Patricks Hospital | (406) 543-7271 |
| Operator Contact: | Timothy Chopp | tchopp@saintpatrick.org |

| | | |
|-----------------|-------------------------------------|-------------------------|
| Owner/Operator: | Saint Patricks Hospital | (406) 543-7271 |
| | Harry McGuire, UST Class B Operator | |
| | Timothy Chopp, UST Class A Operator | tchopp@saintpatrick.org |
| | Timothy Chopp, UST Class B Operator | tchopp@saintpatrick.org |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 02 | Tank Age | 31 | Tank Installed Date | 08/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1960 | Spill Test Date | 11/06/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 2500 | ATG Test Date | 11/06/2023 | Line Tightness Test Date | 02/12/2021 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/06/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: RANGITSCH BROTHERS 2001 WEST BROADWAY
2001 W Broadway St
Missoula, MT 59808-1817 Missoula

System Facility ID:32-09919

Facility Code: 25529
Last Inspected On: 08/21/2023
Operating Permit Renewal Date: 10/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rangitsch Brothers service1@rangitschbrosrv.com.

Operator Contact: Gerry Wolner;Joel Jasperson (406) 721-7561 joelj@rangitschbrosrv.com;service1@rangitschbrosrv.com.

Owner/Operator: Rangitsch Brothers service1@rangitschbrosrv.com.
David Crowder, UST Class B Operator acewheeler65@gmail.com
Gerry Wolner, UST Class A Operator service1@rangitschbrosrv.com.
Joel Jasperson, UST Class A Operator joelj@rangitschbrosrv.com
Joel Jasperson, UST Class B Operator joelj@rangitschbrosrv.com
Russ Dickey, UST Class B Operator service2@rangitschbrosrv.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 27 | Tank Installed Date | 01/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3917 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/01/2025 | | | ATG Type | EMCO Electronics/EECO 1500 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: ROSAUERS 127 FUEL STATION
2350 S Reserve St
Missoula, MT 59801 Missoula

System Facility ID:60-15318

Facility Code: 31015
Last Inspected On: 09/23/2024
Operating Permit Renewal Date: 12/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rosauers Supermarkets Inc Marshall

(509) 326-8900

lillig@rosauers.com

Operator Contact: Dean Hansen;Paco Sutton

(406) 721-5430

127mgr@rosauers.com

Owner/Operator: Rosauers Supermarkets Inc Marshall

(509) 326-8900

lillig@rosauers.com

Dean Hansen, UST Class A Operator

127mgr@rosauers.com

Dean Hansen, UST Class B Operator

127mgr@rosauers.com

Paco Sutton, UST Class A Operator

127mgr@rosauers.com

Paco Sutton, UST Class B Operator

127mgr@rosauers.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 01 | Tank Age | 8 | Tank Installed Date | 06/21/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5814 | Spill Test Date | 08/31/2021 | Piping Installed Date | 06/24/2018 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/10/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | 04/10/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/10/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 02 | Tank Age | 8 | Tank Installed Date | 06/21/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5815 | Spill Test Date | 07/25/2024 | Piping Installed Date | 06/24/2018 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/10/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 9000 | ATG Test Date | 04/10/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| | | Overfill Test Date | 04/10/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 03 | Tank Age | 8 | Tank Installed Date | 06/21/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5816 | Spill Test Date | 07/25/2024 | Piping Installed Date | 06/24/2018 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/10/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 04/10/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/10/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: SILVER SLIPPER
4055 Hwy 93 S
Missoula, MT 59804-7300 Missoula

System Facility ID:32-13711

Facility Code: 25780
Last Inspected On: 08/18/2023
Operating Permit Renewal Date: 08/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Noah Castle;Preslyn LLC (406) 251-5402 noahcastle@hotmail.com

Operator Contact: Melissa Rausch (406) 253-4921 thesilverslippermissoula@gmail.com

Owner/Operator: Noah Castle (406) 251-5402 noahcastle@hotmail.com
Owner/Operator: Preslyn LLC (406) 251-5402 noahcastle@hotmail.com
Melissa Rausch, UST Class A Operator thesilverslippermissoula@gmail.com
Melissa Rausch, UST Class B Operator thesilverslippermissoula@gmail.com

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 30 | Tank Installed Date | 03/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 3251 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 30 | Tank Installed Date | 03/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 3252 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 30 | Tank Installed Date | 03/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 3253 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: SORENSEN TRANSPORT
6575 US Hwy 10 W
Missoula, MT 59808-9086 Missoula

System Facility ID:32-13428

Facility Code: 25748
Last Inspected On: 05/30/2024
Operating Permit Renewal Date: 10/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sorensen Transport (406) 721-5404 jake@sorco-inc.com

Operator Contact: Lane Sorensen (406) 721-5404 Isorensen@trans-system.com

Owner/Operator: Sorensen Transport (406) 721-5404 jake@sorco-inc.com

Lane Sorensen, UST Class A Operator

Isorensen@trans-system.com

Lane Sorensen, UST Class B Operator

Isorensen@trans-system.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 02 | Tank Age | 11 | Tank Installed Date | 06/04/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5576 | Spill Test Date | 05/30/2024 | Piping Installed Date | 06/04/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/30/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 05/30/2024 | Line Tightness Test Date | 06/03/2015 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 05/30/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: SOUTH AVENUE MARKET #11
2401 S Higgins Ave
Missoula, MT 59801 Missoula

System Facility ID:32-05764

Facility Code: 25381
Last Inspected On: 10/29/2025
Operating Permit Renewal Date: 02/19/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Operator Contact: Manpreet Singh;Hi-Star Properties LLC (509) 994-6599;(509) 994-6599 sbasm065@gmail.com;histarms3@yahoo.com

Owner/Operator: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Manpreet Singh, UST Class A Operator

histarms3@yahoo.com

Manpreet Singh, UST Class B Operator

histarms3@yahoo.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 02 | Tank Age | 45 | Tank Installed Date | 04/26/1981 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3849 | Spill Test Date | 11/05/2024 | Piping Installed Date | 07/21/2000 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 10/29/2025 | Tank/Piping CP Test Date | 11/05/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/29/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/05/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 03 | Tank Age | 45 | Tank Installed Date | 04/26/1981 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3850 | Spill Test Date | 11/05/2024 | Piping Installed Date | 07/21/2000 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 10/29/2025 | Tank/Piping CP Test Date | 11/05/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/29/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/05/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 45 | Tank Installed Date | 04/26/1981 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4668 | Spill Test Date | 11/05/2024 | Piping Installed Date | 07/21/2000 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 02/21/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 10/29/2025 | Tank/Piping CP Test Date | 11/05/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/29/2025 | Line Tightness Test Date | 02/21/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/05/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: SOUTHGATE MARKET
1900 South Ave W
Missoula, MT 59801-6508 Missoula

System Facility ID:32-08862

Facility Code: 25477
Last Inspected On: 01/26/2024
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Inc DBA Southgate Market (406) 549-1750 jaysfood08@yahoo.com

Operator Contact: Jagpreet Ghuman;Jays 1 Stop;Jaspal Sandhu;Jays Corporation (406) 549-1750;(406) 880-7677;(406) 549-1031 jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com;jays1stop21@outlook.com

Owner/Operator: Jays Inc DBA Southgate Market (406) 549-1750 jaysfood08@yahoo.com
Jagpreet Ghuman, UST Class A Operator jays1stop21@outlook.com
Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 41 | Tank Installed Date | 12/23/1985 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1354 | Spill Test Date | 01/25/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 01/25/2024 | Tank/Piping CP Test Date | 01/25/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 01/25/2024 | Line Tightness Test Date | 01/28/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 01/25/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 41 | Tank Installed Date | 12/23/1985 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1355 | Spill Test Date | 01/25/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 01/25/2024 | Tank/Piping CP Test Date | 01/25/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 01/25/2024 | Line Tightness Test Date | 01/28/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 01/25/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 03 | Tank Age | 41 | Tank Installed Date | 12/23/1985 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1356 | Spill Test Date | 01/25/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 01/25/2024 | Tank/Piping CP Test Date | 01/25/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 01/25/2024 | Line Tightness Test Date | 01/28/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 01/25/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: SPRINT MISSOULA POP
2515 Railroad St W
Missoula, MT 59808-1680 Missoula

System Facility ID:56-14010

Facility Code: 30670
Last Inspected On: 04/18/2023
Operating Permit Renewal Date: 08/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sprint Communications Co LLP (913) 762-5957

Operator Contact: Brian Schmitt;Brian Wiedower (913) 315-8631 brian.c.wiedower@sprint.com;brian.schmitt@bolininc.com

Owner/Operator: Sprint Communications Co LLP (913) 762-5957

Brian Schmitt, UST Class A Operator
Brian Schmitt, UST Class B Operator
Brian Wiedower, UST Class A Operator
Matt Santee, UST Class B Global Operator
Scott Hallesy, UST Class B Operator

brian.schmitt@bolininc.com
brian.schmitt@bolininc.com
brian.c.wiedower@sprint.com
matt.santee@bolininc.com
scott.g.hallesy@sprint.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|---|----------------|--------------------------------|
| Tank Code | 01 | Tank Age | 25 | Tank Installed Date | 06/01/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 4321 | Spill Test Date | 03/13/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | 3-Year Line Tightness Test;Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2500 | ATG Test Date | 04/24/2024 | Line Tightness Test Date | 04/18/2023 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/18/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: ST PATRICKS HOSPITAL
500 W Broadway St
Missoula, MT 59802-4008 Missoula

System Facility ID:32-04266

Facility Code: 25338
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 05/29/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|-------------------------|-------------------------|
| Owner Operator Contact: | Saint Patricks Hospital | (406) 543-7271 |
| Operator Contact: | Timothy Chopp | tchopp@saintpatrick.org |

| | | |
|-----------------|-------------------------------------|-------------------------|
| Owner/Operator: | Saint Patricks Hospital | (406) 543-7271 |
| | Timothy Chopp, UST Class A Operator | tchopp@saintpatrick.org |
| | Timothy Chopp, UST Class B Operator | tchopp@saintpatrick.org |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 03 | Tank Age | 25 | Tank Installed Date | 10/01/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 4497 | Spill Test Date | 11/06/2023 | Piping Installed Date | 02/29/2008 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/06/2023 | Line Tightness Test Date | 11/06/2023 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/06/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300 | | | | |
| Tank Code | 04 | Tank Age | 18 | Tank Installed Date | 07/18/2008 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm;Positive Shutoff |
| Tag Number | 5175 | Spill Test Date | 11/06/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |

| | | | | | | | | | | | |
|----------|-------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|------------|-----|
| Capacity | 10000 | ATG Test Date | 11/06/2023 | Line Tightness Test Date | 11/06/2023 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 11/06/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: STAR TRAVEL PLAZA
5318 W Harrier
Missoula, MT 59801 Missoula

System Facility ID:60-15010

Facility Code: 30800
Last Inspected On: 02/07/2024
Operating Permit Renewal Date: 04/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Manpreet Singh;Hi-Star Properties LLC (509) 994-6599;(509) 994-6599 sbsm065@gmail.com;histarms3@yahoo.com

Operator Contact: Dean Clinkenbeard;Sheri Taylor (406) 543-8885 office.dcp@bresnan.net;office.dcp@gmail.com

Owner/Operator: Manpreet Singh,Hi-Star Properties LLC (509) 994-6599 sbsm065@gmail.com
Dean Clinkenbeard, UST Class A Operator office.dcp@bresnan.net
Dean Clinkenbeard, UST Class B Global Operator office.dcp@bresnan.net
Sheri Taylor, UST Class A Operator office.dcp@gmail.com
Sheri Taylor, UST Class B Operator office.dcp@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 20 | Tank Installed Date | 01/17/2006 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5027 | Spill Test Date | 01/10/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/17/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 11/17/2023 | Line Tightness Test Date | 09/10/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 01/10/2024 | | | ATG Type | Gilbarco/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 20 | Tank Installed Date | 01/17/2006 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5028 | Spill Test Date | 01/10/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/17/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 11/17/2023 | Line Tightness Test Date | 02/07/2018 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 01/10/2024 | | | ATG Type | Gilbarco/TLS-350 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 20 | Tank Installed Date | 01/17/2006 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5029 | Spill Test Date | 01/10/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/17/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 11/17/2023 | Line Tightness Test Date | 02/07/2018 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 01/10/2024 | | | ATG Type | Gilbarco/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: STAR TRAVEL PLAZA 2
5055 N Reserve St
Missoula, MT 59808-1401 Missoula

System Facility ID:32-03610

Facility Code: 25301
Last Inspected On: 10/30/2025
Operating Permit Renewal Date: 12/21/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|---|-------------------------------|---|
| Owner Operator Contact: | Manpreet Singh;Hi-Star Properties LLC | (509) 994-6599;(509) 994-6599 | sbsm065@gmail.com;histarms3@yahoo.com |
| Operator Contact: | Jeffrey Toole;Hi Star Properties LLC;Sheri Taylor | (406) 543-8885 | histar.jeff@gmail.com;jaysmart09@yahoo.com;office.dcp@gmail.com |

| | | | |
|-----------------|---------------------------------------|----------------|----------------------|
| Owner/Operator: | Manpreet Singh,Hi-Star Properties LLC | (509) 994-6599 | sbsm065@gmail.com |
| | Jeffrey Toole, UST Class A Operator | | jaysmart09@yahoo.com |
| | Jeffrey Toole, UST Class B Operator | | jaysmart09@yahoo.com |
| | Sheri Taylor, UST Class A Operator | | office.dcp@gmail.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|---------------|
| Tank Code | 06 | Tank Age | 35 | Tank Installed Date | 04/02/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 795 | Spill Test Date | 10/14/2025 | Piping Installed Date | 06/22/2007 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 10/14/2025 | Tank/Piping CP Test Date | 10/16/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/14/2025 | Line Tightness Test Date | 07/22/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/14/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 35 | Tank Installed Date | 04/02/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 796 | Spill Test Date | 10/14/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 10/14/2025 | Tank/Piping CP Test Date | 10/16/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/14/2025 | Line Tightness Test Date | 07/23/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/14/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|---------------|
| Tank Code | 08 | Tank Age | 35 | Tank Installed Date | 04/02/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 797 | Spill Test Date | 10/14/2025 | Piping Installed Date | 06/22/2007 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 10/14/2025 | Tank/Piping CP Test Date | 10/16/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/14/2025 | Line Tightness Test Date | 07/23/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/14/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 35 | Tank Installed Date | 04/02/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 798 | Spill Test Date | 10/14/2025 | Piping Installed Date | 06/22/2007 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 10/14/2025 | Tank/Piping CP Test Date | 10/16/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/14/2025 | Line Tightness Test Date | 07/25/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/14/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 10 | Tank Age | 35 | Tank Installed Date | 04/02/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 799 | Spill Test Date | 10/14/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 10/14/2025 | Tank/Piping CP Test Date | 10/16/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/14/2025 | Line Tightness Test Date | 08/22/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/14/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: TA MISSOULA
8018 US Hwy 93 N
Missoula, MT 59808 Missoula

System Facility ID:32-02822

Facility Code: 25272
Last Inspected On: 08/17/2023
Operating Permit Renewal Date: 10/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|--|--|---|
| Owner Operator Contact: | MISSOULA HOLDINGS MT, LLC | (702) 522-8513 | VAL@LVPETROLEUM.NET |
| Operator Contact: | Ben Waverek;TA Operating LLC;Daniel Stubbs;TA Operating LLC;Kelly Gelske | (406) 549-2327;(440) 808-7406;(440) 522-6761 | bwaverek@ta-petro.com;skulkarni3@ta-petro.com;dstubbs@ta-petro.com;skulkarni3@ta-petro.com;kgelske@ta-petro.com |

| | | | |
|-----------------|---|----------------|-------------------------|
| Owner/Operator: | MISSOULA HOLDINGS MT, LLC | (702) 522-8513 | VAL@LVPETROLEUM.NET |
| | Ben Waverek, UST Class A Operator | | skulkarni3@ta-petro.com |
| | Ben Waverek, UST Class B Operator | | skulkarni3@ta-petro.com |
| | Daniel Stubbs, UST Class A Operator | | skulkarni3@ta-petro.com |
| | Daniel Stubbs, UST Class B Operator | | skulkarni3@ta-petro.com |
| | Kelly Gelske, UST Class A Operator | | kgelske@ta-petro.com |
| | Kelly Gelske, UST Class B Global Operator | | kgelske@ta-petro.com |

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 13 | Tank Age | 12 | Tank Installed Date | 08/22/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5511 | Spill Test Date | | Piping Installed Date | 07/29/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Pressurized | CP Met Types | |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Not Listed | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-4I, B, C | | | | |
| Tank Code | 14 | Tank Age | 11 | Tank Installed Date | 02/24/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 5550 | Spill Test Date | | Piping Installed Date | 09/18/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Oil, Motor | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| Capacity | 8000 | ATG Test Date | 08/14/2025 | Line Tightness Test Date | 03/12/2015 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 15 | Tank Age | 11 | Tank Installed Date | 02/24/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 5551 | Spill Test Date | | Piping Installed Date | 09/18/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Gravity Feed | CP Met Types | Non-corrodible |
| Product | Oil, Waste | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 08/14/2025 | Line Tightness Test Date | 03/12/2015 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 16 | Tank Age | 7 | Tank Installed Date | 07/31/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5929 | Spill Test Date | 06/03/2025 | Piping Installed Date | 07/31/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/30/2020 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 04/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | MLLD Line Tightness Testing | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 48 | Tank Installed Date | 02/17/1978 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 786 | Spill Test Date | 02/01/2024 | Piping Installed Date | 08/22/2014 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/16/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 07/18/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|-------------------|
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 03 | Tank Age | 48 | Tank Installed Date | 02/17/1978 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 787 | Spill Test Date | 06/03/2025 | Piping Installed Date | 08/22/2014 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/19/2021 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/16/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 05/19/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 09 | Tank Age | 33 | Tank Installed Date | 11/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 788 | Spill Test Date | | Piping Installed Date | 08/22/2014 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 04/30/2020 | Tank/Piping CP Test Date | 05/16/2020 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 04/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 10 | Tank Age | 33 | Tank Installed Date | 11/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 789 | Spill Test Date | | Piping Installed Date | 08/22/2014 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/16/2020 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 08/04/2014 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 11 | Tank Age | 33 | Tank Installed Date | 11/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 790 | Spill Test Date | | Piping Installed Date | 11/03/2010 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 04/30/2020 | Tank/Piping CP Test Date | 05/16/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 04/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 12 | Tank Age | 33 | Tank Installed Date | 11/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 791 | Spill Test Date | | Piping Installed Date | 11/03/2010 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 04/30/2020 | Tank/Piping CP Test Date | 05/16/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 04/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Missoula County in the City of Missoula

| | | | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|--|--|--|
| Location: TABISH BROTHERS DISTRIBUTORS INC 501 Taylor St Missoula, MT 59802-4920 Missoula | | | | | | Facility Code: 25407 Last Inspected On: 06/20/2023 Operating Permit Renewal Date: 06/22/2026 | | | | | |
| System Facility ID:32-06523 | | | | | | Note: Inspection is due 90 days before the Operating Permit Renewal Date. | | | | | |
| Owner Operator Contact: Tabish Brothers Distributors Inc | | | | | | lss@gwpetrol.com | | | | | |
| Operator Contact: Heather Stiles | | | | | | hstiles@gwpetrol.com | | | | | |
| Owner/Operator: Tabish Brothers Distributors Inc | | | | | | lss@gwpetrol.com | | | | | |
| Heather Stiles, UST Class A Operator | | | | | | hstiles@gwpetrol.com | | | | | |
| Heather Stiles, UST Class B Global Operator | | | | | | hstiles@gwpetrol.com | | | | | |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 45 | Tank Installed Date | 04/16/1981 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2080 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Heating Oil | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 7600 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 45 | Tank Installed Date | 04/16/1981 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2081 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Gravity Feed | CP Met Types | Non-corrodible |
| Product | Oil, Waste | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 7600 | ATG Test Date | 06/20/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | | |
|--|--|--------------------|--|--|--|----------|--|--|--|--|--|
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |
|--|--|--------------------|--|--|--|----------|--|--|--|--|--|

Facility Summary in Missoula County in the City of Missoula

Location: THE OLDE DAIRY
2106 Clements Rd
Missoula, MT 59804-6212 Missoula

System Facility ID:32-08475

Facility Code: 25464
Last Inspected On: 08/16/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dale Johnson;Target Range Development LLC (406) 721-3322;(406) 721-3323 mark@theolde dairy.com

Operator Contact: Jessica Rogers;Target Range Development LLC (406) 721-3323 jessica@theolde dairy.com;mark@theolde dairy.com

Owner/Operator: Dale L Johnson (406) 721-3322
Owner/Operator: Target Range Development LLC (406) 721-3322
Jessica Rogers, UST Class A Operator mark@theolde dairy.com
Jessica Rogers, UST Class B Operator mark@theolde dairy.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 05 | Tank Age | 27 | Tank Installed Date | 03/23/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4086 | Spill Test Date | 08/16/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 10/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 10/01/2025 | | | ATG Type | Gilbarco-Veeder Root/EMC Basic | | | | |
| Tank Code | 06 | Tank Age | 27 | Tank Installed Date | 03/23/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4087 | Spill Test Date | 08/16/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/14/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/01/2025 | Line Tightness Test Date | 02/01/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| | | Overfill Test Date | 10/01/2025 | | | ATG Type | Gilbarco-Veeder Root/EMC Basic | | | | |
| Tank Code | 07 | Tank Age | 27 | Tank Installed Date | 03/23/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4088 | Spill Test Date | 08/16/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 10/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 10/01/2025 | | | ATG Type | Gilbarco-Veeder Root/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 1
5310 Grant Creek Rd
Missoula, MT 59808-1483 Missoula

System Facility ID:32-13336

Facility Code: 25739
Last Inspected On: 06/09/2023
Operating Permit Renewal Date: 10/28/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|--------------------------|----------------|----------------------------|
| Owner Operator Contact: | Missoula 1 Town Pump LLC | (406) 497-6700 | environmental@townpump.com |
| Operator Contact: | Trent Biggers | | Trentb@townpump.com |

| | | | |
|-----------------|--|----------------|----------------------------|
| Owner/Operator: | Missoula 1 Town Pump LLC | (406) 497-6700 | environmental@townpump.com |
| | Trent Biggers, UST Class A Operator | | Trentb@townpump.com |
| | Trent Biggers, UST Class B Global Operator | | Trentb@townpump.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 33 | Tank Installed Date | 12/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2342 | Spill Test Date | 08/25/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 05/04/2021 | Tank/Piping CP Test Date | 03/19/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 33 | Tank Installed Date | 12/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2343 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 05/04/2021 | Tank/Piping CP Test Date | 03/19/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 33 | Tank Installed Date | 12/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2344 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 05/04/2021 | Tank/Piping CP Test Date | 03/19/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | Yes |
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 04 | Tank Age | 33 | Tank Installed Date | 12/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2345 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 05/04/2021 | Tank/Piping CP Test Date | 03/19/2019 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 05 | Tank Age | 17 | Tank Installed Date | 01/25/2009 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5196 | Spill Test Date | | Piping Installed Date | 01/25/2009 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 05/04/2021 | Tank/Piping CP Test Date | 01/11/2010 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 06 | Tank Age | 17 | Tank Installed Date | 01/25/2009 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5197 | Spill Test Date | | Piping Installed Date | 01/25/2009 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |

| | | | | | | | | | | | |
|----------|----------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----|
| Product | Gasoline | PLLD Test Date | 05/04/2021 | Tank/Piping CP Test Date | 01/11/2010 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 3
2210 N Reserve St
Missoula, MT 59808-1323 Missoula

System Facility ID:32-13172

Facility Code: 25725
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Missoula 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2559 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/05/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 09/22/2006 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2560 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/05/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 09/22/2006 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2561 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/05/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 09/30/2006 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 04 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2562 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/05/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 09/30/2006 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 05 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2563 | Spill Test Date | 10/04/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/05/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 09/30/2006 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 10/04/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 8
3420 Mullan Rd Ste A
Missoula, MT 59808-5126 Missoula

System Facility ID:56-13823

Facility Code: 30509
Last Inspected On: 01/07/2026
Operating Permit Renewal Date: 06/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|--------------------------|----------------|----------------------------|
| Owner Operator Contact: | Missoula 8 Town Pump LLC | (406) 497-6700 | environmental@townpump.com |
| Operator Contact: | Trent Biggers | | Trentb@townpump.com |

| | | | |
|-----------------|--|----------------|----------------------------|
| Owner/Operator: | Missoula 8 Town Pump LLC | (406) 497-6700 | environmental@townpump.com |
| | Trent Biggers, UST Class A Operator | | Trentb@townpump.com |
| | Trent Biggers, UST Class B Global Operator | | Trentb@townpump.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 29 | Tank Installed Date | 08/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1444 | Spill Test Date | 07/18/2022 | Piping Installed Date | 05/24/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/21/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 06/21/2023 | Line Tightness Test Date | 05/05/2016 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 07/18/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 29 | Tank Installed Date | 08/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1445 | Spill Test Date | 07/18/2022 | Piping Installed Date | 05/24/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/21/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 06/21/2023 | Line Tightness Test Date | 05/18/2016 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 07/18/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 29 | Tank Installed Date | 08/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1446 | Spill Test Date | 07/18/2022 | Piping Installed Date | 05/24/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/21/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 06/21/2023 | Line Tightness Test Date | 05/17/2016 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 07/18/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 04 | Tank Age | 10 | Tank Installed Date | 05/24/2016 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5629 | Spill Test Date | 07/18/2022 | Piping Installed Date | 05/24/2016 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/21/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 06/21/2023 | Line Tightness Test Date | 05/18/2016 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/18/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

| | | | | | | | |
|---|--|--|--|--|--|--|--|
| Location: TOWN PUMP MISSOULA 9 2001 Brooks St Missoula, MT 59808 Missoula | | | | Facility Code: 30995 Last Inspected On: 01/07/2026 Operating Permit Renewal Date: 06/22/2026 | | | |
| System Facility ID:60-15288 | | | | Note: Inspection is due 90 days before the Operating Permit Renewal Date. | | | |
| Owner Operator Contact: Missoula 9 Town Pump LLC | | | | (406) 497-6700 | | | |
| | | | | environmental@townpump.com | | | |
| Operator Contact: Trent Biggers | | | | Trentb@townpump.com | | | |

Owner/Operator: Missoula 9 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 9 | Tank Installed Date | 03/28/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5683 | Spill Test Date | 07/12/2022 | Piping Installed Date | 03/28/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 25000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/12/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 02 | Tank Age | 9 | Tank Installed Date | 03/28/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5684 | Spill Test Date | 07/12/2022 | Piping Installed Date | 03/28/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 15000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/12/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 03 | Tank Age | 9 | Tank Installed Date | 03/28/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5685 | Spill Test Date | 07/12/2022 | Piping Installed Date | 03/28/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/12/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: UNITED PARCEL SERVICES MISSOULA
221 Expressway Ln
Missoula, MT 59808-1553 Missoula

System Facility ID:32-04536

Facility Code: 25343
Last Inspected On: 07/17/2025
Operating Permit Renewal Date: 10/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: United Parcel Service Inc Seattle cdd6jxd@ups.com

Operator Contact: Dino Ostrow;Jonathan Dunbar;United Parcel Service Inc Seattle (503) 329-7154 dostrow@ups.com;jxdunbar@ups.com;cdd6jxd@ups.com

Owner/Operator: United Parcel Service Inc Seattle cdd6jxd@ups.com
Dino Ostrow, UST Class A Operator dostrow@ups.com
Dino Ostrow, UST Class B Operator dostrow@ups.com
Jonathan Dunbar, UST Class A Operator cdd6jxd@ups.com
Jonathan Dunbar, UST Class B Operator cdd6jxd@ups.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 04 | Tank Age | 33 | Tank Installed Date | 07/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2182 | Spill Test Date | 04/28/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/28/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/28/2025 | Line Tightness Test Date | 04/28/2025 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/28/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: WESTERN TRANSPORT
9310 Cartage Rd
Missoula, MT 59808-9758 Missoula

System Facility ID:32-01348

Facility Code: 25211
Last Inspected On: 04/17/2025
Operating Permit Renewal Date: 04/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | | | |
|--|--|--|--------------------------|--|--|
| Owner Operator Contact: Western Land Investments LLC | | | (307) 674-6305 | | |
| Operator Contact: Cari Goss | | | (307) 674-6305 | | |
| | | | cari@westerntransllc.com | | |

| | | | | | |
|--|--|--|--------------------------|--|--|
| Owner/Operator: Western Land Investments LLC | | | (307) 674-6305 | | |
| Cari Goss, UST Class A Operator | | | cari@westerntransllc.com | | |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 58 | Tank Installed Date | 01/17/1968 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 1654 | Spill Test Date | 09/29/2021 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Single Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/26/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/30/2021 | Line Tightness Test Date | 09/12/2012 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-250 | | | | |
| Tank Code | 02 | Tank Age | 58 | Tank Installed Date | 01/17/1968 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1655 | Spill Test Date | 09/29/2021 | Piping Installed Date | 12/11/2006 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Single Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | 03/22/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/26/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/30/2021 | Line Tightness Test Date | 03/22/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-250 | | | | |
| Tank Code | 03 | Tank Age | 45 | Tank Installed Date | 01/16/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|--|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-----------------------------|----------------|-------------------|
| Tag Number | 1656 | Spill Test Date | | Piping Installed Date | 12/11/2006 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Single Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/26/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 05/27/2010 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-250 | | | | |

Facility Summary in Missoula County in the City of Missoula

| | | | | | |
|--|--|--|--|--|--|
| Location: WESTFIELD MISSOULA 8448 US Hwy 10 W Missoula, MT 59808-9319 Missoula | | | Facility Code: 25776 Last Inspected On: 05/01/2023 Operating Permit Renewal Date: 07/22/2026 | | |
| System Facility ID:32-13674 | | | Note: Inspection is due 90 days before the Operating Permit Renewal Date. | | |
| Owner Operator Contact: Finest Oil Co | | | (406) 543-6969 finestoil@finest-oil.com | | |
| Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson | | | (406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926 chrisglasser@hotmail.com;finestoil@finest-oil.com;jepin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com | | |
| Owner/Operator: Finest Oil Co | | | (406) 543-6969 finestoil@finest-oil.com | | |
| Christopher Glasser, UST Class A Operator | | | chrisglasser@hotmail.com | | |
| David Peyton, UST Class A Operator | | | | | |
| David Peyton, UST Class B Global Operator | | | | | |
| James Brady, UST Class A Operator | | | jepin247.jb@gmail.com | | |
| James DeWaters, UST Class A Operator | | | rivban22@gmail.com | | |
| Joseph McClain, UST Class B Operator | | | jgmccclain25@gmail.com | | |
| Justin Gaudot, UST Class A Operator | | | justgaudot@yahoo.com | | |
| Justin Gaudot, UST Class B Global Operator | | | justgaudot@yahoo.com | | |
| Stephen Hanson, UST Class A Operator | | | finestoil@finest-oil.com | | |
| Stephen Hanson, UST Class B Operator | | | finestoil@finest-oil.com | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 31 | Tank Installed Date | 12/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1077 | Spill Test Date | 04/28/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/28/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 04/28/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/28/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 31 | Tank Installed Date | 12/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1078 | Spill Test Date | 04/28/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|---------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/28/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 04/28/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/28/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 31 | Tank Installed Date | 12/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1079 | Spill Test Date | 04/28/2023 | Piping Installed Date | 09/19/2007 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/28/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 04/28/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/28/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 04 | Tank Age | 31 | Tank Installed Date | 12/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1080 | Spill Test Date | 04/28/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/28/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 04/28/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/28/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 31 | Tank Installed Date | 12/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1081 | Spill Test Date | 04/28/2023 | Piping Installed Date | 05/17/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/28/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|---------------|
| Capacity | 12000 | ATG Test Date | 04/28/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/28/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 31 | Tank Installed Date | 12/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1082 | Spill Test Date | 04/28/2023 | Piping Installed Date | 05/17/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/28/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/25/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/28/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: YOKES FRESH MARKET 21
800 W Broadway St
Missoula, MT 59802-3944 Missoula

System Facility ID:60-15098

Facility Code: 30858
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 06/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|---|-------------------------------|--|
| Owner Operator Contact: | YOKE'S FOOD INC | (509) 921-2292 | |
| Operator Contact: | Rebecca Spicer;Rich Thornock;Shari Goodmanson | (406) 251-7170;(406) 721-2549 | fuelmgr21@yokesfoods.com;MRMBR@YOKESFOODS.COM;sgoodmanson@yokesfoods.com |

| | | | |
|-----------------|---|----------------|----------------------------|
| Owner/Operator: | YOKE'S FOOD INC | (509) 921-2292 | |
| | Rebecca Spicer, UST Class A Operator | | fuelmgr21@yokesfoods.com |
| | Rebecca Spicer, UST Class B Operator | | fuelmgr21@yokesfoods.com |
| | Rich Thornock, UST Class A Operator | | MRMBR@YOKESFOODS.COM |
| | Rich Thornock, UST Class B Operator | | MRMBR@YOKESFOODS.COM |
| | Shari Goodmanson, UST Class A Operator | | sgoodmanson@yokesfoods.com |
| | Shari Goodmanson, UST Class B Global Operator | | sgoodmanson@yokesfoods.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 18 | Tank Installed Date | 08/08/2008 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5167 | Spill Test Date | 10/01/2024 | Piping Installed Date | 07/01/2008 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/09/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/09/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 18 | Tank Installed Date | 08/01/2008 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5168 | Spill Test Date | 10/01/2024 | Piping Installed Date | 07/01/2008 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/09/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|------------------|
| Capacity | 10000 | ATG Test Date | 04/09/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 18 | Tank Installed Date | 08/01/2008 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5169 | Spill Test Date | 04/09/2024 | Piping Installed Date | 07/01/2008 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 04/09/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/09/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/01/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;OPW / EMCO/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: YOKES FRESH MARKET 22
3801 S Reserve St
Missoula, MT 59801-7322 Missoula

System Facility ID:56-14025

Facility Code: 30684
Last Inspected On: 10/14/2025
Operating Permit Renewal Date: 01/04/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | | | |
|---|--|--|--|--|--|
| Owner Operator Contact: YOKE'S FOOD INC | | | (509) 921-2292 | | |
| Operator Contact: Brittany Zeller;Charles Franklin;Jason Rhinehart;YOKE'S FOOD INC;Shari Goodmanson | | | (406) 251-3311;(406) 251-7170;(509) 921-2292 | | |
| | | | mrasst@yokesfoods.com;MRMGR@YOKESFOODS.COM;pipsnchi ps2@gmail.com;sgoodmanson@yokesfoods.com | | |

Owner/Operator: YOKE'S FOOD INC (509) 921-2292

Brittany Zeller, UST Class A Operator
Charles Franklin, UST Class A Operator
Charles Franklin, UST Class B Global Operator
Jason Rhinehart, UST Class A Operator
Shari Goodmanson, UST Class A Operator
Shari Goodmanson, UST Class B Global Operator

MRMGR@YOKESFOODS.COM
pipsnchips2@gmail.com
pipsnchips2@gmail.com
mrasst@yokesfoods.com
sgoodmanson@yokesfoods.com
sgoodmanson@yokesfoods.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| Tank Code | 01 | Tank Age | 25 | Tank Installed Date | 09/01/2001 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4416 | Spill Test Date | 08/28/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/28/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 08/28/2025 | Line Tightness Test Date | 01/16/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/28/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 25 | Tank Installed Date | 09/01/2001 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4417 | Spill Test Date | 08/28/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|-----------------------------------|
| Product | Gasoline | PLLD Test Date | 08/28/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/28/2025 | Line Tightness Test Date | 01/17/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/28/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 03 | Tank Age | 25 | Tank Installed Date | 09/01/2001 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 4418 | Spill Test Date | 08/28/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/28/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/28/2025 | Line Tightness Test Date | 07/09/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/28/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 31
3325 Brooks St
Missoula, MT 59801-8289 Missoula

System Facility ID:32-09730

Facility Code: 25516
Last Inspected On: 02/05/2025
Operating Permit Renewal Date: 05/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|------------------------|-------------------------------|--|
| Owner Operator Contact: | CHS Inc Spokane Valley | (509) 535-7701 | jim.alford@chsinc.com |
| Operator Contact: | Jim Alford;Sean Hurley | (509) 535-7701;(509) 536-7418 | jim.alford@chsinc.com;sean.hurley@chsinc.com |

| | | | |
|-----------------|-------------------------------------|----------------|---------------------------|
| Owner/Operator: | CHS Inc Spokane Valley | (509) 535-7701 | jim.alford@chsinc.com |
| | Jason Brenner, UST Class B Operator | | jason.brenner@chsinc.com |
| | Jim Alford, UST Class A Operator | | jim.alford@chsinc.com |
| | Jim Alford, UST Class B Operator | | jim.alford@chsinc.com |
| | Luci Tuttle, UST Class B Operator | | Lucinda.Tuttle@chsinc.com |
| | Sean Hurley, UST Class A Operator | | sean.hurley@chsinc.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-----------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 38 | Tank Installed Date | 03/18/1988 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1363 | Spill Test Date | 02/05/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 08/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 08/04/2010 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/06/2024 | Line Tightness Test Date | 08/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/06/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 38 | Tank Installed Date | 03/18/1988 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1364 | Spill Test Date | 02/05/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 08/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/06/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/06/2024 | Line Tightness Test Date | 08/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--------------------------------|----------------|----------------|
| | | Overfill Test Date | 02/05/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 38 | Tank Installed Date | 03/18/1988 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1365 | Spill Test Date | 02/05/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 08/06/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/04/2010 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/06/2024 | Line Tightness Test Date | 08/06/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 02/05/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 32
1540 Toole Ave
Missoula, MT 59802-2241 Missoula

System Facility ID:32-03912

Facility Code: 25317
Last Inspected On: 11/06/2025
Operating Permit Renewal Date: 02/04/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|------------------------|-------------------------------|--|
| Owner Operator Contact: | CHS Inc Spokane Valley | (509) 535-7701 | jim.alford@chsinc.com |
| Operator Contact: | Jim Alford;Sean Hurley | (509) 535-7701;(509) 536-7418 | jim.alford@chsinc.com;sean.hurley@chsinc.com |

| | | | |
|-----------------|-------------------------------------|----------------|---------------------------|
| Owner/Operator: | CHS Inc Spokane Valley | (509) 535-7701 | jim.alford@chsinc.com |
| | Jason Brenner, UST Class B Operator | | jason.brenner@chsinc.com |
| | Jim Alford, UST Class A Operator | | jim.alford@chsinc.com |
| | Jim Alford, UST Class B Operator | | jim.alford@chsinc.com |
| | Luci Tuttle, UST Class B Operator | | Lucinda.Tuttle@chsinc.com |
| | Sean Hurley, UST Class A Operator | | sean.hurley@chsinc.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 42 | Tank Installed Date | 03/22/1984 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1342 | Spill Test Date | 11/06/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 08/04/2025 | Tank/Piping CP Test Date | 11/06/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/04/2025 | Line Tightness Test Date | 07/27/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/06/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 42 | Tank Installed Date | 03/22/1984 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1343 | Spill Test Date | 11/06/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 08/04/2025 | Tank/Piping CP Test Date | 11/06/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/04/2025 | Line Tightness Test Date | 07/27/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|---------------|
| | | Overfill Test Date | 11/06/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 42 | Tank Installed Date | 03/22/1984 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1344 | Spill Test Date | 11/06/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 08/04/2025 | Tank/Piping CP Test Date | 11/06/2025 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/04/2025 | Line Tightness Test Date | 07/27/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/06/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: ZOOTOVN SUPER STOP
2105 S Higgins Ave
Missoula, MT 59801-6714 Missoula

System Facility ID:32-07244

Facility Code: 25429
Last Inspected On: 12/20/2023
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|---|---|
| Owner Operator Contact: | Greg Tabish | zootown@gwpetrol.com |
| Operator Contact: | Daniel Marx;Erin Keffeler;Karly Shafer;Yvonne Bunch | (406) 274-2435;(406) 396-2206;(406) 880-0056 |
| | | DanielMarx@inmissoula.com;karly@gwpetrol.com;noons470@hi-noon.com;ybunch1@gmail.com |

| | | |
|-----------------|---|---------------------------|
| Owner/Operator: | Greg Tabish | zootown@gwpetrol.com |
| | Daniel Marx, UST Class A Operator | DanielMarx@inmissoula.com |
| | Daniel Marx, UST Class B Global Operator | DanielMarx@inmissoula.com |
| | Erin Keffeler, UST Class A Operator | noons470@hi-noon.com |
| | Erin Keffeler, UST Class B Operator | noons470@hi-noon.com |
| | Karly Shafer, UST Class A Operator | karly@gwpetrol.com |
| | Karly Shafer, UST Class B Global Operator | karly@gwpetrol.com |
| | Yvonne Bunch, UST Class A Operator | ybunch1@gmail.com |
| | Yvonne Bunch, UST Class B Operator | ybunch1@gmail.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 36 | Tank Installed Date | 12/07/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1799 | Spill Test Date | 12/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 12/20/2023 | Tank/Piping CP Test Date | 12/20/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 12/20/2023 | Line Tightness Test Date | 07/13/2011 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/20/2023 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 04 | Tank Age | 36 | Tank Installed Date | 12/07/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1800 | Spill Test Date | 12/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 12/20/2023 | Tank/Piping CP Test Date | 12/20/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|------------------|
| Capacity | 6000 | ATG Test Date | 12/20/2023 | Line Tightness Test Date | 07/13/2011 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/20/2023 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 12/07/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1801 | Spill Test Date | 12/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 12/20/2023 | Tank/Piping CP Test Date | 12/20/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 12/20/2023 | Line Tightness Test Date | 07/13/2011 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/20/2023 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Missoula County in the City of Missoula

Location: ZOOTOVN SUPER STOP 2
2125 S Higgins Ave
Missoula, MT 59801-6760 Missoula

System Facility ID:32-10053

Facility Code: 25541
Last Inspected On: 01/19/2024
Operating Permit Renewal Date: 01/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Western Petroleum (406) 728-7736

Operator Contact: Karly Shafer (406) 396-2206 karly@gwpetrol.com

Owner/Operator: Great Western Petroleum (406) 728-7736

Karly Shafer, UST Class A Operator
Karly Shafer, UST Class B Operator

karly@gwpetrol.com
karly@gwpetrol.com

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 09/30/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2139 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | 12/02/2020 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | 12/02/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |
| Tank Code | 09 | Tank Age | 36 | Tank Installed Date | 09/30/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2140 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | 12/02/2020 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | 12/02/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |
| Tank Code | 10 | Tank Age | 36 | Tank Installed Date | 09/30/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2141 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|---|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-----------------------------|----------------|----------------|
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 3000 | ATG Test Date | | Line Tightness Test Date | 10/15/2018 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |
| Tank Code | 11 | Tank Age | 0 | Tank Installed Date | | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 6200 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | | AST | No |
| Tank Status | Under Construction | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Seeley Lake

Location: 1 STOP SEELEY LAKE
3072 MT Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:32-09288

Facility Code: 25483
Last Inspected On: 04/10/2024
Operating Permit Renewal Date: 08/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | |
|-------------------------|------------------------|----------------|-----------------------|
| Owner Operator Contact: | MONTANA GAS N SHOP LLC | (510) 714-5045 | TONY@MONTANAGNS.COM |
| Operator Contact: | Gurinderbir Muhar | (408) 660-9884 | gasnshop133@gmail.com |

| | | | |
|-----------------|---|----------------|-----------------------|
| Owner/Operator: | MONTANA GAS N SHOP LLC | (510) 714-5045 | TONY@MONTANAGNS.COM |
| | Gurinderbir Muhar, UST Class A Operator | | gasnshop133@gmail.com |
| | Gurinderbir Muhar, UST Class B Operator | | gasnshop133@gmail.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|------------------|
| Tank Code | S1 | Tank Age | 39 | Tank Installed Date | 04/22/1987 | Tank Material | | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 416 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 10/17/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 10/17/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S2 | Tank Age | 39 | Tank Installed Date | 04/22/1987 | Tank Material | | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 417 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 10/17/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 10/17/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S3 | Tank Age | 39 | Tank Installed Date | 04/22/1987 | Tank Material | | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 418 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | Yes |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-----------------------------|----------------|----|
| Tank Status | Currently in Use | MLLD Test Date | 10/17/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 10/17/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Missoula County in the City of Seeley Lake

Location: LINDEYS LANDING WEST SPB
MT Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:32-05837

Facility Code: 25389
Last Inspected On: 06/24/2023
Operating Permit Renewal Date: 10/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lindeys Inc Saint Paul (406) 677-9229

Operator Contact: Michael Lindemer (406) 677-4101 lindeys@blackfoot.net

Owner/Operator: Lindeys Inc Saint Paul (406) 677-9229

Michael Lindemer, UST Class A Operator
Michael Lindemer, UST Class B Operator
Tanner Stevenson, UST Class B Global Operator

lindeys@blackfoot.net
lindeys@blackfoot.net
jenco1992@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | S3 | Tank Age | 27 | Tank Installed Date | 05/01/1999 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4104 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 06/06/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 1500 | ATG Test Date | 06/06/2025 | Line Tightness Test Date | 10/25/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Missoula County in the City of Seeley Lake

Location: ROVEROS
3182 Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:60-15146

Facility Code: 30890
Last Inspected On: 11/04/2025
Operating Permit Renewal Date: 01/28/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|--|--|
| Owner Operator Contact: | Greg Tabish;Tabish Brothers Distributors Inc | lss@gwpetrol.com;zootown@gwpetrol.com |
| Operator Contact: | Karly Shafer;Kyle Marx | (406) 396-2206;(406) 396-2296 |
| | | karly@gwpetrol.com;roversace@yahoo.com |

| | | |
|-----------------|---|----------------------|
| Owner/Operator: | Greg Tabish | zootown@gwpetrol.com |
| Owner/Operator: | Tabish Brothers Distributors Inc | zootown@gwpetrol.com |
| | Karly Shafer, UST Class A Operator | karly@gwpetrol.com |
| | Karly Shafer, UST Class B Global Operator | karly@gwpetrol.com |
| | Kyle Marx, UST Class A Operator | roversace@yahoo.com |
| | Kyle Marx, UST Class B Global Operator | roversace@yahoo.com |
| | RaeDean Bartlett, UST Class B Global Operator | raedean68@gmail.com |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------|----------------|----------------|
| Tank Code | 07 | Tank Age | 31 | Tank Installed Date | 04/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3337 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/25/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 7000 | ATG Test Date | 03/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 08 | Tank Age | 31 | Tank Installed Date | 04/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3338 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/25/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 03/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------|----------------|----------------|
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 09 | Tank Age | 31 | Tank Installed Date | 04/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3339 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/25/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 10 | Tank Age | 31 | Tank Installed Date | 04/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3340 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/25/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 11 | Tank Age | 31 | Tank Installed Date | 04/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3341 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 03/25/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 12 | Tank Age | 31 | Tank Installed Date | 04/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3342 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------|----------------|----------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/25/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 13 | Tank Age | 31 | Tank Installed Date | 04/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3343 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/25/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 03/25/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |