

Facility Summary in Missoula County in the City of Bonner

Location: POTOMAC BAR AND COUNTRY STORE
29344 MT Hwy 200 E
Bonner, MT 59823-9526 Missoula

System Facility ID:32-12400

Facility Code: 25677
Last Inspected On: 03/06/2026
Operating Permit Renewal Date: 04/19/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kenney Brown;Potomac Bar and Country Store, Inc;Potomac Bar and Country Store, Inc (406) 240-3863;(406) 240-3863;(406) 240-3863 kennybrown@blackfoot.net;kennybrown@blackfoot.net;kennybrown@blackfoot.net

Operator Contact: Christine Yednick potomacbar@outlook.com

Owner/Operator: Kenney Brown,Potomac Bar and Country Store, Inc (406) 240-3863 kennybrown@blackfoot.net

Owner/Operator: Potomac Bar and Country Store, Inc (406) 240-3863 kennybrown@blackfoot.net
Christine Yednick, UST Class A Operator potomacbar@outlook.com
Christine Yednick, UST Class B Operator potomacbar@outlook.com

Tank Code	01	Tank Age	35	Tank Installed Date	05/28/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3488	Spill Test Date	03/06/2026	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/06/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/06/2026	Line Tightness Test Date	11/06/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/06/2026			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	35	Tank Installed Date	05/28/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3489	Spill Test Date	03/06/2026	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/06/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/06/2026	Line Tightness Test Date	11/06/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/06/2026			ATG Type	Gilbarco/EMC Basic				

Tank Code	03	Tank Age	35	Tank Installed Date	05/28/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3490	Spill Test Date	03/06/2026	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/06/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/06/2026	Line Tightness Test Date	11/06/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/06/2026			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	35	Tank Installed Date	05/28/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	3491	Spill Test Date	03/06/2026	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/06/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date	03/06/2026	Line Tightness Test Date	10/20/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/06/2026			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Clinton

Location: BEARMOUTH EXPRESS
16595 US Hwy 10 E
Clinton, MT 59825-9678 Missoula

System Facility ID:32-01572

Facility Code: 25223
Last Inspected On: 09/04/2025
Operating Permit Renewal Date: 11/12/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gene Tripp (406) 825-4000

Operator Contact: Bryan Tripp;Jeff Tripp (406) 825-4000 bearmouth66@blackfoot.net;bryan.tripp44@gmail.com

Owner/Operator: Gene Tripp (406) 825-4000

Bryan Tripp, UST Class A Operator
Bryan Tripp, UST Class B Operator
Jeff Tripp, UST Class A Operator
Jeff Tripp, UST Class B Operator

bryan.tripp44@gmail.com
bryan.tripp44@gmail.com
bearmouth66@blackfoot.net
bearmouth66@blackfoot.net

Tank Code	01	Tank Age	47	Tank Installed Date	04/29/1979	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1205	Spill Test Date	09/02/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/02/2025	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/02/2025			ATG Type					

Facility Summary in Missoula County in the City of Clinton

Location: CLINTON MARKET
20500 Hwy 10 E
Clinton, MT 59825 Missoula

System Facility ID:56-14040

Facility Code: 30695
Last Inspected On: 11/19/2024
Operating Permit Renewal Date: 04/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: RR Investments of Montana (406) 546-4940 roy.handley6543@gmail.com

Operator Contact: Roy Handley (406) 546-4940 roy.handley6543@gmail.com

Owner/Operator: RR Investments of Montana (406) 546-4940 roy.handley6543@gmail.com

Roy Handley, UST Class A Operator

roy.handley6543@gmail.com

Roy Handley, UST Class B Global Operator

roy.handley6543@gmail.com

Tank Code	01	Tank Age	24	Tank Installed Date	05/16/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4651	Spill Test Date	05/17/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/19/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	11/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/17/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	02	Tank Age	24	Tank Installed Date	05/16/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4652	Spill Test Date	05/17/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/19/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/19/2024	Line Tightness Test Date	02/26/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	24	Tank Installed Date	05/16/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4653	Spill Test Date	05/17/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/19/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/19/2024	Line Tightness Test Date	02/28/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	17	Tank Installed Date	10/29/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5223	Spill Test Date	05/17/2024	Piping Installed Date	10/14/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/19/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/19/2024	Line Tightness Test Date	02/26/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	8	Tank Installed Date	08/28/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5851	Spill Test Date	05/17/2024	Piping Installed Date	08/28/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/19/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	11/19/2024	Line Tightness Test Date	02/26/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Clinton

Location: ROCK CREEK LODGE
7 Rock Creek Rd
Clinton, MT 59825 Missoula

System Facility ID:32-11093

Facility Code: 25616
Last Inspected On: 01/05/2024
Operating Permit Renewal Date: 01/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nicholas Caras;SEVEN ROCK LLC (406) 203-4467;(406) 203-4467 nickcaras@gmail.com;sjw@cararealestate.com

Operator Contact: Gene Swick;Rock Creek Lodge LLC (406) 825-4868 geneswick1976@gmail.com;brncoswin64@gmail.com

Owner/Operator: Nicholas Caras,SEVEN ROCK LLC (406) 203-4467 nickcaras@gmail.com

Gene Swick, UST Class A Operator
Gene Swick, UST Class B Operator

brncoswin64@gmail.com
brncoswin64@gmail.com

Tank Code	03	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4572	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4573	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	09/20/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Condon

Location: MISSION MOUNTAINS MERCANTILE
7217 MT Hwy 83
Condon, MT 59826 Missoula

System Facility ID:32-01619

Facility Code: 25226
Last Inspected On: 03/04/2026
Operating Permit Renewal Date: 06/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Leonard Kobylenski (406) 754-2387 len@swanvalley.com

Operator Contact: Leonard Kobylenski (406) 754-2387 len@swanvalley.com

Owner/Operator: Len Kobylenski (406) 754-2387 len@swanvalley.com

Len Kobylenski, UST Class A Operator

len@swanvalley.com

Len Kobylenski, UST Class B Operator

len@swanvalley.com

Tank Code	04	Tank Age	34	Tank Installed Date	05/20/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1495	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/12/2023	Line Tightness Test Date	04/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	34	Tank Installed Date	05/20/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1496	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/12/2023	Line Tightness Test Date	04/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	34	Tank Installed Date	05/20/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm

Tag Number	1497	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/12/2023	Line Tightness Test Date	04/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Frenchtown

Location: BRONCS GROCERIES INC
16640 Beckwith St
Frenchtown, MT 59834-9747 Missoula

System Facility ID:32-05767

Facility Code: 25384
Last Inspected On: 11/28/2023
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeremy Louvar (406) 546-3656 jeremylouvar@yahoo.com

Operator Contact:

Owner/Operator: Jeremy Louvar (406) 546-3656 jeremylouvar@yahoo.com

Jeremy Louvar, UST Class B Operator

jeremylouvar@yahoo.com

Tank Code	04	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	2702	Spill Test Date	05/30/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/06/2024	Line Tightness Test Date	05/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/06/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	2703	Spill Test Date	05/30/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/06/2024	Line Tightness Test Date	05/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/06/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Frenchtown

Location: FRENCHIES
16875 Beckwith St
Frenchtown, MT 59834-9646 Missoula

System Facility ID:32-11177

Facility Code: 25623
Last Inspected On: 05/13/2025
Operating Permit Renewal Date: 11/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Operator Contact: Joe Heuchert;Karly Shafer

(406) 396-2206

dahoyk@yahoo.com;karly@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Joe Heuchert, UST Class A Operator

dahoyk@yahoo.com

Karly Shafer, UST Class A Operator

karly@gwpetrol.com

Karly Shafer, UST Class B Global Operator

karly@gwpetrol.com

Tank Code	05	Tank Age	36	Tank Installed Date	06/25/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4372	Spill Test Date	11/09/2023	Piping Installed Date	11/20/2023	Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/18/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/14/2024	Line Tightness Test Date	12/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	36	Tank Installed Date	06/25/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4373	Spill Test Date	11/09/2023	Piping Installed Date	11/20/2023	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/18/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/14/2024	Line Tightness Test Date	12/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type	Veeder Root/TLS-450PLUS				

Tank Code	07	Tank Age	36	Tank Installed Date	06/25/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4374	Spill Test Date	11/09/2023	Piping Installed Date	11/20/2023	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/18/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/14/2024	Line Tightness Test Date	12/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2022			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	36	Tank Installed Date	06/25/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4375	Spill Test Date	11/09/2023	Piping Installed Date	11/20/2023	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/18/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	11/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/14/2024	Line Tightness Test Date	12/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2022			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	3	Tank Installed Date	11/16/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6209	Spill Test Date	11/09/2023	Piping Installed Date	11/20/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	11/14/2024	Line Tightness Test Date	12/30/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/09/2023			ATG Type					

Facility Summary in Missoula County in the City of Greenough

Location: CLEARWATER STOP N GO
44676 MT Hwy 200 E
Greenough, MT 59823-9557 Missoula

System Facility ID:32-07114

Facility Code: 25422
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 06/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: The Cow Group (406) 396-8431 jjross9185@msn.com

Operator Contact: Jeff Stavish;Sherri Housley (406) 244-5598 clearwaterstopngo@gmail.com;jjross9185@msn.com

Owner/Operator: The Cow Group (406) 396-8431 jjross9185@msn.com

Jeff Stavish, UST Class A Operator	clearwaterstopngo@gmail.com
Jeff Stavish, UST Class B Global Operator	clearwaterstopngo@gmail.com
Sherri Housley, UST Class A Operator	jjross9185@msn.com
Sherri Housley, UST Class B Operator	jjross9185@msn.com

Tank Code	04	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4474	Spill Test Date	03/28/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date	03/27/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/28/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4475	Spill Test Date	03/28/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/27/2025	Line Tightness Test Date	03/27/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/28/2024			ATG Type	Gilbarco/EMC Basic				

Tank Code	06	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4476	Spill Test Date	03/27/2024	Piping Installed Date	03/19/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date	03/27/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	03/27/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Lolo

Location: LOLO SUPERSTOP
12011 US Hwy 93 S
Lolo, MT 59847-9666 Missoula

System Facility ID:56-13795

Facility Code: 30482
Last Inspected On: 08/21/2025
Operating Permit Renewal Date: 10/03/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Operator Contact: Bri Mader;Karly Shafer

(406) 396-2206

karly@gwpetrol.com;knotts.brianna@yahoo.com

Owner/Operator: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Bri Mader, UST Class A Operator

knotts.brianna@yahoo.com

Bri Mader, UST Class B Operator

knotts.brianna@yahoo.com

Karly Shafer, UST Class A Operator

karly@gwpetrol.com

Karly Shafer, UST Class B Global Operator

karly@gwpetrol.com

Tank Code	05	Tank Age	28	Tank Installed Date	01/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2086	Spill Test Date	11/25/2025	Piping Installed Date	12/01/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/07/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/23/2025	Line Tightness Test Date	04/27/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	28	Tank Installed Date	01/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2087	Spill Test Date	11/25/2025	Piping Installed Date	12/01/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/07/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/23/2025	Line Tightness Test Date	05/01/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	07/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	28	Tank Installed Date	01/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2088	Spill Test Date	11/25/2025	Piping Installed Date	12/01/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/07/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	07/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/23/2025	Line Tightness Test Date	05/07/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	28	Tank Installed Date	01/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2089	Spill Test Date	07/23/2025	Piping Installed Date	12/01/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/07/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/23/2025	Line Tightness Test Date	05/07/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	28	Tank Installed Date	01/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2090	Spill Test Date	07/23/2025	Piping Installed Date	12/01/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/07/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/23/2025	Line Tightness Test Date	05/01/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 1
10955 US Hwy 93 S
Lolo, MT 59847 Missoula

System Facility ID:32-09414

Facility Code: 25493
Last Inspected On: 03/31/2023
Operating Permit Renewal Date: 10/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lolo 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Lolo 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	05	Tank Age	5	Tank Installed Date	04/20/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6029	Spill Test Date	07/19/2022	Piping Installed Date	04/20/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/19/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	03/24/2023	Line Tightness Test Date	05/04/2021	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/19/2022			ATG Type					
Tank Code	06	Tank Age	5	Tank Installed Date	04/20/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6030	Spill Test Date	07/19/2022	Piping Installed Date	04/20/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/19/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	03/24/2023	Line Tightness Test Date	05/04/2021	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/19/2022			ATG Type					
Tank Code	07	Tank Age	5	Tank Installed Date	04/20/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	6031	Spill Test Date	07/19/2022	Piping Installed Date	04/20/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/19/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	03/24/2023	Line Tightness Test Date	05/04/2021	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/19/2022			ATG Type					
Tank Code	08	Tank Age	5	Tank Installed Date	04/20/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6032	Spill Test Date	07/19/2022	Piping Installed Date	04/20/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/19/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/24/2023	Line Tightness Test Date	05/04/2021	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/19/2022			ATG Type					
Tank Code	09	Tank Age	5	Tank Installed Date	04/20/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6033	Spill Test Date	12/15/2025	Piping Installed Date	04/20/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date		Line Tightness Test Date	05/04/2021	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/02/2021			ATG Type					

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 2
11880 US HWY 93 S, STE 1
Lolo, MT 59847 Missoula

System Facility ID:32-01639

Facility Code: 25228
Last Inspected On: 03/31/2023
Operating Permit Renewal Date: 10/22/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lolo 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Lolo 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	13	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2545	Spill Test Date	07/20/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date	12/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	14	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2546	Spill Test Date	07/20/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date	12/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	17	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2549	Spill Test Date	07/20/2022	Piping Installed Date	08/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date	12/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	18	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2550	Spill Test Date	07/20/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date	12/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	15	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4289	Spill Test Date	07/20/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date	12/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	16	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4290	Spill Test Date	07/20/2022	Piping Installed Date	08/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date	12/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	20	Tank Age	22	Tank Installed Date	09/15/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4942	Spill Test Date	07/20/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	21	Tank Age	22	Tank Installed Date	09/15/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4943	Spill Test Date	07/20/2022	Piping Installed Date	08/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/03/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Lolo

Location: TRAVELERS REST
10565 Lolo Creek Rd
Lolo, MT 59847-9471 Missoula

System Facility ID:32-11303

Facility Code: 25632
Last Inspected On: 09/26/2024
Operating Permit Renewal Date: 12/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Manpreet Singh (509) 994-6599 histarms01@yahoo.com

Operator Contact: Emily Day;Jeffrey Toole histar.jeff@gmail.com;Travelersrestlolo@gmail.com

Owner/Operator: Manpreet Singh (509) 994-6599 histarms01@yahoo.com
 Emily Day, UST Class A Operator Travelersrestlolo@gmail.com
 Jeffrey Toole, UST Class A Operator histar.jeff@gmail.com
 Jeffrey Toole, UST Class B Operator histar.jeff@gmail.com

Tank Code	S4	Tank Age	23	Tank Installed Date	08/13/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4854	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	09/26/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/26/2024	Line Tightness Test Date	09/26/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S5	Tank Age	23	Tank Installed Date	08/13/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4855	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	09/26/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/26/2024	Line Tightness Test Date	09/26/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S6	Tank Age	23	Tank Installed Date	06/23/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4856	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	09/26/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/26/2024	Line Tightness Test Date	09/26/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S7	Tank Age	23	Tank Installed Date	06/23/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4857	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	09/26/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/26/2024	Line Tightness Test Date	09/26/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S8	Tank Age	23	Tank Installed Date	06/23/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4858	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	09/26/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/26/2024	Line Tightness Test Date	09/26/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Milltown

Location: TOWN PUMP INC BONNER-MILLTOWN
7985 MT Hwy 200 E
Milltown, MT 59851 Missoula

System Facility ID:32-13629

Facility Code: 25772
Last Inspected On: 03/30/2023
Operating Permit Renewal Date: 11/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bonner Town Pump and Casino Inc (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Bonner Town Pump and Casino Inc (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2564	Spill Test Date	06/06/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2568	Spill Test Date	06/06/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	07	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2570	Spill Test Date	11/18/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/18/2026			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2571	Spill Test Date	06/06/2022	Piping Installed Date	10/17/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2572	Spill Test Date	06/06/2022	Piping Installed Date	10/17/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2574	Spill Test Date	11/18/2025	Piping Installed Date	10/17/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	11/18/2025			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4260	Spill Test Date	06/06/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4261	Spill Test Date	06/06/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4262	Spill Test Date	06/06/2022	Piping Installed Date	10/13/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4263	Spill Test Date	06/06/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	12	Tank Age	23	Tank Installed Date	12/03/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4871	Spill Test Date	06/06/2022	Piping Installed Date	10/17/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	13	Tank Age	23	Tank Installed Date	12/03/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4872	Spill Test Date	06/06/2022	Piping Installed Date	10/17/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	10	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4889	Spill Test Date	06/06/2022	Piping Installed Date	10/17/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	14	Tank Age	13	Tank Installed Date	06/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5363	Spill Test Date		Piping Installed Date	07/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring;Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring;Deferred	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	15	Tank Age	8	Tank Installed Date	01/01/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5802	Spill Test Date	06/06/2022	Piping Installed Date	12/22/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	03/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Missoula County in the City of Missoula

Location: 3RD STREET MART
2340 S 3rd St W
Missoula, MT 59801 Missoula

System Facility ID:32-02179

Facility Code: 25246
Last Inspected On: 07/22/2025
Operating Permit Renewal Date: 08/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu;Jays Corporation (406) 549-1750;(406) 880-7677 jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com
 Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
 Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
 Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
 Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

Tank Code	01	Tank Age	50	Tank Installed Date	04/23/1976	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3624	Spill Test Date	07/22/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	02/03/2025	Tank/Piping CP Test Date	06/04/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/04/2025	Line Tightness Test Date	04/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	50	Tank Installed Date	04/23/1976	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3625	Spill Test Date	07/22/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	02/03/2025	Tank/Piping CP Test Date	06/04/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/04/2025	Line Tightness Test Date	04/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	02/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	50	Tank Installed Date	04/23/1976	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3626	Spill Test Date	07/22/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	02/03/2025	Tank/Piping CP Test Date	06/04/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/04/2025	Line Tightness Test Date	10/11/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: 70 MILE SUPER STOP 2
930 N Russell St
Missoula, MT 59808 Missoula

System Facility ID:32-13472

Facility Code: 25751
Last Inspected On: 01/04/2024
Operating Permit Renewal Date: 01/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hi-Star Properties LLC

(509) 994-6599

histarms3@yahoo.com

Operator Contact:

Owner/Operator: Hi-Star Properties LLC

(509) 994-6599

histarms3@yahoo.com

Tank Code	01	Tank Age	32	Tank Installed Date	06/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1450	Spill Test Date	10/23/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/04/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/15/2025	Line Tightness Test Date	10/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/28/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1451	Spill Test Date	02/28/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/04/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/15/2025	Line Tightness Test Date	10/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	32	Tank Installed Date	06/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	1452	Spill Test Date	02/28/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/04/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/15/2025	Line Tightness Test Date	10/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/28/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: AIRWAY FLEET FUEL
5355 W Harrier
Missoula, MT 59808 Missoula

System Facility ID:56-14133

Facility Code: 30771
Last Inspected On: 11/17/2025
Operating Permit Renewal Date: 02/18/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Finest Oil Co (406) 543-6969 finestoil@finest-oil.com

Operator Contact: Christopher Glasser;James Brady;John Stordahl;Justin Gaudot;Stephen Hanson (406) 218-1563;(406) 543-6969;(406) 544-1005;(714) 333-8926 chrisglasser@hotmail.com;finestoil@finest-oil.com;fireman2201@msn.com;jeepin247.jb@gmail.com;justgaudot@yahoo.com

Owner/Operator: Finest Oil Co (406) 543-6969 finestoil@finest-oil.com

Christopher Glasser, UST Class A Operator chrisglasser@hotmail.com
 James Brady, UST Class A Operator jeepin247.jb@gmail.com
 John Stordahl, UST Class A Operator fireman2201@msn.com
 Joseph McClain, UST Class B Operator jgmcclain25@gmail.com
 Justin Gaudot, UST Class A Operator justgaudot@yahoo.com
 Justin Gaudot, UST Class B Global Operator justgaudot@yahoo.com
 Stephen Hanson, UST Class A Operator finestoil@finest-oil.com
 Stephen Hanson, UST Class B Operator finestoil@finest-oil.com

Tank Code	01	Tank Age	21	Tank Installed Date	04/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4904	Spill Test Date	10/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/13/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/14/2025	Line Tightness Test Date	06/12/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	21	Tank Installed Date	04/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4905	Spill Test Date	10/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	10/13/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/14/2025	Line Tightness Test Date	06/12/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	21	Tank Installed Date	04/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4906	Spill Test Date	10/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	10/13/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/14/2025	Line Tightness Test Date	06/12/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	21	Tank Installed Date	04/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4907	Spill Test Date	10/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/13/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	25000	ATG Test Date	10/14/2025	Line Tightness Test Date	06/12/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	21	Tank Installed Date	04/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5038	Spill Test Date	10/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/13/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/14/2025	Line Tightness Test Date	06/12/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	10/30/2025			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Missoula County in the City of Missoula

Location: BEACH TRANSPORTATION CO
825 Mount Ave
Missoula, MT 59801-5607 Missoula

System Facility ID:32-11904

Facility Code: 25660
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 05/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Beach Transportation

Operator Contact: Carlin Cavill;Shawnae Stanton;Beach Transportation

(406) 549-6121

ccavill@beachtrans.com;sstanton@beachtrans.com

Owner/Operator: Beach Transportation

Carlin Cavill, UST Class A Operator
Carlin Cavill, UST Class B Operator
Shawnae Stanton, UST Class A Operator
Shawnae Stanton, UST Class B Operator

ccavill@beachtrans.com
ccavill@beachtrans.com
sstanton@beachtrans.com
sstanton@beachtrans.com

Tank Code	03	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2361	Spill Test Date	04/01/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/19/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/19/2026	Line Tightness Test Date	03/03/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/01/2025			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: BIG SKY GAS N SHOP LLC
318 S Orange St
Missoula, MT 59801-1811 Missoula

System Facility ID:32-08715

Facility Code: 25471
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BIG SKY GAS N SHOP LLC (510) 714-5045

Operator Contact:

Owner/Operator: BIG SKY GAS N SHOP LLC (510) 714-5045

Tank Code	04	Tank Age	36	Tank Installed Date	05/24/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2552	Spill Test Date	10/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/12/2023	Tank/Piping CP Test Date	05/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/20/2023	Line Tightness Test Date	05/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	36	Tank Installed Date	05/29/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2553	Spill Test Date	07/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/12/2023	Tank/Piping CP Test Date	05/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/20/2023	Line Tightness Test Date	05/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	36	Tank Installed Date	05/29/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	2554	Spill Test Date	07/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	05/12/2023	Tank/Piping CP Test Date	05/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	06/20/2023	Line Tightness Test Date	05/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: CHS MISSOULA PETROLEUM TERMINAL
3576 Grant Creek Rd
Missoula, MT 59808 Missoula

System Facility ID:60-15296

Facility Code: 31000
Last Inspected On: 10/08/2025
Operating Permit Renewal Date: 01/17/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Laurel (406) 628-5200

Operator Contact: Matthew Mill

Matt.Mill@chsinc.com

Owner/Operator: CHS Inc Laurel (406) 628-5200

Matthew Mill, UST Class A Operator
Matthew Mill, UST Class B Operator

Matt.Mill@chsinc.com
Matt.Mill@chsinc.com

Tank Code	01	Tank Age	18	Tank Installed Date	02/01/2008	Tank Material	Not Listed	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	5708	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	11/19/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	7750	ATG Test Date		Line Tightness Test Date	04/18/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746278
403 S Russell St
Missoula, MT 59801-2311 Missoula

System Facility ID:32-08072

Facility Code: 25460
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 04/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Operator Contact: Veronica Rivera ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com

Tank Code	06	Tank Age	31	Tank Installed Date	07/31/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3024	Spill Test Date	07/07/2025	Piping Installed Date	06/10/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/06/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/06/2025	Line Tightness Test Date	07/25/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/07/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	31	Tank Installed Date	07/31/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3025	Spill Test Date	01/06/2025	Piping Installed Date	06/10/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/06/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	01/06/2025	Line Tightness Test Date	07/27/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	01/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	31	Tank Installed Date	07/31/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3026	Spill Test Date	01/06/2025	Piping Installed Date	06/10/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/06/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	01/06/2025	Line Tightness Test Date	08/02/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	31	Tank Installed Date	07/31/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4700	Spill Test Date	01/06/2025	Piping Installed Date	06/10/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/06/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	01/06/2025	Line Tightness Test Date	10/13/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746282
605 S Higgins Ave
Missoula, MT 59801-2733 Missoula

System Facility ID:32-09733

Facility Code: 25517
Last Inspected On: 05/03/2023
Operating Permit Renewal Date: 08/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Operator Contact: Veronica Rivera ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	38	Tank Installed Date	08/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3028	Spill Test Date	05/03/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	06/27/2022	Line Tightness Test Date	06/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	38	Tank Installed Date	08/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3029	Spill Test Date	05/03/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	06/27/2022	Line Tightness Test Date	06/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	38	Tank Installed Date	08/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3030	Spill Test Date	05/03/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	06/27/2022	Line Tightness Test Date	06/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746283
2325 S Reserve St
Missoula, MT 59801-6446 Missoula

System Facility ID:32-09694

Facility Code: 25512
Last Inspected On: 10/17/2023
Operating Permit Renewal Date: 02/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Operator Contact: Veronica Rivera ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	39	Tank Installed Date	08/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3706	Spill Test Date	11/21/2024	Piping Installed Date	04/10/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/03/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	06/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	06/07/2023	Line Tightness Test Date	07/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	39	Tank Installed Date	08/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3707	Spill Test Date	11/21/2024	Piping Installed Date	04/10/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/03/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	06/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	06/07/2023	Line Tightness Test Date	06/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	39	Tank Installed Date	08/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3708	Spill Test Date	04/11/2022	Piping Installed Date	04/10/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/03/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	06/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	06/07/2023	Line Tightness Test Date	06/17/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	39	Tank Installed Date	08/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3709	Spill Test Date	06/22/2021	Piping Installed Date	04/10/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/03/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date	06/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/07/2023	Line Tightness Test Date	06/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: COMMUNITY MEDICAL CENTER
2827 Fort Missoula Rd
Missoula, MT 59804 Missoula

System Facility ID:32-11740

Facility Code: 25652
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 03/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: RCHP Billings - Missoula LLC

cclark@communitymed.org

Operator Contact: Randy Allen;Community Medical Center

(406) 327-4029

rallen6261@gmail.com

Owner/Operator: RCHP Billings - Missoula LLC

cclark@communitymed.org

Randy Allen, UST Class A Operator

rallen6261@gmail.com

Randy Allen, UST Class B Operator

rallen6261@gmail.com

Tank Code	04	Tank Age	32	Tank Installed Date	07/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2353	Spill Test Date	11/28/2023	Piping Installed Date	06/03/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/05/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/28/2023	Line Tightness Test Date	11/28/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date	11/28/2023			ATG Type	Franklin Fueling Systems/S940				

Facility Summary in Missoula County in the City of Missoula

Location: CORNER QWIK STOP
2480 39th St
Missoula, MT 59803-1123 Missoula

System Facility ID:32-09690

Facility Code: 25511
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 08/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Operator Contact: Jagpreet Ghuman;Manpreet Singh (406) 880-7677;(509) 994-6599 histarms01@yahoo.com;jaysfood08@outlook.com

Owner/Operator: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com
 Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
 Jaspal Sandhu, UST Class B Global Operator jas_sandhu75@hotmail.com
 Manpreet Singh, UST Class A Operator histarms01@yahoo.com

Tank Code	01	Tank Age	44	Tank Installed Date	11/03/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1360	Spill Test Date	04/27/2021	Piping Installed Date	04/27/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/27/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	11/08/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	44	Tank Installed Date	11/03/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1361	Spill Test Date	04/27/2021	Piping Installed Date	04/27/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/27/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/03/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	11/08/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	06/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	44	Tank Installed Date	11/03/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1362	Spill Test Date	04/27/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	Yes
Capacity	6000	ATG Test Date	11/08/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: COSTCO WHOLESALE FUELING MSLA
3220 N Reserve St
Missoula, MT 59808-1556 Missoula

System Facility ID:56-13977

Facility Code: 30639
Last Inspected On: 07/11/2024
Operating Permit Renewal Date: 07/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Operator Contact: Brandon Krause;Sean Davis;Costco Wholesale Corporation Missoula;Shawn Willis w067gas@costco.com;w067ops@costco.com

Owner/Operator: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Brandon Krause, UST Class A Operator w067gas@costco.com
 Sean Davis, UST Class A Operator w067ops@costco.com
 Sean Davis, UST Class B Operator w067ops@costco.com
 Shawn Willis, UST Class A Operator w067gas@costco.com
 Shawn Willis, UST Class B Global Operator w067gas@costco.com
 Shawn Willis, UST Class B Operator w067gas@costco.com

Tank Code	01	Tank Age	26	Tank Installed Date	05/15/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4189	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/11/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/10/2024	Line Tightness Test Date	07/10/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	26	Tank Installed Date	05/15/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4190	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/11/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	20000	ATG Test Date	07/10/2024	Line Tightness Test Date	07/10/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	26	Tank Installed Date	05/15/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4191	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/11/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/10/2024	Line Tightness Test Date	07/10/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	15	Tank Installed Date	08/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5283	Spill Test Date	07/10/2024	Piping Installed Date	10/25/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/11/2024	Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1500	ATG Test Date	07/10/2024	Line Tightness Test Date	07/10/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: DEMAROIS, INC
3115 W Broadway St
Missoula, MT 59808-1613 Missoula

System Facility ID:32-10552

Facility Code: 25588
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 01/08/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: DeMarois Inc (406) 721-4000

Operator Contact: Jack DeMarois (406) 721-4000 jack@demarois.com

Owner/Operator: DeMarois Inc (406) 721-4000

Jack DeMarois, UST Class A Operator
Jack DeMarois, UST Class B Operator

jack@demarois.com
jack@demarois.com

Tank Code	03	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2188	Spill Test Date	11/08/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	12/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/13/2024			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: FAST TRIP CONOCO
2730 S Reserve St
Missoula, MT 59801-7641 Missoula

System Facility ID:56-13914

Facility Code: 30584
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 07/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Scott Worster

scottoej@gmail.com

Operator Contact: Deb Privett

(406) 529-7771

fasttripinc@gmail.com

Owner/Operator: Scott Worster

scottoej@gmail.com

Deb Privett, UST Class A Operator

fasttripinc@gmail.com

Deb Privett, UST Class B Operator

fasttripinc@gmail.com

Tank Code	01	Tank Age	27	Tank Installed Date	08/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4913	Spill Test Date	06/24/2024	Piping Installed Date	06/03/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/23/2025	Line Tightness Test Date	12/02/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	27	Tank Installed Date	08/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4914	Spill Test Date	06/24/2024	Piping Installed Date	06/03/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/23/2025	Line Tightness Test Date	11/14/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	10/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	27	Tank Installed Date	08/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4915	Spill Test Date	06/24/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/23/2025	Line Tightness Test Date	10/25/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: FINEST OIL CO MISSOULA NORTHGATE
3665 Grant Creek Rd
Missoula, MT 59808-1431 Missoula

System Facility ID:32-02295

Facility Code: 25257
Last Inspected On: 04/10/2026
Operating Permit Renewal Date: 08/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Finest Oil Co	(406) 543-6969	finestoil@finest-oil.com
Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson	(406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926	chrisglasser@hotmail.com;finestoil@finest-oil.com;jeepin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com
Owner/Operator: Finest Oil Co	(406) 543-6969	finestoil@finest-oil.com
Christopher Glasser, UST Class A Operator		chrisglasser@hotmail.com
David Peyton, UST Class A Operator		
David Peyton, UST Class B Global Operator		
James Brady, UST Class A Operator		jeepin247.jb@gmail.com
James DeWaters, UST Class A Operator		rivban22@gmail.com
Joseph McClain, UST Class B Operator		jgmcclain25@gmail.com
Justin Gaudot, UST Class A Operator		justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator		justgaudot@yahoo.com
Stephen Hanson, UST Class A Operator		finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator		finestoil@finest-oil.com

Tank Code	06	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1066	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1067	Spill Test Date	06/14/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/14/2023	Tank/Piping CP Test Date	06/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1068	Spill Test Date	06/14/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/14/2023	Tank/Piping CP Test Date	06/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1069	Spill Test Date	06/14/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/14/2023	Tank/Piping CP Test Date	06/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1070	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/14/2023	Tank/Piping CP Test Date	04/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	12000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1071	Spill Test Date	08/04/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/14/2023	Tank/Piping CP Test Date	04/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	12	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1072	Spill Test Date	08/04/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/14/2023	Tank/Piping CP Test Date	04/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	13	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1073	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/14/2023	Tank/Piping CP Test Date	04/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: FINEST OIL EASTGATE
940 E Broadway St
Missoula, MT 59802-4915 Missoula

System Facility ID:32-10284

Facility Code: 25565
Last Inspected On: 08/27/2025
Operating Permit Renewal Date: 09/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Finest Oil Co	(406) 543-6969	finestoil@finest-oil.com
Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson	(406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926	chrisglasser@hotmail.com;finestoil@finest-oil.com;jeepin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com

Owner/Operator: Finest Oil Co	(406) 543-6969	finestoil@finest-oil.com
Christopher Glasser, UST Class A Operator		chrisglasser@hotmail.com
David Peyton, UST Class A Operator		
David Peyton, UST Class B Global Operator		
James Brady, UST Class A Operator		jeepin247.jb@gmail.com
James DeWaters, UST Class A Operator		rivban22@gmail.com
John Stordahl, UST Class B Global Operator		fireman2201@msn.com
Joseph McClain, UST Class B Operator		jgmccclain25@gmail.com
Justin Gaudot, UST Class A Operator		justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator		justgaudot@yahoo.com
Stephen Hanson, UST Class A Operator		finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator		finestoil@finest-oil.com

Tank Code	07	Tank Age	29	Tank Installed Date	10/27/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1074	Spill Test Date	08/27/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/27/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	08	Tank Age	29	Tank Installed Date	10/27/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1075	Spill Test Date	08/27/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/27/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	29	Tank Installed Date	10/27/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1076	Spill Test Date	05/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/27/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: GREAT WESTERN PETROLEUM
1002 E Broadway St
Missoula, MT 59802-4930 Missoula

System Facility ID:32-07431

Facility Code: 25437
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/30/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Operator Contact: Heather Stiles

hstiles@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Heather Stiles, UST Class A Operator

hstiles@gwpetrol.com

Heather Stiles, UST Class B Global Operator

hstiles@gwpetrol.com

Tank Code	10	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1432	Spill Test Date	10/17/2024	Piping Installed Date	08/26/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/01/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/01/2024	Line Tightness Test Date	05/01/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/01/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	S11	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1433	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/01/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	17000	ATG Test Date	10/07/2021	Line Tightness Test Date	05/01/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date				ATG Type					
Tank Code	S12	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1434	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/01/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	11000	ATG Test Date	10/07/2021	Line Tightness Test Date	05/01/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S13	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1435	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/01/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	14600	ATG Test Date	10/07/2021	Line Tightness Test Date	05/01/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S14	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1436	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/01/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	11000	ATG Test Date	10/07/2021	Line Tightness Test Date	05/01/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: HEATING PLANT
Physical Plant Bldg #32
Missoula, MT 59812 Missoula

System Facility ID:32-00505

Facility Code: 25184
Last Inspected On: 10/01/2025
Operating Permit Renewal Date: 02/22/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: University of Montana

(406) 243-2190

Operator Contact: Anthony Ey

anthony.ey@mso.umt.edu

Owner/Operator: University of Montana

(406) 243-2190

Anthony Ey, UST Class A Operator
Anthony Ey, UST Class B Operator

anthony.ey@mso.umt.edu
anthony.ey@mso.umt.edu

Tank Code	09	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4221	Spill Test Date	01/27/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	09/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE CONOCO SERVICE CENTER
711 E Broadway St
Missoula, MT 59802-4609 Missoula

System Facility ID:32-00144

Facility Code: 25156
Last Inspected On: 03/24/2026
Operating Permit Renewal Date: 06/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hellgate Conoco Service Center;Ross Grenfell;Hellgate Conoco Service Center **(406) 728-9966;(406) 728-9966;(406) 728-9966** **hellgateconoco@gmail.com;hellgateconoco@gmail.com;hellgateconoco@gmail.com**

Operator Contact: Ross Grenfell;Hellgate Conoco Service Center **(406) 728-9966;(406) 728-9966** **hellgateconoco@gmail.com;hellgateconoco@gmail.com**

Owner/Operator: Hellgate Conoco Service Center (406) 728-9966 hellgateconoco@gmail.com

Owner/Operator: Ross Grenfell,Hellgate Conoco Service Center (406) 728-9966 hellgateconoco@gmail.com

Ross Grenfell, UST Class A Operator hellgateconoco@gmail.com

Ross Grenfell, UST Class B Global Operator hellgateconoco@gmail.com

Tank Code	01	Tank Age	60	Tank Installed Date	03/31/1966	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3765	Spill Test Date	06/12/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/12/2023	Sump Tightness Test Date	06/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	03/26/2025	Line Tightness Test Date	06/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/12/2023			ATG Type	Gilbarco/EMC				
Tank Code	02	Tank Age	60	Tank Installed Date	03/31/1966	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3766	Spill Test Date	06/12/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/12/2023	Sump Tightness Test Date	06/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/26/2025	Line Tightness Test Date	06/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/12/2023			ATG Type	Gilbarco/EMC				

Tank Code	03	Tank Age	60	Tank Installed Date	03/31/1966	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3767	Spill Test Date	06/12/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/12/2023	Sump Tightness Test Date	06/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/26/2025	Line Tightness Test Date	06/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/12/2023			ATG Type	Gilbarco/EMC				
Tank Code	08	Tank Age	16	Tank Installed Date	12/16/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5279	Spill Test Date	06/12/2023	Piping Installed Date	12/16/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/12/2023	Sump Tightness Test Date	06/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/15/2017	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	03/26/2025	Line Tightness Test Date	06/12/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/12/2023			ATG Type	Gilbarco/EMC				

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE TRADING POST INC
6265 Mullan Rd
Missoula, MT 59808-5650 Missoula

System Facility ID:32-00211

Facility Code: 25173
Last Inspected On: 03/12/2025
Operating Permit Renewal Date: 06/03/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Operator Contact: Karly Shafer

(406) 396-2206

karly@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Heather Stiles, UST Class B Global Operator

hstiles@gwpetrol.com

Karly Shafer, UST Class A Operator

karly@gwpetrol.com

Karly Shafer, UST Class B Global Operator

karly@gwpetrol.com

Tank Code	03	Tank Age	32	Tank Installed Date	09/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1425	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/12/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/12/2025	Line Tightness Test Date	03/12/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	32	Tank Installed Date	09/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1426	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/12/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/12/2025	Line Tightness Test Date	03/12/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORES 400
540 E Broadway St
Missoula, MT 59802-4614 Missoula

System Facility ID:32-03614

Facility Code: 25304
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 08/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JACKSONS FOOD STORES INC

(208) 888-6061

compliance@jacksons.com

Operator Contact: Earl Allen

Owner/Operator: JACKSONS FOOD STORES INC

(208) 888-6061

compliance@jacksons.com

Earl Allen, UST Class A Operator

Earl Allen, UST Class B Operator

Tank Code	05	Tank Age	11	Tank Installed Date	04/28/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5573	Spill Test Date	04/09/2024	Piping Installed Date	04/28/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/09/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/03/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	18000	ATG Test Date	05/03/2023	Line Tightness Test Date	02/13/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/31/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	11	Tank Installed Date	04/28/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5574	Spill Test Date	04/09/2024	Piping Installed Date	04/28/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/09/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/03/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/03/2023	Line Tightness Test Date	02/13/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	07/31/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	11	Tank Installed Date	04/28/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5575	Spill Test Date	05/18/2021	Piping Installed Date	04/28/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/18/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/18/2021	Line Tightness Test Date	02/13/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/31/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORES 401
1605 S Russell St
Missoula, MT 59801-5636 Missoula

System Facility ID:32-08863

Facility Code: 25478
Last Inspected On: 10/23/2024
Operating Permit Renewal Date: 02/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: GYPSY LLC

(208) 888-6061

compliance@jacksons.com

Operator Contact: Earl Allen

Owner/Operator: GYPSY LLC

(208) 888-6061

compliance@jacksons.com

Earl Allen, UST Class A Operator

Earl Allen, UST Class B Operator

Tank Code	01	Tank Age	41	Tank Installed Date	06/23/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1357	Spill Test Date	10/23/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/23/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	41	Tank Installed Date	06/23/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1358	Spill Test Date	11/26/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/26/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	41	Tank Installed Date	06/23/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	1359	Spill Test Date	10/23/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/23/2024			ATG Type	Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORES 402
1250 39th St
Missoula, MT 59803 Missoula

System Facility ID:32-05763

Facility Code: 25380
Last Inspected On: 09/13/2025
Operating Permit Renewal Date: 12/10/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JACKSONS FOOD STORES INC

(208) 888-6061

compliance@jacksons.com

Operator Contact: Earl Allen

Owner/Operator: JACKSONS FOOD STORES INC

(208) 888-6061

compliance@jacksons.com

Earl Allen, UST Class A Operator
Earl Allen, UST Class B Global Operator

Tank Code	01	Tank Age	46	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1348	Spill Test Date	04/23/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/23/2025	Line Tightness Test Date	06/14/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	46	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1349	Spill Test Date	04/23/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/23/2025	Line Tightness Test Date	06/14/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	46	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1350	Spill Test Date	04/23/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/23/2025	Line Tightness Test Date	06/14/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: JAYS 1 STOP
505 Highton St
Missoula, MT 59801-5424 Missoula

System Facility ID:32-06680

Facility Code: 25412
Last Inspected On: 06/24/2025
Operating Permit Renewal Date: 06/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman;Jays 1 Stop;Jaspal Sandhu;Jays Corporation (406) 549-1750;(406) 880-7677;(406) 549-1031 jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com;jays1stop21@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com
 Jagpreet Ghuman, UST Class A Operator jays1stop21@outlook.com
 Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
 Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
 Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

Tank Code	03	Tank Age	36	Tank Installed Date	01/10/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2298	Spill Test Date	09/03/2024	Piping Installed Date	02/21/2025	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/21/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/12/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/25/2025	Line Tightness Test Date	07/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/03/2025			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	36	Tank Installed Date	01/10/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2299	Spill Test Date	09/03/2024	Piping Installed Date	02/21/2025	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/21/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/12/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/25/2025	Line Tightness Test Date	07/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/03/2025			ATG Type	Veeder Root/TLS-450PLUS				

Tank Code	05	Tank Age	36	Tank Installed Date	01/10/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2300	Spill Test Date	09/03/2024	Piping Installed Date	02/21/2025	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/21/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/12/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/25/2025	Line Tightness Test Date	07/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/03/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	2	Tank Installed Date	08/07/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6252	Spill Test Date	09/03/2024	Piping Installed Date	02/21/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	02/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/03/2025			ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

System Facility ID:32-05760

Facility Code: 25377
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 08/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu (406) 880-7677 jas_sandhu75@hotmail.com;jaysfood08@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
 Jagpreet Ghuman, UST Class B Global Operator jaysfood08@outlook.com
 Jaspal Sandhu, UST Class A Operator jas_sandhu75@hotmail.com
 Jaspal Sandhu, UST Class B Global Operator jas_sandhu75@hotmail.com
 Jaspal Sandhu, UST Class B Operator jas_sandhu75@hotmail.com

Tank Code	01	Tank Age	54	Tank Installed Date	11/18/1972	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1345	Spill Test Date	04/11/2022	Piping Installed Date	10/10/2015	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	12/03/2019	Tank/Piping CP Test Date	03/01/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/08/2022	Line Tightness Test Date	10/12/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	50	Tank Installed Date	11/18/1976	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1346	Spill Test Date	04/11/2022	Piping Installed Date	10/10/2015	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	12/03/2019	Tank/Piping CP Test Date	03/01/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	4000	ATG Test Date		Line Tightness Test Date	10/14/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	54	Tank Installed Date	11/18/1972	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1347	Spill Test Date	04/11/2022	Piping Installed Date	10/10/2015	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	12/03/2019	Tank/Piping CP Test Date	03/01/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/08/2022	Line Tightness Test Date	10/14/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE CARDLOCK
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

System Facility ID:32-05761

Facility Code: 25378
Last Inspected On: 04/18/2025
Operating Permit Renewal Date: 06/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman (406) 880-7677 jaysfood08@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Global Operator jaysfood08@outlook.com
Jaspal Sandhu, UST Class B Global Operator jas_sandhu75@hotmail.com

Tank Code	01	Tank Age	47	Tank Installed Date	11/14/1979	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3627	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/28/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	51	Tank Installed Date	11/14/1975	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3628	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	06/28/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	03	Tank Age	47	Tank Installed Date	11/14/1979	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3629	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/28/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: LOVES TRAVEL STOP #753
8077 Hwy 10 W
Missoula, MT 59808 Missoula

System Facility ID:60-15321

Facility Code: 31018
Last Inspected On: 10/01/2024
Operating Permit Renewal Date: 01/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Loves Travel Stops and Country Stores Inc (281) 655-9425 environmental@loves.com

Operator Contact: Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Lowery;Loves Travel Stops and Country Stores Inc (281) 655-9425;(405) 779-3768;(281) 655-9425 environmental@loves.com;environmental@loves.com

Owner/Operator: Loves Travel Stops and Country Stores Inc (281) 655-9425 environmental@loves.com

- | | |
|---------------------------------------|-------------------------|
| Eric Bennett, UST Class A Operator | environmental@loves.com |
| Eric Bennett, UST Class B Operator | environmental@loves.com |
| Eric Candelaria, UST Class B Operator | environmental@loves.com |
| Ted Lowery, UST Class A Operator | environmental@loves.com |
| Ted Lowery, UST Class B Operator | environmental@loves.com |

Tank Code	01	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5830	Spill Test Date	09/20/2022	Piping Installed Date	08/15/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	01/27/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/27/2026			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5831	Spill Test Date	09/20/2022	Piping Installed Date	08/15/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/27/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes

		Overfill Test Date	01/27/2026			ATG Type	Incon/TS-550 EVO				
Tank Code	03	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5832	Spill Test Date	09/20/2022	Piping Installed Date	08/15/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/27/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/20/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	04	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5833	Spill Test Date	09/20/2022	Piping Installed Date	08/15/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	01/27/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/27/2026			ATG Type	Incon/TS-550 EVO				
Tank Code	05	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5834	Spill Test Date	09/20/2022	Piping Installed Date	08/15/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	01/27/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/27/2026			ATG Type	Incon/TS-550 EVO				
Tank Code	06	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5835	Spill Test Date	09/22/2022	Piping Installed Date	08/15/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	01/27/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/27/2026			ATG Type	Incon/TS-550 EVO				
Tank Code	07	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5836	Spill Test Date	09/20/2022	Piping Installed Date	08/15/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Biodiesel B99	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	01/27/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/27/2026			ATG Type	Incon/TS-550 EVO				
Tank Code	08	Tank Age	7	Tank Installed Date	08/15/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5837	Spill Test Date		Piping Installed Date	08/15/2019	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/29/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	09	Tank Age	8	Tank Installed Date	10/26/2018	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5863	Spill Test Date	10/01/2023	Piping Installed Date	12/17/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/15/2023	Line Tightness Test Date	11/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/24/2022			ATG Type	Incon/TS-550 EVO				

Tank Code	10	Tank Age	8	Tank Installed Date	10/26/2018	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5864	Spill Test Date	10/01/2024	Piping Installed Date	12/17/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/15/2023	Line Tightness Test Date	11/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/24/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	11	Tank Age	8	Tank Installed Date	10/26/2018	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5865	Spill Test Date	10/01/2024	Piping Installed Date	12/17/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/15/2023	Line Tightness Test Date	11/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/24/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	12	Tank Age	8	Tank Installed Date	10/26/2018	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5866	Spill Test Date	10/01/2023	Piping Installed Date	12/17/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/15/2023	Line Tightness Test Date	11/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/24/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	13	Tank Age	8	Tank Installed Date	10/26/2018	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5867	Spill Test Date	10/01/2023	Piping Installed Date	12/17/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Safe Suction	CP Met Types	Non-corrodible

Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/15/2023	Line Tightness Test Date	11/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/24/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	14	Tank Age	8	Tank Installed Date	10/26/2018	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5868	Spill Test Date	10/01/2023	Piping Installed Date	12/17/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/15/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	11/15/2023	Line Tightness Test Date	11/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/24/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	15	Tank Age	8	Tank Installed Date	10/26/2018	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5869	Spill Test Date	10/01/2023	Piping Installed Date	12/17/2019	Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/15/2023	Line Tightness Test Date	11/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/24/2022			ATG Type	Incon/TS-550 EVO				

Facility Summary in Missoula County in the City of Missoula

Location: MDOT MISSOULA
8350 Old Hwy 10
Missoula, MT 59808 Missoula

System Facility ID:60-15231

Facility Code: 30948
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 09/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Department of Transportation Helena

Operator Contact: Joe Radonich;Montana Dept of Transportation;Michael Carstensen;MDT 11 3211 Missoula W Broadway

(406) 444-9204;(406) 444-7632;(406) 523-5836

jradonich@mt.gov;jradonich@mt.gov;mcarstensen@mt.gov

Owner/Operator: Montana Department of Transportation Helena

Joe Radonich, UST Class A Operator

Joe Radonich, UST Class B Operator

Michael Carstensen, UST Class A Operator

Michael Carstensen, UST Class B Operator

jradonich@mt.gov

jradonich@mt.gov

mcarstensen@mt.gov

mcarstensen@mt.gov

Tank Code	01	Tank Age	12	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5438	Spill Test Date	11/16/2021	Piping Installed Date	08/30/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/16/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/16/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/16/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	12	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5439	Spill Test Date		Piping Installed Date	08/25/2013	Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Non Regulated	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.1;ELLD 0.2	Vapor Recovery	No

Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA #7 FLYING J
8745 Hwy 93 N
Missoula, MT 59808 Missoula

System Facility ID:60-15158

Facility Code: 30899
Last Inspected On: 06/27/2023
Operating Permit Renewal Date: 10/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula 7 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Missoula 7 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5256	Spill Test Date	10/25/2022	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5257	Spill Test Date	10/25/2022	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5258	Spill Test Date	10/25/2022	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	25000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5259	Spill Test Date	10/25/2022	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5260	Spill Test Date	10/25/2022	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5261	Spill Test Date	10/25/2022	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5262	Spill Test Date	10/25/2022	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5331	Spill Test Date	12/16/2025	Piping Installed Date	07/19/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/22/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	06/22/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	16	Tank Installed Date	09/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5361	Spill Test Date		Piping Installed Date	04/11/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	

Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring	Primary Pipe Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA AIRPORT WASHINGTON HANGER
5225 W Broadway St
Missoula, MT 59808-9385 Missoula

System Facility ID:32-07606

Facility Code: 25444
Last Inspected On: 12/13/2025
Operating Permit Renewal Date: 05/25/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Washington Corporations

Operator Contact: Andrew Ihle;Missoula Airport Washington Hanger;Ryan Opheim

(406) 214-8531

aihle@washcorp.com;ropheim@washcorp.com

Owner/Operator: Washington Corporations

Andrew Ihle, UST Class A Operator
Andrew Ihle, UST Class B Operator
Ryan Opheim, UST Class A Operator
Ryan Opheim, UST Class B Operator

aihle@washcorp.com
aihle@washcorp.com
ropheim@washcorp.com
ropheim@washcorp.com

Tank Code	01	Tank Age	42	Tank Installed Date	05/07/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	2242	Spill Test Date	11/09/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/17/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date	11/09/2025	Tank/Piping CP Test Date	02/26/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/09/2025	Line Tightness Test Date	03/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/09/2025			ATG Type	Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA CHEVROLET
3663 N Reserve St
Missoula, MT 59808-1509 Missoula

System Facility ID:56-14056

Facility Code: 30710
Last Inspected On: 03/06/2026
Operating Permit Renewal Date: 09/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MISSOULA MOTOR COMPANY LLC (406) 721-2438 terryh@missoulamc.com

Operator Contact: Terry Hedrick (406) 532-2437 terryh@missoulamc.com

Owner/Operator: MISSOULA MOTOR COMPANY LLC (406) 721-2438 terryh@missoulamc.com

Terry Hedrick, UST Class A Operator terryh@missoulamc.com
Terry Hedrick, UST Class B Operator terryh@missoulamc.com

Tank Code	02	Tank Age	24	Tank Installed Date	07/22/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4695	Spill Test Date	11/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/17/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/17/2022	Line Tightness Test Date	09/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/17/2022			ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	24	Tank Installed Date	07/22/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4696	Spill Test Date	11/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/17/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	4000	ATG Test Date	11/17/2022	Line Tightness Test Date	09/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/17/2022			ATG Type	Veeder Root/TLS-300				
Tank Code	S1	Tank Age	24	Tank Installed Date	07/30/2002	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4699	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/17/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA COUNTY DETENTION CENTER
2340 Mullan Rd
Missoula, MT 59808-1830 Missoula

System Facility ID:56-13921

Facility Code: 30591
Last Inspected On: 08/18/2025
Operating Permit Renewal Date: 11/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula County Detention Center

Operator Contact: Gary Zinke;Jess Ebel

(406) 531-3627

gezinke@missoulacounty.us;jebel@missoulacounty.us

Owner/Operator: Missoula County Detention Center

Gary Zinke, UST Class A Operator
Gary Zinke, UST Class B Operator
Jess Ebel, UST Class A Operator
Jess Ebel, UST Class B Operator

gezinke@missoulacounty.us
gezinke@missoulacounty.us
jebel@missoulacounty.us
jebel@missoulacounty.us

Tank Code	S1	Tank Age	27	Tank Installed Date	06/01/1999	Tank Material	Unknown	Piping Material	Copper	Overfill Types	
Tag Number	3774	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	08/18/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA SERVICE CENTER
1900 S Russell St
Missoula, MT 59801-6624 Missoula

System Facility ID:32-01182

Facility Code: 25203
Last Inspected On: 12/23/2025
Operating Permit Renewal Date: 06/13/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwestern Energy Butte (406) 655-2521 eric.larson@northwestern.com

Operator Contact: Eric Larson;Jeremy Salle (406) 565-6871 eric.larson@northwestern.com;jeremy.salle@northwestern.com

Owner/Operator: Northwestern Energy Butte (406) 655-2521 eric.larson@northwestern.com

Eric Larson, UST Class A Operator eric.larson@northwestern.com
Eric Larson, UST Class B Global Operator eric.larson@northwestern.com
Jeremy Salle, UST Class A Operator jeremy.salle@northwestern.com
Joe Vigue, UST Class B Operator Joseph.Vigue@northwestern.com

Tank Code	04	Tank Age	36	Tank Installed Date	07/27/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1680	Spill Test Date	04/16/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/23/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	13000	ATG Test Date	12/23/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	05	Tank Age	36	Tank Installed Date	07/27/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1681	Spill Test Date	04/16/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/23/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date	12/23/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA URBAN TRANSPORTATION
1221 Shakespeare St
Missoula, MT 59802-2307 Missoula

System Facility ID:32-04427

Facility Code: 25341
Last Inspected On: 12/16/2025
Operating Permit Renewal Date: 06/05/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula Urban Transportation (406) 543-8386

Operator Contact: Jeffrey Logan;John Roseboom (406) 215-2455;(406) 215-2458 jlogan@mountainline.com;john@mountainline.com

Owner/Operator: Missoula Urban Transportation (406) 543-8386

Brian Dildine, UST Class B Operator	bildine@mountainline.com
Cody Bush, UST Class B Operator	cbush@mountainline.com
David Loewen, UST Class B Operator	
Jacob Nolen, UST Class B Operator	jnolen@mountainline.com
Jeffrey Logan, UST Class A Operator	jlogan@mountainline.com
Jeffrey Logan, UST Class B Operator	jlogan@mountainline.com
John Roseboom, UST Class A Operator	john@mountainline.com
John Roseboom, UST Class B Operator	john@mountainline.com
Kent Russell, UST Class B Operator	krussell@mountainline.com

Tank Code	04	Tank Age	28	Tank Installed Date	04/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1658	Spill Test Date	12/16/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/16/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/16/2025			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	05	Tank Age	28	Tank Installed Date	04/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1659	Spill Test Date	12/16/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	600	ATG Test Date	12/16/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/16/2025			ATG Type	Gilbarco/EMC Basic; Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: MOUNTAIN WEST COOP
4570 N Reserve St
Missoula, MT 59808 Missoula

System Facility ID:32-02437

Facility Code: 25260
Last Inspected On: 03/27/2024
Operating Permit Renewal Date: 06/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Inver Grove Heights (800) 232-3638 mary.blel@chsinc.com

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Michael Gourley;CHS Inc Inver Grove Heights;Robin McCurdy;Will Dukart (406) 370-3920;(800) 232-3638;(406) 541-6800;(406) 543-8383;(406) 546-4885 chuck.thompson@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;mary.blel@chsinc.com;robin.mccurdy@chsinc.com;will.dukart@chsinc.com

Owner/Operator: CHS Inc Inver Grove Heights (800) 232-3638 mary.blel@chsinc.com

Bill Griffin, UST Class B Operator
Bob Westin, UST Class A Operator
Bob Westin, UST Class B Global Operator
Dusty Smith, UST Class A Operator
Dusty Smith, UST Class B Global Operator
John Thompson, UST Class A Operator
John Thompson, UST Class B Global Operator
John Thompson, UST Class B Operator
Michael Gourley, UST Class A Operator
Mike Dunlon, UST Class B Operator
Robin McCurdy, UST Class A Operator
Robin McCurdy, UST Class B Operator
Will Dukart, UST Class A Operator

dusty.smith@chsinc.com
dusty.smith@chsinc.com
chuck.thompson@chsinc.com
chuck.thompson@chsinc.com
chuck.thompson@chsinc.com
mary.blel@chsinc.com
michael.dunlop@chsinc.com
robin.mccurdy@chsinc.com
robin.mccurdy@chsinc.com
will.dukart@chsinc.com

Tank Code	16	Tank Age	31	Tank Installed Date	03/29/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	2859	Spill Test Date	10/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	03/27/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/27/2024	Line Tightness Test Date	06/12/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	17	Tank Age	12	Tank Installed Date	11/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5554	Spill Test Date	10/07/2021	Piping Installed Date	01/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	03/27/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/27/2024	Line Tightness Test Date	01/16/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	18	Tank Age	12	Tank Installed Date	11/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5555	Spill Test Date	10/07/2021	Piping Installed Date	01/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	03/27/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	25000	ATG Test Date	03/27/2024	Line Tightness Test Date	01/16/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	19	Tank Age	12	Tank Installed Date	11/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5556	Spill Test Date	10/07/2021	Piping Installed Date	01/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	03/27/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2024	Line Tightness Test Date	01/16/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	20	Tank Age	12	Tank Installed Date	11/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5557	Spill Test Date	10/07/2021	Piping Installed Date	01/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	03/27/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/27/2024	Line Tightness Test Date	01/16/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	21	Tank Age	12	Tank Installed Date	11/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5558	Spill Test Date	10/07/2021	Piping Installed Date	01/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	03/27/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2024	Line Tightness Test Date	01/16/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	22	Tank Age	12	Tank Installed Date	11/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5559	Spill Test Date	10/07/2021	Piping Installed Date	01/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	03/27/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	03/27/2024	Line Tightness Test Date	09/16/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: MURALTS TRUCK PLAZA
8800 Truck Stop Rd
Missoula, MT 59808-9708 Missoula

System Facility ID:32-00146

Facility Code: 25157
Last Inspected On: 12/20/2023
Operating Permit Renewal Date: 01/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Muralts Inc;Walter Muralt (406) 728-4700 walt@muralts.com

Operator Contact: Curtis Wilson curtis@muralts.com

Owner/Operator: Muralts Inc (406) 728-4700

Owner/Operator: Walter Muralt (406) 728-4700

Bonnie Kelley, UST Class B Global Operator
Curtis Wilson, UST Class A Operator
Curtis Wilson, UST Class B Operator
Kevin Linton, UST Class B Operator

bonnie@muralts.com
curtis@muralts.com
curtis@muralts.com
jesselinton14@gmail.com

Tank Code	10	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1734	Spill Test Date		Piping Installed Date	01/12/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	05/19/2009	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1735	Spill Test Date		Piping Installed Date	01/12/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	05/19/2009	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	01	Tank Age	58	Tank Installed Date	03/26/1968	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3650	Spill Test Date		Piping Installed Date	01/12/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	07/23/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	58	Tank Installed Date	03/26/1968	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3651	Spill Test Date		Piping Installed Date	01/12/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	07/23/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	58	Tank Installed Date	03/26/1968	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3652	Spill Test Date		Piping Installed Date	01/12/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	07/23/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	58	Tank Installed Date	03/26/1968	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve

Tag Number	3653	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	07/23/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	58	Tank Installed Date	03/26/1968	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3654	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	07/23/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	53	Tank Installed Date	03/26/1973	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3655	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	12/17/2020	Tank/Piping CP Test Date	07/23/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 11
1600 S Russell St
Missoula, MT 59801-5637 Missoula

System Facility ID:32-04620

Facility Code: 25345
Last Inspected On: 10/22/2024
Operating Permit Renewal Date: 03/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: DDJ Investments LLC;Jennifer Louquet (406) 728-7618 olescs11@gmail.com

Operator Contact: Derek Louquet (406) 369-5855 derek.louquet@gmail.com

Owner/Operator: DDJ Investments LLC (406) 728-7618 olescs11@gmail.com
Owner/Operator: Jennifer Louquet (406) 728-7618 olescs11@gmail.com
 Derek Louquet, UST Class A Operator derek.louquet@gmail.com
 Mary Fleming, UST Class B Operator olescs11@gmail.com

Tank Code	04	Tank Age	38	Tank Installed Date	10/30/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1721	Spill Test Date	04/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/23/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	02/06/2024	Line Tightness Test Date	02/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/06/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	38	Tank Installed Date	10/30/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1722	Spill Test Date	10/27/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/23/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/06/2024	Line Tightness Test Date	02/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/06/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	38	Tank Installed Date	10/30/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1723	Spill Test Date	10/27/2021	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/23/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/06/2024	Line Tightness Test Date	02/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/06/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 12
3705 MT Hwy 200 E
Missoula, MT 59802 Missoula

System Facility ID:32-03190

Facility Code: 25284
Last Inspected On: 10/29/2025
Operating Permit Renewal Date: 02/09/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tri East Inc (406) 728-7736

Operator Contact: Peggy Wolfe peggy_wlf@yahoo.com

Owner/Operator: Tri East Inc (406) 728-7736

LeeAnn Dean, UST Class B Global Operator
Peggy Wolfe, UST Class A Operator
Peggy Wolfe, UST Class B Operator

peggy_wlf@yahoo.com
peggy_wlf@yahoo.com

Tank Code	01	Tank Age	62	Tank Installed Date	05/01/1964	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1427	Spill Test Date	07/24/2025	Piping Installed Date	01/11/2018	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/21/2025	Tank/Piping CP Test Date	10/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/21/2025	Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	62	Tank Installed Date	05/01/1964	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1428	Spill Test Date	07/24/2025	Piping Installed Date	01/11/2018	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/21/2025	Tank/Piping CP Test Date	10/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/21/2025	Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	62	Tank Installed Date	05/01/1964	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1429	Spill Test Date	07/24/2025	Piping Installed Date	01/11/2018	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/21/2025	Tank/Piping CP Test Date	10/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/21/2025	Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	62	Tank Installed Date	05/01/1964	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1430	Spill Test Date	07/24/2025	Piping Installed Date	01/11/2018	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/21/2025	Tank/Piping CP Test Date	10/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/21/2025	Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	47	Tank Installed Date	05/02/1979	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1431	Spill Test Date	07/24/2025	Piping Installed Date	01/11/2018	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/21/2025	Tank/Piping CP Test Date	10/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/21/2025	Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 2
923 N Orange St
Missoula, MT 59802-2927 Missoula

System Facility ID:32-05216

Facility Code: 25359
Last Inspected On: 01/28/2026
Operating Permit Renewal Date: 03/14/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Oles Country Stores Inc Missoula (406) 542-2224 olesmanager@aol.com

Operator Contact: Casie Schwindt;Scott Denning;Oles Country Stores Inc Missoula (406) 880-7272;(406) 542-2224 rschwindt92@yahoo.com;scottden22@yahoo.com;olesmanager@aol.com

Owner/Operator: Oles Country Stores Inc Missoula (406) 542-2224 olesmanager@aol.com
 Casie Schwindt, UST Class A Operator rschwindt92@yahoo.com
 Casie Schwindt, UST Class B Operator rschwindt92@yahoo.com
 Scott Denning, UST Class A Operator olesmanager@aol.com
 Scott Denning, UST Class B Operator olesmanager@aol.com

Tank Code	04	Tank Age	36	Tank Installed Date	09/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2357	Spill Test Date	12/02/2025	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/02/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	12/02/2025	Line Tightness Test Date	12/02/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/09/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	36	Tank Installed Date	09/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2358	Spill Test Date	12/02/2025	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/02/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/02/2025	Line Tightness Test Date	12/02/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/09/2022			ATG Type	Gilbarco/EMC Basic				

Tank Code	06	Tank Age	36	Tank Installed Date	09/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2359	Spill Test Date	12/02/2025	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/02/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/02/2025	Line Tightness Test Date	12/02/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/09/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 Raser Dr
Missoula, MT 59808-1534 Missoula

System Facility ID:32-08732

Facility Code: 25472
Last Inspected On: 01/23/2025
Operating Permit Renewal Date: 06/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal

allen.eggen@p66.com

Operator Contact: Chris Cote;Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal;Tanner Beadles;Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal

chris.r.cote@p66.com;allen.eggen@p66.com;tanner.j.beadles@p66.com;allen.eggen@p66.com

Owner/Operator: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal

allen.eggen@p66.com

Andrew Snyder, UST Class B Operator

andrew.a.snyder@conocophillips.com

Chris Binder, UST Class B Operator

Chris Cote, UST Class A Operator

allen.eggen@p66.com

Chris Cote, UST Class B Operator

allen.eggen@p66.com

Dusty Nagel, UST Class B Operator

dusty.a.nagel@p66.com

Orlando Rodriguez, UST Class B Operator

orlando.r.rodriquez@conocophillips.com

Tanner Beadles, UST Class A Operator

allen.eggen@p66.com

Tanner Beadles, UST Class B Operator

allen.eggen@p66.com

Tank Code	S15	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2793	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	630000	ATG Test Date		Line Tightness Test Date	09/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S18	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2796	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No

Capacity	1260000	ATG Test Date		Line Tightness Test Date	09/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S19	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2797	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	647892	ATG Test Date		Line Tightness Test Date	08/30/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S23	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2800	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	847000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S24	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2801	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	847000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S25	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2802	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No

Capacity	648000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S26	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2803	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	648000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S13	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4581	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	630000	ATG Test Date		Line Tightness Test Date	09/04/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S17	Tank Age	72	Tank Installed Date	06/01/1954	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4909	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	08/29/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED MISSOULA
 TERMINAL
 3330 Raser Dr
 Missoula, MT 59808-1534 Missoula

System Facility ID:32-03320

Facility Code: 25289
Last Inspected On: 01/23/2025
Operating Permit Renewal Date: 06/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal

allen.eggen@p66.com

Operator Contact: Adam Pfeifer;Dusty Nagel

adam.pfeifer@p66.com;dusty.a.nagel@p66.com

Owner/Operator: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal

allen.eggen@p66.com

Adam Pfeifer, UST Class A Operator

adam.pfeifer@p66.com

Adam Pfeifer, UST Class B Global Operator

adam.pfeifer@p66.com

Andrew Snyder, UST Class B Operator

andrew.a.snyder@conocophillips.com

Chris Binder, UST Class B Operator

Dustin Rogers, UST Class B Operator

dustin.w.rogers@conocophilips.com

Dusty Nagel, UST Class A Operator

dusty.a.nagel@p66.com

Dusty Nagel, UST Class B Operator

dusty.a.nagel@p66.com

Marcus Eppard, UST Class B Operator

marcus.k.eppard@p66.com

Orlando Rodriguez, UST Class B Operator

orlando.r.rodriquez@conocophillips.com

Tank Code	22	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel - Terminal Piping	Overfill Types	High Level Alarm
Tag Number	738	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/22/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S09	Tank Age	73	Tank Installed Date	01/01/1953	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	739	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	09/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S11	Tank Age	73	Tank Installed Date	01/01/1953	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	741	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	09/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S13	Tank Age	73	Tank Installed Date	01/01/1953	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	743	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	09/16/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S15	Tank Age	73	Tank Installed Date	01/01/1953	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	745	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasohol/Ethanol	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	08/27/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S17	Tank Age	54	Tank Installed Date	01/01/1972	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	747	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	09/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S19	Tank Age	52	Tank Installed Date	01/01/1974	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	749	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	4200000	ATG Test Date		Line Tightness Test Date	09/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S20	Tank Age	52	Tank Installed Date	01/01/1974	Tank Material	Cathodically Protected Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	750	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	2646000	ATG Test Date		Line Tightness Test Date	09/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: PROVIDENCE CENTER
900 N Orange St
Missoula, MT 59802-2998 Missoula

System Facility ID:32-13405

Facility Code: 25746
Last Inspected On: 11/12/2023
Operating Permit Renewal Date: 04/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Saint Patricks Hospital

(406) 543-7271

Operator Contact: Timothy Chopp

tchopp@saintpatrick.org

Owner/Operator: Saint Patricks Hospital

(406) 543-7271

Harry McGuire, UST Class B Operator
Timothy Chopp, UST Class A Operator
Timothy Chopp, UST Class B Operator

tchopp@saintpatrick.org
tchopp@saintpatrick.org

Tank Code	02	Tank Age	31	Tank Installed Date	08/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1960	Spill Test Date	11/06/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2500	ATG Test Date	11/06/2023	Line Tightness Test Date	02/12/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: RANGITSCH BROTHERS 2001 WEST BROADWAY
2001 W Broadway St
Missoula, MT 59808-1817 Missoula

System Facility ID:32-09919

Facility Code: 25529
Last Inspected On: 03/05/2026
Operating Permit Renewal Date: 10/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rangitsch Brothers

service1@rangitschbrosv.com.

Operator Contact: Gerry Wolner;Joel Jasperson

(406) 721-7561

joelj@rangitschbrosv.com;service1@rangitschbrosv.com.

Owner/Operator: Rangitsch Brothers

service1@rangitschbrosv.com.

David Crowder, UST Class B Operator
Gerry Wolner, UST Class A Operator
Joel Jasperson, UST Class A Operator
Joel Jasperson, UST Class B Operator
Russ Dickey, UST Class B Operator

acewheeler65@gmail.com
service1@rangitschbrosv.com.
joelj@rangitschbrosv.com
joelj@rangitschbrosv.com
service2@rangitschbrosv.com

Tank Code	03	Tank Age	27	Tank Installed Date	01/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3917	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	10/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/01/2025			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Missoula County in the City of Missoula

Location: ROSAUERS 127 FUEL STATION
2350 S Reserve St
Missoula, MT 59801 Missoula

System Facility ID:60-15318

Facility Code: 31015
Last Inspected On: 09/23/2024
Operating Permit Renewal Date: 12/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rosauers Supermarkets Inc Marshall (509) 326-8900 lillig@rosauers.com

Operator Contact: Dean Hansen;Paco Sutton (406) 721-5430 127mgr@rosauers.com

Owner/Operator: Rosauers Supermarkets Inc Marshall (509) 326-8900 lillig@rosauers.com
 Dean Hansen, UST Class A Operator 127mgr@rosauers.com
 Dean Hansen, UST Class B Operator 127mgr@rosauers.com
 Paco Sutton, UST Class A Operator 127mgr@rosauers.com
 Paco Sutton, UST Class B Operator 127mgr@rosauers.com

Tank Code	01	Tank Age	8	Tank Installed Date	06/21/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5814	Spill Test Date	08/31/2021	Piping Installed Date	06/24/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	04/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/10/2025			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	8	Tank Installed Date	06/21/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5815	Spill Test Date	07/25/2024	Piping Installed Date	06/24/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	9000	ATG Test Date	04/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	04/10/2025			ATG Type	Incon/TS-550 EVO				
Tank Code	03	Tank Age	8	Tank Installed Date	06/21/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5816	Spill Test Date	07/25/2024	Piping Installed Date	06/24/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	04/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/10/2025			ATG Type	Incon/TS-550 EVO				

Facility Summary in Missoula County in the City of Missoula

Location: SILVER SLIPPER
4055 Hwy 93 S
Missoula, MT 59804-7300 Missoula

System Facility ID:32-13711

Facility Code: 25780
Last Inspected On: 08/18/2023
Operating Permit Renewal Date: 08/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Noah Castle;Preslyn LLC (406) 251-5402 noahcastle@hotmail.com

Operator Contact: Melissa Rausch (406) 253-4921 thesilverslippermissoula@gmail.com

Owner/Operator: Noah Castle (406) 251-5402 noahcastle@hotmail.com
Owner/Operator: Preslyn LLC (406) 251-5402 noahcastle@hotmail.com
 Melissa Rausch, UST Class A Operator thesilverslippermissoula@gmail.com
 Melissa Rausch, UST Class B Operator thesilverslippermissoula@gmail.com

Tank Code	01	Tank Age	30	Tank Installed Date	03/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3251	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	30	Tank Installed Date	03/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3252	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	03	Tank Age	30	Tank Installed Date	03/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3253	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Missoula

Location: SORENSEN TRANSPORT
6575 US Hwy 10 W
Missoula, MT 59808-9086 Missoula

System Facility ID:32-13428

Facility Code: 25748
Last Inspected On: 05/30/2024
Operating Permit Renewal Date: 10/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sorensen Transport (406) 721-5404 jake@sorco-inc.com

Operator Contact: Lane Sorensen (406) 721-5404 Isorensen@trans-system.com

Owner/Operator: Sorensen Transport (406) 721-5404 jake@sorco-inc.com
Lane Sorensen, UST Class A Operator Isorensen@trans-system.com
Lane Sorensen, UST Class B Operator Isorensen@trans-system.com

Tank Code	02	Tank Age	11	Tank Installed Date	06/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5576	Spill Test Date	05/30/2024	Piping Installed Date	06/04/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/30/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/30/2024	Line Tightness Test Date	06/03/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/30/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: SOUTH AVENUE MARKET #11
2401 S Higgins Ave
Missoula, MT 59801 Missoula

System Facility ID:32-05764

Facility Code: 25381
Last Inspected On: 10/29/2025
Operating Permit Renewal Date: 02/19/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Operator Contact: Manpreet Singh;Hi-Star Properties LLC (509) 994-6599;(509) 994-6599 histarms01@yahoo.com;histarms3@yahoo.com

Owner/Operator: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Manpreet Singh, UST Class A Operator histarms3@yahoo.com

Manpreet Singh, UST Class B Operator histarms3@yahoo.com

Tank Code	02	Tank Age	45	Tank Installed Date	04/26/1981	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3849	Spill Test Date	11/05/2024	Piping Installed Date	07/21/2000	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/29/2025	Tank/Piping CP Test Date	11/05/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	45	Tank Installed Date	04/26/1981	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3850	Spill Test Date	11/05/2024	Piping Installed Date	07/21/2000	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/29/2025	Tank/Piping CP Test Date	11/05/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	01	Tank Age	45	Tank Installed Date	04/26/1981	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4668	Spill Test Date	11/05/2024	Piping Installed Date	07/21/2000	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/21/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/29/2025	Tank/Piping CP Test Date	11/05/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/29/2025	Line Tightness Test Date	02/21/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: SOUTHGATE MARKET
1900 South Ave W
Missoula, MT 59801-6508 Missoula

System Facility ID:32-08862

Facility Code: 25477
Last Inspected On: 01/26/2024
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Inc DBA Southgate Market (406) 549-1750 jaysfood08@yahoo.com

Operator Contact: Jagpreet Ghuman;Jays 1 Stop;Jaspal Sandhu;Jays Corporation (406) 549-1750;(406) 880-7677;(406) 549-1031 jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com;jays1stop21@outlook.com

Owner/Operator: Jays Inc DBA Southgate Market (406) 549-1750 jaysfood08@yahoo.com
 Jagpreet Ghuman, UST Class A Operator jays1stop21@outlook.com
 Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
 Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
 Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

Tank Code	01	Tank Age	41	Tank Installed Date	12/23/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1354	Spill Test Date	01/25/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date	01/25/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/25/2024	Line Tightness Test Date	01/28/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	12/23/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1355	Spill Test Date	01/25/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date	01/25/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/25/2024	Line Tightness Test Date	01/28/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	41	Tank Installed Date	12/23/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1356	Spill Test Date	01/25/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date	01/25/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/25/2024	Line Tightness Test Date	01/28/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: SPRINT MISSOULA POP
2515 Railroad St W
Missoula, MT 59808-1680 Missoula

System Facility ID:56-14010

Facility Code: 30670
Last Inspected On: 04/18/2023
Operating Permit Renewal Date: 08/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sprint Communications Co LLP (913) 762-5957

Operator Contact: Brian Schmitt; Brian Wiedower (913) 315-8631 brian.c.wiedower@sprint.com; brian.schmitt@bolininc.com

Owner/Operator: Sprint Communications Co LLP (913) 762-5957

Brian Schmitt, UST Class A Operator
Brian Schmitt, UST Class B Operator
Brian Wiedower, UST Class A Operator
Matt Santee, UST Class B Global Operator
Scott Hallesy, UST Class B Operator

brian.schmitt@bolininc.com
brian.schmitt@bolininc.com
brian.c.wiedower@sprint.com
matt.santee@bolininc.com
scott.g.hallesy@sprint.com

Tank Code	01	Tank Age	25	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve; High Level Alarm
Tag Number	4321	Spill Test Date	03/13/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test; Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2500	ATG Test Date	04/24/2024	Line Tightness Test Date	04/18/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: ST PATRICKS HOSPITAL
500 W Broadway St
Missoula, MT 59802-4008 Missoula

System Facility ID:32-04266

Facility Code: 25338
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 05/29/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Saint Patricks Hospital

(406) 543-7271

Operator Contact: Timothy Chopp

tchopp@saintpatrick.org

Owner/Operator: Saint Patricks Hospital

(406) 543-7271

Timothy Chopp, UST Class A Operator
Timothy Chopp, UST Class B Operator

tchopp@saintpatrick.org
tchopp@saintpatrick.org

Tank Code	03	Tank Age	25	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4497	Spill Test Date	11/06/2023	Piping Installed Date	02/29/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/06/2023	Line Tightness Test Date	11/06/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				
Tank Code	04	Tank Age	18	Tank Installed Date	07/18/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5175	Spill Test Date	11/06/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No

Capacity	10000	ATG Test Date	11/06/2023	Line Tightness Test Date	11/06/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	11/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: STAR TRAVEL PLAZA
5318 W Harrier
Missoula, MT 59801 Missoula

System Facility ID:60-15010

Facility Code: 30800
Last Inspected On: 02/07/2024
Operating Permit Renewal Date: 04/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Manpreet Singh;Hi-Star Properties LLC (509) 994-6599;(509) 994-6599 histarms01@yahoo.com;histarms3@yahoo.com

Operator Contact: Dean Clinkenbeard;Sheri Taylor (406) 543-8885 office.dcp@bresnan.net;office.dcp@gmail.com

Owner/Operator: Manpreet Singh,Hi-Star Properties LLC (509) 994-6599 histarms01@yahoo.com

Dean Clinkenbeard, UST Class A Operator office.dcp@bresnan.net
Dean Clinkenbeard, UST Class B Global Operator office.dcp@bresnan.net
Sheri Taylor, UST Class A Operator office.dcp@gmail.com
Sheri Taylor, UST Class B Operator office.dcp@gmail.com

Tank Code	01	Tank Age	20	Tank Installed Date	01/17/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5027	Spill Test Date	01/10/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/17/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/17/2023	Line Tightness Test Date	09/10/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/10/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	02	Tank Age	20	Tank Installed Date	01/17/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5028	Spill Test Date	01/10/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/17/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/17/2023	Line Tightness Test Date	02/07/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/10/2024			ATG Type	Gilbarco/TLS-350				

Tank Code	03	Tank Age	20	Tank Installed Date	01/17/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5029	Spill Test Date	01/10/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/17/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/17/2023	Line Tightness Test Date	02/07/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/10/2024			ATG Type	Gilbarco/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: STAR TRAVEL PLAZA 2
5055 N Reserve St
Missoula, MT 59808-1401 Missoula

System Facility ID:32-03610

Facility Code: 25301
Last Inspected On: 10/30/2025
Operating Permit Renewal Date: 12/21/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Manpreet Singh;Hi-Star Properties LLC (509) 994-6599;(509) 994-6599 histarms01@yahoo.com;histarms3@yahoo.com

Operator Contact: Jeffrey Toole;Hi Star Properties LLC;Sheri Taylor (406) 543-8885 histar.jeff@gmail.com;jaysmart09@yahoo.com;office.dcp@gmail.com

Owner/Operator: Manpreet Singh,Hi-Star Properties LLC (509) 994-6599 histarms01@yahoo.com
Jeffrey Toole, UST Class A Operator jaysmart09@yahoo.com
Jeffrey Toole, UST Class B Operator jaysmart09@yahoo.com
Sheri Taylor, UST Class A Operator office.dcp@gmail.com

Tank Code	06	Tank Age	35	Tank Installed Date	04/02/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	795	Spill Test Date	10/14/2025	Piping Installed Date	06/22/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/14/2025	Tank/Piping CP Test Date	10/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/14/2025	Line Tightness Test Date	07/22/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/14/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	35	Tank Installed Date	04/02/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	796	Spill Test Date	10/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/14/2025	Tank/Piping CP Test Date	10/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/14/2025	Line Tightness Test Date	07/23/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/14/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	08	Tank Age	35	Tank Installed Date	04/02/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	797	Spill Test Date	10/14/2025	Piping Installed Date	06/22/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/14/2025	Tank/Piping CP Test Date	10/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/14/2025	Line Tightness Test Date	07/23/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/14/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	35	Tank Installed Date	04/02/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	798	Spill Test Date	10/14/2025	Piping Installed Date	06/22/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/14/2025	Tank/Piping CP Test Date	10/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/14/2025	Line Tightness Test Date	07/25/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/14/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	35	Tank Installed Date	04/02/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	799	Spill Test Date	10/14/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/14/2025	Tank/Piping CP Test Date	10/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/14/2025	Line Tightness Test Date	08/22/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/14/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: TA MISSOULA
8018 US Hwy 93 N
Missoula, MT 59808 Missoula

System Facility ID:32-02822

Facility Code: 25272
Last Inspected On: 08/17/2023
Operating Permit Renewal Date: 10/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MISSOULA HOLDINGS MT, LLC (702) 522-8513 VAL@LVPETROLEUM.NET

Operator Contact: Gary Stilley;LV PETROLEUM (406) 239-8499;(702) 522-8513 tamissoula@lvpetroleum.net;VAL@LVPETROLEUM.NET

Owner/Operator: MISSOULA HOLDINGS MT, LLC (702) 522-8513 VAL@LVPETROLEUM.NET

Gary Stilley, UST Class A Operator
Gary Stilley, UST Class B Operator

VAL@LVPETROLEUM.NET
VAL@LVPETROLEUM.NET

Tank Code	13	Tank Age	12	Tank Installed Date	08/22/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5511	Spill Test Date		Piping Installed Date	07/29/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-4I, B, C				
Tank Code	14	Tank Age	11	Tank Installed Date	02/24/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5550	Spill Test Date	02/27/2026	Piping Installed Date	09/18/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/14/2025	Line Tightness Test Date	03/12/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/27/2026			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	15	Tank Age	11	Tank Installed Date	02/24/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5551	Spill Test Date	02/27/2026	Piping Installed Date	09/18/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/14/2025	Line Tightness Test Date	03/12/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/27/2026			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	16	Tank Age	7	Tank Installed Date	07/31/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5929	Spill Test Date	02/27/2026	Piping Installed Date	07/31/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/27/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	04/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	02/27/2026			ATG Type					
Tank Code	02	Tank Age	48	Tank Installed Date	02/17/1978	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	786	Spill Test Date	04/16/2026	Piping Installed Date	08/22/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/18/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/27/2026			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	48	Tank Installed Date	02/17/1978	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	787	Spill Test Date	02/27/2026	Piping Installed Date	08/22/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/27/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/19/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	02/27/2026			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	33	Tank Installed Date	11/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	788	Spill Test Date	02/27/2026	Piping Installed Date	08/22/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/30/2020	Tank/Piping CP Test Date	05/16/2020	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	04/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	02/27/2026			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	33	Tank Installed Date	11/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	789	Spill Test Date	02/27/2026	Piping Installed Date	08/22/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/16/2020	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/04/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	02/27/2026			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	33	Tank Installed Date	11/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	790	Spill Test Date	02/27/2026	Piping Installed Date	11/03/2010	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	02/27/2026	Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	04/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	02/27/2026			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	12	Tank Age	33	Tank Installed Date	11/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	791	Spill Test Date	02/27/2026	Piping Installed Date	11/03/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	02/27/2026	Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	04/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: TABISH BROTHERS DISTRIBUTORS INC
501 Taylor St
Missoula, MT 59802-4920 Missoula

System Facility ID:32-06523

Facility Code: 25407
Last Inspected On: 02/04/2026
Operating Permit Renewal Date: 06/22/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Operator Contact: Heather Stiles

hstiles@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc

lss@gwpetrol.com

Heather Stiles, UST Class A Operator

hstiles@gwpetrol.com

Heather Stiles, UST Class B Global Operator

hstiles@gwpetrol.com

Tank Code	01	Tank Age	45	Tank Installed Date	04/16/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2080	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7600	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	45	Tank Installed Date	04/16/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2081	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7600	ATG Test Date	06/17/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Missoula County in the City of Missoula

Location: THE OLDE DAIRY
2106 Clements Rd
Missoula, MT 59804-6212 Missoula

System Facility ID:32-08475

Facility Code: 25464
Last Inspected On: 03/27/2026
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dale Johnson;Target Range Development LLC (406) 721-3322;(406) 721-3323 mark@theoldedairy.com

Operator Contact: Jessica Rogers;Target Range Development LLC (406) 721-3323 jessica@theoldedairy.com;mark@theoldedairy.com

Owner/Operator: Dale L Johnson (406) 721-3322

Owner/Operator: Target Range Development LLC (406) 721-3322

Jessica Rogers, UST Class A Operator
Jessica Rogers, UST Class B Operator

mark@theoldedairy.com
mark@theoldedairy.com

Tank Code	05	Tank Age	27	Tank Installed Date	03/23/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4086	Spill Test Date	08/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/01/2025			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	06	Tank Age	27	Tank Installed Date	03/23/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4087	Spill Test Date	08/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/14/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/01/2025	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	10/01/2025			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	07	Tank Age	27	Tank Installed Date	03/23/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4088	Spill Test Date	08/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/01/2025			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 1
5310 Grant Creek Rd
Missoula, MT 59808-1483 Missoula

System Facility ID:32-13336

Facility Code: 25739
Last Inspected On: 06/09/2023
Operating Permit Renewal Date: 10/28/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Missoula 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	33	Tank Installed Date	12/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2342	Spill Test Date	08/25/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date	03/19/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	33	Tank Installed Date	12/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2343	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date	03/19/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	33	Tank Installed Date	12/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2344	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date	03/19/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	33	Tank Installed Date	12/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2345	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date	03/19/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	17	Tank Installed Date	01/25/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5196	Spill Test Date		Piping Installed Date	01/25/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date	01/11/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	17	Tank Installed Date	01/25/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5197	Spill Test Date	02/10/2026	Piping Installed Date	01/25/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	

Product	Diesel	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date	01/11/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 3
2210 N Reserve St
Missoula, MT 59808-1323 Missoula

System Facility ID:32-13172

Facility Code: 25725
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Missoula 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2559	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/05/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	09/22/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2560	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/05/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	09/22/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2561	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/05/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	09/30/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2562	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/05/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	09/30/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2563	Spill Test Date	10/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/05/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	09/30/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 8
3420 Mullan Rd Ste A
Missoula, MT 59808-5126 Missoula

System Facility ID:56-13823

Facility Code: 30509
Last Inspected On: 01/07/2026
Operating Permit Renewal Date: 06/21/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula 8 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Missoula 8 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1444	Spill Test Date	06/25/2025	Piping Installed Date	05/24/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/07/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/07/2026	Line Tightness Test Date	05/05/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/25/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1445	Spill Test Date	06/25/2025	Piping Installed Date	05/24/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/07/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/07/2026	Line Tightness Test Date	05/18/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/25/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1446	Spill Test Date	06/25/2025	Piping Installed Date	05/24/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/07/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	01/07/2026	Line Tightness Test Date	05/17/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/25/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	10	Tank Installed Date	05/24/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5629	Spill Test Date	06/25/2025	Piping Installed Date	05/24/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/07/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	01/07/2026	Line Tightness Test Date	05/18/2016	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/25/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP MISSOULA 9
2001 Brooks St
Missoula, MT 59808 Missoula

System Facility ID:60-15288

Facility Code: 30995
Last Inspected On: 01/07/2026
Operating Permit Renewal Date: 06/22/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Missoula 9 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Missoula 9 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Operator

Trentb@townpump.com

Tank Code	01	Tank Age	9	Tank Installed Date	03/28/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5683	Spill Test Date	06/26/2025	Piping Installed Date	03/28/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/07/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	25000	ATG Test Date	01/07/2026	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/26/2025			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	9	Tank Installed Date	03/28/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5684	Spill Test Date	09/09/2025	Piping Installed Date	03/28/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/07/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	01/07/2026	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/26/2025			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	9	Tank Installed Date	03/28/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5685	Spill Test Date	06/26/2025	Piping Installed Date	03/28/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/07/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/07/2026	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/26/2025			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Missoula County in the City of Missoula

Location: UNITED PARCEL SERVICES MISSOULA
221 Expressway Ln
Missoula, MT 59808-1553 Missoula

System Facility ID:32-04536

Facility Code: 25343
Last Inspected On: 07/17/2025
Operating Permit Renewal Date: 10/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: United Parcel Service Inc Seattle

cdd6jxd@ups.com

Operator Contact: Dino Ostrow;Jonathan Dunbar;United Parcel Service Inc Seattle

(503) 329-7154

dostrow@ups.com;jxdunbar@ups.com;cdd6jxd@ups.com

Owner/Operator: United Parcel Service Inc Seattle

cdd6jxd@ups.com

Dino Ostrow, UST Class A Operator

dostrow@ups.com

Dino Ostrow, UST Class B Operator

dostrow@ups.com

Jonathan Dunbar, UST Class A Operator

cdd6jxd@ups.com

Jonathan Dunbar, UST Class B Operator

cdd6jxd@ups.com

Tank Code	04	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2182	Spill Test Date	04/28/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/28/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/28/2025	Line Tightness Test Date	04/28/2025	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: WESTERN TRANSPORT
9310 Cartage Rd
Missoula, MT 59808-9758 Missoula

System Facility ID:32-01348

Facility Code: 25211
Last Inspected On: 04/17/2025
Operating Permit Renewal Date: 04/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Western Land Investments LLC (307) 674-6305

Operator Contact: Cari Goss (307) 674-6305 cari@westerntransllc.com

Owner/Operator: Western Land Investments LLC (307) 674-6305
Cari Goss, UST Class A Operator cari@westerntransllc.com

Tank Code	01	Tank Age	58	Tank Installed Date	01/17/1968	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1654	Spill Test Date	09/29/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/26/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	09/30/2021	Line Tightness Test Date	09/12/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-250				
Tank Code	02	Tank Age	58	Tank Installed Date	01/17/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1655	Spill Test Date	09/29/2021	Piping Installed Date	12/11/2006	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	03/22/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/26/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/30/2021	Line Tightness Test Date	03/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-250				
Tank Code	03	Tank Age	45	Tank Installed Date	01/16/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1656	Spill Test Date		Piping Installed Date	12/11/2006	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/26/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/27/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-250				

Facility Summary in Missoula County in the City of Missoula

Location: WESTFIELD MISSOULA
8448 US Hwy 10 W
Missoula, MT 59808-9319 Missoula

System Facility ID:32-13674

Facility Code: 25776
Last Inspected On: 04/07/2026
Operating Permit Renewal Date: 07/22/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Finest Oil Co (406) 543-6969 finestoil@finest-oil.com

Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson (406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926 chrisglasser@hotmail.com;finestoil@finest-oil.com;jee-pin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com

Owner/Operator: Finest Oil Co (406) 543-6969 finestoil@finest-oil.com

Christopher Glasser, UST Class A Operator chrisglasser@hotmail.com
David Peyton, UST Class A Operator
David Peyton, UST Class B Global Operator
James Brady, UST Class A Operator jee-pin247.jb@gmail.com
James DeWaters, UST Class A Operator rivban22@gmail.com
Joseph McClain, UST Class B Operator jgmccclain25@gmail.com
Justin Gaudot, UST Class A Operator justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator justgaudot@yahoo.com
Stephen Hanson, UST Class A Operator finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator finestoil@finest-oil.com

Tank Code	01	Tank Age	31	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1077	Spill Test Date	04/28/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	31	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1078	Spill Test Date	04/28/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	31	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1079	Spill Test Date	04/28/2023	Piping Installed Date	09/19/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	31	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1080	Spill Test Date	04/28/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	31	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1081	Spill Test Date	04/28/2023	Piping Installed Date	05/17/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	12000	ATG Test Date	04/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	31	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1082	Spill Test Date	04/28/2023	Piping Installed Date	05/17/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: YOKES FRESH MARKET 21
800 W Broadway St
Missoula, MT 59802-3944 Missoula

System Facility ID:60-15098

Facility Code: 30858
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 06/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: YOKE'S FOOD INC (509) 921-2292

Operator Contact: Rebecca Spicer;Rich Thornock;Shari Goodmanson (406) 251-7170;(406) 721-2549
fuelmgr21@yokesfoods.com;MRMBR@YOKESFOODS.COM;sgoodmanson@yokesfoods.com

Owner/Operator: YOKE'S FOOD INC (509) 921-2292

Rebecca Spicer, UST Class A Operator
Rebecca Spicer, UST Class B Operator
Rich Thornock, UST Class A Operator
Rich Thornock, UST Class B Operator
Shari Goodmanson, UST Class A Operator
Shari Goodmanson, UST Class B Global Operator

fuelmgr21@yokesfoods.com
fuelmgr21@yokesfoods.com
MRMBR@YOKESFOODS.COM
MRMBR@YOKESFOODS.COM
sgoodmanson@yokesfoods.com
sgoodmanson@yokesfoods.com

Tank Code	01	Tank Age	18	Tank Installed Date	08/08/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5167	Spill Test Date	10/01/2024	Piping Installed Date	07/01/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/09/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/01/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	18	Tank Installed Date	08/01/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5168	Spill Test Date	10/01/2024	Piping Installed Date	07/01/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/09/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	04/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/01/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	18	Tank Installed Date	08/01/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5169	Spill Test Date	04/09/2024	Piping Installed Date	07/01/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/09/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/01/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;OPW / EMCO/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: YOKES FRESH MARKET 22
3801 S Reserve St
Missoula, MT 59801-7322 Missoula

System Facility ID:56-14025

Facility Code: 30684
Last Inspected On: 10/14/2025
Operating Permit Renewal Date: 01/04/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: YOKE'S FOOD INC (509) 921-2292

Operator Contact: Brittany Zeller;Charles Franklin;Jason Rhinehart;YOKE'S FOOD INC;Shari Goodmanson (406) 251-3311;(406) 251-7170;(509) 921-2292 mrasst@yokesfoods.com;MRMGR@YOKESFOODS.COM;pipsnchips2@gmail.com;sgoodmanson@yokesfoods.com

Owner/Operator: YOKE'S FOOD INC (509) 921-2292

Brittany Zeller, UST Class A Operator
Charles Franklin, UST Class A Operator
Charles Franklin, UST Class B Global Operator
Jason Rhinehart, UST Class A Operator
Shari Goodmanson, UST Class A Operator
Shari Goodmanson, UST Class B Global Operator

MRMGR@YOKESFOODS.COM
pipsnchips2@gmail.com
pipsnchips2@gmail.com
mrasst@yokesfoods.com
sgoodmanson@yokesfoods.com
sgoodmanson@yokesfoods.com

Tank Code	01	Tank Age	25	Tank Installed Date	09/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4416	Spill Test Date	08/28/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/28/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/28/2025	Line Tightness Test Date	01/16/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/28/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	25	Tank Installed Date	09/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4417	Spill Test Date	08/28/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	08/28/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/28/2025	Line Tightness Test Date	01/17/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/28/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	25	Tank Installed Date	09/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4418	Spill Test Date	08/28/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/28/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/28/2025	Line Tightness Test Date	07/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/28/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 31
3325 Brooks St
Missoula, MT 59801-8289 Missoula

System Facility ID:32-09730

Facility Code: 25516
Last Inspected On: 02/05/2025
Operating Permit Renewal Date: 05/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jason Brenner, UST Class B Operator jason.brenner@chsinc.com
 Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com

Tank Code	01	Tank Age	38	Tank Installed Date	03/18/1988	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1363	Spill Test Date	02/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/04/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date	08/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	38	Tank Installed Date	03/18/1988	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1364	Spill Test Date	02/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/06/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date	08/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	02/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	38	Tank Installed Date	03/18/1988	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1365	Spill Test Date	02/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/04/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date	08/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 32
1540 Toole Ave
Missoula, MT 59802-2241 Missoula

System Facility ID:32-03912

Facility Code: 25317
Last Inspected On: 11/06/2025
Operating Permit Renewal Date: 02/04/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jason Brenner, UST Class B Operator jason.brenner@chsinc.com
 Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com

Tank Code	01	Tank Age	42	Tank Installed Date	03/22/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1342	Spill Test Date	11/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/04/2025	Tank/Piping CP Test Date	11/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2025	Line Tightness Test Date	07/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	42	Tank Installed Date	03/22/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1343	Spill Test Date	11/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/04/2025	Tank/Piping CP Test Date	11/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2025	Line Tightness Test Date	07/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	11/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	42	Tank Installed Date	03/22/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1344	Spill Test Date	11/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/04/2025	Tank/Piping CP Test Date	11/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2025	Line Tightness Test Date	07/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: ZOOTOWN SUPER STOP
2105 S Higgins Ave
Missoula, MT 59801-6714 Missoula

System Facility ID:32-07244

Facility Code: 25429
Last Inspected On: 12/20/2023
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Greg Tabish

zootown@gwpetrol.com

Operator Contact: Daniel Marx;Erin Keffeler;Karly Shafer;Yvonne Bunch

(406) 274-2435;(406) 396-2206;(406) 880-0056

DanielMarx@inmissoula.com;karly@gwpetrol.com;noons470@hi-noon.com;ybunch1@gmail.com

Owner/Operator: Greg Tabish

zootown@gwpetrol.com

Daniel Marx, UST Class A Operator
Daniel Marx, UST Class B Global Operator
Erin Keffeler, UST Class A Operator
Erin Keffeler, UST Class B Operator
Karly Shafer, UST Class A Operator
Karly Shafer, UST Class B Global Operator
Yvonne Bunch, UST Class A Operator
Yvonne Bunch, UST Class B Operator

DanielMarx@inmissoula.com
DanielMarx@inmissoula.com
noons470@hi-noon.com
noons470@hi-noon.com
karly@gwpetrol.com
karly@gwpetrol.com
ybunch1@gmail.com
ybunch1@gmail.com

Tank Code	03	Tank Age	36	Tank Installed Date	12/07/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1799	Spill Test Date	12/20/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	12/20/2023	Tank/Piping CP Test Date	12/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/20/2023	Line Tightness Test Date	07/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/20/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	36	Tank Installed Date	12/07/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1800	Spill Test Date	12/20/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	12/20/2023	Tank/Piping CP Test Date	12/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	6000	ATG Test Date	12/20/2023	Line Tightness Test Date	07/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/20/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	36	Tank Installed Date	12/07/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1801	Spill Test Date	12/20/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	12/20/2023	Tank/Piping CP Test Date	12/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/20/2023	Line Tightness Test Date	07/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/20/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: ZOOTOWN SUPER STOP 2
2125 S Higgins Ave
Missoula, MT 59801-6760 Missoula

System Facility ID:32-10053

Facility Code: 25541
Last Inspected On: 01/19/2024
Operating Permit Renewal Date: 01/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Western Petroleum (406) 728-7736

Operator Contact: Karly Shafer (406) 396-2206 karly@gwpetrol.com

Owner/Operator: Great Western Petroleum (406) 728-7736

Karly Shafer, UST Class A Operator
Karly Shafer, UST Class B Operator

karly@gwpetrol.com
karly@gwpetrol.com

Tank Code	08	Tank Age	36	Tank Installed Date	09/30/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2139	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	12/02/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	12/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	09	Tank Age	36	Tank Installed Date	09/30/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2140	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	12/02/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	12/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	10	Tank Age	36	Tank Installed Date	09/30/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2141	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	10/15/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	11	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6200	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Under Construction	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Seeley Lake

Location: 1 STOP SEELEY LAKE
3072 MT Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:32-09288

Facility Code: 25483
Last Inspected On: 04/10/2024
Operating Permit Renewal Date: 08/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MONTANA GAS N SHOP LLC (510) 714-5045 TONY@MONTANAGNS.COM

Operator Contact: Gurinderbir Muhar (408) 660-9884 gasnshop133@gmail.com

Owner/Operator: MONTANA GAS N SHOP LLC (510) 714-5045 TONY@MONTANAGNS.COM

Gurinderbir Muhar, UST Class A Operator
Gurinderbir Muhar, UST Class B Operator

gasnshop133@gmail.com
gasnshop133@gmail.com

Tank Code	S1	Tank Age	39	Tank Installed Date	04/22/1987	Tank Material		Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	416	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	10/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	39	Tank Installed Date	04/22/1987	Tank Material		Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	417	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	10/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	39	Tank Installed Date	04/22/1987	Tank Material		Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	418	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	Yes

Tank Status	Currently in Use	MLLD Test Date	10/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Missoula County in the City of Seeley Lake

Location: LINDEYS LANDING WEST SPB
 MT Hwy 83
 Seeley Lake, MT 59868 Missoula

System Facility ID:32-05837

Facility Code: 25389
Last Inspected On: 06/24/2023
Operating Permit Renewal Date: 10/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lindeys Inc Saint Paul (406) 677-9229

Operator Contact: Michael Lindemer (406) 677-4101 lindeys@blackfoot.net

Owner/Operator: Lindeys Inc Saint Paul (406) 677-9229

Michael Lindemer, UST Class A Operator
 Michael Lindemer, UST Class B Operator
 Tanner Stevenson, UST Class B Global Operator

lindeys@blackfoot.net
 lindeys@blackfoot.net
 jenco1992@gmail.com

Tank Code	S3	Tank Age	27	Tank Installed Date	05/01/1999	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4104	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	06/06/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1500	ATG Test Date	06/06/2025	Line Tightness Test Date	10/25/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Seeley Lake

Location: ROVEROS
3182 Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:60-15146

Facility Code: 30890
Last Inspected On: 11/04/2025
Operating Permit Renewal Date: 01/28/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Greg Tabish;Tabish Brothers Distributors Inc

lss@gwpetrol.com;zootown@gwpetrol.com

Operator Contact: Karly Shafer;Kyle Marx

(406) 396-2206;(406) 396-2296

karly@gwpetrol.com;roversace@yahoo.com

Owner/Operator: Greg Tabish

zootown@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc

zootown@gwpetrol.com

Karly Shafer, UST Class A Operator

karly@gwpetrol.com

Karly Shafer, UST Class B Global Operator

karly@gwpetrol.com

Kyle Marx, UST Class A Operator

roversace@yahoo.com

Kyle Marx, UST Class B Global Operator

roversace@yahoo.com

RaeDean Bartlett, UST Class B Global Operator

raedean68@gmail.com

Tank Code	07	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3337	Spill Test Date	11/04/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3338	Spill Test Date	03/27/2026	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	11/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3339	Spill Test Date	11/04/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3340	Spill Test Date	11/04/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3341	Spill Test Date	11/04/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	12	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3342	Spill Test Date	11/04/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	13	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3343	Spill Test Date	11/04/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				