

Facility Summary in Missoula County in the City of Bonner

Location: JMBC INC
29344 MT Hwy 200 E
Bonner, MT 59823-9526 Missoula

Legacy ID:32-12400

Facility ID: 25677
Last Inspected On: 11/06/2019
Operating Permit Renewal Date: 04/19/2023

Owner Operator Contact:

Operator Contact: Doug Zimmerman;Jim Fry;Joe Johnson	4062443100;4062613569
---	------------------------------

Owner/Operator: JMBC Inc Bonner

Doug Zimmerman, UST Class A Operator
Doug Zimmerman, UST Class B Operator
Jim Fry, UST Class A Operator
Jim Fry, UST Class B Operator
Joe Johnson, UST Class A Operator
Joe Johnson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	30	05/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3488	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/30/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000		10/20/2010	Gilbarco/EMC Basic		No
02	30	05/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3489	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/30/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000		10/20/2010	Gilbarco/EMC Basic		No

03	30	05/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3490	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/30/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000		10/20/2010	Gilbarco/EMC Basic		No
04	30	05/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
3491	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		01/30/2017	Automatic Tank Gauging 0.2	Not Listed	No
3,000		10/20/2010	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Clinton

Location: BEARMOUTH EXPRESS
16595 US Hwy 10 E
Clinton, MT 59825-9678 Missoula

Legacy ID:32-01572

Facility ID: 25223
Last Inspected On: 11/06/2019
Operating Permit Renewal Date: 11/12/2022

Owner Operator Contact: Gene Tripp **4068254000**

Operator Contact: Bryan Tripp;Jeff Tripp **4068254000**

Owner/Operator: Gene Tripp

Bryan Tripp, UST Class A Operator
Bryan Tripp, UST Class B Operator
Jeff Tripp, UST Class A Operator
Jeff Tripp, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	42	04/29/1979	Cathodically Protected Steel	Steel	Flapper Valve
1205	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		11/02/2016	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
12,000					No

Facility Summary in Missoula County in the City of Clinton

Location: CLINTON MARKET
20500 Hwy 10 E
Clinton, MT 59825 Missoula

Legacy ID:56-14040

Facility ID: 30695
Last Inspected On: 06/03/2019
Operating Permit Renewal Date: 04/09/2022

Owner Operator Contact: Clinton Market Inc;Roy Handley;Clinton Market Inc;RR Investments of Montana **4065464940**

Operator Contact: Roy Handley **4065464940**

Owner/Operator: Clinton Market Inc

Owner/Operator: Roy Handley,Clinton Market Inc

Owner/Operator: RR Investments of Montana

Roy Handley, UST Class A Operator
 Roy Handley, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	19	05/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4651	No			Double Walled	Yes
Currently in Use				Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;Deferred	No
10,000			Gilbarco/TLS-350		No
02	19	05/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4652	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350		No
03	19	05/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4653	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350		No
04	12	10/29/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5223	No		Double-Walled	Double Walled	Yes

Currently in Use		10/14/2009	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes
05	3	08/28/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5851	No	08/29/2018	Double-Walled	Double Walled	Yes
Currently in Use		08/28/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
6,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Missoula County in the City of Condon

Location: MISSION MOUNTAINS MERCANTILE
7217 MT Hwy 83
Condon, MT 59826 Missoula

Legacy ID:32-01619

Facility ID: 25226
Last Inspected On: 06/10/2020
Operating Permit Renewal Date: 06/10/2023

Owner Operator Contact: Leonard Kobylenski **4067542387**

Operator Contact: Leonard Kobylenski **4067542387**

Owner/Operator: Len Kobylenski

Len Kobylenski, UST Class A Operator
Len Kobylenski, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	29	05/20/1992	Cathodically Protected Steel	Steel	High Level Alarm
1495	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/13/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No

6,000		04/17/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	29	05/20/1992	Cathodically Protected Steel	Steel	High Level Alarm
1496	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		06/13/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		04/17/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	29	05/20/1992	Cathodically Protected Steel	Steel	High Level Alarm
1497	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/13/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		04/17/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Frenchtown

Location: BRONCS GROCERIES INC
16640 Beckwith St
Frenchtown, MT 59834-9747 Missoula

Legacy ID:32-05767

Facility ID: 25384
Last Inspected On: 02/19/2021
Operating Permit Renewal Date: 03/03/2024

Owner Operator Contact: Jeremy Louvar

4065463656

Operator Contact:

Owner/Operator: Jeremy Louvar

Jeremy Louvar, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
2702	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000		12/15/2017	Gilbarco/EMC Basic		No
05	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
2703	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000		12/15/2017	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Frenchtown

Location: FRENCHIES
16875 Beckwith St
Frenchtown, MT 59834-9646 Missoula

Legacy ID:32-11177

Facility ID: 25623
Last Inspected On: 05/29/2019
Operating Permit Renewal Date: 11/01/2022

Owner Operator Contact: Tabish Brothers Distributors Inc

4065437621

Operator Contact: Joe Heuchert;Karly Shafer

4063962206

Owner/Operator: Tabish Brothers Distributors Inc

Heather Stiles, UST Class B Global Operator

Joe Heuchert, UST Class A Operator

Karly Shafer, UST Class A Operator

Karly Shafer, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	31	06/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4372	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		04/18/2018	Veeder Root/TLS-300		No
06	31	06/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4373	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		04/18/2018	Veeder Root/TLS-300		No
07	31	06/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4374	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No

6,000		04/18/2018	Veeder Root/TLS-300		No
08	31	06/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4375	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		04/18/2018	Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Greenough

Location: CLEARWATER STOP N GO
44676 MT Hwy 200 E
Greenough, MT 59823-9557 Missoula

Legacy ID:32-07114

Facility ID: 25422
Last Inspected On: 06/08/2019
Operating Permit Renewal Date: 06/24/2022

Owner Operator Contact:

Operator Contact: Sherri Housley	4062445598
---	-------------------

Owner/Operator: The Cow Group

Sherri Housley, UST Class A Operator
Sherri Housley, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	22	04/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4474	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		12/13/2017	Gilbarco/EMC Basic		No
05	22	04/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

4475	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000		12/13/2017	Gilbarco/EMC Basic		No
06	22	04/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4476	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		12/13/2017	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Lolo

Location: LOLO SUPERSTOP
12011 US Hwy 93 S
Lolo, MT 59847-9666 Missoula

Legacy ID:56-13795

Facility ID: 30482
Last Inspected On: 08/05/2019
Operating Permit Renewal Date: 10/03/2022

Owner Operator Contact: Tabish Brothers Distributors Inc

4065437621

Operator Contact: Karly Shafer;Yvonne Bunch

4063962206;4068800056

Owner/Operator: Tabish Brothers Distributors Inc

- Bri Knotts, UST Class B Operator
- Karly Shafer, UST Class A Operator
- Karly Shafer, UST Class B Global Operator
- Yvonne Bunch, UST Class A Operator
- Yvonne Bunch, UST Class B Global Operator
- Yvonne Bunch, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

05	23	01/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
----	----	------------	------------	------------------	------------------

2086	No	09/16/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	23	01/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2087	No	09/16/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	23	01/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2088	No	09/16/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	23	01/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2089	No	09/16/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	23	01/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2090	No	09/16/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No

10,000

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 1
10955 US Hwy 93 S
Lolo, MT 59847 Missoula

Legacy ID:32-09414

Facility ID: 25493
Last Inspected On: 08/03/2021
Operating Permit Renewal Date: 11/01/2024

Owner Operator Contact: Don Edmisten;Town Pump O Mat of Cut Bank Inc

4064976948;4064976700

Operator Contact: Trent Biggers

Owner/Operator: Lolo 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	07/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2555	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	Yes
12,000					No
02	34	07/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2556	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000					No
03	34	07/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

2557	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000					No
04	34	07/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2558	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000					No
05	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
6029	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000					Yes
06	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
6030	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000					Yes
07	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve

6031	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
7,000				Yes
08	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
6032	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000				Yes
09	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
6033	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel, Dyed		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
7,000				Yes

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 2
11882 US Hwy 93 S
Lolo, MT 59847-9567 Missoula

Legacy ID:32-01639

Facility ID: 25228
Last Inspected On: 05/03/2021
Operating Permit Renewal Date: 05/07/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Lolo LLC PTRCB
1354;Town Pump Inc Lolo Org 17036

4064976948

Operator Contact: Trent Biggers

Owner/Operator: Lolo 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
13	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2545	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/05/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
14	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2546	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/05/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
17	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2549	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/05/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
18	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

2550	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/05/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
15	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4289	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/05/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
16	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4290	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/05/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
20	17	09/15/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4942	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
21	17	09/15/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4943	No	Double-Walled	Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000		Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Missoula County in the City of Lolo

Location: TRAVELS REST COUNTRY STORE
10565 Lolo Creek Rd
Lolo, MT 59847-9471 Missoula

Legacy ID:32-11303

Facility ID: 25632
Last Inspected On: 10/18/2021
Operating Permit Renewal Date: 12/12/2021

Owner Operator Contact: Franklin Miller;Travels Rest Country Store

Operator Contact: Glen Doty;Steve Mortenson;Terri Sullivan

4062732037

Owner/Operator: Travels Rest Country Store

- Glen Doty, UST Class A Operator
- Glen Doty, UST Class B Operator
- Steve Mortenson, UST Class A Operator
- Steve Mortenson, UST Class B Operator
- Terri Sullivan, UST Class A Operator
- Terri Sullivan, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S4	18	08/13/2003	Concrete	Flexible Plastic	High Level Alarm
4854	Yes			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.1;Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		07/09/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

S5	18	08/13/2003	Concrete	Flexible Plastic	High Level Alarm
4855	Yes			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.1;Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		07/09/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
S6	18	06/23/2003	Concrete	Flexible Plastic	High Level Alarm
4856	Yes			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.1;Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000		07/09/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
S7	18	06/23/2003	Concrete	Flexible Plastic	High Level Alarm
4857	Yes			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.1;Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000		07/09/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
S8	18	06/23/2003	Concrete	Flexible Plastic	High Level Alarm
4858	Yes			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.1;Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000		07/09/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Milltown

Location: TOWN PUMP INC BONNER-MILLTOWN
 7985 MT Hwy 200 E
 Milltown, MT 59851 Missoula

Legacy ID:32-13629

Facility ID: 25772
Last Inspected On: 05/11/2021
Operating Permit Renewal Date: 05/14/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Bonner Town Pump & Casino Inc

Trent Biggers, UST Class A Operator
 Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2564	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
05	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2568	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
07	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2570	No	03/04/2016	Double-Walled	Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
08	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2571	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
09	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2572	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
11	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2574	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
10,000			Gilbarco-Veeder Root/TLS-450		No
02	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4260	No	03/04/2016	Double-Walled	Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
03	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4261	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
04	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4262	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/13/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
06	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4263	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
12	18	12/03/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4871	No	03/04/2016	Double-Walled	Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-450		No
13	18	12/03/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4872	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
10	26	09/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4889	No	03/04/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/13/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-450		No
15	3	01/01/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5802	No	12/15/2017	Double-Walled	Double Walled	Yes
Currently in Use		12/22/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
30,000			Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Missoula County in the City of Missoula

Location: 3RD STREET MART
 2340 S 3rd St W
 Missoula, MT 59801 Missoula

Legacy ID:32-02179

Facility ID: 25246
Last Inspected On: 08/10/2019
Operating Permit Renewal Date: 08/28/2022

Owner Operator Contact: Jays Corporation

Operator Contact: Charles Weight;Jagpreet Ghuman;John McKay;Justin McKay **4062074884;4062931873;4065420550;4068807677**

Owner/Operator: Jays Corporation

- Amy Williams, UST Class B Operator
- Charles Weight, UST Class A Operator
- Charles Weight, UST Class B Operator
- Jagpreet Ghuman, UST Class A Operator
- John McKay, UST Class A Operator
- John McKay, UST Class B Operator
- Justin McKay, UST Class A Operator
- Justin McKay, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	45	04/23/1976	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3624	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/18/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350		No
02	45	04/23/1976	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3625	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/18/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350		No

03	45	04/23/1976	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3626	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/18/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Missoula County in the City of Missoula

Location: AIRWAY FLEET FUEL
5355 W Harrier
Missoula, MT 59808 Missoula

Legacy ID:56-14133

Facility ID: 30771
Last Inspected On: 09/29/2019
Operating Permit Renewal Date: 02/18/2023

Owner Operator Contact: Finest Oil Co

4065436969

Operator Contact: Christopher Glasser;James Brady;John Stordahl;Justin Gaudot;Stephen Hanson **4062181563;4065436969;4065441005;7143338926**

Owner/Operator: Finest Oil Co

Christopher Glasser, UST Class A Operator
James Brady, UST Class A Operator
John Stordahl, UST Class A Operator
Joseph McClain, UST Class B Operator
Justin Gaudot, UST Class A Operator
Justin Gaudot, UST Class B Global Operator
Stephen Hanson, UST Class A Operator
Stephen Hanson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	16	04/05/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4904	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

8,000		06/12/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	16	04/05/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4905	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000		06/12/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	16	04/05/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4906	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		06/12/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	16	04/05/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4907	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
25,000		06/12/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	16	04/05/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5038	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		06/12/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: ALLIED WASTE SERVICES OF NORTH AMERICA
 LLC
 1501 Rodgers St
 Missoula, MT 59802-1735 Missoula

Legacy ID:32-09872

Facility ID: 25524
Last Inspected On: 07/15/2020
Operating Permit Renewal Date: 08/30/2023

Owner Operator Contact: Allied Waste Services of North America LLC;N/A ZZZ - **4065433157**
 TBL_OWN : 1216;BFI Waste Systems of North
 America Inc Missoula

Operator Contact: David Seeberger **4065433157**

Owner/Operator: Allied Waste Services of North America LLC

David Seeberger, UST Class A Operator
 David Seeberger, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	31	01/24/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
500	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		02/27/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
05	31	01/24/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
501	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Oil, Waste		02/27/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test	No
2,000		07/18/2006	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: BEACH TRANSPORTATION CO
825 Mount Ave
Missoula, MT 59801-5607 Missoula

Legacy ID:32-11904

Facility ID: 25660
Last Inspected On: 05/09/2019
Operating Permit Renewal Date: 05/20/2022

Owner Operator Contact: Beach Transportation

4065496121

Operator Contact: Carlin Cavill;Scott Beach

4065496121

Owner/Operator: Beach Transportation

Carlin Cavill, UST Class A Operator
Carlin Cavill, UST Class B Operator
Scott R Beach, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	24	09/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2361	No	10/11/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: CHS MISSOULA PETROLEUM TERMINAL
3576 Grant Creek Rd
Missoula, MT 59808 Missoula

Legacy ID:60-15296

Facility ID: 31000
Last Inspected On: 10/22/2019
Operating Permit Renewal Date: 01/17/2023

Owner Operator Contact: CHS Inc Laurel

4066285200

Operator Contact: Chris Fink

4066828509

Owner/Operator: CHS Inc Laurel

Chris Fink, UST Class A Operator
Chris Fink, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	13	02/01/2008	Not Listed	Steel - Terminal Piping
5708	Yes		None	No
Currently in Use		Not Required	Pressurized	
Gasoline	10/01/2016	Not Listed	Terminal Piping Annual Line Test	No
7,750	07/01/2016			No

Facility Summary in Missoula County in the City of Missoula

Location: COMMUNITY MEDICAL CENTER
2827 Fort Missoula Rd
Missoula, MT 59804 Missoula

Legacy ID:32-11740

Facility ID: 25652
Last Inspected On: 12/29/2020
Operating Permit Renewal Date: 03/08/2024

Owner Operator Contact:

Operator Contact:

Owner/Operator: RCHP Billings - Missoula LLC

Jeff Nixon, UST Class B Operator
Steve Martin, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	27	07/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2353	No	12/22/2017	Double-Walled	Double Walled	Yes
Currently in Use	06/03/2015	Continuous Interstitial Monitoring	U.S. Suction	Galvanic	
Diesel	12/08/2017	Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No	
4,000	05/29/2015	Gilbarco-Veeder Root/ILS-250		No	

Facility Summary in Missoula County in the City of Missoula

Location: COSTCO WHOLESALE FUELING FACILITY
3220 N Reserve St
Missoula, MT 59808-1556 Missoula

Legacy ID:56-13977

Facility ID: 30639
Last Inspected On: 12/19/2018
Operating Permit Renewal Date: 02/15/2022

Owner Operator Contact:

Operator Contact: Dan Walsh;Denise Parrott;Lance Philliber;Shane Meeker;Shawn Willis;Wayne Rhoades **4065239982;4065436445**

Owner/Operator: Costco Wholesale

Brett Smith, UST Class B Operator
Dan Walsh, UST Class A Operator
Denise Parrott, UST Class A Operator
Lance Philliber, UST Class A Operator
Shane Meeker, UST Class A Operator
Shawn Willis, UST Class A Operator
Shawn Willis, UST Class B Global Operator
Shawn Willis, UST Class B Operator
Wayne Rhoades, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	21	05/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4189	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		11/16/2015	Gilbarco-Veeder Root/TLS-350		No
02	21	05/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4190	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000		11/16/2015	Gilbarco-Veeder Root/TLS-350		No
03	21	05/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4191	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000		11/16/2015	Gilbarco-Veeder Root/TLS-350		No
04	10	08/01/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve; High Level Alarm
5283	No		Double-Walled	Double Walled	Yes
Currently in Use		10/25/2010	Mechanical Line Leak Detector	Pressurized	
Hazardous Substance			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; MLLD Line Tightness Testing	No
1,500		10/31/2018	Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Missoula County in the City of Missoula

Location: DEANOS TRAVEL PLAZA 14
5055 N Reserve St
Missoula, MT 59808-1401 Missoula

Legacy ID:32-03610

Facility ID: 25301
Last Inspected On: 10/30/2019
Operating Permit Renewal Date: 12/21/2022

Owner Operator Contact: DC Petroleum Inc; Dean Clinkenbeard; DC Petroleum Inc **4067286052**

Operator Contact: Dean Clinkenbeard; Sheri Taylor **4065438885**

Owner/Operator: DC Petroleum Inc

Dean Clinkenbeard, UST Class A Operator
Dean Clinkenbeard, UST Class B Global Operator
Sheri Taylor, UST Class A Operator
Sheri Taylor, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	30	04/02/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
795	No			Double Walled	Yes
Currently in Use		06/22/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/05/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		07/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	30	04/02/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
796	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/05/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		07/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	30	04/02/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
797	No			Double Walled	Yes
Currently in Use		06/22/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/05/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		07/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	30	04/02/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
798	No			Double Walled	Yes
Currently in Use		06/22/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/05/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		07/25/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	30	04/02/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
799	No			Double Walled	Yes

Currently in Use		Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	07/05/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000	08/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: DEANOS TRAVEL PLAZA II
5318 W Harrier
Missoula, MT 59801 Missoula

Legacy ID:60-15010

Facility ID: 30800
Last Inspected On: 04/23/2021
Operating Permit Renewal Date: 04/27/2024

Owner Operator Contact: DC Petroleum Inc

4067286052

Operator Contact: Dean Clinkenbeard;Sheri Taylor

4065438885

Owner/Operator: DC Petroleum Inc

Dean Clinkenbeard, UST Class A Operator
Dean Clinkenbeard, UST Class B Global Operator
Sheri Taylor, UST Class A Operator
Sheri Taylor, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	15	01/17/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
----	----	------------	-------------------------------	------------------	------------------

5027	No			Double Walled	Yes
-------------	----	--	--	---------------	-----

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		09/10/2017	Gilbarco/TLS-350		No

02	15	01/17/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
----	----	------------	-------------------------------	------------------	------------------

5028	No			Double Walled	Yes
-------------	----	--	--	---------------	-----

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

12,000		02/07/2018	Gilbarco/TLS-350		No
03	15	01/17/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5029	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		02/07/2018	Gilbarco/TLS-350		No

Facility Summary in Missoula County in the City of Missoula

Location: DECKER TRUCK LINE INC
8350 Old Hwy 10
Missoula, MT 59808 Missoula

Legacy ID:60-15231

Facility ID: 30948
Last Inspected On: 06/25/2020
Operating Permit Renewal Date: 09/01/2023

Owner Operator Contact: Decker Truck Line Inc

5155764141

Operator Contact: Liam Lederer

4062747987

Owner/Operator: Decker Truck Line Inc

Cory Jelletich, UST Class B Global Operator
Liam Lederer, UST Class A Operator
Liam Lederer, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5438	No	04/04/2014	Double-Walled	Double Walled	Yes
Currently in Use		08/30/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Missoula County in the City of Missoula

Location: DEMAROIS, INC
3115 W Broadway St
Missoula, MT 59808-1613 Missoula

Legacy ID:32-10552

Facility ID: 25588
Last Inspected On: 10/26/2021
Operating Permit Renewal Date: 01/08/2025

Owner Operator Contact: DeMarois Inc

Operator Contact: Jack DeMarois

4067214000

Owner/Operator: DeMarois Inc

Jack DeMarois, UST Class A Operator
Jack DeMarois, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
2188	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
4,000			Incon/EECO 1500		No

Facility Summary in Missoula County in the City of Missoula

Location: FAST TRIP CONOCO
2730 S Reserve St
Missoula, MT 59801-7641 Missoula

Legacy ID:56-13914

Facility ID: 30584
Last Inspected On: 06/06/2019
Operating Permit Renewal Date: 07/02/2022

Owner Operator Contact: Scott Worster

Operator Contact: Deb Privett

4065297771

Owner/Operator: Scott Worster

Deb Privett, UST Class A Operator
Deb Privett, UST Class B Operator
Debbie Macy, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	22	08/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4913	No		Double Walled	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible	
Gasoline		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No	
15,000	10/13/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No	
02	22	08/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4914	No		Double Walled	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible	
Gasoline		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No	
8,000	10/13/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No	
03	22	08/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4915	No		Double Walled	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible	
Diesel		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No	
8,000	10/08/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No	

Facility Summary in Missoula County in the City of Missoula

Location: FINEST OIL CO MISSOULA NORTHGATE
3665 Grant Creek Rd
Missoula, MT 59808-1431 Missoula

Legacy ID:32-02295

Facility ID: 25257
Last Inspected On: 04/21/2020
Operating Permit Renewal Date: 08/09/2023

Owner Operator Contact: Finest Oil Co

4065436969

Operator Contact: Christopher Glasser; David Peyton; James Brady; James DeWaters; Justin Gaudot; Stephen Hanson **4062181563; 4063606327; 4065436969; 4065441005; 7143338926**

Owner/Operator: Finest Oil Co

Christopher Glasser, UST Class A Operator

David Peyton, UST Class A Operator
 David Peyton, UST Class B Global Operator
 James Brady, UST Class A Operator
 James DeWaters, UST Class A Operator
 Joseph McClain, UST Class B Operator
 Justin Gaudot, UST Class A Operator
 Justin Gaudot, UST Class B Global Operator
 Stephen Hanson, UST Class A Operator
 Stephen Hanson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1066	No			None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/29/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
5,000					No
07	30	07/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1067	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/29/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350		No
08	28	06/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1068	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Diesel		07/29/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350		No
09	28	06/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1069	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/29/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350		No
10	28	06/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1070	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/29/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350		No
11	28	06/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1071	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/29/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350		No
12	27	05/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1072	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/29/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350		No
13	27	05/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

1073	No		None	Yes
Currently in Use			Electronic Line Leak Detector Pressurized	Galvanic
Gasoline	07/29/2014		Automatic Tank Gauging 0.2 ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350	No

Facility Summary in Missoula County in the City of Missoula

Location: FINEST OIL EASTGATE
940 E Broadway St
Missoula, MT 59802-4915 Missoula

Legacy ID:32-10284

Facility ID: 25565
Last Inspected On: 05/07/2019
Operating Permit Renewal Date: 09/17/2022

Owner Operator Contact: Finest Oil Co;Steve Hanson;Finest Oil Co

4065436969;4065436969;4065436969

Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson

4062181563;4063606327;4065436969;4065441005;7143338926

Owner/Operator: Finest Oil Co

- Christopher Glasser, UST Class A Operator
- David Peyton, UST Class A Operator
- David Peyton, UST Class B Global Operator
- James Brady, UST Class A Operator
- James DeWaters, UST Class A Operator
- John Stordahl, UST Class B Global Operator
- Joseph McClain, UST Class B Operator
- Justin Gaudot, UST Class A Operator
- Justin Gaudot, UST Class B Global Operator
- Stephen Hanson, UST Class A Operator
- Stephen Hanson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	24	10/27/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1074	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000			Gilbarco/EMC Basic		No
08	24	10/27/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1075	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No
09	24	10/27/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1076	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: GARYS CONOCO SERVICE
2125 S Higgins Ave
Missoula, MT 59801-6760 Missoula

Legacy ID:32-10053

Facility ID: 25541
Last Inspected On: 12/02/2020
Operating Permit Renewal Date: 01/22/2024

Owner Operator Contact: Gary Little

4065420121

Operator Contact: Timothy Little

4065420121

Owner/Operator: Gary D Little

Timothy Little, UST Class A Operator

Timothy Little, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	31	09/30/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve

2139	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000		10/15/2018	Gilbarco-Veeder Root/TLS-300		No
09	31	09/30/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2140	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		10/15/2018	Gilbarco-Veeder Root/TLS-300		No
10	31	09/30/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2141	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
3,000		10/15/2018	Gilbarco-Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Missoula

Location: GRAY WOLF PEAK
20750 US Hwy 93 N
Missoula, MT 59808-8582 Missoula

Legacy ID:32-06789

Facility ID: 25414
Last Inspected On: 11/02/2004
Operating Permit Renewal Date:

Owner Operator Contact: S and K Gaming LLC

4067263778

Operator Contact: Jennifer Domebo

4067263778

Owner/Operator: S and K Gaming LLC

Jennifer Domebo, UST Class A Operator
Jennifer Domebo, UST Class B Global Operator
Jennifer Domebo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	43	05/05/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3805	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000					No
02	43	05/05/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3806	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000					No
03	43	05/05/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3807	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000					No
04	43	05/05/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3808	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000					No
S5	20	04/01/2001	Concrete	Flexible Plastic	High Level Alarm

4509	Yes	Double-Walled	Double Walled	Yes
Currently in Use		Mechanical Line Leak Detector	Pressurized	
Diesel		Continuous Interstitial Monitoring;Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000				No

Facility Summary in Missoula County in the City of Missoula

Location: GREAT WESTERN PETROLEUM
1002 E Broadway St
Missoula, MT 59802-4930 Missoula

Legacy ID:32-07431

Facility ID: 25437
Last Inspected On: 10/21/2021
Operating Permit Renewal Date: 10/30/2024

Owner Operator Contact: Greg Tabish;Tabish Brothers Distributors Inc;Tabish Brothers Distributors Inc **4065437621;4067282575;4065437621**

Operator Contact: Heather Stiles

Owner/Operator: Tabish Brothers Distributors Inc

Heather Stiles, UST Class A Operator
Heather Stiles, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	23	06/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1432	No	07/27/2018		Double Walled	Yes
Currently in Use		08/26/2006	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000			Gilbarco/EMC Basic		No
S11	23	06/01/1998	Cathodically Protected Steel	Flexible Plastic	
1433	Yes	07/27/2018		Double Walled	Yes

Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
17,000					No
S12	23	06/01/1998	Cathodically Protected Steel	Flexible Plastic	
1434	Yes	07/27/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
11,000					No
S13	23	06/01/1998	Cathodically Protected Steel	Flexible Plastic	
1435	Yes	07/27/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
14,600					No
S14	23	06/01/1998	Cathodically Protected Steel	Flexible Plastic	
1436	Yes	07/27/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
11,000					No

Facility Summary in Missoula County in the City of Missoula

Location: HEATING PLANT
Physical Plant Bldg #32
Missoula, MT 59812 Missoula

Legacy ID:32-00505

Facility ID: 25184
Last Inspected On: 11/08/2019
Operating Permit Renewal Date: 02/22/2023

Owner Operator Contact: University of Montana

4062432190

Operator Contact: Michael Burke;Neil Maier

4062432190;4065466013

Owner/Operator: University of Montana

Michael Burke, UST Class A Operator
Michael Burke, UST Class B Operator
Neil Maier, UST Class A Operator
Neil Maier, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
09	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4221	No	11/01/2016	Double-Walled	Double Walled	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
20,000			Gilbarco-Veeder Root/TLS- 300;Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE CONOCO SERVICE CENTER
711 E Broadway St
Missoula, MT 59802-4609 Missoula

Legacy ID:32-00144

Facility ID: 25156
Last Inspected On: 04/20/2020
Operating Permit Renewal Date: 06/14/2023

Owner Operator Contact: Hellgate Conoco Service Center;N/A ZZZ - TBL_OWN : 463;Hellgate Conoco Service Center **4067289966**

Operator Contact: Ross Grenfell

4067289966

Owner/Operator: Hellgate Conoco Service Center

Owner/Operator: Ross Grenfell

Ross Grenfell, UST Class A Operator
Ross Grenfell, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	55	03/31/1966	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3765	No	10/28/2015	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		03/15/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	55	03/31/1966	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3766	No	10/28/2015	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/15/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	55	03/31/1966	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3767	No	10/28/2015	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		03/15/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	11	12/16/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5279	No	10/28/2015	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible

Gasoline	03/15/2017	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	Yes
8,000		Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE TRADING POST INC
6265 Mullan Rd
Missoula, MT 59808-5650 Missoula

Legacy ID:32-00211

Facility ID: 25173
Last Inspected On: 05/29/2019
Operating Permit Renewal Date: 06/03/2022

Owner Operator Contact: Tabish Brothers Distributors Inc

4065437621

Operator Contact: Karly Shafer;Malinda Davis

4063962206;4805440698

Owner/Operator: Tabish Brothers Distributors Inc

Heather Stiles, UST Class B Global Operator
Karly Shafer, UST Class A Operator
Karly Shafer, UST Class B Global Operator
Malinda Davis, UST Class A Operator
Malinda Davis, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	27	09/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1425	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		10/09/2017	Gilbarco/EMC Basic		No
04	27	09/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1426	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		10/09/2017	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: HOLIDAY STATIONSTORE 278
 403 S Russell St
 Missoula, MT 59801-2311 Missoula

Legacy ID:32-08072

Facility ID: 25460
Last Inspected On: 04/23/2019
Operating Permit Renewal Date: 04/23/2022

Owner Operator Contact: Steve Visocan;Visocan Petroleum Co Helena

Operator Contact: Chuck Nyberg;Dean Townsend;Kegan Krueger;Patrick Patnaude;Ronald VanDenBroeke;Stephen Reckinger;Valeria Jeffries **4063210938;9528308028;9528308721;9528308722**

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
 Chuck Nyberg, UST Class A Operator
 Dean Townsend, UST Class A Operator
 Kegan Krueger, UST Class A Operator
 Patrick Patnaude, UST Class A Operator
 Ronald VanDenBroeke, UST Class A Operator
 Stephen Reckinger, UST Class A Operator
 Todd White, UST Class B Global Operator
 Todd White, UST Class B Operator
 Travis Struckman, UST Class B Global Operator
 Valeria Jeffries, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	26	07/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3024	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000		03/05/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	26	07/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3025	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000		02/27/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	26	07/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3026	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000		02/27/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	26	07/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
4700	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
12,000		03/05/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: HOLIDAY STATIONSTORE 282
605 S Higgins Ave
Missoula, MT 59801-2733 Missoula

Legacy ID:32-09733

Facility ID: 25517
Last Inspected On: 02/21/2020
Operating Permit Renewal Date: 08/17/2023

Owner Operator Contact:

Operator Contact: Chuck Nyberg; Patrick Patnaude; Stephen Reckinger; Valeria Jeffries

9528308028; 9528308721; 9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

- Andrea Niceschwander, UST Class B Global Operator
- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Debbie Geer, UST Class B Operator
- Greg Voorhees, UST Class B Operator
- Mary Gray, UST Class B Operator
- Patrick Patnaude, UST Class A Operator
- Stephen Reckinger, UST Class A Operator
- Todd White, UST Class B Global Operator
- Travis Struckman, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	33	08/01/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3028	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/09/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
12,000		05/21/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	33	08/01/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3029	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/09/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
12,000		08/04/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	33	08/01/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3030	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/09/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
12,000		04/09/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: HOLIDAY STATIONSTORE 283
2325 S Reserve St
Missoula, MT 59801-6446 Missoula

Legacy ID:32-09694

Facility ID: 25512
Last Inspected On: 12/01/2020
Operating Permit Renewal Date: 02/13/2024

Owner Operator Contact:

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
 Christina Hartman, UST Class B Operator
 Chuck Nyberg, UST Class A Operator
 Patrick Patnaude, UST Class A Operator
 Stephen Reckinger, UST Class A Operator
 Todd White, UST Class B Global Operator
 Travis Struckman, UST Class B Global Operator
 Valeria Jeffries, UST Class A Operator
 Veronica Rivera, UST Class A Operator
 Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	08/01/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3706	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/10/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
12,000		07/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	34	08/01/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3707	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/10/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
10,000		07/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	34	08/01/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

3708	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	01/10/2017		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
10,000	07/18/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	34	08/01/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3709	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel	01/10/2017		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000	07/16/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

Legacy ID:32-05760

Facility ID: 25377
Last Inspected On: 02/20/2020
Operating Permit Renewal Date: 08/02/2023

Owner Operator Contact: Jays Corporation

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu

4068807677

Owner/Operator: Jays Corporation

- Jagpreet Ghuman, UST Class A Operator
- Jagpreet Ghuman, UST Class B Global Operator
- Jaspal Sandhu, UST Class A Operator
- Jaspal Sandhu, UST Class B Global Operator
- Jaspal Sandhu, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	49	11/18/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1345	No	10/10/2015	Lined Interior/Impressed Current	Double Walled	Yes

Currently in Use		10/10/2015	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		10/05/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	45	11/18/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1346	No	10/10/2015	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		10/10/2015	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000		10/05/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	49	11/18/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1347	No	10/10/2015	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		10/10/2015	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000		10/05/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE CARDLOCK
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

Legacy ID:32-05761

Facility ID: 25378
Last Inspected On: 08/08/2019
Operating Permit Renewal Date:

Owner Operator Contact: Jays Corporation

Operator Contact: Jagpreet Ghuman

4068807677

Owner/Operator: Jays Corporation

Jagpreet Ghuman, UST Class A Operator
Jagpreet Ghuman, UST Class B Global Operator
Jaspal Sandhu, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	42	11/14/1979	Bare Steel	Steel	Flapper Valve
3627	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		12/05/2017	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
10,000					No
02	46	11/14/1975	Bare Steel	Steel	Flapper Valve
3628	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		12/05/2017	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
4,000					No
03	42	11/14/1979	Bare Steel	Steel	Flapper Valve
3629	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		12/05/2017	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
10,000					No

Facility Summary in Missoula County in the City of Missoula

Location: JAYS MART INC
2480 39th St
Missoula, MT 59803-1123 Missoula

Legacy ID:32-09690

Facility ID: 25511
Last Inspected On: 02/20/2020
Operating Permit Renewal Date: 08/02/2023

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula

4065420384

Operator Contact: Jagpreet Ghuman;Manpreet Singh

4068807677;5099946599

Owner/Operator: Hi-Star Properties LLC

Jagpreet Ghuman, UST Class A Operator
Jagpreet Ghuman, UST Class B Global Operator
Jaspal Sandhu, UST Class B Global Operator
Manpreet Singh, UST Class A Operator

Manpreet Singh, UST Class B Global Operator
 Manpreet Singh, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	39	11/03/1982	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1360	No	04/27/2018		Double Walled	Yes
Currently in Use		04/27/2018	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/03/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	39	11/03/1982	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1361	No	04/27/2018		Double Walled	Yes
Currently in Use		04/27/2018	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/03/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	39	11/03/1982	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1362	No	04/27/2018		Double Walled	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		11/03/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	Yes
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: KARL TYLER CHEVROLET INC N RESERVE
 3663 N Reserve St
 Missoula, MT 59808-1509 Missoula

Legacy ID:56-14056

Facility ID: 30710
Last Inspected On: 01/15/2021
Operating Permit Renewal Date: 09/10/2023

Owner Operator Contact: Karl Tyler Chevrolet Inc

Operator Contact: Terry Hedrick

Owner/Operator: Karl Tyler Chevrolet Inc

Terry Hedrick, UST Class A Operator

Terry Hedrick, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	19	07/22/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4695	No	03/08/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
6,000			Veeder Root/TLS-300		No
03	19	07/22/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4696	No	03/08/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
4,000			Veeder Root/TLS-300		No
S1	19	07/30/2002	Aboveground Tank	Flexible Plastic	High Level Alarm
4699	Yes	03/18/2016		Double Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil, Waste			Not Listed	Continuous Interstitial Monitoring	No

10,000

No

Facility Summary in Missoula County in the City of Missoula

Location: KWIK STOP SINCLAIR
505 Highton St
Missoula, MT 59801-5424 Missoula

Legacy ID:32-06680

Facility ID: 25412
Last Inspected On: 04/07/2020
Operating Permit Renewal Date: 07/31/2023

Owner Operator Contact: Mayur LLC

4065493286

Operator Contact: Ashish Patel;Jayprakash Patel

6509968294

Owner/Operator: Mayur LLC

Owner/Operator: Rohit Patel

Ashish Patel, UST Class A Operator
Ashish Patel, UST Class B Operator
Jayprakash Patel, UST Class A Operator
Jayprakash Patel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	01/10/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2298	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		07/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000		07/24/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	31	01/10/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2299	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		07/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No

6,000		07/24/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	31	01/10/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2300	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		07/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000		07/24/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: LITHIA AUTO CENTER
5001 Grizzly Ct
Missoula, MT 59808-8672 Missoula

Legacy ID:56-14004

Facility ID: 30665
Last Inspected On: 05/16/2019
Operating Permit Renewal Date: 06/24/2022

Owner Operator Contact: Lithia Chrysler Dodge of Missoula

4067215000

Operator Contact: Betty Johnson

4067215000

Owner/Operator: Lithia Chrysler Dodge of Missoula

Betty Johnson, UST Class A Operator

Betty Johnson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4359	No			Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
6,000					No
02	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4360	No			Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
4,000					No

Facility Summary in Missoula County in the City of Missoula

Location: LOVES TRAVEL STOP #753
8077 Hwy 10 W
Missoula, MT 59808 Missoula

Legacy ID:60-15321

Facility ID: 31018
Last Inspected On:
Operating Permit Renewal Date: 04/20/2020

Owner Operator Contact: Loves Travel Stops and Country Stores Inc

Operator Contact:

Owner/Operator: Loves Travel Stops and Country Stores Inc

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5830	No				No
Currently in Use				Pressurized	
Gasoline			Not Listed	Not Listed	Yes
30,000					Yes
02	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5831	No				No
Currently in Use				Pressurized	
Gasoline			Not Listed	Not Listed	No
12,000					No
03	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5832	No				No
Currently in Use				Pressurized	
Gasoline			Not Listed	Not Listed	No
8,000					No
04	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	

5833	No			No
Currently in Use			Pressurized	
Diesel		Not Listed	Not Listed	No
30,000				Yes
05	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5834	No			No
Currently in Use			Pressurized	
Diesel		Not Listed	Not Listed	No
30,000				Yes
06	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5835	No			No
Currently in Use			Pressurized	
Diesel		Not Listed	Not Listed	No
30,000				Yes
07	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5836	No			No
Currently in Use			Pressurized	
Biodiesel, <=B20		Not Listed	Not Listed	No
20,000				Yes
08	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5837	No			No
Currently in Use			Pressurized	
DEF (Not Regulated)		Not Listed	Not Listed	No

20,000

Yes

Facility Summary in Missoula County in the City of Missoula

Location: MDOT MISSOULA
2100 W Broadway St
Missoula, MT 59808-1816 Missoula

Legacy ID:32-09304

Facility ID: 25486
Last Inspected On: 06/22/2021
Operating Permit Renewal Date: 07/10/2024

Owner Operator Contact: Doug Compton;Montana Dept of Transportation;MDOT Helena **4064446163;4064447647**

Operator Contact: Jeff Gleason;Joe Radonich;Michael Carstensen;Mike Murolo;Walt Kerttula

Owner/Operator: MDOT Helena

- Chad Pearson, UST Class B Operator
- Jeff Gleason, UST Class A Operator
- Joe Radonich, UST Class A Operator
- Joe Radonich, UST Class B Global Operator
- John Maricelli, UST Class B Operator
- Justin Marin, UST Class B Operator
- Michael Carstensen, UST Class A Operator
- Michael Carstensen, UST Class B Operator
- Mike Murolo, UST Class A Operator
- Richard Bick, UST Class B Operator
- Walt Kerttula, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	05/01/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2917	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/26/2018	Automatic Tank Gauging 0.2	Not Listed	No
10,000			Gilbarco/EMC Basic		No
06	34	04/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

2918	No		None	Yes
Currently in Use		Not Required	Safe Suction	Galvanic
Diesel	06/26/2018	Automatic Tank Gauging 0.2	Not Listed	No
10,000		Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA #7 FLYING J
8745 Hwy 93 N
Missoula, MT 59808 Missoula

Legacy ID:60-15158

Facility ID: 30899
Last Inspected On: 09/09/2021
Operating Permit Renewal Date: 02/21/2025

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Missoula 7 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5256	No		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		Yes
02	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5257	No		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		Yes
03	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5258	No		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
25,000			Gilbarco-Veeder Root/TLS-450		Yes
04	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5259	No		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
30,000			Gilbarco-Veeder Root/TLS-450		Yes
05	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5260	No		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
8,000			Gilbarco-Veeder Root/TLS-450		Yes
06	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5261	No		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-450		Yes
07	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5262	No		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		Yes
08	11	09/01/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5331	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000			Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA AIRPORT WASHINGTON HANGER
5225 W Broadway St
Missoula, MT 59808-9385 Missoula

Legacy ID:32-07606

Facility ID: 25444
Last Inspected On: 03/12/2020
Operating Permit Renewal Date: 05/25/2023

Owner Operator Contact: Lynn Fagan;Missoula County Airport Authority;Washington Corporations

4065231349

Operator Contact: Gabriel Martinez;Roy Felt;Ryan Opheim

4062148531;4065231427

Owner/Operator: Washington Corporations

- Gabriel Martinez, UST Class A Operator
- Gabriel Martinez, UST Class B Operator
- Roy Felt, UST Class A Operator
- Roy Felt, UST Class B Global Operator
- Ryan Opheim, UST Class A Operator
- Ryan Opheim, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	05/07/1984	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve;High Level Alarm
2242	No	05/18/2018		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Jet Fuel (Jet-A, Jet-A1, JP5)		04/11/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		04/11/2017	Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA COUNTY DETENTION CENTER
2340 Mullan Rd
Missoula, MT 59808-1830 Missoula

Legacy ID:56-13921

Facility ID: 30591
Last Inspected On: 10/30/2019
Operating Permit Renewal Date: 12/12/2022

Owner Operator Contact: Missoula County Detention Center

4068294000

Operator Contact: Gary Zinke

4065313627

Owner/Operator: Missoula County Detention Center

Gary Zinke, UST Class A Operator
Gary Zinke, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	22	06/01/1999	Unknown	Copper	High Level Alarm
3774	Yes	10/05/2016	Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	Pressurized	

 Diesel Deferred Continuous Interstitial Monitoring No

 3,000 No

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA FRESH MARKET #3416
 3801 S Reserve St
 Missoula, MT 59801-7322 Missoula

Legacy ID:56-14025

Facility ID: 30684
Last Inspected On: 09/04/2019
Operating Permit Renewal Date: 01/04/2023

Owner Operator Contact: Missoula Fresh Market LLC

Operator Contact: Aaron Nelson;Lynn Pehrson;Shari Goodmanson **4062517170;4252016301**

Owner/Operator: Missoula Fresh Market LLC

- Aaron Nelson, UST Class A Operator
- Allen Trimp, UST Class B Global Operator
- Betty Heidrick, UST Class B Operator
- Lynn Pehrson, UST Class A Operator
- Shari Goodmanson, UST Class A Operator
- Shari Goodmanson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	09/01/2001	Steel Clad	Flexible Plastic	Ball Float Valve;High Level Alarm
4416	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
20,000					No
02	20	09/01/2001	Steel Clad	Flexible Plastic	Ball Float Valve;High Level Alarm
4417	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000					No
03	20	09/01/2001	Steel Clad	Flexible Plastic	Ball Float Valve; High Level Alarm
4418	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000					No

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA FRESH MARKET #3417
800 W Broadway St
Missoula, MT 59802-3944 Missoula

Legacy ID:60-15098

Facility ID: 30858
Last Inspected On: 05/13/2021
Operating Permit Renewal Date: 06/11/2024

Owner Operator Contact: Missoula Fresh Market LLC

Operator Contact: Aaron Nelson; Lynn Pehrson; Rebecca Spicer; Shari Goodmanson **4062517170; 4067212549; 4252016301**

Owner/Operator: Missoula Fresh Market LLC

- Aaron Nelson, UST Class A Operator
- Cathie Hinds, UST Class B Global Operator
- Lynn Pehrson, UST Class A Operator
- Rebecca Spicer, UST Class A Operator
- Rebecca Spicer, UST Class B Operator
- Shari Goodmanson, UST Class A Operator
- Shari Goodmanson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	13	08/08/2008	Steel Clad	Flexible Plastic	High Level Alarm
5167	No		Double-Walled	Double Walled	Yes
Currently in Use		07/01/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
02	13	08/01/2008	Steel Clad	Flexible Plastic	High Level Alarm
5168	No		Double-Walled	Double Walled	Yes
Currently in Use		07/01/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
03	13	08/01/2008	Steel Clad	Flexible Plastic	High Level Alarm
5169	No		Double-Walled	Double Walled	Yes
Currently in Use		07/01/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA SERVICE CENTER
 1900 S Russell St
 Missoula, MT 59801-6624 Missoula

Legacy ID:32-01182

Facility ID: 25203
Last Inspected On: 01/08/2020
Operating Permit Renewal Date: 06/13/2023

Owner Operator Contact: Northwestern Energy Butte

4064972838

Operator Contact: John Habeger

Owner/Operator: Northwestern Energy Butte

Bruce Schlichenmayer, UST Class B Operator
 Greg Sponseller, UST Class B Operator
 Joe Vigue, UST Class B Operator
 John Habeger, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	31	07/27/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1680	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		01/25/2017	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
13,000			Gilbarco-Veeder Root/TLS-300		No
05	31	07/27/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1681	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		01/25/2017	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
3,000			Gilbarco-Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA TRAVEL CENTER
 8018 US Hwy 93 N
 Missoula, MT 59808 Missoula

Legacy ID:32-02822

Facility ID: 25272
Last Inspected On: 10/09/2020
Operating Permit Renewal Date: 10/31/2023

Owner Operator Contact: Dave Campbell;Crossroads Truck Center;TA Operating LLC

Operator Contact: Alex Hoskinson;Greg Goodwin;Jack Odyk;Joshua Johnson;Kelly Gelske;Kimberly Komar;Lisa Hendon;Tracy Mullins **4058331186;4065492327;4408087406;5092172694**

Owner/Operator: TA Operating LLC

- Alex Hoskinson, UST Class A Operator
- Alex Hoskinson, UST Class B Operator
- Greg Goodwin, UST Class A Operator
- Greg Goodwin, UST Class B Global Operator
- Jack Odyk, UST Class A Operator
- Jack Odyk, UST Class B Global Operator
- Jack Odyk, UST Class B Operator
- Joshua Johnson, UST Class A Operator
- Joshua Johnson, UST Class B Global Operator
- Joshua Johnson, UST Class B Operator
- Kelly Gelske, UST Class A Operator
- Kelly Gelske, UST Class B Global Operator
- Kimberly Komar, UST Class A Operator
- Kimberly Komar, UST Class B Global Operator
- Lisa Hendon, UST Class A Operator
- Lisa Hendon, UST Class B Global Operator
- Tracy Mullins, UST Class A Operator
- Tracy Mullins, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
14	6	02/24/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;High Level Alarm
5550	No	10/16/2014	Double-Walled	Double Walled	Yes
Currently in Use		09/18/2014	Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible

Oil Substance			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000		03/12/2015	Gilbarco-Veeder Root/TLS-350		Yes
15	6	02/24/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;High Level Alarm
5551	No	10/16/2014	Double-Walled	Double Walled	No
Currently in Use		09/18/2014	Continuous Interstitial Monitoring	Gravity Feed	Non-corrodible
Oil Substance			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000		03/12/2015	Gilbarco-Veeder Root/TLS-350		Yes
16	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
5929	No		Double-Walled	Double Walled	No
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000					Yes
02	43	02/17/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
786	No	08/18/2014	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/22/2014	Not Required	Pressurized	Impressed Current
Diesel		07/18/2017	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring	No
10,000		07/18/2017	Gilbarco-Veeder Root/TLS-350		No
03	43	02/17/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
787	No	08/18/2014	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/22/2014	Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		07/18/2017	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		07/18/2017	Gilbarco-Veeder Root/TLS-350		No

09	28	11/01/1993	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
788	No	08/18/2014		Double Walled	Yes
Currently in Use		06/10/2010	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/18/2017	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		09/14/2013	Gilbarco-Veeder Root/TLS-350		No
10	28	11/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
789	No	08/18/2014		Double Walled	Yes
Currently in Use		08/22/2014	Not Required	Pressurized	Galvanic
Gasoline		07/18/2017	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		08/04/2014	Gilbarco-Veeder Root/TLS-350		No
11	28	11/01/1993	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
790	No	08/18/2014		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/18/2017	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		09/14/2013	Gilbarco-Veeder Root/TLS-350		No
12	28	11/01/1993	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
791	No	08/18/2014		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/18/2017	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000		09/14/2013	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA URBAN TRANSPORTATION
 1221 Shakespeare St
 Missoula, MT 59802-2307 Missoula

Legacy ID:32-04427

Facility ID: 25341
Last Inspected On: 04/02/2020
Operating Permit Renewal Date: 06/05/2023

Owner Operator Contact: Missoula Urban Transportation;Sally Mullen
 Or;Mountain Line Msla Urban Transprttn Dist

Operator Contact: Jeffrey Logan;John Roseboom

4062152455;4062152458

Owner/Operator: Missoula Urban Transportation

Brian Dildine, UST Class B Operator
 Cody Bush, UST Class B Operator
 David Loewen, UST Class B Operator
 Jacob Nolen, UST Class B Operator
 Jeffrey Logan, UST Class A Operator
 Jeffrey Logan, UST Class B Operator
 John Roseboom, UST Class A Operator
 John Roseboom, UST Class B Operator
 Kent Russell, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	23	04/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
1658	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic		No
05	23	04/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1659	No	01/26/2017	Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Gravity Feed	Non-corrodible

Oil, Waste	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
600	Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: MONTANA RAIL LINK INC RAILYARD MISSOULA
101 International Dr
Missoula, MT 59808-1549 Missoula

Legacy ID:32-11226

Facility ID: 25626
Last Inspected On: 03/25/2021
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: Montana Rail Link Inc Missoula **4065231500**

Operator Contact: Richard Shelley **4062223764**

Owner/Operator: Montana Rail Link Inc Missoula

Richard Shelley, UST Class A Operator
Richard Shelley, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	31	11/01/1990	Unknown	Steel	
3872	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		10/03/2017	Not Listed	Terminal Piping Annual Line Test	No
30,000		10/09/2017			No

Facility Summary in Missoula County in the City of Missoula

Location: MOUNTAIN WEST COOP
4570 N Reserve St
Missoula, MT 59808 Missoula

Legacy ID:32-02437

Facility ID: 25260
Last Inspected On: 04/01/2021
Operating Permit Renewal Date: 06/15/2024

Owner Operator Contact: Jerry Eide;Cenex Harvest States Jerry Eide;Mark
Lalum;Mountain West Cooperative **4065438383**

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Will Dukart **4066651728;4067557427;4068808169**

Owner/Operator: CHS Inc Inver Grove Heights

Bill Griffin, UST Class B Operator
 Bob Westin, UST Class A Operator
 Bob Westin, UST Class B Global Operator
 Dusty Smith, UST Class A Operator
 Dusty Smith, UST Class B Global Operator
 John Thompson, UST Class A Operator
 John Thompson, UST Class B Global Operator
 John Thompson, UST Class B Operator
 Mike Dunlon, UST Class B Operator
 Robin McCurdy, UST Class B Operator
 Will Dukart, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
16	26	03/29/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve;High Level Alarm
2859	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/20/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000		06/12/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
17	7	11/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5554	No	12/11/2014	Double-Walled	Double Walled	Yes
Currently in Use		01/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
25,000		01/16/2015	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
18	7	11/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

5555	No	12/11/2014	Double-Walled	Double Walled	Yes
Currently in Use		01/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
25,000		01/16/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
19	7	11/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5556	No	12/11/2014	Double-Walled	Double Walled	Yes
Currently in Use		01/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		01/16/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
20	7	11/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5557	No	12/11/2014	Double-Walled	Double Walled	Yes
Currently in Use		01/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000		01/16/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
21	7	11/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5558	No	12/11/2014	Double-Walled	Double Walled	Yes
Currently in Use		01/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		01/16/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
22	7	11/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

5559	No	12/11/2014	Double-Walled	Double Walled	Yes
Currently in Use		01/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
10,000		01/16/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Missoula County in the City of Missoula

Location: MURALTS TRUCK PLAZA
8800 Truck Stop Rd
Missoula, MT 59808-9708 Missoula

Legacy ID:32-00146

Facility ID: 25157
Last Inspected On: 01/14/2021
Operating Permit Renewal Date: 01/14/2024

Owner Operator Contact: Muralts Inc;Walter Muralt;Muralts Inc

4067284700;4067284700;4067284700

Operator Contact: Curtis Wilson;Laci Carvey;Willy Baker

4062075448;4063967420;4068300479

Owner/Operator: Muralts Inc

- Brenda Boyd, UST Class B Global Operator
- Christopher Smith, UST Class B Operator
- Curtis Wilson, UST Class A Operator
- Curtis Wilson, UST Class B Operator
- J Kelley, UST Class B Global Operator
- Laci Carvey, UST Class A Operator
- Laci Carvey, UST Class B Operator
- Victoria Krause, UST Class B Global Operator
- Willy Baker, UST Class A Operator
- Willy Baker, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	26	11/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1734	No			Double Walled	Yes
Currently in Use		01/12/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		05/19/2009	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		03/23/2012	Gilbarco-Veeder Root/TLS-450		No
11	26	11/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1735	No			Double Walled	Yes
Currently in Use		01/12/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/19/2009	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
5,000		03/23/2012	Gilbarco-Veeder Root/TLS-450		No
01	53	03/26/1968	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3650	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		01/12/2016	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		03/23/2012	Gilbarco-Veeder Root/TLS-450		No
02	53	03/26/1968	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3651	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		01/12/2016	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		07/27/2018	Gilbarco-Veeder Root/TLS-450		No
03	53	03/26/1968	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3652	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		01/12/2016	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		03/23/2012	Gilbarco-Veeder Root/TLS-450		No
04	53	03/26/1968	Cathodically Protected Steel	Steel	Flapper Valve

3653	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/30/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		12/27/2017	Gilbarco-Veeder Root/TLS-450		No
05	53	03/26/1968	Cathodically Protected Steel	Steel	Flapper Valve
3654	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/30/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		01/17/2018	Gilbarco-Veeder Root/TLS-450		No
06	48	03/26/1973	Cathodically Protected Steel	Steel	Flapper Valve
3655	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/30/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		12/27/2017	Gilbarco-Veeder Root/TLS-450		No

Facility Summary in Missoula County in the City of Missoula

Location: NOONS 426
1250 39th St
Missoula, MT 59803 Missoula

Legacy ID:32-05763

Facility ID: 25380
Last Inspected On: 06/27/2019
Operating Permit Renewal Date: 12/10/2022

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula;Hi Noon Petroleum Missoula

4065420384

Operator Contact: Andrew Young;Earl Allen;Erin Keffeler;John Monahan;Willy Baker

4063967578;4068300479

Owner/Operator: Hi Noon Petroleum Missoula

Allisa Gilstrap, UST Class B Global Operator
Allisa Gilstrap, UST Class B Operator
Andrew Young, UST Class A Operator
Andrew Young, UST Class B Global Operator
Cameron Fulmer, UST Class B Global Operator
Earl Allen, UST Class A Operator
Earl Allen, UST Class B Global Operator

Erin Keffeler, UST Class A Operator
 Erin Keffeler, UST Class B Global Operator
 Holly Dale, UST Class B Global Operator
 John Monahan, UST Class A Operator
 John Monahan, UST Class B Global Operator
 Laci Carvey, UST Class B Global Operator
 Lisa Millsbaugh, UST Class B Operator
 Patrick Bakken, UST Class B Global Operator
 Willy Baker, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	41	01/01/1980	Bare Steel	Flexible Plastic	Flapper Valve
1348	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/09/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		06/14/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	41	01/01/1980	Bare Steel	Flexible Plastic	Flapper Valve
1349	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/09/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		06/14/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	41	01/01/1980	Bare Steel	Flexible Plastic	Flapper Valve
1350	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current

Gasoline	03/09/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000	06/14/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: NOONS 457
540 E Broadway St
Missoula, MT 59802-4614 Missoula

Legacy ID:32-03614

Facility ID: 25304
Last Inspected On: 05/18/2021
Operating Permit Renewal Date: 08/26/2024

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula;Hi Noon Petroleum Missoula **4065420384**

Operator Contact: Andrew Young;Earl Allen;Erin Keffeler;John Monahan **4063967578**

Owner/Operator: Hi Noon Petroleum Missoula

- Allisa Gilstrap, UST Class B Global Operator
- Allisa Gilstrap, UST Class B Operator
- Andrew Young, UST Class A Operator
- Andrew Young, UST Class B Global Operator
- Cameron Fulmer, UST Class B Global Operator
- Earl Allen, UST Class A Operator
- Earl Allen, UST Class B Operator
- Erin Keffeler, UST Class A Operator
- Erin Keffeler, UST Class B Global Operator
- Holly Dale, UST Class B Global Operator
- John Monahan, UST Class A Operator
- John Monahan, UST Class B Global Operator
- Laci Carvey, UST Class B Global Operator
- Lisa Millsbaugh, UST Class B Operator
- Patrick Bakken, UST Class B Global Operator
- Timothy Kamerman, UST Class B Operator
- Willy Baker, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	6	04/28/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5573	No	04/27/2015	Double-Walled	Double Walled	Yes

Currently in Use		04/28/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
18,000		11/11/2017	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
06	6	04/28/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5574	No	04/27/2015	Double-Walled	Double Walled	Yes
Currently in Use		04/28/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000		11/05/2017	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
07	6	04/28/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5575	No	04/27/2015	Double-Walled	Double Walled	Yes
Currently in Use		04/28/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000		11/05/2017	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Missoula County in the City of Missoula

Location: NOONS 470
1605 S Russell St
Missoula, MT 59801-5636 Missoula

Legacy ID:32-08863

Facility ID: 25478
Last Inspected On: 09/30/2021
Operating Permit Renewal Date: 02/09/2025

Owner Operator Contact: Hi Noon Petroleum Missoula

4065420384

Operator Contact: Andrew Young;Earl Allen;Erin Keffeler;John Monahan

4063967578

Owner/Operator: Hi Noon Petroleum Missoula

Andrew Young, UST Class A Operator
Andrew Young, UST Class B Global Operator
Cameron Fulmer, UST Class B Global Operator
Deven Cornell, UST Class B Global Operator
Earl Allen, UST Class A Operator
Earl Allen, UST Class B Operator

Erin Keffeler, UST Class A Operator
 Erin Keffeler, UST Class B Operator
 Holly Dale, UST Class B Global Operator
 John Monahan, UST Class A Operator
 John Monahan, UST Class B Global Operator
 Laci Carvey, UST Class B Global Operator
 Lisa Millsbaugh, UST Class B Operator
 Patrick Bakken, UST Class B Global Operator
 Willy Baker, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	06/23/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1357	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Veeder Root/TLS-300		No
02	36	06/23/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1358	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Veeder Root/TLS-300		No
03	36	06/23/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1359	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000	Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 11
1600 S Russell St
Missoula, MT 59801-5637 Missoula

Legacy ID:32-04620

Facility ID: 25345
Last Inspected On: 10/03/2018
Operating Permit Renewal Date: 03/05/2022

Owner Operator Contact: DDJ Investments LLC **4067287618**

Operator Contact: Derek Louquet **4063695855**

Owner/Operator: DDJ Investments LLC

Owner/Operator: Jennifer Louquet

Derek Louquet, UST Class A Operator
Mary Fleming, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	33	10/30/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1721	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/03/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		02/19/2018	Gilbarco/EMC Basic		No
05	33	10/30/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1722	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/03/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		02/19/2018	Gilbarco/EMC Basic		No

06	33	10/30/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1723	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/03/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		02/19/2018	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 12 and DIXIES DINER
3705 MT Hwy 200 E
Missoula, MT 59802 Missoula

Legacy ID:32-03190

Facility ID: 25284
Last Inspected On: 09/23/2019
Operating Permit Renewal Date: 02/09/2023

Owner Operator Contact: Gary Louquet;JGL Distributing Inc;JGL Distributing Inc;Mark Olson;Tri-East Inc.

4065422224;4067287736

Operator Contact: Peggy Wolfe

Owner/Operator: J Gary Louquet

Owner/Operator: JGL Distributing Inc

LeeAnn Dean, UST Class B Global Operator
Peggy Wolfe, UST Class A Operator
Peggy Wolfe, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	57	05/01/1964	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1427	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		08/23/2016	Gilbarco/EMC Basic		No
02	57	05/01/1964	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

1428	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		08/23/2016	Gilbarco/EMC Basic		No
03	57	05/01/1964	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1429	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		08/23/2016	Gilbarco/EMC Basic		No
04	57	05/01/1964	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1430	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		08/23/2016	Gilbarco/EMC Basic		No
05	42	05/02/1979	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1431	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000		08/23/2016	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE INC 2
923 N Orange St
Missoula, MT 59802-2927 Missoula

Legacy ID:32-05216

Facility ID: 25359
Last Inspected On: 11/05/2019
Operating Permit Renewal Date: 03/14/2023

Owner Operator Contact: Oles Country Stores Inc Missoula

Operator Contact: Casie Schwindt

Owner/Operator: Oles Country Stores Inc Missoula

Casie Schwindt, UST Class A Operator

Casie Schwindt, UST Class B Operator

Erika Nicklay, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	31	09/25/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2357	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/29/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
15,000		08/22/2007	Gilbarco/EMC Basic		No
05	31	09/25/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2358	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/29/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/22/2007	Gilbarco/EMC Basic		No
06	31	09/25/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2359	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/29/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/22/2007	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED
 MISSOULA TERMINAL
 3330 Raser Dr
 Missoula, MT 59808-1534 Missoula

Legacy ID:32-08732

Facility ID: 25472
Last Inspected On: 03/25/2019
Operating Permit Renewal Date: 06/09/2022

Owner Operator Contact:

Operator Contact: Mark Shellabarger

Owner/Operator: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal

Andrew Snyder, UST Class B Operator
 Brent Schreckendgust, UST Class B Operator
 Chris Binder, UST Class B Operator
 Dusty Nagel, UST Class B Operator
 Kerry Sweten, UST Class B Operator
 Kyle Jackson, UST Class B Operator
 Mark Shellabarger, UST Class A Operator
 Mark Shellabarger, UST Class B Global Operator
 Mark Shellabarger, UST Class B Operator
 Michael McArthur, UST Class B Operator
 Orlando Rodriguez, UST Class B Operator
 Randy Dayley, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S15	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2793	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
630,000		09/23/2015			No
S18	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2796	Yes			None	Yes

Currently in Use			Not Required	Pressurized	
Gasoline		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
1,260,000		09/23/2015			No
S19	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2797	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
647,892		09/23/2015			No
S23	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2800	Yes			None	Yes
Temporarily Out of Use			Not Required	Pressurized	
Diesel			Deferred	Terminal Piping Annual Line Test	No
847,000					No
S24	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2801	Yes			None	Yes
Temporarily Out of Use			Not Required	Pressurized	
Diesel			Deferred	Terminal Piping Annual Line Test	No
847,000					No
S25	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2802	Yes			None	Yes
Temporarily Out of Use			Not Required	Pressurized	
Gasoline			Deferred	Terminal Piping Annual Line Test	No
648,000					No

S26	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2803	Yes			None	Yes
Temporarily Out of Use			Not Required	Pressurized	
Gasoline			Deferred	Terminal Piping Annual Line Test	No
648,000					No
S13	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
4581	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Gasoline		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
630,000		09/23/2015			No
S17	67	06/01/1954	Cathodically Protected Steel	Steel - Terminal Piping	
4909	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
840,000		09/23/2015			No

Facility Summary in Missoula County in the City of Missoula

Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED
MISSOULA TERMINAL
3330 Raser Dr
Missoula, MT 59808-1534 Missoula

Legacy ID:32-03320

Facility ID: 25289
Last Inspected On: 03/25/2019
Operating Permit Renewal Date: 06/09/2022

Owner Operator Contact:

Operator Contact: Mark Shellabarger

Owner/Operator: Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal

- Andrew Snyder, UST Class B Operator
- Brent Schreckengust, UST Class B Operator
- Chris Binder, UST Class B Operator
- Dustin Rogers, UST Class B Operator
- Dusty Nagel, UST Class B Operator

Kerry Sweten, UST Class B Operator
 Kyle Jackson, UST Class B Operator
 Mark Shellabarger, UST Class A Operator
 Mark Shellabarger, UST Class B Global Operator
 Mark Shellabarger, UST Class B Operator
 Michael McArthur, UST Class B Operator
 Orlando Rodriguez, UST Class B Operator
 Randy Dayley, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
22	24	11/01/1997	Fiberglass Reinforced Plastic	Steel - Terminal Piping	High Level Alarm
738	No		Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	
Mixture		06/03/2015	Continuous Interstitial Monitoring	3-Year Line Tightness Test	No
8,000		03/08/2016			No
S09	68	01/01/1953	Cathodically Protected Steel	Steel - Terminal Piping	
739	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Gasoline		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
1,260,000		10/09/2015			No
S11	68	01/01/1953	Cathodically Protected Steel	Steel - Terminal Piping	
741	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Gasoline		06/03/2015	Deferred	Terminal Piping Annual Line Test	No

840,000		10/09/2015			No
S13	68	01/01/1953	Cathodically Protected Steel	Steel - Terminal Piping	
743	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Mixture		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
840,000		10/09/2015			No
S15	68	01/01/1953	Cathodically Protected Steel	Steel - Terminal Piping	
745	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Gasohol/Ethanol		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
840,000		10/09/2015			No
S17	49	01/01/1972	Cathodically Protected Steel	Steel - Terminal Piping	
747	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
840,000		10/09/2015			No
S19	47	01/01/1974	Cathodically Protected Steel	Steel - Terminal Piping	
749	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Gasoline		06/03/2015	Deferred	Terminal Piping Annual Line Test	No
4,200,000		10/09/2015			No
S20	47	01/01/1974	Cathodically Protected Steel	Steel - Terminal Piping	
750	Yes			None	Yes

Currently in Use		Not Required	Pressurized	
Diesel	06/03/2015	Deferred	Terminal Piping Annual Line Test	No
2,646,000	10/09/2015			No

Facility Summary in Missoula County in the City of Missoula

Location: PROVIDENCE CENTER
900 N Orange St
Missoula, MT 59802-2998 Missoula

Legacy ID:32-13405

Facility ID: 25746
Last Inspected On: 02/15/2021
Operating Permit Renewal Date: 04/03/2024

Owner Operator Contact: Saint Patricks Hospital

4065437271

Operator Contact: Timothy Chopp

Owner/Operator: Saint Patricks Hospital

Harry McGuire, UST Class B Operator
Timothy Chopp, UST Class A Operator
Timothy Chopp, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	26	08/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
1960	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
2,500		01/05/2018	Gilbarco-Veeder Root/TLS- 300;Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Missoula

Location: PS MINI MART
930 N Russell St
Missoula, MT 59801-2006 Missoula

Legacy ID:32-13472

Facility ID: 25751
Last Inspected On: 12/29/2020
Operating Permit Renewal Date: 01/06/2024

Owner Operator Contact:

Operator Contact: Scott Denning

4068807272

Owner/Operator: Christine Denning

Scott Denning, UST Class A Operator

Scott Denning, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	06/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1450	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/04/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		08/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	27	06/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1451	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		08/04/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		08/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	27	06/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1452	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/04/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: RANGITSCH BROTHERS 2001 WEST BROADWAY
2001 W Broadway St
Missoula, MT 59808-1817 Missoula

Legacy ID:32-09919

Facility ID: 25529
Last Inspected On: 07/22/2020
Operating Permit Renewal Date: 10/29/2023

Owner Operator Contact: Rangitsch Brothers

4067284040

Operator Contact: Gerry Wolner;Joel Jasperson

4067217561

Owner/Operator: Rangitsch Brothers

David Crowder, UST Class B Operator
Gerry Wolner, UST Class A Operator
Joel Jasperson, UST Class A Operator
Joel Jasperson, UST Class B Operator
Russ Dickey, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	22	01/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3917	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
12,000			EMCO Electronics/EECO 1500		No

Facility Summary in Missoula County in the City of Missoula

Location: ROSAUERS 127 FUEL STATION
2350 S Reserve St
Missoula, MT 59801 Missoula

Legacy ID:60-15318

Facility ID: 31015
Last Inspected On: 10/03/2018
Operating Permit Renewal Date: 12/23/2021

Owner Operator Contact: Rosauers Supermarkets Inc Marshall

5093268900

Operator Contact: Keith Wolf

4067215430

Owner/Operator: Rosauers Supermarkets Inc Marshall

Jerry Kuykendall, UST Class B Global Operator
Keith Wolf, UST Class A Operator
Keith Wolf, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	3	06/21/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5814	No	06/24/2018	Double-Walled	Double Walled	Yes
Currently in Use		06/24/2018	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2;Not Listed	Yes
20,000			Incon/TS-550 EVO		Yes
02	3	06/21/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5815	No	06/24/2018	Double-Walled	Double Walled	Yes
Currently in Use		06/24/2018	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2;Not Listed	No
9,000			Incon/TS-550 EVO		Yes
03	3	06/21/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5816	No	06/24/2018	Double-Walled	Double Walled	Yes
Currently in Use		06/24/2018	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2;Not Listed	Yes
6,000			Incon/TS-550 EVO		Yes

Facility Summary in Missoula County in the City of Missoula

Location: SILVER SLIPPER
4055 Hwy 93 S
Missoula, MT 59804-7300 Missoula

Legacy ID:32-13711

Facility ID: 25780
Last Inspected On: 11/25/2020
Operating Permit Renewal Date:

Owner Operator Contact: Preslyn LLC

4062515402

Owner/Operator: Kathy Ogren

Owner/Operator: Preslyn LLC

Melissa Rausch, UST Class A Operator

Melissa Rausch, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	03/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3251	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
15,000					No
02	25	03/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3252	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
15,000					No
03	25	03/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3253	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
5,000					No

Facility Summary in Missoula County in the City of Missoula

Location: SORENSEN TRANSPORT
6575 US Hwy 10 W
Missoula, MT 59808-9086 Missoula

Legacy ID:32-13428

Facility ID: 25748
Last Inspected On: 05/12/2021
Operating Permit Renewal Date: 10/15/2024

Owner Operator Contact: Sorensen Transport **4067215404**

Operator Contact: Lane Sorensen **4067215404**

Owner/Operator: Sorensen Transport

Lane Sorensen, UST Class A Operator
Lane Sorensen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	6	06/04/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5576	No	05/19/2015	Double-Walled	Double Walled	Yes
Currently in Use		06/04/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		06/03/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Missoula County in the City of Missoula

Location: SOUTH AVE MARKET 2
2401 S Higgins Ave
Missoula, MT 59801 Missoula

Legacy ID:32-05764

Facility ID: 25381
Last Inspected On: 09/24/2019
Operating Permit Renewal Date: 02/19/2023

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula;Steven Schmidt **4062404925;4065420384**

Operator Contact: Steven Schmidt **4062404925**

Owner/Operator: Steven Schmidt

Steven Schmidt, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	40	04/26/1981	Bare Steel	Flexible Plastic	Flapper Valve
3849	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	11/02/2016		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No
03	40	04/26/1981	Bare Steel	Flexible Plastic	Flapper Valve
3850	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	11/02/2016		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No
01	40	04/26/1981	Bare Steel	Flexible Plastic	Flapper Valve
4668	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	11/02/2016		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Missoula

Location: SOUTHGATE MARKET
1900 South Ave W
Missoula, MT 59801-6508 Missoula

Legacy ID:32-08862

Facility ID: 25477
Last Inspected On: 02/02/2021
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact:

Operator Contact: Diana Hintz; Steve Hintz

4063701314;4065422685

Owner/Operator: Fugli LLC

Owner/Operator: Steve Hintz

Diana Hintz, UST Class A Operator
 Gary Keith, UST Class B Operator
 Steve Hintz, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	12/23/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1354	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/27/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		10/12/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	36	12/23/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1355	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/27/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		10/20/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	36	12/23/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1356	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/27/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		10/20/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: SPRINT MISSOULA POP
 2515 Railroad St W
 Missoula, MT 59808-1680 Missoula

Legacy ID:56-14010

Facility ID: 30670
Last Inspected On: 06/08/2020
Operating Permit Renewal Date: 08/12/2023

Owner Operator Contact: Sprint Communications Co LLP

9137625957

Operator Contact: Brian Wiedower

9133158631

Owner/Operator: Sprint Communications Co LLP

Brian Wiedower, UST Class A Operator
Matt Santee, UST Class B Global Operator
Nikki Lattin, UST Class B Global Operator
Scott Hallesy, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
4321	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
2,500		02/14/2017	Gilbarco-Veeder Root/TLS-300		No

Facility Summary in Missoula County in the City of Missoula

Location: ST PATRICKS HOSPITAL
500 W Broadway St
Missoula, MT 59802-4008 Missoula

Legacy ID:32-04266

Facility ID: 25338
Last Inspected On: 02/15/2021
Operating Permit Renewal Date: 05/29/2024

Owner Operator Contact: Saint Patricks Hospital

4065437271

Operator Contact: Timothy Chopp

Owner/Operator: Saint Patricks Hospital

Timothy Chopp, UST Class A Operator
Timothy Chopp, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	20	10/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
4497	No		Double-Walled	Double Walled	Yes
Currently in Use	02/29/2008		Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
10,000	01/05/2018		Gilbarco-Veeder Root/TLS- 300;Veeder Root/TLS-300		No
04	13	07/18/2008	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5175	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
10,000	01/05/2018		Gilbarco-Veeder Root/TLS- 300;Veeder Root/TLS-300		Yes

Facility Summary in Missoula County in the City of Missoula

Location: TABISH BROTHERS DISTRIBUTORS INC
501 Taylor St
Missoula, MT 59802-4920 Missoula

Legacy ID:32-06523

Facility ID: 25407
Last Inspected On: 04/25/2020
Operating Permit Renewal Date: 06/22/2023

Owner Operator Contact: Tabish Brothers Distributors Inc

4065437621

Operator Contact: Heather Stiles

Owner/Operator: Tabish Brothers Distributors Inc

Heather Stiles, UST Class A Operator
Heather Stiles, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	40	04/16/1981	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve

2080	No			Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Heating Oil			Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
7,600			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	40	04/16/1981	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
2081	No	07/13/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Non-corrodible
Oil, Waste			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
7,600			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: THE OLDE DAIRY
2106 Clements Rd
Missoula, MT 59804-6212 Missoula

Legacy ID:32-08475

Facility ID: 25464
Last Inspected On: 08/25/2020
Operating Permit Renewal Date: 09/03/2023

Owner Operator Contact: Steven Schmidt;Schmidtco1 LLC

4062404925;4062404925

Operator Contact: Madison Jones;Mark Jones

4062397387;4067213322

Owner/Operator: Dale L Johnson

Owner/Operator: Target Range Development LLC

Madison Jones, UST Class A Operator
Madison Jones, UST Class B Operator
Mark Jones, UST Class A Operator
Mark Jones, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	22	03/23/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4086	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	22	03/23/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4087	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; MLLD Line Tightness Testing	No
8,000		08/08/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	22	03/23/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4088	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 1
5310 Grant Creek Rd
Missoula, MT 59808-1483 Missoula

Legacy ID:32-13336

Facility ID: 25739
Last Inspected On: 05/08/2021
Operating Permit Renewal Date: 05/08/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Missoula 1 Town Pump LLC

Owner/Operator: Town Pump Inc

- Charles Armstrong, UST Class A Operator
- Charles Armstrong, UST Class B Global Operator
- Trent Biggers, UST Class A Operator
- Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	12/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2342	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		01/16/2013	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-350		No
02	28	12/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2343	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		01/16/2013	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000			Gilbarco-Veeder Root/TLS-350		No
03	28	12/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2344	No			Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		01/16/2013	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	Yes
4,000			Gilbarco-Veeder Root/TLS-350		No
04	28	12/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2345	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Diesel		01/16/2013	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
05	12	01/25/2009	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5196	No		Double-Walled	Double Walled	Yes
Currently in Use		01/25/2009	Electronic Line Leak Detector	Pressurized	
Gasoline		01/11/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-350		No
06	12	01/25/2009	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5197	No		Double-Walled	Double Walled	Yes
Currently in Use		01/25/2009	Electronic Line Leak Detector	Pressurized	
Diesel		01/11/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 2
318 S Orange St
Missoula, MT 59801-1811 Missoula

Legacy ID:32-08715

Facility ID: 25471
Last Inspected On: 05/04/2021
Operating Permit Renewal Date: 05/07/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Missoula 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	31	05/24/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2552	No		None	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized		
Gasoline		Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No	
12,000		Gilbarco-Veeder Root/TLS-350		No	
05	31	05/29/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2553	No		None	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized		
Gasoline		Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No	
10,000		Gilbarco-Veeder Root/TLS-350		No	
06	31	05/29/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2554	No		None	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized		
Diesel		Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No	
10,000		Gilbarco-Veeder Root/TLS-350		No	

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 3
2210 N Reserve St
Missoula, MT 59808-1323 Missoula

Legacy ID:32-13172

Facility ID: 25725
Last Inspected On: 05/08/2021
Operating Permit Renewal Date: 05/08/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Missoula 3 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2559	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		09/22/2006	Gilbarco-Veeder Root/TLS-350		No
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2560	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		09/22/2006	Gilbarco-Veeder Root/TLS-350		No
03	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2561	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		09/30/2006	Gilbarco-Veeder Root/TLS-350		No
04	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve

2562	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		09/30/2006	Gilbarco-Veeder Root/TLS-350		No
05	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2563	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		09/30/2006	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 8
3420 Mullan Rd Ste A
Missoula, MT 59808-5126 Missoula

Legacy ID:56-13823

Facility ID: 30509
Last Inspected On: 04/27/2021
Operating Permit Renewal Date: 10/01/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Missoula 8 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1444	No	05/04/2016		Double Walled	Yes

Currently in Use		05/24/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		05/05/2016	Gilbarco-Veeder Root/TLS-350		No
02	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1445	No	05/04/2016		Double Walled	Yes
Currently in Use		05/24/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		05/18/2016	Gilbarco-Veeder Root/TLS-350		No
03	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1446	No	05/04/2016		Double Walled	Yes
Currently in Use		05/24/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		05/17/2016	Gilbarco-Veeder Root/TLS-350		No
04	5	05/24/2016	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5629	No	05/04/2016	Double-Walled	Double Walled	Yes
Currently in Use		05/24/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000		05/18/2016	Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP MISSOULA 9
 2001 Brooks St
 Missoula, MT 59808 Missoula

Legacy ID:60-15288

Facility ID: 30995
Last Inspected On: 05/10/2021
Operating Permit Renewal Date: 05/14/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Missoula 9 Town Pump LLC

Trent Biggers, UST Class A Operator
 Trent Biggers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	4	03/28/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5683	No	10/24/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
25,000			Gilbarco-Veeder Root/TLS-450		Yes
02	4	03/28/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5684	No	10/24/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-450		Yes
03	4	03/28/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5685	No	10/24/2016	Double-Walled	Double Walled	Yes

Currently in Use	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000	Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Missoula County in the City of Missoula

Location: UNITED PARCEL SERVICES MISSOULA
221 Expressway Ln
Missoula, MT 59808-1553 Missoula

Legacy ID:32-04536

Facility ID: 25343
Last Inspected On: 05/31/2019
Operating Permit Renewal Date: 10/11/2022

Owner Operator Contact: Kaytee Villafrancaa;Thomas McKenna;United Parcel Service Inc Billings;United Parcel Service Inc Seattle

2066216286;2066216380;4066986391;4066568964

Operator Contact: Dino Ostrow;Kaytee Villafrancaa;Trear Smith

2066216286;2066216380;5033297154

Owner/Operator: United Parcel Service Inc Seattle

- Dino Ostrow, UST Class A Operator
- Dino Ostrow, UST Class B Operator
- Kaytee Villafrancaa, UST Class A Operator
- Kaytee Villafrancaa, UST Class B Global Operator
- Trear Smith, UST Class A Operator
- Trear Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	28	07/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2182	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		04/06/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: WESTERN TRANSPORT
 9310 Cartage Rd
 Missoula, MT 59808-9758 Missoula

Legacy ID:32-01348

Facility ID: 25211
Last Inspected On: 03/20/2019
Operating Permit Renewal Date: 06/09/2022

Owner Operator Contact: Alan Williams;Missoula Cartage Co;James Haacke;Hanson Trucking Inc. Missoula;Ken Williams;AKB Investments LLP

4065494171;4065870485

Operator Contact: Cari Goss;Neil Hanson;Scott Allen

3076746305;4064937876

Owner/Operator: Western Land Investments LLC

Cari Goss, UST Class A Operator
 Jeff Drushel, UST Class B Operator
 Neil Hanson, UST Class A Operator
 Neil Hanson, UST Class B Global Operator
 Robin Titus, UST Class B Global Operator
 Scott Allen, UST Class A Operator
 Scott Allen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	53	01/17/1968	Cathodically Protected Steel	Steel	High Level Alarm
1654	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		03/18/2015	Automatic Tank Gauging 0.2	Deferred	No
10,000		09/12/2012	Veeder Root/TLS-250		No
02	53	01/17/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1655	No		Lined Interior/Impressed Current	None	Yes
Currently in Use		12/11/2006	Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		03/18/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/14/2015	Veeder Root/TLS-250		No

03	40	01/16/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1656	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use		12/11/2006	Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		03/18/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		05/27/2010	Veeder Root/TLS-250		No

Facility Summary in Missoula County in the City of Missoula

Location: WESTFIELD MISSOULA
8448 US Hwy 10 W
Missoula, MT 59808-9319 Missoula

Legacy ID:32-13674

Facility ID: 25776
Last Inspected On: 04/20/2020
Operating Permit Renewal Date: 07/22/2023

Owner Operator Contact: Finest Oil Co

4065436969

Operator Contact: Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson **4062181563;4063606327;4065436969;4065441005;7143338926**

Owner/Operator: Finest Oil Co

- Christopher Glasser, UST Class A Operator
- David Peyton, UST Class A Operator
- David Peyton, UST Class B Global Operator
- James Brady, UST Class A Operator
- James DeWaters, UST Class A Operator
- Joseph McClain, UST Class B Operator
- Justin Gaudot, UST Class A Operator
- Justin Gaudot, UST Class B Global Operator
- Stephen Hanson, UST Class A Operator
- Stephen Hanson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	26	12/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1077	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Gasoline		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	26	12/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1078	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	26	12/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1079	No			Double Walled	Yes
Currently in Use		09/19/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	26	12/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1080	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	26	12/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1081	No			Double Walled	Yes
Currently in Use		05/17/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	26	12/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

1082	No		Double Walled	Yes
Currently in Use	05/17/2012	Electronic Line Leak Detector	Safe Suction	Galvanic
Diesel	03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 31
3325 Brooks St
Missoula, MT 59801-8289 Missoula

Legacy ID:32-09730

Facility ID: 25516
Last Inspected On: 05/09/2019
Operating Permit Renewal Date: 05/20/2022

Owner Operator Contact:

Operator Contact: Jason Cocke;Jim Alford;Sean Hurley **5095357701;5095367418**

Owner/Operator: CHS Inc Spokane Valley

- Jason Cocke, UST Class A Operator
- Jason Cocke, UST Class B Global Operator
- Jason Cocke, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Justin Mace, UST Class B Operator
- Luci Tuttle, UST Class B Operator
- Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	33	03/18/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1363	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		08/04/2010	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		11/05/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

02	33	03/18/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1364	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/04/2010	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		11/05/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	33	03/18/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1365	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/04/2010	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		11/05/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 32
1540 Toole Ave
Missoula, MT 59802-2241 Missoula

Legacy ID:32-03912

Facility ID: 25317
Last Inspected On: 08/16/2019
Operating Permit Renewal Date: 02/04/2023

Owner Operator Contact:

Operator Contact: Jason Cocke;Jim Alford;Sean Hurley

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Jason Cocke, UST Class A Operator
- Jason Cocke, UST Class B Global Operator
- Jason Cocke, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Justin Mace, UST Class B Operator
- Luci Tuttle, UST Class B Operator
- Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	37	03/22/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1342	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	10/09/2013		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	37	03/22/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1343	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	10/09/2013		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	37	03/22/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1344	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel	10/09/2013		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Missoula County in the City of Missoula

Location: ZOOTOVN SUPER STOP
2105 S Higgins Ave
Missoula, MT 59801-6714 Missoula

Legacy ID:32-07244

Facility ID: 25429
Last Inspected On: 01/29/2021
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact: Greg Tabish

4067282575

Operator Contact: Daniel Marx; Erin Keffeler; Karly Shafer; Yvonne Bunch **4062742435; 4063962206; 4068800056**

Owner/Operator: Greg Tabish

Daniel Marx, UST Class A Operator
Daniel Marx, UST Class B Global Operator
Erin Keffeler, UST Class A Operator
Erin Keffeler, UST Class B Operator

Karly Shafer, UST Class A Operator
 Karly Shafer, UST Class B Global Operator
 Yvonne Bunch, UST Class A Operator
 Yvonne Bunch, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	12/07/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1799	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/27/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		07/13/2011	Gilbarco/EMC Basic		No
04	31	12/07/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1800	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/27/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000		07/13/2011	Gilbarco/EMC Basic		No
05	31	12/07/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1801	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/27/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000		07/13/2011	Gilbarco/EMC Basic		No

Facility Summary in Missoula County in the City of Seeley Lake

Location: LINDEYS LANDING WEST SPB
MT Hwy 83
Seeley Lake, MT 59868 Missoula

Legacy ID:32-05837

Facility ID: 25389
Last Inspected On: 09/09/2020
Operating Permit Renewal Date: 10/17/2023

Owner Operator Contact: Lindeys Inc Saint Paul

4066779229

Operator Contact: Michael Lindemer

4066774101

Owner/Operator: Lindeys Inc Saint Paul

Michael Lindemer, UST Class A Operator
Michael Lindemer, UST Class B Operator
Tanner Stevenson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	22	05/01/1999	Concrete	Flexible Plastic	High Level Alarm
4104	Yes	05/18/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
1,500					No

Facility Summary in Missoula County in the City of Seeley Lake

Location: ROVEROS
3182 Hwy 83
Seeley Lake, MT 59868 Missoula

Legacy ID:60-15146

Facility ID: 30890
Last Inspected On: 12/13/2019
Operating Permit Renewal Date: 01/28/2023

Owner Operator Contact:

Operator Contact: Karly Shafer; Kyle Marx

4063962206;4063962296

Owner/Operator: Addrien Marx

Owner/Operator: Greg Tabish

Owner/Operator: Roveros LLC

Owner/Operator: Tabish Brothers Distributors Inc

Pat Mitchell, UST Class A Operator

Pat Mitchell, UST Class B Global Operator
 Karly Shafer, UST Class A Operator
 Karly Shafer, UST Class B Global Operator
 Kathy Sindelar, UST Class B Operator
 Kyle Marx, UST Class A Operator
 Kyle Marx, UST Class B Global Operator
 RaeDean Bartlett, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	26	04/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3337	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.2	No
7,000			Gilbarco-Veeder Root/TLS-450		No
08	26	04/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3338	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-450		No
09	26	04/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3339	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-450		No

10	26	04/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3340	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-450		No
11	26	04/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3341	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-450		No
12	26	04/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3342	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-450		No
13	26	04/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3343	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.2	No
2,000			Gilbarco-Veeder Root/TLS-450		No

Facility Summary in Missoula County in the City of Seeley Lake

Location: SEELEY LAKE CONVENIENCE STORE
3072 MT Hwy 83
Seeley Lake, MT 59868 Missoula

Legacy ID:32-09288

Facility ID: 25483
Last Inspected On: 07/19/2021
Operating Permit Renewal Date: 08/22/2024

Owner Operator Contact: Norman W and M Rose Baier

4066772004

Operator Contact: Norman Baier;Rose Baier

Owner/Operator: Norman W and M Rose Baier

Norman Baier, UST Class A Operator
 Norman Baier, UST Class B Operator
 Rose Baier, UST Class A Operator
 Rose Baier, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	34	04/22/1987	Concrete	Fiberglass Reinforced Plastic	Ball Float Valve
416	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
8,000		09/27/2017			No
S2	34	04/22/1987	Concrete	Fiberglass Reinforced Plastic	Ball Float Valve
417	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
8,000		09/27/2017			No
S3	34	04/22/1987	Concrete	Fiberglass Reinforced Plastic	Ball Float Valve
418	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
8,000		09/27/2017			No

Facility Summary in Missoula County in the City of TURAH

Location: TURAH STORE and CAMPGROUND
 13555 Turah Rd
 TURAH, MT 59825-9775 Missoula

Legacy ID:32-04899

Facility ID: 25351
Last Inspected On: 09/09/2019
Operating Permit Renewal Date: 11/01/2022

Owner Operator Contact: Morton Kimball;Turah Store and Campground LLC **4062589773**

Operator Contact: Kathleen Marshall

Owner/Operator: Turah Store and Campground LLC

Jerry Kinney, UST Class B Operator
 Kathleen Marshall, UST Class A Operator
 Kathleen Marshall, UST Class B Global Operator
 Pamela Asbridge, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	49	04/18/1972	Cathodically Protected Steel	Steel	Flapper Valve
4007	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		09/01/2016	Statistical Inventory Reconciliation	Deferred	No
3,000		10/10/2007			No
02	49	04/18/1972	Cathodically Protected Steel	Steel	Flapper Valve
4008	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		09/01/2016	Statistical Inventory Reconciliation	Deferred	No
1,000		10/10/2007			No