

Facility Summary in Musselshell County in the City of Melstone

Location: JAKES GARAGE
221 US Hwy 12
Melstone, MT 59054 Musselshell

Legacy ID:33-01481

Facility ID: 25794
Last Inspected On: 09/20/2021
Operating Permit Renewal Date: 10/01/2024

Owner Operator Contact: Jakes Garage Inc;Larry Zaharko;Jakes Garage Inc **4063582389;4063582389;4063582389**

Operator Contact: Larry Zaharko;Tim DeJaegher **4063582389**

Owner/Operator: Jake Zaharko

Owner/Operator: Jakes Garage Inc

Larry Zaharko, UST Class A Operator
Larry Zaharko, UST Class B Operator
Tim DeJaegher, UST Class A Operator
Tim DeJaegher, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
3770	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		01/04/2013	Manual Interstitial Monitoring	Deferred	No
3,750					No
09	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
3771	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		01/04/2013	Manual Interstitial Monitoring	Deferred	No
2,250					No

Facility Summary in Musselshell County in the City of Roundup

Location: CONOCO CONVENIENCE CENTER
 806 Main St
 Roundup, MT 59072-2224 Musselshell

Legacy ID:33-05030

Facility ID: 25845
Last Inspected On: 10/25/2019
Operating Permit Renewal Date: 12/14/2022

Owner Operator Contact: McCleary Distributing Inc;Terry Watkins;McCleary Distributing Inc

4063231108;4063231108;4063231108

Operator Contact: Terry Watkins

4063231108

Owner/Operator: McCleary Distributing Inc

Terry Watkins, UST Class A Operator
 Terry Watkins, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	32	08/30/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1591	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		09/09/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	32	08/30/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1592	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		09/09/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	29	09/01/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1593	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Gasoline		08/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		09/09/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	25	10/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1594	No	08/26/2015	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/22/2014	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000		11/09/2011	Gilbarco-Veeder Root/ILS-350		No
10	25	10/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1595	No	08/26/2015	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/22/2014	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
2,000		09/07/2010	Gilbarco-Veeder Root/ILS-350		No
11	25	10/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1596	No	08/26/2015	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/22/2014	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000		09/07/2010	Gilbarco-Veeder Root/ILS-350		No
12	25	10/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1597	No	08/26/2015	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/22/2014	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No

2,000

09/07/2010

Gilbarco-Veeder Root/ILS-350

No

Facility Summary in Musselshell County in the City of Roundup

Location: Express Stop
701 1st Ave W
Roundup, MT 59072 Musselshell

Legacy ID:33-06612

Facility ID: 25862
Last Inspected On: 09/05/2019
Operating Permit Renewal Date: 09/10/2022

Owner Operator Contact: Dan Stockton;Stockton Oil Co Billings;Thind Inc

5108945533

Operator Contact: Michael Stockton

4062456376

Owner/Operator: Dan Stockton

Owner/Operator: Thind Inc

Christopher Stockton, UST Class B Global Operator
Dan Stockton Jr, UST Class B Operator
Joseph Stockton, UST Class B Global Operator
Michael Stockton, UST Class A Operator
Michael Stockton, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	23	10/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1985	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/12/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No
05	23	10/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1986	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/12/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	23	10/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1987	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/12/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
01	36	03/26/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3757	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/17/2014	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		08/29/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	36	03/26/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3758	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/17/2014	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	36	03/26/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3759	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/17/2014	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		07/15/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Musselshell County in the City of Roundup

Location: WELLS FARGO BANK ROUNDUP
12 Main St
Roundup, MT 59072-2828 Musselshell

Legacy ID:33-02079

Facility ID: 25806
Last Inspected On: 06/28/2019
Operating Permit Renewal Date: 07/02/2022

Owner Operator Contact: Wells Fargo Bank Roundup

4063232000

Operator Contact: Chris Anderson

Owner/Operator: Wells Fargo Bank Roundup

Chris Anderson, UST Class A Operator

Chris Anderson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	28	10/06/1993	Cathodically Protected Steel	Copper	Flapper Valve
3495	No	10/28/2016	Double-Walled	Double Walled	Yes
Temporarily Out of Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		10/28/2016	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
2,000			Gilbarco-Veeder Root/TLS-300		No