

Facility Summary in Musselshell County in the City of Melstone

Location: JAKES GARAGE
221 US Hwy 12
Melstone, MT 59054 Musselshell

System Facility ID:33-01481

Facility Code: 25794
Last Inspected On: 09/20/2021
Operating Permit Renewal Date: 10/01/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Jake Zaharko;Jakes Garage Inc	4063582389
Operator Contact:	Larry Zaharko;Tim DeJaegher	4063582389

Owner/Operator: Jake Zaharko

Owner/Operator: Jakes Garage Inc

Larry Zaharko, UST Class A Operator

Larry Zaharko, UST Class B Operator

Tim DeJaegher, UST Class A Operator

Tim DeJaegher, UST Class B Operator

Tank Code	08	Tank Age	26	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3770	Spill Test Date	11/16/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/04/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3750	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/20/2021			ATG Type					
Tank Code	09	Tank Age	26	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3771	Spill Test Date	11/17/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/04/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2250	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/20/2021			ATG Type					

Facility Summary in Musselshell County in the City of Roundup

Location: CONOCO CONVENIENCE CENTER
806 Main St
Roundup, MT 59072-2224 Musselshell

System Facility ID:33-05030

Facility Code: 25845
Last Inspected On: 10/04/2022
Operating Permit Renewal Date: 12/14/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: McCleary Distributing Inc4063231108

Operator Contact: Terry Watkins4063231108

Owner/Operator: McCleary Distributing Inc

Terry Watkins, UST Class A Operator
Terry Watkins, UST Class B Operator

Tank Code	06	Tank Age	35	Tank Installed Date	08/30/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1591	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	08/23/2022	Line Tightness Test Date	09/09/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	35	Tank Installed Date	08/30/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1592	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/23/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/23/2022	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	32	Tank Installed Date	09/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	1593	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/23/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/23/2022	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	28	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1594	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/23/2022	Sump Tightness Test Date	07/10/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/23/2022	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	10	Tank Age	28	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1595	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/23/2022	Sump Tightness Test Date	07/10/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/23/2022	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	11	Tank Age	28	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1596	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/23/2022	Sump Tightness Test Date	07/10/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	4000	ATG Test Date	08/23/2022	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	12	Tank Age	28	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1597	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/23/2022	Sump Tightness Test Date	07/10/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/23/2022	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Musselshell County in the City of Roundup

Location: EXPRESS STOP
701 1st Ave W
Roundup, MT 59072 Musselshell

System Facility ID:33-06612

Facility Code: 25862
Last Inspected On: 07/14/2022
Operating Permit Renewal Date: 09/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Thind Inc5108945533

Operator Contact: Lakhbir Singh5108945533

Owner/Operator: Thind Inc

Lakhbir Singh, UST Class A Operator
Lakhbir Singh, UST Class B Operator

Tank Code	04	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1985	Spill Test Date	07/14/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	12/12/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/14/2022	Line Tightness Test Date	02/10/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/14/2022			ATG Type	Gilbarco/TLS-350				
Tank Code	05	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1986	Spill Test Date	07/14/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	12/12/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/14/2022	Line Tightness Test Date	07/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1987	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/12/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	39	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3757	Spill Test Date	07/14/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	08/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/14/2022	Line Tightness Test Date	02/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	39	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3758	Spill Test Date	07/14/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	08/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/14/2022	Line Tightness Test Date	02/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	39	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3759	Spill Test Date	08/16/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	08/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/14/2022	Line Tightness Test Date	07/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/24/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Musselshell County in the City of Roundup

Location: FORMER WELLS FARGO BANK ROUNDUP

12 Main St

Roundup, MT 59072-2828 Musselshell

System Facility ID:33-02079

Facility Code: 25806

Last Inspected On: 03/23/2022

Operating Permit Renewal Date: 07/02/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Roundup SD 55 and 55H

Operator Contact: A. Paul Thompson;Scott Wells4068607125;4069405377

Owner/Operator: Roundup SD 55 and 55H

- A. Paul Thompson, UST Class A Operator
- A. Paul Thompson, UST Class B Global Operator
- Scott Wells, UST Class A Operator
- Scott Wells, UST Class B Global Operator

Tank Code	S2	Tank Age	31	Tank Installed Date	10/06/1993	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	3495	Spill Test Date	03/23/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	10/28/2016	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	03/23/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				