

Facility Summary in Musselshell County in the City of Melstone

Location: JAKES GARAGE
221 US Hwy 12
Melstone, MT 59054 Musselshell

System Facility ID:33-01481

Facility Code: 25794
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 10/01/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jake Zaharko;Jakes Garage Inc

(406) 358-2389

Operator Contact: Larry Zaharko;Tim DeJaegher

(406) 358-2389

Fivezs@midrivers.com;tdejaegher@live.com

Owner/Operator: Jake Zaharko

Owner/Operator: Jakes Garage Inc

Larry Zaharko, UST Class A Operator

Fivezs@midrivers.com

Larry Zaharko, UST Class B Operator

Fivezs@midrivers.com

Tim DeJaegher, UST Class A Operator

tdejaegher@live.com

Tim DeJaegher, UST Class B Operator

tdejaegher@live.com

Tank Code	08	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3770	Spill Test Date	06/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/04/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3750	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/03/2024			ATG Type					
Tank Code	09	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3771	Spill Test Date	06/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/04/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2250	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/03/2024			ATG Type					

Facility Summary in Musselshell County in the City of Roundup

Location: CONOCO CONVENIENCE CENTER
806 Main St
Roundup, MT 59072-2224 Musselshell

System Facility ID:33-05030

Facility Code: 25845
Last Inspected On: 09/02/2025
Operating Permit Renewal Date: 12/14/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: McCleary Distributing Inc

(406) 323-1108

Operator Contact: Terry Watkins

(406) 323-1108

dwatkins3389@hotmail.com

Owner/Operator: McCleary Distributing Inc

(406) 323-1108

Terry Watkins, UST Class A Operator

dwatkins3389@hotmail.com

Terry Watkins, UST Class B Operator

dwatkins3389@hotmail.com

Tank Code	06	Tank Age	37	Tank Installed Date	08/30/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1591	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	37	Tank Installed Date	08/30/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1592	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	34	Tank Installed Date	09/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	1593	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/29/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	30	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1594	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	08/29/2025	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	10	Tank Age	30	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1595	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	08/29/2025	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	11	Tank Age	30	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1596	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/29/2025	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	4000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	12	Tank Age	30	Tank Installed Date	10/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1597	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/29/2025	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Musselshell County in the City of Roundup

Location: EXPRESS STOP
701 1st Ave W
Roundup, MT 59072 Musselshell

System Facility ID:33-06612

Facility Code: 25862
Last Inspected On: 06/10/2025
Operating Permit Renewal Date: 09/10/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Thind Inc	(510) 894-5533	lakhbirkamboj@yahoo.com
--	----------------	-------------------------

Operator Contact: Lakhbir Singh	(510) 894-5533	lakhbirkamboj@yahoo.com
--	----------------	-------------------------

Owner/Operator: Thind Inc	(510) 894-5533	lakhbirkamboj@yahoo.com
----------------------------------	----------------	-------------------------

Lakhbir Singh, UST Class A Operator
Lakhbir Singh, UST Class B Operator

Tank Code	04	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1985	Spill Test Date	06/10/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/10/2025	Tank/Piping CP Test Date	06/10/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/10/2025	Line Tightness Test Date	02/10/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/10/2025			ATG Type	Gilbarco/TLS-350				
Tank Code	05	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1986	Spill Test Date	06/10/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/10/2025	Tank/Piping CP Test Date	06/10/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	06/10/2025	Line Tightness Test Date	07/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1987	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/12/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	41	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3757	Spill Test Date	06/10/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/10/2025	Tank/Piping CP Test Date	06/10/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/10/2025	Line Tightness Test Date	02/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3758	Spill Test Date	06/10/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/10/2025	Tank/Piping CP Test Date	06/10/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/10/2025	Line Tightness Test Date	02/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	41	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3759	Spill Test Date	06/10/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLL D Test Date	06/10/2025	Tank/Piping CP Test Date	06/10/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/10/2025	Line Tightness Test Date	07/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				