

Facility Summary in Park County in the City of Clyde Park

Location: DALES FUEL INC
301 1st Ave
Clyde Park, MT 59018 Park

System Facility ID:34-07600

Facility Code: 26059
Last Inspected On: 03/13/2025
Operating Permit Renewal Date: 06/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dales Fuel Inc

dalesfuel@gmail.com

Operator Contact: Dale Jones

(406) 686-4681

Owner/Operator: Dales Fuel Inc

dalesfuel@gmail.com

Dale Jones, UST Class A Operator
Jackie Jones, UST Class B Operator

dalesfuel@gmail.com

Tank Code	05	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3991	Spill Test Date	03/13/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/13/2025			ATG Type					
Tank Code	06	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3992	Spill Test Date	03/13/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/13/2025			ATG Type					
Tank Code	07	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3993	Spill Test Date	08/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1900	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/13/2025			ATG Type					
Tank Code	08	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3994	Spill Test Date	08/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1900	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/20/2025			ATG Type					

Facility Summary in Park County in the City of Clyde Park

Location: SHIELDS VALLEY HIGH SCHOOL
401 1st St E
Clyde Park, MT 59018 Park

System Facility ID:34-12515

Facility Code: 26147
Last Inspected On: 10/29/2024
Operating Permit Renewal Date: 03/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist Shields Valley (406) 578-2176

Operator Contact: Dan Johnston;Shields Valley School Dist djohnston@shieldsvalleyschools.org

Owner/Operator: School Dist Shields Valley (406) 578-2176

Dan Johnston, UST Class A Operator
Mitchell Marx, UST Class B Operator

djohnston@shieldsvalleyschools.org
mmarx@shieldsvalleyschools.org

Tank Code	01	Tank Age	61	Tank Installed Date	07/01/1965	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2725	Spill Test Date	10/29/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/29/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	10/29/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/29/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY EXXON
204 Main St
Cooke City, MT 59020 Park

System Facility ID:34-01584

Facility Code: 25925
Last Inspected On: 06/13/2025
Operating Permit Renewal Date: 09/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wea Enterprises Inc. (406) 838-2244 cookecityexxon@gmail.com

Operator Contact: Joelle Passerello;Timmy Weamer (406) 855-5792 cookecityexxon@gmail.com;joellepasserello@gmail.com

Owner/Operator: Wea Enterprises Inc. (406) 838-2244 cookecityexxon@gmail.com

Joelle Passerello, UST Class A Operator joellepasserello@gmail.com
Joelle Passerello, UST Class B Operator joellepasserello@gmail.com
Timmy Weamer, UST Class A Operator cookecityexxon@gmail.com
Timmy Weamer, UST Class B Global Operator cookecityexxon@gmail.com

Tank Code	07	Tank Age	35	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	757	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date	05/20/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/20/2025	Line Tightness Test Date	05/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/20/2025			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	08	Tank Age	35	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	758	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/03/2019	Tank/Piping CP Test Date	05/20/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	05/20/2025	Line Tightness Test Date	06/03/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/20/2025			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	09	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	759	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date	05/20/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/20/2025	Line Tightness Test Date	05/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/20/2025			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	10	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	760	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date	05/20/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/20/2025	Line Tightness Test Date	05/31/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/20/2025			ATG Type	Franklin Fueling Systems/EVO 6000				

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY SINCLAIR AND CABINS
115 Main St
Cooke City, MT 59020 Park

System Facility ID:34-10046

Facility Code: 26103
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 09/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cooke City Sinclair and Lodging, Inc. (406) 579-9993 benzavora@gmail.com

Operator Contact: Ben Zavora;Cooke City Sinclair and Lodging, Inc.;Benjamin Zavora;Cooke City Sinclair and Lodging, Inc.;Rick Sommers (406) 579-9993;(406) 838-2244 benzavora@gmail.com;benzavora@gmail.com

Owner/Operator: Cooke City Sinclair and Lodging, Inc. (406) 579-9993 benzavora@gmail.com

Ben Zavora, UST Class A Operator benzavora@gmail.com
Ben Zavora, UST Class B Operator benzavora@gmail.com
Benjamin Zavora, UST Class A Operator benzavora@gmail.com
Benjamin Zavora, UST Class B Operator benzavora@gmail.com
Rick Sommers, UST Class A Operator benzavora@gmail.com
Rick Sommers, UST Class B Global Operator benzavora@gmail.com

Tank Code	06	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3670	Spill Test Date	05/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/20/2025	Line Tightness Test Date	06/03/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/20/2025			ATG Type	Incon/Other				
Tank Code	07	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3671	Spill Test Date	05/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date	05/20/2025	Line Tightness Test Date	06/03/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/20/2025			ATG Type	Incon/				

Facility Summary in Park County in the City of Cooke City

Location: NORTHEAST ENTRANCE GAS PUMPS
NE Entrance of Park
Cooke City, MT 59020 Park

System Facility ID:34-08869

Facility Code: 26082
Last Inspected On: 06/26/2025
Operating Permit Renewal Date: 09/26/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Mammoth (307) 344-2333

Operator Contact: Jason Ogle;Joel Browning;Nathan Munson (307) 344-2333;(406) 595-0840;(406) 823-9578
jason_ogle@nps.gov;joel_browning@nps.gov;nathan_munson@nps.gov

Owner/Operator: National Park Service Mammoth (307) 344-2333

Jason Ogle, UST Class A Operator
Joel Browning, UST Class A Operator
Nathan Munson, UST Class A Operator

jason_ogle@nps.gov
joel_browning@nps.gov
nathan_munson@nps.gov

Tank Code	04	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1741	Spill Test Date	08/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/15/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	06/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/05/2024			ATG Type					
Tank Code	05	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1742	Spill Test Date	08/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/15/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	06/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/05/2024			ATG Type					

Facility Summary in Park County in the City of Emigrant

Location: B BUNK INC
 Parcel 38 N Glastonbury
 Emigrant, MT 59027-0519 Park

System Facility ID:34-10959

Facility Code: 26118
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 08/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: B Bunk Inc (757) 498-6060 padma36mtnow@protonmail.com

Operator Contact: Bradford Tisdale (757) 498-6060 padma36mtnow@protonmail.com

Owner/Operator: B Bunk Inc (757) 498-6060 padma36mtnow@protonmail.com
 Bradford Tisdale, UST Class A Operator padma36mtnow@protonmail.com
 Bradford Tisdale, UST Class B Operator padma36mtnow@protonmail.com

Tank Code	01	Tank Age	36	Tank Installed Date	04/18/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	415	Spill Test Date	05/23/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/23/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	05/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: CAPSTONE SHELTER
 Lot 105 S Glastonbury
 Emigrant, MT 59027 Park

System Facility ID:34-10989

Facility Code: 26125
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 04/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Capstone Project (480) 657-2564

Operator Contact: Enrico DArgenzio (602) 859-4563 rico4ddd@gmail.com

Owner/Operator: Capstone Project (480) 657-2564

Enrico DArgenzio, UST Class A Operator
 Enrico DArgenzio, UST Class B Operator

rico4ddd@gmail.com
 rico4ddd@gmail.com

Tank Code	01	Tank Age	36	Tank Installed Date	04/13/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4827	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/23/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONSERVATION ASSOCIATION
2 B Taurus Rd
Emigrant, MT 59027 Park

System Facility ID:34-10934

Facility Code: 26116
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 06/12/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Conservation Association Inc Emigrant (406) 579-3399

Operator Contact: Edward Dratz (406) 579-3399 edratz@gmail.com

Owner/Operator: Community Conservation Association Inc Emigrant (406) 579-3399

Edward Dratz, UST Class A Operator

edratz@gmail.com

Edward Dratz, UST Class B Global Operator

edratz@gmail.com

Edward Dratz, UST Class B Operator

edratz@gmail.com

Tank Code	01	Tank Age	36	Tank Installed Date	04/18/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4684	Spill Test Date	05/16/2025	Piping Installed Date	11/06/1998	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	05/16/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/16/2025			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONTINUITY INC
18 Polaris Way Parcel 70 S Glastonbury
Emigrant, MT 59027 Park

System Facility ID:34-10930

Facility Code: 26113
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Continuity Inc

Operator Contact: Daniel Kehoe

(406) 223-2232

dankehoe56@gmail.com

Owner/Operator: Community Continuity Inc

Daniel Kehoe, UST Class A Operator

dankehoe56@gmail.com

Daniel Kehoe, UST Class B Operator

dankehoe56@gmail.com

Dennis Franks, UST Class B Global Operator

dennis@ajminc.net

Tank Code	01	Tank Age	36	Tank Installed Date	02/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4821	Spill Test Date	06/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/16/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY RESTORATION INC
Hercules Rd and Polaris Way
Emigrant, MT 59027 Park

System Facility ID:34-10931

Facility Code: 26114
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Restoration Inc (406) 222-4222

Operator Contact: Daniel Kehoe (406) 223-2232 dankehoe56@gmail.com

Owner/Operator: Community Restoration Inc (406) 222-4222

Daniel Kehoe, UST Class A Operator

dankehoe56@gmail.com

Daniel Kehoe, UST Class B Operator

dankehoe56@gmail.com

Dennis Franks, UST Class B Global Operator

dennis@ajminc.net

Tank Code	01	Tank Age	36	Tank Installed Date	02/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	701	Spill Test Date	06/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/16/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: DENNIS CURTIN
70 Ramshorn Rd
Emigrant, MT 59027 Park

System Facility ID:56-14035

Facility Code: 30691
Last Inspected On: 07/28/2025
Operating Permit Renewal Date: 12/31/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: D M Curtin Family Limited Partnership (918) 630-3467 dcurtin@rmxreg.com

Operator Contact: Channell Libbey;Todd Fredericksen (406) 223-1459 chan.libbey@earthlink.net;fredericksentodd@gmail.com

Owner/Operator: D M Curtin Family Limited Partnership (918) 630-3467 dcurtin@rmxreg.com
Channell Libbey, UST Class A Operator chan.libbey@earthlink.net
Todd Fredericksen, UST Class A Operator fredericksentodd@gmail.com
Todd Fredericksen, UST Class B Operator fredericksentodd@gmail.com

Tank Code	01	Tank Age	25	Tank Installed Date	10/15/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4435	Spill Test Date	08/28/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/28/2025			ATG Type	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Park County in the City of Emigrant

Location: EARTH HOME PROPERTIES LLC
Evening Star Dr
Emigrant, MT 59027 Park

System Facility ID:34-10978

Facility Code: 26123
Last Inspected On: 08/15/2024
Operating Permit Renewal Date: 08/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Earth Home Properties LLC (978) 658-3010 newhousebuilders@gmail.com

Operator Contact: Craig Newhouse (978) 65-87675 newhousebuilders@gmail.com

Owner/Operator: Earth Home Properties LLC (978) 658-3010 newhousebuilders@gmail.com
 Craig Newhouse, UST Class A Operator newhousebuilders@gmail.com
 Craig Newhouse, UST Class B Operator newhousebuilders@gmail.com

Tank Code	01	Tank Age	36	Tank Installed Date	04/23/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4753	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/11/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	36	Tank Installed Date	04/23/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	4754	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/11/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Park County in the City of Emigrant

Location: EMIGRANT GENERAL STORE
3 Murphy Ln
Emigrant, MT 59027-6100 Park

System Facility ID:34-06713

Facility Code: 26035
Last Inspected On: 08/28/2024
Operating Permit Renewal Date: 05/28/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: EMGS LLC (406) 333-4434 cameron@emigrantgeneralstore.com

Operator Contact: Cameron Ehrlich;Emigrant General Store cehlich112@gmail.com;otisranch@wispwest.net

Owner/Operator: EMGS LLC (406) 333-4434 cameron@emigrantgeneralstore.com
Cameron Ehrlich, UST Class A Operator otisranch@wispwest.net
Cameron Ehrlich, UST Class B Operator otisranch@wispwest.net

Tank Code	02	Tank Age	37	Tank Installed Date	09/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4351	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/07/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	29	Tank Installed Date	01/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4352	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/07/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	01	Tank Age	37	Tank Installed Date	09/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4353	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	8	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5852	Spill Test Date	08/28/2024	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	08/28/2024	Line Tightness Test Date	03/01/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/28/2024			ATG Type	Incon/TS-550 EVO				
Tank Code	08	Tank Age	8	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5853	Spill Test Date	08/28/2024	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/28/2024	Line Tightness Test Date	03/05/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/28/2024			ATG Type	Incon/TS-550 EVO				

Tank Code	09	Tank Age	8	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5854	Spill Test Date	08/28/2024	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/28/2024	Line Tightness Test Date	03/05/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/28/2024			ATG Type	Incon/TS-550 EVO				

Facility Summary in Park County in the City of Emigrant

Location: ROSKIND RANCH
65 Arcturus Dr
Emigrant, MT 59027 Park

System Facility ID:34-13180

Facility Code: 26156
Last Inspected On: 09/19/2025
Operating Permit Renewal Date: 09/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Alicia Roskind (424) 610-6640 arcturusdrmt@gmail.com

Operator Contact: Alicia Roskind;Kenneth Mueller (406) 333-4669;(424) 610-6640 arcturusdrmt@gmail.com;kencmueller@gmail.com

Owner/Operator: Alicia Roskind (424) 610-6640 arcturusdrmt@gmail.com

- | | |
|---|------------------------|
| Alicia Roskind, UST Class A Operator | arcturusdrmt@gmail.com |
| Alicia Roskind, UST Class B Global Operator | arcturusdrmt@gmail.com |
| Alicia Roskind, UST Class B Operator | arcturusdrmt@gmail.com |
| Kenneth Mueller, UST Class A Operator | kencmueller@gmail.com |
| Kenneth Mueller, UST Class B Operator | kencmueller@gmail.com |

Tank Code	02	Tank Age	31	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3123	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/19/2025	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Park County in the City of Gardiner

Location: CUT RANCH OFFICE
558 Old Yellowstone Trl S
Gardiner, MT 59030-9359 Park

System Facility ID:34-03402

Facility Code: 25977
Last Inspected On: 06/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Church Universal and Triumphant Inc (406) 848-9200

Operator Contact: David Otis (406) 848-9043 daotis@tsl.org

Owner/Operator: Church Universal and Triumphant Inc (406) 848-9200

David Otis, UST Class A Operator
David Otis, UST Class B Operator

daotis@tsl.org
daotis@tsl.org

Tank Code	07	Tank Age	38	Tank Installed Date	10/21/1988	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1861	Spill Test Date	06/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/05/2023	Line Tightness Test Date	06/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	38	Tank Installed Date	10/21/1988	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1862	Spill Test Date	06/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/05/2023	Line Tightness Test Date	06/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SERVICE CENTER
US Hwy 89 S
Gardiner, MT 59030 Park

System Facility ID:34-08868

Facility Code: 26081
Last Inspected On: 05/05/2025
Operating Permit Renewal Date: 07/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Xanterra Parks and Resorts Inc (307) 344-5204 DYHOFFMAN@XANTERRA.COM

Operator Contact: Anthony Bevill;Xanterra Parks and Resorts Inc;Dylan Hoffman;Josiah Reese;Samuel Krasnobrod (307) 344-5204;(307) 344-5593;(406) 220-9348 abevill@xanterra.com;DYHOFFMAN@XANTERRA.COM;dhoffman@xanterra.com;jreese@xanterra.com;skrasnobrod@xanterra.com

Owner/Operator: Xanterra Parks and Resorts Inc (307) 344-5204 DYHOFFMAN@XANTERRA.COM

Anthony Bevill, UST Class A Operator
Anthony Bevill, UST Class B Operator
Dylan Hoffman, UST Class A Operator
Dylan Hoffman, UST Class B Operator
Josiah Reese, UST Class A Operator
Josiah Reese, UST Class B Global Operator
Samuel Krasnobrod, UST Class A Operator

DYHOFFMAN@XANTERRA.COM
DYHOFFMAN@XANTERRA.COM
dhoffman@xanterra.com
dhoffman@xanterra.com
jreese@xanterra.com
jreese@xanterra.com
skrasnobrod@xanterra.com

Tank Code	06	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3492	Spill Test Date	04/29/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	03/14/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/29/2025			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	07	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3493	Spill Test Date	04/29/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	03/14/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/29/2025			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SINCLAIR
375 US Hwy 89 S
Gardiner, MT 59030 Park

System Facility ID:60-15332

Facility Code: 32332
Last Inspected On: 09/19/2025
Operating Permit Renewal Date: 02/15/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: GBP Enterprises LLC (406) 223-7333 jg@ypss.com

Operator Contact: Jeff Guengerich;Paul Bauer (406) 223-7333;(406) 224-2620 jg@ypss.com;paul.r.bauer@gmail.com

Owner/Operator: GBP Enterprises LLC (406) 223-7333 jg@ypss.com

Jeff Guengerich, UST Class A Operator jg@ypss.com
 Jeff Guengerich, UST Class B Global Operator jg@ypss.com
 Paul Bauer, UST Class A Operator paul.r.bauer@gmail.com
 Paul Bauer, UST Class B Global Operator paul.r.bauer@gmail.com

Tank Code	1	Tank Age	7	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5904	Spill Test Date	09/19/2025	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/19/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline, E10	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	09/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/19/2025			ATG Type					
Tank Code	2	Tank Age	7	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5905	Spill Test Date	09/19/2025	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/19/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	09/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/19/2025			ATG Type					

Tank Code	3	Tank Age	7	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5906	Spill Test Date	09/19/2025	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/19/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	09/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/19/2025			ATG Type					
Tank Code	4	Tank Age	7	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5907	Spill Test Date	09/19/2025	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/19/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	09/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/19/2025			ATG Type					
Tank Code	5	Tank Age	7	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5908	Spill Test Date	09/19/2025	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/19/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	09/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/19/2025			ATG Type					

Facility Summary in Park County in the City of Gardiner

Location: TOWN STATION
401 Scott St W
Gardiner, MT 59030-0507 Park

System Facility ID:34-06531

Facility Code: 26030
Last Inspected On: 10/10/2023
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gardiner Town Club Inc (406) 848-7322 townstation@outlook.com

Operator Contact: Wade Laubach (406) 223-0847 townstation@outlook.com

Owner/Operator: Gardiner Town Club Inc (406) 848-7322 townstation@outlook.com

Scott Kremer, UST Class B Global Operator
Wade Laubach, UST Class A Operator

patty@kremerbrothers.com;kremer4mt@wildblue.net
townstation@outlook.com

Tank Code	01	Tank Age	42	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3189	Spill Test Date		Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/10/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	42	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3190	Spill Test Date	10/10/2023	Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	03	Tank Age	42	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3191	Spill Test Date	10/10/2023	Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/10/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	42	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3192	Spill Test Date	10/10/2023	Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/10/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: CASEYS CORNER 80204
2050 S Park
Livingston, MT 59047-9133 Park

System Facility ID:34-09906

Facility Code: 26096
Last Inspected On: 04/08/2025
Operating Permit Renewal Date: 07/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation

jake.thomas@sunoco.com

Operator Contact: Jake Thomas;Parkland USA Corporation

jake.thomas@sunoco.com;jake.thomas@sunoco.com

Owner/Operator: Parkland USA Corporation

jake.thomas@sunoco.com

Jake Thomas, UST Class A Operator

jake.thomas@sunoco.com

Jake Thomas, UST Class B Operator

jake.thomas@sunoco.com

Tank Code	05	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2033	Spill Test Date	04/16/2021	Piping Installed Date	02/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/08/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/26/2025	Line Tightness Test Date	02/23/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/08/2025			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	06	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2034	Spill Test Date	04/16/2021	Piping Installed Date	02/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/08/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/26/2025	Line Tightness Test Date	02/23/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	04/08/2025			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	07	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2035	Spill Test Date	03/18/2021	Piping Installed Date	02/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/08/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/26/2025	Line Tightness Test Date	02/23/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/08/2025			ATG Type	Franklin Fueling Systems/EVO 6000				

Facility Summary in Park County in the City of Livingston

Location: CITY COUNTY COMPLEX
414 E Callender St
Livingston, MT 59047-2700 Park

System Facility ID:34-10573

Facility Code: 26105
Last Inspected On: 06/05/2025
Operating Permit Renewal Date: 10/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Park County Shop - City of Livingston

Operator Contact: Kelly Johnson

(406) 222-4141

maintenance@parkcounty.org

Owner/Operator: Park County Shop - City of Livingston

Kelly Johnson, UST Class A Operator

maintenance@parkcounty.org

Kelly Johnson, UST Class B Global Operator

maintenance@parkcounty.org

Tank Code	02	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1783	Spill Test Date	06/05/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date	06/05/2025	Line Tightness Test Date	06/05/2025	Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Park County in the City of Livingston

Location: TJS GAS N CONVENIENCE
204 E Park St
Livingston, MT 59047-2713 Park

System Facility ID:34-13736

Facility Code: 26167
Last Inspected On: 05/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: TJs Gas N Convenience (406) 222-9720

Operator Contact: Becky Thomas;William Woods (406) 222-9720 becalicious@yahoo.com;wjwoods10@gmail.com

Owner/Operator: TJs Gas N Convenience (406) 222-9720

Becky Thomas, UST Class A Operator

becalicious@yahoo.com

Becky Thomas, UST Class B Global Operator

becalicious@yahoo.com

William Woods, UST Class A Operator

wjwoods10@gmail.com

William Woods, UST Class B Operator

wjwoods10@gmail.com

Tank Code	01	Tank Age	30	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3371	Spill Test Date	05/05/2023	Piping Installed Date	06/24/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/12/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/22/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/05/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	30	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3372	Spill Test Date	05/05/2023	Piping Installed Date	06/24/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/12/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/22/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/05/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 2
716 E Park St
Livingston, MT 59047 Park

System Facility ID:34-08713

Facility Code: 26078
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 08/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Livingston 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Livingston 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	03	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2575	Spill Test Date	08/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2576	Spill Test Date	08/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	08/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2577	Spill Test Date	08/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2578	Spill Test Date	08/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 3
2200 Park St S
Livingston, MT 59047 Park

System Facility ID:34-13409

Facility Code: 26162
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 08/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Livingston 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Livingston 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	32	Tank Installed Date	05/20/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2579	Spill Test Date	11/04/2024	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	32	Tank Installed Date	05/20/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2580	Spill Test Date	05/12/2021	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2581	Spill Test Date	07/19/2021	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2582	Spill Test Date	07/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2583	Spill Test Date	07/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	25	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4377	Spill Test Date	07/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	25	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4378	Spill Test Date	11/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	25	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4379	Spill Test Date	11/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: YELLOWSTONE TRAVEL PLAZA
1226 US Hwy 10 W
Livingston, MT 59047-9004 Park

System Facility ID:34-11200

Facility Code: 26137
Last Inspected On: 10/20/2025
Operating Permit Renewal Date: 03/25/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: LIVINGSTON 10W LLC (406) 222-6180 MOTIBALYAN@GMAIL.COM

Operator Contact: Moti Balyan;Yellowstone Travel Plaza MOTIBALYAN@GMAIL.COM;gchana26@gmail.com

Owner/Operator: LIVINGSTON 10W LLC (406) 222-6180 MOTIBALYAN@GMAIL.COM
 Moti Balyan, UST Class A Operator gchana26@gmail.com
 Moti Balyan, UST Class B Operator gchana26@gmail.com

Tank Code	01	Tank Age	37	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2313	Spill Test Date	09/25/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/25/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/25/2025			ATG Type	Incon/TS-1001				
Tank Code	02	Tank Age	37	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2314	Spill Test Date	09/25/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/25/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/25/2025			ATG Type	Incon/TS-1001				
Tank Code	03	Tank Age	37	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2315	Spill Test Date	09/25/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/25/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/25/2025			ATG Type	Incon/TS-1001				
Tank Code	04	Tank Age	37	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2316	Spill Test Date	09/25/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/25/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/25/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/25/2025			ATG Type	Incon/TS-1001				

Facility Summary in Park County in the City of Livingston

Location: ZIP TRIP 47
101 Centennial Dr
Livingston, MT 59047-9155 Park

System Facility ID:34-11741

Facility Code: 26145
Last Inspected On: 09/03/2024
Operating Permit Renewal Date: 11/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jim Alford, UST Class A Operator Jim Alford, UST Class B Operator Luci Tuttle, UST Class B Operator Sean Hurley, UST Class A Operator Travis Weber, UST Class B Operator	jim.alford@chsinc.com jim.alford@chsinc.com Lucinda.Tuttle@chsinc.com sean.hurley@chsinc.com travis.weber3@chsinc.com
--	---

Tank Code	01	Tank Age	36	Tank Installed Date	09/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	562	Spill Test Date	08/15/2024	Piping Installed Date	06/25/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/06/2024	Tank/Piping CP Test Date	08/15/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date	01/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	36	Tank Installed Date	09/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	563	Spill Test Date	08/15/2024	Piping Installed Date	06/25/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/06/2024	Tank/Piping CP Test Date	08/15/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date	01/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	08/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	36	Tank Installed Date	09/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	564	Spill Test Date	08/15/2024	Piping Installed Date	06/25/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/06/2024	Tank/Piping CP Test Date	08/15/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date	01/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Wilsall

Location: PARK FARMERS COOP
114 S Elliot
Wilsall, MT 59086 Park

System Facility ID:34-06686

Facility Code: 26034
Last Inspected On: 05/06/2025
Operating Permit Renewal Date: 05/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Park Farmers Coop (406) 578-2543

Operator Contact: Don Scott pfcoop@aol.com

Owner/Operator: Park Farmers Coop (406) 578-2543

Don Scott, UST Class A Operator pfcoop@aol.com
 Don Scott, UST Class B Operator pfcoop@aol.com
 Donald Scott, UST Class B Operator pfcoop@aol.com

Tank Code	13	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1784	Spill Test Date	05/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/06/2025	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/06/2025	Line Tightness Test Date	02/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1785	Spill Test Date	05/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/06/2025	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/06/2025	Line Tightness Test Date	02/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	15	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1786	Spill Test Date	05/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/06/2025	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/06/2025	Line Tightness Test Date	02/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	16	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1787	Spill Test Date	05/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/06/2025	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/06/2025	Line Tightness Test Date	02/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				