

Facility Summary in Park County in the City of Clyde Park

Location: DALES FUEL INC
301 1st Ave
Clyde Park, MT 59018 Park

Legacy ID:34-07600

Facility ID: 26059
Last Inspected On: 05/09/2019
Operating Permit Renewal Date: 06/15/2022

Owner Operator Contact: Dale Jones

Operator Contact: Dale Jones

Owner/Operator: Dales Fuel Inc

Dale Jones, UST Class A Operator
Dennis Franks, UST Class B Global Operator
Jackie Jones, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	22	04/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3991	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Deferred	No
6,000					No
06	22	04/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3992	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Deferred	No
2,500					No
07	22	04/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3993	No		Double-Walled	Double Walled	Yes

Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Deferred	No
1,900					No
08	22	04/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3994	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Deferred	No
1,900					No

Facility Summary in Park County in the City of Clyde Park

Location: SHIELDS VALLEY HIGH SCHOOL
401 1st St E
Clyde Park, MT 59018 Park

Legacy ID:34-12515

Facility ID: 26147
Last Inspected On: 06/27/2019
Operating Permit Renewal Date: 03/01/2022

Owner Operator Contact: School Dist Shields Valley

4065782176

Operator Contact: Billi Taylor;Darcy Street;Dennis Kuhl;Randy Russell;William Sarrazin

4065782535;4066864725

Owner/Operator: School Dist Shields Valley

- Billi Taylor, UST Class A Operator
- Billi Taylor, UST Class B Global Operator
- Darcy Street, UST Class A Operator
- Darcy Street, UST Class B Operator
- Dennis Kuhl, UST Class A Operator
- Dennis Kuhl, UST Class B Operator
- Randy Russell, UST Class A Operator
- Randy Russell, UST Class B Operator
- Tom Johnson, UST Class B Global Operator
- William Sarrazin, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	56	07/01/1965	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
2725	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		09/25/2018	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco/EMC Basic		No

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY EXXON
204 Main St
Cooke City, MT 59020 Park

Legacy ID:34-01584

Facility ID: 25925
Last Inspected On: 06/03/2019
Operating Permit Renewal Date: 09/17/2022

Owner Operator Contact:

Operator Contact:

Owner/Operator: Wea Enterprises Inc.

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	30	10/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
757	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	30	10/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
758	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	24	10/01/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
759	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	24	10/01/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

760	No		None	Yes	
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	06/08/2016		Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY SINCLAIR AND CABINS
115 Main St
Cooke City, MT 59020 Park

Legacy ID:34-10046

Facility ID: 26103
Last Inspected On: 06/03/2019
Operating Permit Renewal Date: 09/17/2022

Owner Operator Contact: Patti Smith

4062221373

Operator Contact: Ben Zavora;Cooke City Sinclair and Lodging, Inc.;Rick Sommers **4065799993;4068382244**

Owner/Operator: Cooke City Sinclair and Lodging, Inc.

Ben Zavora, UST Class A Operator
Ben Zavora, UST Class B Operator
Rick Sommers, UST Class A Operator
Rick Sommers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
06	23	10/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
3670	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000					No
07	23	10/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
3671	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000					No

Facility Summary in Park County in the City of Cooke City

Location: NORTHEAST ENTRANCE GAS PUMPS
NE Entrance of Park
Cooke City, MT 59020 Park

Legacy ID:34-08869

Facility ID: 26082
Last Inspected On: 05/30/2019
Operating Permit Renewal Date: 09/26/2022

Owner Operator Contact: National Park Service Mammoth

3073442333

Operator Contact: Claude Long;Harry Laney

3073442333;4065819206

Owner/Operator: National Park Service Mammoth

Claude Long, UST Class A Operator
Harry Laney, UST Class A Operator
Harry Laney, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	29	08/01/1992	Cathodically Protected Steel	Steel	Flapper Valve
1741	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		05/15/2016	Continuous Interstitial Monitoring	Deferred	No
2,000					No
05	29	08/01/1992	Cathodically Protected Steel	Steel	Flapper Valve
1742	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		05/15/2016	Continuous Interstitial Monitoring	Deferred	No
2,000					No

Facility Summary in Park County in the City of Emigrant

Location: B BUNK INC
Parcel 38 N Glastonbury
Emigrant, MT 59027-0519 Park

Legacy ID:34-10959

Facility ID: 26118
Last Inspected On: 08/27/2020
Operating Permit Renewal Date: 08/27/2023

Owner Operator Contact: B Bunk Inc

7574986060

Operator Contact: Bradford Tisdale

7574986060

Owner/Operator: B Bunk Inc

Bradford Tisdale, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	04/18/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
415	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		09/28/2017	Automatic Tank Gauging 0.2	Deferred	No
10,000			Veeder Root/TLS-300		No

Facility Summary in Park County in the City of Emigrant

Location: CAPSTONE SHELTER
Lot 105 S Glastonbury
Emigrant, MT 59027 Park

Legacy ID:34-10989

Facility ID: 26125
Last Inspected On: 06/27/2019
Operating Permit Renewal Date: 07/23/2022

Owner Operator Contact: Capstone Project

4806572564

Operator Contact: Enrico DArgenzio

6024639838

Owner/Operator: Capstone Project

Enrico DArgenzio, UST Class A Operator
Enrico DArgenzio, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	04/13/1990	Cathodically Protected Steel	Steel	Positive Shutoff

4827	No	Double-Walled	Double Walled	Yes
Temporarily Out of Use		Not Required	Safe Suction	Galvanic
Diesel	09/16/2016	Continuous Interstitial Monitoring; Vapor Monitoring	Not Listed	No
12,000				No

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONSERVATION ASSOCIATION
2 B Taurus Rd
Emigrant, MT 59027 Park

Legacy ID:34-10934

Facility ID: 26116
Last Inspected On: 06/04/2019
Operating Permit Renewal Date: 06/12/2022

Owner Operator Contact: Community Conservation Association Inc Emigrant **4065793399**

Operator Contact: Edward Dratz **4065875667**

Owner/Operator: Community Conservation Association Inc
Emigrant
Edward Dratz, UST Class A Operator
Edward Dratz, UST Class B Global Operator
Edward Dratz, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	04/18/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4684	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/05/2016	Automatic Tank Gauging 0.2	Deferred	No
12,000			Veeder Root/TLS-300		No

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONTINUITY INC
18 Polaris Way Parcel 70 S Glastonbury
Emigrant, MT 59027 Park

Legacy ID:34-10930

Facility ID: 26113
Last Inspected On: 08/24/2020
Operating Permit Renewal Date: 10/02/2023

Owner Operator Contact: Community Continuity Inc

Operator Contact: Daniel Kehoe

4062232232

Owner/Operator: Community Continuity Inc

Daniel Kehoe, UST Class A Operator
Daniel Kehoe, UST Class B Operator
Dennis Franks, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	02/01/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4821	No	06/16/2017		Double Walled	Yes
Currently in Use			Auto Dialer	Gravity Feed	Galvanic
Diesel		06/16/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
20,000			Veeder Root/TLS-300		No

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY RESTORATION INC
Hercules Rd & Polaris Way
Emigrant, MT 59027 Park

Legacy ID:34-10931

Facility ID: 26114
Last Inspected On: 08/24/2020
Operating Permit Renewal Date: 10/02/2023

Owner Operator Contact: Community Restoration Inc

8006318885

Operator Contact: Daniel Kehoe

4062232232

Owner/Operator: Community Restoration Inc

Daniel Kehoe, UST Class A Operator
Daniel Kehoe, UST Class B Operator
Dennis Franks, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	31	02/20/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
701	No	06/16/2017		Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Diesel		06/16/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
20,000			Veeder Root/TLS-300		No

Facility Summary in Park County in the City of Emigrant

Location: DENNIS CURTIN
70 Ramshorn Rd
Emigrant, MT 59027 Park

Legacy ID:56-14035

Facility ID: 30691
Last Inspected On: 07/30/2019
Operating Permit Renewal Date: 12/31/2022

Owner Operator Contact: D M Curtin Family Limited Partnership **4063334056**

Operator Contact: Channell Libbey;Todd Fredericksen **4062231459**

Owner/Operator: D M Curtin Family Limited Partnership

Channell Libbey, UST Class A Operator
Todd Fredericksen, UST Class A Operator
Todd Fredericksen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	10/15/2001	Steel Clad	Flexible Plastic	Flapper Valve
4435	No	10/13/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000			Gilbarco-Veeder Root/ILS-350		No

Facility Summary in Park County in the City of Emigrant

Location: EARTH HOME PROPERTIES LLC
Evening Star Dr
Emigrant, MT 59027 Park

Legacy ID:34-10978

Facility ID: 26123
Last Inspected On: 04/17/2019
Operating Permit Renewal Date: 06/24/2019

Owner Operator Contact:

Operator Contact: Craig Newhouse

Owner/Operator: Earth Home Properties LLC

Craig Newhouse, UST Class A Operator

Craig Newhouse, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	04/23/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4753	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		06/11/2016	Vapor Monitoring	Deferred	No
12,000					No
02	31	04/23/1990	Cathodically Protected Steel	No Piping	Flapper Valve
4754	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		06/11/2016	Vapor Monitoring		No
10,000					No

Facility Summary in Park County in the City of Emigrant

Location: EMIGRANT GENERAL STORE
3 Murphy Ln
Emigrant, MT 59027-6100 Park

Legacy ID:34-06713

Facility ID: 26035
Last Inspected On: 03/07/2019
Operating Permit Renewal Date: 05/28/2022

Owner Operator Contact: Bert Otis;Emigrant General Store

4063334502;4063334434

Operator Contact: Bert Otis

4063334502

Owner/Operator: Bert Otis

Bert Otis, UST Class A Operator

Bert Otis, UST Class B Operator
 Jason Otis, UST Class B Operator
 Josh Otis, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	32	09/01/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4351	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/13/2016	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	No
6,000			Veeder Root/TLS-300		No
06	24	01/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4352	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/13/2016	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000			Veeder Root/TLS-300		No
01	32	09/01/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4353	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		05/13/2016	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	No

6,000			Veeder Root/TLS-300		No
07	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5852	No		Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
12,000			Incon/TS-550 EVO		Yes
08	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5853	No		Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Incon/TS-550 EVO		Yes
09	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5854	No		Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Incon/TS-550 EVO		Yes

Facility Summary in Park County in the City of Emigrant

Location: LIFESAVERS INC
Lot 28 N Glastonbury
Emigrant, MT 59027-0056 Park

Legacy ID:34-10965

Facility ID: 26120
Last Inspected On: 06/21/2021
Operating Permit Renewal Date:

Owner Operator Contact: Lifesavers Inc

Operator Contact: Patricia Jones;Robert Smith

4062955852

Owner/Operator: Lifesavers Inc

Patricia Jones, UST Class A Operator

Patricia Jones, UST Class B Operator

Robert Smith, UST Class A Operator
 Robert Smith, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	04/01/1990	Cathodically Protected Steel	Copper	Flapper Valve
4499	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		08/08/2018	Vapor Monitoring	Continuous Interstitial Monitoring; Vapor Monitoring	No
12,000					No

Facility Summary in Park County in the City of Emigrant

Location: MARKS ARK INC
 Parcel #7 N Glastonbury
 Emigrant, MT 59027-1626 Park

Legacy ID:34-10960

Facility ID: 26119
 Last Inspected On: 12/14/2017
 Operating Permit Renewal Date:

Owner Operator Contact: Marks Ark Inc

4062231699

Operator Contact: Phillip Hoag

4062231699

Owner/Operator: Marks Ark Inc

Phillip Hoag, UST Class A Operator
 Phillip Hoag, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	04/11/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1579	No			Double Walled	Yes

Temporarily Out of Use		Not Required	Safe Suction	Galvanic
Diesel	12/14/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Deferred	No
10,000				No

Facility Summary in Park County in the City of Emigrant

Location: ROSKIND RANCH
65 Arcturus Dr
Emigrant, MT 59027 Park

Legacy ID:34-13180

Facility ID: 26156
Last Inspected On: 04/05/2020
Operating Permit Renewal Date: 06/30/2020

Owner Operator Contact: Alicia Roskind

4246106640

Operator Contact: Alicia Roskind;Kenneth Mueller

4063334669;4246106640

Owner/Operator: Alicia Roskind

- Alicia Roskind, UST Class A Operator
- Alicia Roskind, UST Class B Global Operator
- Alicia Roskind, UST Class B Operator
- Kenneth Mueller, UST Class A Operator
- Kenneth Mueller, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	26	12/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3123	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel	05/01/2017		Statistical Inventory Reconciliation	Not Listed	No
10,000					No

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SERVICE CENTER
US Hwy 89 S
Gardiner, MT 59030 Park

Legacy ID:34-08868

Facility ID: 26081
Last Inspected On: 03/11/2019
Operating Permit Renewal Date: 07/28/2022

Owner Operator Contact: N/A ZZZ - TBL_OWN : 1003;TW Recreational Services Inc;Xanterra Parks and Resorts Inc **3073445340;3073447901**

Owner/Operator: Xanterra Parks and Resorts Inc

Cameron Walker, UST Class A Operator
 Cameron Walker, UST Class B Global Operator
 Dylan Hoffman, UST Class A Operator
 Dylan Hoffman, UST Class B Operator
 Josiah Reese, UST Class A Operator
 Josiah Reese, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	25	04/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3492	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;Deferred	No
10,000			Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic		No
07	25	04/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3493	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;Deferred	No
5,000			Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic		No

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SINCLAIR
 375 US Hwy 89 S
 Gardiner, MT 59030 Park

Legacy ID:60-15332

Facility ID: 32332
Last Inspected On: 11/27/2019
Operating Permit Renewal Date: 02/15/2023

Owner Operator Contact: GBP Enterprises LLC

4062237333

Operator Contact:

Owner/Operator: GBP Enterprises LLC

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5904	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline, E10			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
20,000					Yes
2	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5905	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
10,000					Yes
3	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5906	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000					No

4	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5907	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
10,000				Yes
5	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5908	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel, Dyed		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000				Yes

Facility Summary in Park County in the City of Gardiner

Location: RANCH OFFICE
558 Old Yellowstone Trl S
Gardiner, MT 59030-9359 Park

Legacy ID:34-03402

Facility ID: 25977
Last Inspected On: 06/23/2020
Operating Permit Renewal Date: 09/03/2023

Owner Operator Contact: Adiel Pantoja;Church Universal and Triumphant
Inc;Church Universal and Triumphant Inc

4068489200

Operator Contact: David Otis

Owner/Operator: Church Universal and Triumphant Inc

David Otis, UST Class A Operator

David Otis, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	33	10/21/1988	Cathodically Protected Steel	Steel	High Level Alarm
1861	No			None	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	05/31/2017		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
20,000	05/31/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	33	10/21/1988	Cathodically Protected Steel	Steel	High Level Alarm
1862	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel	05/31/2017		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
20,000	05/31/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Park County in the City of Gardiner

Location: TOWN STATION
401 Scott St W
Gardiner, MT 59030-0507 Park

Legacy ID:34-06531

Facility ID: 26030
Last Inspected On: 11/24/2020
Operating Permit Renewal Date: 03/03/2024

Owner Operator Contact: Gardiner Town Club Inc

4068487322

Operator Contact: Wade Laubach

4062230847

Owner/Operator: Gardiner Town Club Inc

- Wade Laubach, UST Class A Operator
- Wade Laubach, UST Class B Operator
- Scott Kremer, UST Class B Global Operator
- Wade Laubach, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	04/16/1984	Bare Steel	Flexible Plastic	Flapper Valve
3189	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	10/03/2017		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

8,000		10/03/2017	Gilbarco-Veeder Root/TLS-350		No
02	37	04/16/1984	Bare Steel	Flexible Plastic	Flapper Valve
3190	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/03/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000		10/03/2017	Gilbarco-Veeder Root/TLS-350		No
03	37	04/16/1984	Bare Steel	Flexible Plastic	Flapper Valve
3191	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/03/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000		10/03/2017	Gilbarco-Veeder Root/TLS-350		No
04	37	04/16/1984	Bare Steel	Flexible Plastic	Flapper Valve
3192	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/03/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		10/03/2017	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Park County in the City of Livingston

Location: BURLINGTON NORTHERN LIVINGSTON SHOP
 COMPLEX
 331 Bennett St
 Livingston, MT 59047-9236 Park

Legacy ID:60-15080

Facility ID: 30851
Last Inspected On:
Operating Permit Renewal Date:

Owner Operator Contact: BNSF Railway Helena

4062564040

Operator Contact:

Owner/Operator: BNSF Railway Helena

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	14	10/01/2007	Unknown	Fiberglass Reinforced Plastic	
5158	No				No
Currently in Use				Not Listed	
Mixture			Not Listed	Not Listed	No
20					Yes

Facility Summary in Park County in the City of Livingston

Location: CASEYS #4
 2050 S Park
 Livingston, MT 59047-9133 Park

Legacy ID:34-09906

Facility ID: 26096
Last Inspected On: 02/21/2019
Operating Permit Renewal Date: 07/22/2022

Owner Operator Contact:

Operator Contact: Calvin Wilson

Owner/Operator: Story Distributing Co Bozeman

Calvin Wilson, UST Class A Operator
 Calvin Wilson, UST Class B Global Operator
 Kelly Shutes, UST Class B Global Operator
 Venus Banthem, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	23	05/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2033	No			Double Walled	Yes
Currently in Use		02/20/2017	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		02/23/2016	Veeder Root/TLS-300		No
06	23	05/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2034	No			Double Walled	Yes
Currently in Use		02/20/2017	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		02/23/2016	Veeder Root/TLS-300		No
07	23	05/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2035	No			Double Walled	Yes
Currently in Use		02/20/2017	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		02/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		02/23/2016	Veeder Root/TLS-300		No

Facility Summary in Park County in the City of Livingston

Location: CITY COUNTY COMPLEX
414 E Callender St
Livingston, MT 59047-2700 Park

Legacy ID:34-10573

Facility ID: 26105
Last Inspected On: 09/26/2019
Operating Permit Renewal Date: 10/01/2022

Owner Operator Contact: Dennis Brandon; Park County Shop - City of Livingston; Park County Shop - City of Livingston

4062224106

Operator Contact: Kelly Johnson

4062224141

Owner/Operator: Park County Shop - City of Livingston

Kelly Johnson, UST Class A Operator
 Kelly Johnson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
02	26	11/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1783	No		Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
3,000		08/11/2016	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300		No

Facility Summary in Park County in the City of Livingston

Location: TJS GAS N CONVENIENCE
 204 E Park St
 Livingston, MT 59047-2713 Park

Legacy ID:34-13736

Facility ID: 26167
Last Inspected On: 05/27/2020
Operating Permit Renewal Date: 09/03/2023

Owner Operator Contact: TJs Gas N Convenience

4062229720

Operator Contact: Becky Thomas

4062229720

Owner/Operator: TJs Gas N Convenience

Becky Thomas, UST Class A Operator
 Becky Thomas, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	25	05/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3371	No			Double Walled	Yes

Currently in Use	06/24/2014	Electronic Line Leak Detector	Pressurized	Galvanic	
Gasoline	05/31/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No	
10,000		Veeder Root/TLS-300		No	
02	25	05/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3372	No		Double Walled	Yes	
Currently in Use	06/24/2014	Electronic Line Leak Detector	Pressurized	Galvanic	
Gasoline	05/31/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No	
10,000		Veeder Root/TLS-300		No	

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 2
716 E Park St
Livingston, MT 59047 Park

Legacy ID:34-08713

Facility ID: 26078
Last Inspected On: 08/06/2021
Operating Permit Renewal Date: 08/09/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Livingston

4064976948

Operator Contact: Trent Biggers

Owner/Operator: Livingston 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	25	09/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2575	No		Double-Walled	Double Walled	Yes
Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible	
Gasoline		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No	

12,000			Gilbarco-Veeder Root/EMC Basic		No
04	25	09/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2576	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000					No
05	25	09/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2577	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/EMC Basic		No
06	25	09/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2578	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/EMC Basic		No

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 3
2200 Park St S
Livingston, MT 59047 Park

Legacy ID:34-13409

Facility ID: 26162
Last Inspected On: 07/30/2021
Operating Permit Renewal Date: 08/02/2024

Owner Operator Contact: Don Edmisten;Livingston Holdings LLC

4064976948

Operator Contact: Trent Biggers

Owner/Operator: Livingston 3 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	05/20/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2579	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
02	27	05/20/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2580	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
03	27	05/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2581	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No

04	27	05/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2582	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
05	27	05/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2583	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
06	20	10/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4377	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
07	20	10/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4378	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-450		No

08	20	10/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4379	No	02/12/2019	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No

Facility Summary in Park County in the City of Livingston

Location: YELLOWSTONE TRAVEL PLAZA
1226 US Hwy 10 W
Livingston, MT 59047-9004 Park

Legacy ID:34-11200

Facility ID: 26137
Last Inspected On: 02/13/2020
Operating Permit Renewal Date: 03/25/2023

Owner Operator Contact: Carol Graybill;Yellowstone Truck Stop;Yellowstone Travel Plaza

4062226180;4062226180;4062222131

Operator Contact: Jerry Graybill

Owner/Operator: Yellowstone Travel Plaza

Candace Egan, UST Class B Operator
Donald Burkenpas, UST Class B Operator
Jerry Graybill, UST Class A Operator
Jerry Graybill, UST Class B Operator
Stacey Lofing, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	32	01/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2313	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/01/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Incon/TS-1001		No

02	32	01/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2314	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		02/02/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000			Incon/TS-1001		No
03	32	01/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2315	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/02/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000			Incon/TS-1001		No
04	32	01/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2316	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/02/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000			Incon/TS-1001		No

Facility Summary in Park County in the City of Livingston

Location: ZIP TRIP 47
101 Centennial Dr
Livingston, MT 59047-9155 Park

Legacy ID:34-11741

Facility ID: 26145
Last Inspected On: 05/21/2021
Operating Permit Renewal Date: 11/08/2024

Owner Operator Contact: Jim Alford;CHS Inc - Spokane;Tim Lakers;Kum and Go L C **5095367418**

Operator Contact: Ian Johnstone;Jim Alford;Nicholas Merritt;Sean Hurley **4066330023;5095357701;5095367418**

Owner/Operator: CHS Inc Spokane Valley

Darcy Ziegler, UST Class B Operator
Ian Johnstone, UST Class A Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Karina Serrano, UST Class B Global Operator

Nicholas Merritt, UST Class A Operator
 Nicholas Merritt, UST Class B Global Operator
 Nicholas Merritt, UST Class B Operator
 Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	09/01/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
562	No	06/25/2018		Double Walled	Yes
Currently in Use		06/25/2018	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/09/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		07/01/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	31	09/01/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
563	No	06/25/2018		Double Walled	Yes
Currently in Use		06/25/2018	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/09/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		07/01/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	31	09/01/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
564	No	06/25/2018		Double Walled	Yes
Currently in Use		06/25/2018	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/09/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		06/29/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Park County in the City of Wilsall

Location: PARK FARMERS COOP
 114 S Elliot
 Wilsall, MT 59086 Park

Legacy ID:34-06686

Facility ID: 26034
Last Inspected On: 12/12/2018
Operating Permit Renewal Date: 05/24/2022

Owner Operator Contact: Don Scott;Park Farmers Coop

4065782543

Operator Contact: Don Scott

Owner/Operator: Park Farmers Coop

Don Scott, UST Class A Operator
 Don Scott, UST Class B Operator
 Donald Scott, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
13	28	07/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1784	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		04/26/2010	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		10/11/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
14	28	07/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1785	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		04/26/2010	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		10/17/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
15	28	07/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1786	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Gasoline		04/26/2010	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		10/09/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
16	28	07/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1787	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		04/26/2010	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		10/09/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No