

Facility Summary in Park County in the City of Clyde Park

Location: DALES FUEL INC  
301 1st Ave  
Clyde Park, MT 59018 Park

System Facility ID:34-07600

Facility Code: 26059  
Last Inspected On: 04/18/2022  
Operating Permit Renewal Date: 06/15/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dales Fuel Inc

Operator Contact: Dale Jones4066864681

Owner/Operator: Dales Fuel Inc

Dale Jones, UST Class A Operator  
Jackie Jones, UST Class B Operator

Tank Code	05	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3991	Spill Test Date	08/11/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/03/2021			ATG Type					
Tank Code	06	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3992	Spill Test Date	08/11/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/03/2021			ATG Type					
Tank Code	07	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3993	Spill Test Date	08/03/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1900	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/03/2021			ATG Type					
Tank Code	08	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3994	Spill Test Date	08/03/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1900	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/03/2021			ATG Type					

Facility Summary in Park County in the City of Clyde Park

Location: SHIELDS VALLEY HIGH SCHOOL  
401 1st St E  
Clyde Park, MT 59018 Park

System Facility ID:34-12515

Facility Code: 26147  
Last Inspected On: 12/29/2021  
Operating Permit Renewal Date: 03/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist Shields Valley 4065782176

Operator Contact: Dan Johnston;Shields Valley School Dist

Owner/Operator: School Dist Shields Valley

Dan Johnston, UST Class A Operator  
Mitchell Marx, UST Class B Operator

Tank Code	01	Tank Age	59	Tank Installed Date	07/01/1965	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2725	Spill Test Date	08/03/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/29/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	08/03/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/03/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY EXXON  
204 Main St  
Cooke City, MT 59020 Park

System Facility ID:34-01584

Facility Code: 25925  
Last Inspected On: 07/05/2022  
Operating Permit Renewal Date: 09/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wea Enterprises Inc. 4068382244

Operator Contact: Joelle Passerello;Timmy Weamer 4068555792

Owner/Operator: Wea Enterprises Inc.

Joelle Passerello, UST Class A Operator  
Joelle Passerello, UST Class B Operator  
Timmy Weamer, UST Class A Operator  
Timmy Weamer, UST Class B Global Operator

Tank Code	07	Tank Age	33	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	757	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/31/2022	Tank/Piping CP Test Date	09/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/26/2023	Line Tightness Test Date	05/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/05/2022			ATG Type	Other/				
Tank Code	08	Tank Age	33	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	758	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/03/2019	Tank/Piping CP Test Date	09/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	05/26/2023	Line Tightness Test Date	06/03/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/05/2022			ATG Type	Other/				

Tank Code	09	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	759	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/31/2022	Tank/Piping CP Test Date	09/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/26/2023	Line Tightness Test Date	05/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/05/2022			ATG Type	Other/				
Tank Code	10	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	760	Spill Test Date	09/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/31/2022	Tank/Piping CP Test Date	09/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/26/2023	Line Tightness Test Date	05/31/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/05/2022			ATG Type	Other/				

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY SINCLAIR AND CABINS  
115 Main St  
Cooke City, MT 59020 Park

System Facility ID:34-10046

Facility Code: 26103  
Last Inspected On: 05/31/2022  
Operating Permit Renewal Date: 09/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cooke City Sinclair and Lodging, Inc. 4065799993

Operator Contact: Ben Zavora;Cooke City Sinclair and Lodging, Inc.;Benjamin Zavora;Cooke City Sinclair and Lodging, Inc.;Rick Sommers 4065799993;4068382244

Owner/Operator: Cooke City Sinclair and Lodging, Inc.

Ben Zavora, UST Class A Operator  
Ben Zavora, UST Class B Operator  
Benjamin Zavora, UST Class A Operator  
Benjamin Zavora, UST Class B Operator  
Rick Sommers, UST Class A Operator  
Rick Sommers, UST Class B Global Operator

Tank Code	06	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3670	Spill Test Date	05/31/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/31/2022	Line Tightness Test Date	06/03/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/31/2022			ATG Type	Incon/Other				
Tank Code	07	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3671	Spill Test Date	05/31/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date	05/31/2022	Line Tightness Test Date	06/03/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/31/2022			ATG Type	Incon/				

Facility Summary in Park County in the City of Cooke City

Location: NORTHEAST ENTRANCE GAS PUMPS  
NE Entrance of Park  
Cooke City, MT 59020 Park

System Facility ID:34-08869

Facility Code: 26082  
Last Inspected On: 07/12/2022  
Operating Permit Renewal Date: 09/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Mammoth 3073442333

Operator Contact: Claude Long;Harry Laney;Jason Ogle;Joel Browning;Nathan Munson 3043442333;3073442333;4062331326;4065819206;4065950840

Owner/Operator: National Park Service Mammoth

Claude Long, UST Class A Operator  
Harry Laney, UST Class A Operator  
Harry Laney, UST Class B Operator  
Jason Ogle, UST Class A Operator  
Joel Browning, UST Class A Operator  
Nathan Munson, UST Class A Operator

Tank Code	04	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1741	Spill Test Date	08/25/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/15/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	08/25/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/25/2021			ATG Type					
Tank Code	05	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1742	Spill Test Date	08/25/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/15/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	08/25/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No



	Overfill Test Date	08/25/2021		ATG Type				
--	--------------------	------------	--	----------	--	--	--	--

Facility Summary in Park County in the City of Emigrant

Location: B BUNK INC  
Parcel 38 N Glastonbury  
Emigrant, MT 59027-0519 Park

System Facility ID:34-10959

Facility Code: 26118  
Last Inspected On: 05/23/2023  
Operating Permit Renewal Date: 08/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: B Bunk Inc7574986060

Operator Contact: Bradford Tisdale7574986060

Owner/Operator: B Bunk Inc

Bradford Tisdale, UST Class A Operator  
Bradford Tisdale, UST Class B Operator

Tank Code	01	Tank Age	34	Tank Installed Date	04/18/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	415	Spill Test Date	05/23/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/23/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	05/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: CAPSTONE SHELTER  
Lot 105 S Glastonbury  
Emigrant, MT 59027 Park

System Facility ID:34-10989

Facility Code: 26125  
Last Inspected On: 07/06/2022  
Operating Permit Renewal Date: 07/06/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Capstone Project4806572564

Operator Contact: Enrico DArgenzio6024639838

Owner/Operator: Capstone Project

Enrico DArgenzio, UST Class A Operator  
Enrico DArgenzio, UST Class B Operator

Tank Code	01	Tank Age	34	Tank Installed Date	04/13/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4827	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/23/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONSERVATION ASSOCIATION  
2 B Taurus Rd  
Emigrant, MT 59027 Park

System Facility ID:34-10934

Facility Code: 26116  
Last Inspected On: 05/18/2022  
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Conservation Association Inc Emigrant 4065793399

Operator Contact: Edward Dratz 4065793399

Owner/Operator: Community Conservation Association Inc  
Emigrant  
Edward Dratz, UST Class A Operator  
Edward Dratz, UST Class B Global Operator  
Edward Dratz, UST Class B Operator

Tank Code	01	Tank Age	34	Tank Installed Date	04/18/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4684	Spill Test Date	05/18/2022	Piping Installed Date	11/06/1998	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	05/18/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2022			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONTINUITY INC  
18 Polaris Way Parcel 70 S Glastonbury  
Emigrant, MT 59027 Park

System Facility ID:34-10930

Facility Code: 26113  
Last Inspected On: 06/16/2023  
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Continuity Inc

Operator Contact: Daniel Kehoe 4062232232

Owner/Operator: Community Continuity Inc

Daniel Kehoe, UST Class A Operator  
Daniel Kehoe, UST Class B Operator  
Dennis Franks, UST Class B Global Operator

Tank Code	01	Tank Age	34	Tank Installed Date	02/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4821	Spill Test Date	06/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/16/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/16/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY RESTORATION INC  
Hercules Rd and Polaris Way  
Emigrant, MT 59027 Park

System Facility ID:34-10931

Facility Code: 26114  
Last Inspected On: 06/16/2023  
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Restoration Inc4062224222

Operator Contact: Daniel Kehoe4062232232

Owner/Operator: Community Restoration Inc

Daniel Kehoe, UST Class A Operator  
Daniel Kehoe, UST Class B Operator  
Dennis Franks, UST Class B Global Operator

Tank Code	01	Tank Age	34	Tank Installed Date	02/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	701	Spill Test Date	06/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/16/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/16/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: DENNIS CURTIN  
70 Ramshorn Rd  
Emigrant, MT 59027 Park

Facility Code: 30691  
Last Inspected On: 09/06/2022  
System Facility ID:56-14035  
Operating Permit Renewal Date: 12/31/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: D M Curtin Family Limited Partnership4063334056

Operator Contact: Channell Libbey;Todd Fredericksen4062231459

Owner/Operator: D M Curtin Family Limited Partnership

Channell Libbey, UST Class A Operator  
Todd Fredericksen, UST Class A Operator  
Todd Fredericksen, UST Class B Operator

Tank Code	01	Tank Age	23	Tank Installed Date	10/15/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4435	Spill Test Date	09/06/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/06/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Park County in the City of Emigrant

Location: EARTH HOME PROPERTIES LLC  
Evening Star Dr  
Emigrant, MT 59027 Park

System Facility ID:34-10978

Facility Code: 26123  
Last Inspected On: 11/11/2021  
Operating Permit Renewal Date: 11/11/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Earth Home Properties LLC9786583010

Operator Contact: Craig Newhouse978 6587675

Owner/Operator: Earth Home Properties LLC

Craig Newhouse, UST Class A Operator  
Craig Newhouse, UST Class B Operator

Tank Code	01	Tank Age	34	Tank Installed Date	04/23/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4753	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/11/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	34	Tank Installed Date	04/23/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	4754	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/11/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					



Facility Summary in Park County in the City of Emigrant

Location: EMIGRANT GENERAL STORE  
3 Murphy Ln  
Emigrant, MT 59027-6100 Park

System Facility ID:34-06713

Facility Code: 26035  
Last Inspected On: 10/06/2021  
Operating Permit Renewal Date: 05/28/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bert Otis;Bert Otis;Emigrant General Store

Operator Contact: Bert Otis

Owner/Operator: Bert Otis

Owner/Operator: Bert Otis,Emigrant General Store

Bert Otis, UST Class A Operator  
Bert Otis, UST Class B Operator  
Jason Otis, UST Class B Operator  
Josh Otis, UST Class B Operator

Tank Code	02	Tank Age	35	Tank Installed Date	09/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4351	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/07/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	27	Tank Installed Date	01/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4352	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/07/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	01	Tank Age	35	Tank Installed Date	09/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4353	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	6	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5852	Spill Test Date	10/06/2021	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	01/12/2023	Line Tightness Test Date	03/01/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/06/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	08	Tank Age	6	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5853	Spill Test Date	10/06/2021	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/12/2023	Line Tightness Test Date	03/05/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/06/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	09	Tank Age	6	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5854	Spill Test Date	10/06/2021	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/12/2023	Line Tightness Test Date	03/05/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/06/2021			ATG Type	Incon/TS-550 EVO				

Facility Summary in Park County in the City of Emigrant

Location: LIFESAVERS INC  
Lot 28 N Glastonbury  
Emigrant, MT 59027-0056 Park

System Facility ID:34-10965

Facility Code: 26120  
Last Inspected On: 06/21/2021  
Operating Permit Renewal Date: 06/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lifesavers Inc

Operator Contact: Patricia Jones;Robert Smith 4062955852

Owner/Operator: Lifesavers Inc

Patricia Jones, UST Class A Operator  
Patricia Jones, UST Class B Operator  
Robert Smith, UST Class A Operator  
Robert Smith, UST Class B Operator

Tank Code	01	Tank Age	34	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	4499	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/21/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring;Vapor Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Park County in the City of Emigrant

Location: ROSKIND RANCH  
65 Arcturus Dr  
Emigrant, MT 59027 Park

System Facility ID:34-13180

Facility Code: 26156  
Last Inspected On: 01/16/2023  
Operating Permit Renewal Date: 01/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Alicia Roskind4246106640

Operator Contact: Alicia Roskind;Kenneth Mueller4063334669;4246106640

Owner/Operator: Alicia Roskind

- Alicia Roskind, UST Class A Operator
- Alicia Roskind, UST Class B Global Operator
- Alicia Roskind, UST Class B Operator
- Kenneth Mueller, UST Class A Operator
- Kenneth Mueller, UST Class B Operator

Tank Code	02	Tank Age	29	Tank Installed Date	12/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3123	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/16/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Park County in the City of Emigrant

Location: SHELTER INVINCIBLE INC  
25 Gemini Rd  
Emigrant, MT 59027 Park

System Facility ID:34-10933

Facility Code: 26115  
Last Inspected On: 09/21/2020  
Operating Permit Renewal Date: 08/24/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Shelter Invincible Inc4063334485

Operator Contact: David Tonkin

Owner/Operator: Shelter Invincible Inc

Charles Widaman, UST Class B Operator  
David Tonkin, UST Class A Operator  
David Tonkin, UST Class B Operator

Tank Code	01	Tank Age	34	Tank Installed Date	04/17/1990	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	1882	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SCHOOL DIST 4  
510 Stone St  
Gardiner, MT 59030-9378 Park

System Facility ID:34-09287

Facility Code: 26086  
Last Inspected On: 11/09/2017  
Operating Permit Renewal Date: 01/02/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 7 & 4 Gardiner Public

Operator Contact: Douglas Coy;Tom Nelson4068487563

Owner/Operator: School Dist 7 & 4 Gardiner Public

Douglas Coy, UST Class A Operator  
Douglas Coy, UST Class B Operator  
Tom Nelson, UST Class A Operator  
Tom Nelson, UST Class B Operator

Tank Code	S2	Tank Age	37	Tank Installed Date	04/24/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4451	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	10/31/2018	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	11/09/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SERVICE CENTER  
US Hwy 89 S  
Gardiner, MT 59030 Park

System Facility ID:34-08868

Facility Code: 26081  
Last Inspected On: 03/01/2022  
Operating Permit Renewal Date: 07/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Xanterra Parks and Resorts Inc3073445204

Operator Contact: Cameron Walker;Dylan Hoffman;Josiah Reese;Samuel Krasnobrod3073445204;3073445566;3073445593;4062209348

Owner/Operator: Xanterra Parks and Resorts Inc

- Cameron Walker, UST Class A Operator
- Cameron Walker, UST Class B Global Operator
- Dylan Hoffman, UST Class A Operator
- Dylan Hoffman, UST Class B Operator
- Josiah Reese, UST Class A Operator
- Josiah Reese, UST Class B Global Operator
- Samuel Krasnobrod, UST Class A Operator

Tank Code	06	Tank Age	28	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3492	Spill Test Date	05/12/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2018	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	09/17/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/01/2022			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	07	Tank Age	28	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3493	Spill Test Date	09/17/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2018	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible



Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	09/17/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/01/2022			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SINCLAIR  
375 US Hwy 89 S  
Gardiner, MT 59030 Park

System Facility ID:60-15332

Facility Code: 32332  
Last Inspected On: 09/07/2022  
Operating Permit Renewal Date: 02/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: GBP Enterprises LLC	4062237333
Operator Contact: Jeff Guengerich;Paul Bauer	4062237333;4062242620

Owner/Operator: GBP Enterprises LLC

Jeff Guengerich, UST Class A Operator  
Jeff Guengerich, UST Class B Global Operator  
Paul Bauer, UST Class A Operator  
Paul Bauer, UST Class B Global Operator

Tank Code	1	Tank Age	5	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5904	Spill Test Date	09/07/2022	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline, E10	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/07/2022			ATG Type					
Tank Code	2	Tank Age	5	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5905	Spill Test Date	09/07/2022	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/07/2022			ATG Type					

Tank Code	3	Tank Age	5	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5906	Spill Test Date	09/07/2022	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/07/2022			ATG Type					
Tank Code	4	Tank Age	5	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5907	Spill Test Date	09/07/2022	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/07/2022			ATG Type					
Tank Code	5	Tank Age	5	Tank Installed Date	08/12/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5908	Spill Test Date	09/07/2022	Piping Installed Date	08/12/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/07/2022			ATG Type					

Facility Summary in Park County in the City of Gardiner

Location: RANCH OFFICE  
558 Old Yellowstone Trl S  
Gardiner, MT 59030-9359 Park

System Facility ID:34-03402

Facility Code: 25977  
Last Inspected On: 06/05/2023  
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Church Universal and Triumphant Inc4068489200

Operator Contact: David Otis4068489043

Owner/Operator: Church Universal and Triumphant Inc

David Otis, UST Class A Operator

David Otis, UST Class B Operator

Tank Code	07	Tank Age	36	Tank Installed Date	10/21/1988	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1861	Spill Test Date	06/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/05/2023	Line Tightness Test Date	06/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	36	Tank Installed Date	10/21/1988	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1862	Spill Test Date	06/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/05/2023	Line Tightness Test Date	06/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Gardiner

Location: TOWN STATION  
401 Scott St W  
Gardiner, MT 59030-0507 Park

System Facility ID:34-06531

Facility Code: 26030  
Last Inspected On: 10/10/2023  
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Gardiner Town Club Inc	4068487322
Operator Contact:	Wade Laubach	4062230847

Owner/Operator: Gardiner Town Club Inc

Wade Laubach, UST Class A Operator  
Wade Laubach, UST Class B Operator  
Scott Kremer, UST Class B Global Operator  
Wade Laubach, UST Class A Operator

Tank Code	01	Tank Age	40	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3189	Spill Test Date		Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/12/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	40	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3190	Spill Test Date	10/10/2023	Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/10/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	40	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3191	Spill Test Date	10/10/2023	Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/12/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	40	Tank Installed Date	04/16/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3192	Spill Test Date	10/10/2023	Piping Installed Date	11/12/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/12/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/04/2024	Tank/Piping CP Test Date	10/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/04/2024	Line Tightness Test Date	10/03/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: CASEY'S CORNER 4  
2050 S Park  
Livingston, MT 59047-9133 Park

System Facility ID:34-09906

Facility Code: 26096  
Last Inspected On: 05/02/2022  
Operating Permit Renewal Date: 07/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Superpumper Inc	7018521194
Operator Contact:	Calvin Wilson;Nancy Coen	7204212140

Owner/Operator: Superpumper Inc

Calvin Wilson, UST Class A Operator  
Nancy Coen, UST Class A Operator  
Nancy Coen, UST Class B Operator  
Venus Banthem, UST Class B Operator

Tank Code	05	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2033	Spill Test Date	04/16/2021	Piping Installed Date	02/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/18/2023	Line Tightness Test Date	02/23/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/18/2023			ATG Type	Other/TLS-350				
Tank Code	06	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2034	Spill Test Date	04/16/2021	Piping Installed Date	02/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/18/2023	Line Tightness Test Date	02/23/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/18/2023			ATG Type	Other/				

Tank Code	07	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2035	Spill Test Date	03/18/2021	Piping Installed Date	02/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/18/2023	Line Tightness Test Date	02/23/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/18/2023			ATG Type	Other/				



Facility Summary in Park County in the City of Livingston

Location: CITY COUNTY COMPLEX  
414 E Callender St  
Livingston, MT 59047-2700 Park

System Facility ID:34-10573

Facility Code: 26105  
Last Inspected On: 09/07/2022  
Operating Permit Renewal Date: 10/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Park County Shop - City of Livingston

Operator Contact: Kelly Johnson4062224141

Owner/Operator: Park County Shop - City of Livingston

Kelly Johnson, UST Class A Operator  
Kelly Johnson, UST Class B Global Operator

Tank Code	02	Tank Age	29	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1783	Spill Test Date	09/07/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date	09/07/2022	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Park County in the City of Livingston

Location: TJS GAS N CONVENIENCE  
204 E Park St  
Livingston, MT 59047-2713 Park

System Facility ID:34-13736

Facility Code: 26167  
Last Inspected On: 05/05/2023  
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	TJs Gas N Convenience	4062229720
Operator Contact:	Becky Thomas;William Woods	4062229720

Owner/Operator: TJs Gas N Convenience

Becky Thomas, UST Class A Operator  
Becky Thomas, UST Class B Global Operator  
William Woods, UST Class A Operator  
William Woods, UST Class B Operator

Tank Code	01	Tank Age	28	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3371	Spill Test Date	05/05/2023	Piping Installed Date	06/24/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/22/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/05/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	28	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3372	Spill Test Date	05/05/2023	Piping Installed Date	06/24/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/22/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/05/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 2  
716 E Park St  
Livingston, MT 59047 Park

System Facility ID:34-08713

Facility Code: 26078  
Last Inspected On: 08/15/2022  
Operating Permit Renewal Date: 08/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Livingston 2 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Livingston 2 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	03	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2575	Spill Test Date	08/02/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date	08/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/15/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/02/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2576	Spill Test Date	05/13/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date	08/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/15/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes

		Overfill Test Date	08/02/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2577	Spill Test Date	08/02/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date	08/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/15/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/02/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2578	Spill Test Date	08/02/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date	08/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/15/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/02/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 3  
2200 Park St S  
Livingston, MT 59047 Park

System Facility ID:34-13409

Facility Code: 26162  
Last Inspected On: 08/16/2022  
Operating Permit Renewal Date: 08/02/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Livingston 3 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Livingston 3 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	30	Tank Installed Date	05/20/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2579	Spill Test Date	07/19/2021	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	30	Tank Installed Date	05/20/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2580	Spill Test Date	05/12/2021	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	30	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2581	Spill Test Date	07/19/2021	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	30	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2582	Spill Test Date	07/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	30	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2583	Spill Test Date	07/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	23	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4377	Spill Test Date	07/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	23	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4378	Spill Test Date	07/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	23	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4379	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	12/30/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				



Facility Summary in Park County in the City of Livingston

Location: YELLOWSTONE TRAVEL PLAZA  
1226 US Hwy 10 W  
Livingston, MT 59047-9004 Park

System Facility ID:34-11200

Facility Code: 26137  
Last Inspected On: 11/16/2022  
Operating Permit Renewal Date: 03/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Yellowstone Travel Plaza

Operator Contact: Bailey Kostman;Gagandeep Chana;Yellowstone Travel Plaza 5099616186

Owner/Operator: Yellowstone Travel Plaza

Bailey Kostman, UST Class A Operator  
Bailey Kostman, UST Class B Operator  
Gagandeep Chana, UST Class A Operator  
Gagandeep Chana, UST Class B Operator

Tank Code	01	Tank Age	35	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2313	Spill Test Date	08/26/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/21/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/26/2022			ATG Type	Incon/TS-1001				
Tank Code	02	Tank Age	35	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2314	Spill Test Date	08/26/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/21/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/26/2022			ATG Type	Incon/TS-1001				
Tank Code	03	Tank Age	35	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	2315	Spill Test Date	08/26/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/21/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/26/2022			ATG Type	Incon/TS-1001				
Tank Code	04	Tank Age	35	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2316	Spill Test Date	08/26/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/21/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/26/2022			ATG Type	Incon/TS-1001				

Facility Summary in Park County in the City of Livingston

Location: ZIP TRIP 47  
101 Centennial Dr  
Livingston, MT 59047-9155 Park

System Facility ID:34-11741

Facility Code: 26145  
Last Inspected On: 05/21/2021  
Operating Permit Renewal Date: 11/08/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley 5095357701

Operator Contact: Ian Johnstone;Jim Alford;Nicholas Merritt;Sean Hurley 4066330023;5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Darcy Ziegler, UST Class B Operator
- Ian Johnstone, UST Class A Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Karina Serrano, UST Class B Global Operator
- Nicholas Merritt, UST Class A Operator
- Nicholas Merritt, UST Class B Global Operator
- Nicholas Merritt, UST Class B Operator
- Sean Hurley, UST Class A Operator

Tank Code	01	Tank Age	34	Tank Installed Date	09/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	562	Spill Test Date	08/26/2021	Piping Installed Date	06/25/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/25/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/26/2020	Tank/Piping CP Test Date	09/25/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/26/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	34	Tank Installed Date	09/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	563	Spill Test Date	08/26/2021	Piping Installed Date	06/25/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/25/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Gasoline	PLLD Test Date	08/26/2020	Tank/Piping CP Test Date	09/25/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/26/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	34	Tank Installed Date	09/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	564	Spill Test Date	08/26/2021	Piping Installed Date	06/25/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/25/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/26/2020	Tank/Piping CP Test Date	09/25/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/26/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Wilsall

Location: PARK FARMERS COOP  
114 S Elliot  
Wilsall, MT 59086 Park

System Facility ID:34-06686

Facility Code: 26034  
Last Inspected On: 04/20/2022  
Operating Permit Renewal Date: 05/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Park Farmers Coop4065782543

Operator Contact: Don Scott

Owner/Operator: Park Farmers Coop

Don Scott, UST Class A Operator  
Don Scott, UST Class B Operator  
Donald Scott, UST Class B Operator

Tank Code	13	Tank Age	31	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1784	Spill Test Date	06/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/20/2022	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/20/2022	Line Tightness Test Date	02/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	31	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1785	Spill Test Date	06/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	04/20/2022	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/20/2022	Line Tightness Test Date	02/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	15	Tank Age	31	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1786	Spill Test Date	06/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/20/2022	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/20/2022	Line Tightness Test Date	02/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	16	Tank Age	31	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1787	Spill Test Date	06/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/20/2022	Tank/Piping CP Test Date	04/26/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/20/2022	Line Tightness Test Date	02/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				