

Facility Summary in Park County in the City of Clyde Park

Location: DALES FUEL INC
301 1st Ave
Clyde Park, MT 59018 Park

System Facility ID:34-07600

Facility Code: 26059
Last Inspected On: 04/18/2022
Operating Permit Renewal Date: 06/15/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dales Fuel Inc

Operator Contact: Dale Jones4066864681

Owner/Operator: Dales Fuel Inc

Dale Jones, UST Class A Operator
Jackie Jones, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 05 | Tank Age | 25 | Tank Installed Date | 04/01/1999 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3991 | Spill Test Date | 08/11/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/03/2021 | | | ATG Type | | | | | |
| Tank Code | 06 | Tank Age | 25 | Tank Installed Date | 04/01/1999 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3992 | Spill Test Date | 08/11/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2500 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/03/2021 | | | ATG Type | | | | | |
| Tank Code | 07 | Tank Age | 25 | Tank Installed Date | 04/01/1999 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3993 | Spill Test Date | 08/03/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 1900 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/03/2021 | | | ATG Type | | | | | |
| Tank Code | 08 | Tank Age | 25 | Tank Installed Date | 04/01/1999 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3994 | Spill Test Date | 08/03/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 1900 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/03/2021 | | | ATG Type | | | | | |

Facility Summary in Park County in the City of Clyde Park

Location: SHIELDS VALLEY HIGH SCHOOL
401 1st St E
Clyde Park, MT 59018 Park

System Facility ID:34-12515

Facility Code: 26147
Last Inspected On: 12/29/2021
Operating Permit Renewal Date: 03/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist Shields Valley 4065782176

Operator Contact: Dan Johnston;Shields Valley School Dist

Owner/Operator: School Dist Shields Valley

Dan Johnston, UST Class A Operator
Mitchell Marx, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------|----------------|--------------------------------|
| Tank Code | 01 | Tank Age | 59 | Tank Installed Date | 07/01/1965 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 2725 | Spill Test Date | 08/03/2021 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 12/29/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 08/03/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/03/2021 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY EXXON
204 Main St
Cooke City, MT 59020 Park

System Facility ID:34-01584

Facility Code: 25925
Last Inspected On: 07/05/2022
Operating Permit Renewal Date: 09/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wea Enterprises Inc. 4068382244

Operator Contact: Joelle Passerello;Timmy Weamer 4068555792

Owner/Operator: Wea Enterprises Inc.

Joelle Passerello, UST Class A Operator
Joelle Passerello, UST Class B Operator
Timmy Weamer, UST Class A Operator
Timmy Weamer, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|-----------------------------------|
| Tank Code | 07 | Tank Age | 33 | Tank Installed Date | 10/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 757 | Spill Test Date | 09/23/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 05/31/2022 | Tank/Piping CP Test Date | 09/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/26/2023 | Line Tightness Test Date | 05/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/05/2022 | | | ATG Type | Other/ | | | | |
| Tank Code | 08 | Tank Age | 33 | Tank Installed Date | 10/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 758 | Spill Test Date | 09/23/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 06/03/2019 | Tank/Piping CP Test Date | 09/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/26/2023 | Line Tightness Test Date | 06/03/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/05/2022 | | | ATG Type | Other/ | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|--------------------------------|
| Tank Code | 09 | Tank Age | 27 | Tank Installed Date | 10/01/1997 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 759 | Spill Test Date | 09/23/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 05/31/2022 | Tank/Piping CP Test Date | 09/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 05/26/2023 | Line Tightness Test Date | 05/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/05/2022 | | | ATG Type | Other/ | | | | |
| Tank Code | 10 | Tank Age | 27 | Tank Installed Date | 10/01/1997 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 760 | Spill Test Date | 09/23/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 05/31/2022 | Tank/Piping CP Test Date | 09/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/26/2023 | Line Tightness Test Date | 05/31/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/05/2022 | | | ATG Type | Other/ | | | | |

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY SINCLAIR AND CABINS
115 Main St
Cooke City, MT 59020 Park

System Facility ID:34-10046

Facility Code: 26103
Last Inspected On: 05/31/2022
Operating Permit Renewal Date: 09/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cooke City Sinclair and Lodging, Inc. 4065799993

Operator Contact: Ben Zavora;Cooke City Sinclair and Lodging, Inc.;Benjamin Zavora;Cooke City Sinclair and Lodging, Inc.;Rick Sommers 4065799993;4068382244

Owner/Operator: Cooke City Sinclair and Lodging, Inc.

Ben Zavora, UST Class A Operator
Ben Zavora, UST Class B Operator
Benjamin Zavora, UST Class A Operator
Benjamin Zavora, UST Class B Operator
Rick Sommers, UST Class A Operator
Rick Sommers, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 06 | Tank Age | 26 | Tank Installed Date | 10/01/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 3670 | Spill Test Date | 05/31/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/31/2022 | Line Tightness Test Date | 06/03/2019 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/31/2022 | | | ATG Type | Incon/Other | | | | |
| Tank Code | 07 | Tank Age | 26 | Tank Installed Date | 10/01/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 3671 | Spill Test Date | 05/31/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |

| | | | | | | | | | | | |
|----------|------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------|--------------------------|------------------------------------|------------|----|
| Capacity | 8000 | ATG Test Date | 05/31/2022 | Line Tightness Test Date | 06/03/2019 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/31/2022 | | | ATG Type | Incon/ | | | | |

Facility Summary in Park County in the City of Cooke City

Location: NORTHEAST ENTRANCE GAS PUMPS
NE Entrance of Park
Cooke City, MT 59020 Park

System Facility ID:34-08869

Facility Code: 26082
Last Inspected On: 07/12/2022
Operating Permit Renewal Date: 09/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Mammoth 3073442333

Operator Contact: Claude Long;Harry Laney;Jason Ogle;Joel Browning;Nathan Munson 3043442333;3073442333;4062331326;4065819206;4065950840

Owner/Operator: National Park Service Mammoth

Claude Long, UST Class A Operator
Harry Laney, UST Class A Operator
Harry Laney, UST Class B Operator
Jason Ogle, UST Class A Operator
Joel Browning, UST Class A Operator
Nathan Munson, UST Class A Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|---------------|----------------|---------------|
| Tank Code | 04 | Tank Age | 32 | Tank Installed Date | 08/01/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 1741 | Spill Test Date | 08/25/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/15/2022 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 08/25/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/25/2021 | | | ATG Type | | | | | |
| Tank Code | 05 | Tank Age | 32 | Tank Installed Date | 08/01/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 1742 | Spill Test Date | 08/25/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/15/2022 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 08/25/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | |
|--|--------------------|------------|--|----------|--|--|--|
| | Overfill Test Date | 08/25/2021 | | ATG Type | | | |
|--|--------------------|------------|--|----------|--|--|--|

Facility Summary in Park County in the City of Emigrant

Location: B BUNK INC
Parcel 38 N Glastonbury
Emigrant, MT 59027-0519 Park

System Facility ID:34-10959

Facility Code: 26118
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 08/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: B Bunk Inc7574986060

Operator Contact: Bradford Tisdale7574986060

Owner/Operator: B Bunk Inc

Bradford Tisdale, UST Class A Operator
Bradford Tisdale, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------|--------------------------|------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 04/18/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 415 | Spill Test Date | 05/23/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/23/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/23/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/23/2023 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Park County in the City of Emigrant

Location: CAPSTONE SHELTER
Lot 105 S Glastonbury
Emigrant, MT 59027 Park

System Facility ID:34-10989

Facility Code: 26125
Last Inspected On: 07/06/2022
Operating Permit Renewal Date: 07/06/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Capstone Project4806572564

Operator Contact: Enrico DArgenzio6024639838

Owner/Operator: Capstone Project

Enrico DArgenzio, UST Class A Operator
Enrico DArgenzio, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|---------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 04/13/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 4827 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 09/23/2021 | Primary Tank Leak Detection | Vapor Monitoring | Primary Pipe Detection | Not Listed | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONSERVATION ASSOCIATION
2 B Taurus Rd
Emigrant, MT 59027 Park

System Facility ID:34-10934

Facility Code: 26116
Last Inspected On: 05/18/2022
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Conservation Association Inc Emigrant 4065793399

Operator Contact: Edward Dratz 4065793399

Owner/Operator: Community Conservation Association Inc
Emigrant
Edward Dratz, UST Class A Operator
Edward Dratz, UST Class B Global Operator
Edward Dratz, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------|--------------------------|------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 04/18/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4684 | Spill Test Date | 05/18/2022 | Piping Installed Date | 11/06/1998 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/18/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/18/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/18/2022 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONTINUITY INC
18 Polaris Way Parcel 70 S Glastonbury
Emigrant, MT 59027 Park

System Facility ID:34-10930

Facility Code: 26113
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Continuity Inc

Operator Contact: Daniel Kehoe 4062232232

Owner/Operator: Community Continuity Inc

Daniel Kehoe, UST Class A Operator
Daniel Kehoe, UST Class B Operator
Dennis Franks, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 02/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4821 | Spill Test Date | 06/16/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/16/2023 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Gravity Feed | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/16/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 06/16/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/16/2023 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY RESTORATION INC
Hercules Rd and Polaris Way
Emigrant, MT 59027 Park

System Facility ID:34-10931

Facility Code: 26114
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Community Restoration Inc4062224222

Operator Contact: Daniel Kehoe4062232232

Owner/Operator: Community Restoration Inc

Daniel Kehoe, UST Class A Operator
Daniel Kehoe, UST Class B Operator
Dennis Franks, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 02/20/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 701 | Spill Test Date | 06/16/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/16/2023 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/16/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 06/16/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/16/2023 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Park County in the City of Emigrant

Location: DENNIS CURTIN
70 Ramshorn Rd
Emigrant, MT 59027 Park

Facility Code: 30691
Last Inspected On: 09/06/2022
System Facility ID:56-14035
Operating Permit Renewal Date: 12/31/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: D M Curtin Family Limited Partnership4063334056

Operator Contact: Channell Libbey;Todd Fredericksen4062231459

Owner/Operator: D M Curtin Family Limited Partnership

Channell Libbey, UST Class A Operator
Todd Fredericksen, UST Class A Operator
Todd Fredericksen, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 01 | Tank Age | 23 | Tank Installed Date | 10/15/2001 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4435 | Spill Test Date | 09/06/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 09/06/2022 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/06/2022 | | | ATG Type | Gilbarco-Veeder Root/ILS-350 | | | | |

Facility Summary in Park County in the City of Emigrant

Location: EARTH HOME PROPERTIES LLC
Evening Star Dr
Emigrant, MT 59027 Park

System Facility ID:34-10978

Facility Code: 26123
Last Inspected On: 11/11/2021
Operating Permit Renewal Date: 11/11/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Earth Home Properties LLC9786583010

Operator Contact: Craig Newhouse978 6587675

Owner/Operator: Earth Home Properties LLC

Craig Newhouse, UST Class A Operator
Craig Newhouse, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------|--------------------------|------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 04/23/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4753 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/11/2021 | Primary Tank Leak Detection | Vapor Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 34 | Tank Installed Date | 04/23/1990 | Tank Material | Cathodically Protected Steel | Piping Material | No Piping | Overfill Types | Flapper Valve |
| Tag Number | 4754 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/11/2021 | Primary Tank Leak Detection | Vapor Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Park County in the City of Emigrant

Location: EMIGRANT GENERAL STORE
3 Murphy Ln
Emigrant, MT 59027-6100 Park

System Facility ID:34-06713

Facility Code: 26035
Last Inspected On: 10/06/2021
Operating Permit Renewal Date: 05/28/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bert Otis;Bert Otis;Emigrant General Store

Operator Contact: Bert Otis

Owner/Operator: Bert Otis

Owner/Operator: Bert Otis,Emigrant General Store

Bert Otis, UST Class A Operator
Bert Otis, UST Class B Operator
Jason Otis, UST Class B Operator
Josh Otis, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|-----------------------------------------------------------------|--------------------------|------------------------------------------------------------------------------------|----------------|---------------|
| Tank Code | 02 | Tank Age | 35 | Tank Installed Date | 09/01/1989 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4351 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation | Primary Pipe Detection | ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 06 | Tank Age | 27 | Tank Installed Date | 01/01/1997 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4352 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|------------|--------------------------|------------|-------------------------------|-----------------------------------------------------------------|--------------------------|------------------------------------------------------------------------------------|----------------|---------------|
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation | Primary Pipe Detection | ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 01 | Tank Age | 35 | Tank Installed Date | 09/01/1989 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4353 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation | Primary Pipe Detection | ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 07 | Tank Age | 6 | Tank Installed Date | 11/15/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5852 | Spill Test Date | 10/06/2021 | Piping Installed Date | 11/15/2018 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2018 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 01/12/2023 | Line Tightness Test Date | 03/01/2019 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 10/06/2021 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 08 | Tank Age | 6 | Tank Installed Date | 11/15/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5853 | Spill Test Date | 10/06/2021 | Piping Installed Date | 11/15/2018 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2018 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 01/12/2023 | Line Tightness Test Date | 03/05/2019 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 10/06/2021 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 09 | Tank Age | 6 | Tank Installed Date | 11/15/2018 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5854 | Spill Test Date | 10/06/2021 | Piping Installed Date | 11/15/2018 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2018 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 01/12/2023 | Line Tightness Test Date | 03/05/2019 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 10/06/2021 | | | ATG Type | Incon/TS-550 EVO | | | | |

Facility Summary in Park County in the City of Emigrant

Location: LIFESAVERS INC
Lot 28 N Glastonbury
Emigrant, MT 59027-0056 Park

System Facility ID:34-10965

Facility Code: 26120
Last Inspected On: 06/21/2021
Operating Permit Renewal Date: 06/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lifesavers Inc

Operator Contact: Patricia Jones;Robert Smith 4062955852

Owner/Operator: Lifesavers Inc

Patricia Jones, UST Class A Operator
Patricia Jones, UST Class B Operator
Robert Smith, UST Class A Operator
Robert Smith, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------|--------------------------|-----------------------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 04/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Copper | Overfill Types | Flapper Valve |
| Tag Number | 4499 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/21/2021 | Primary Tank Leak Detection | Vapor Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring;Vapor Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Park County in the City of Emigrant

Location: ROSKIND RANCH
65 Arcturus Dr
Emigrant, MT 59027 Park

System Facility ID:34-13180

Facility Code: 26156
Last Inspected On: 01/16/2023
Operating Permit Renewal Date: 01/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Alicia Roskind4246106640

Operator Contact: Alicia Roskind;Kenneth Mueller4063334669;4246106640

Owner/Operator: Alicia Roskind

Alicia Roskind, UST Class A Operator
Alicia Roskind, UST Class B Global Operator
Alicia Roskind, UST Class B Operator
Kenneth Mueller, UST Class A Operator
Kenneth Mueller, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|------------------|----------------|---------------|
| Tank Code | 02 | Tank Age | 29 | Tank Installed Date | 12/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3123 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 01/16/2023 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Park County in the City of Emigrant

Location: SHELTER INVINCIBLE INC
25 Gemini Rd
Emigrant, MT 59027 Park

System Facility ID:34-10933

Facility Code: 26115
Last Inspected On: 09/21/2020
Operating Permit Renewal Date: 08/24/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Shelter Invincible Inc4063334485

Operator Contact: David Tonkin

Owner/Operator: Shelter Invincible Inc

Charles Widaman, UST Class B Operator
David Tonkin, UST Class A Operator
David Tonkin, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|-------------------------------------------|--------------------------|-----------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 04/17/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Copper | Overfill Types | Flapper Valve |
| Tag Number | 1882 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Secondary Containment Chase | AST | No |
| Tank Status | Permanently Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 09/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SCHOOL DIST 4
510 Stone St
Gardiner, MT 59030-9378 Park

System Facility ID:34-09287

Facility Code: 26086
Last Inspected On: 11/09/2017
Operating Permit Renewal Date: 01/02/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 7 & 4 Gardiner Public

Operator Contact: Douglas Coy;Tom Nelson4068487563

Owner/Operator: School Dist 7 & 4 Gardiner Public

Douglas Coy, UST Class A Operator
Douglas Coy, UST Class B Operator
Tom Nelson, UST Class A Operator
Tom Nelson, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|-------------------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | S2 | Tank Age | 37 | Tank Installed Date | 04/24/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4451 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Permanently Out of Use | MLLD Test Date | | Sump Tightness Test Date | 10/31/2018 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Heating Oil | PLLD Test Date | | Tank/Piping CP Test Date | 11/09/2017 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SERVICE CENTER
US Hwy 89 S
Gardiner, MT 59030 Park

System Facility ID:34-08868

Facility Code: 26081
Last Inspected On: 03/01/2022
Operating Permit Renewal Date: 07/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Xanterra Parks and Resorts Inc3073445204

Operator Contact: Anthony Bevill;Xanterra Parks and Resorts Inc;Dylan Hoffman;Josiah Reese;Samuel Krasnobrod3073445204;3073445593;4062209348

Owner/Operator: Xanterra Parks and Resorts Inc

Anthony Bevill, UST Class A Operator
Anthony Bevill, UST Class B Operator
Dylan Hoffman, UST Class A Operator
Dylan Hoffman, UST Class B Operator
Josiah Reese, UST Class A Operator
Josiah Reese, UST Class B Global Operator
Samuel Krasnobrod, UST Class A Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---------------------------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 06 | Tank Age | 28 | Tank Installed Date | 04/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3492 | Spill Test Date | 05/12/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/16/2018 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/17/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/01/2022 | | | ATG Type | Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic | | | | |
| Tank Code | 07 | Tank Age | 28 | Tank Installed Date | 04/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3493 | Spill Test Date | 09/17/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/16/2018 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|----------|--------|--------------------|------------|--------------------------|--|-------------------------------|---------------------------------------------------|--------------------------|--|----------------|----|
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 09/17/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/01/2022 | | | ATG Type | Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic | | | | |

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SINCLAIR
375 US Hwy 89 S
Gardiner, MT 59030 Park

System Facility ID:60-15332

Facility Code: 32332
Last Inspected On: 09/07/2022
Operating Permit Renewal Date: 02/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | |
|----------------------------------------------|-----------------------|
| Owner Operator Contact: GBP Enterprises LLC | 4062237333 |
| Operator Contact: Jeff Guengerich;Paul Bauer | 4062237333;4062242620 |

Owner/Operator: GBP Enterprises LLC

Jeff Guengerich, UST Class A Operator
Jeff Guengerich, UST Class B Global Operator
Paul Bauer, UST Class A Operator
Paul Bauer, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 1 | Tank Age | 5 | Tank Installed Date | 08/12/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5904 | Spill Test Date | 09/07/2022 | Piping Installed Date | 08/12/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/15/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline, E10 | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | 09/07/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 09/07/2022 | | | ATG Type | | | | | |
| Tank Code | 2 | Tank Age | 5 | Tank Installed Date | 08/12/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5905 | Spill Test Date | 09/07/2022 | Piping Installed Date | 08/12/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/15/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 10000 | ATG Test Date | 09/07/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 09/07/2022 | | | ATG Type | | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 3 | Tank Age | 5 | Tank Installed Date | 08/12/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5906 | Spill Test Date | 09/07/2022 | Piping Installed Date | 08/12/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/15/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 09/07/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 09/07/2022 | | | ATG Type | | | | | |
| Tank Code | 4 | Tank Age | 5 | Tank Installed Date | 08/12/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5907 | Spill Test Date | 09/07/2022 | Piping Installed Date | 08/12/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/15/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 10000 | ATG Test Date | 09/07/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 09/07/2022 | | | ATG Type | | | | | |
| Tank Code | 5 | Tank Age | 5 | Tank Installed Date | 08/12/2019 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5908 | Spill Test Date | 09/07/2022 | Piping Installed Date | 08/12/2019 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/15/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 09/07/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 09/07/2022 | | | ATG Type | | | | | |

Facility Summary in Park County in the City of Gardiner

Location: RANCH OFFICE
558 Old Yellowstone Trl S
Gardiner, MT 59030-9359 Park

System Facility ID:34-03402

Facility Code: 25977
Last Inspected On: 06/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Church Universal and Triumphant Inc4068489200

Operator Contact: David Otis4068489043

Owner/Operator: Church Universal and Triumphant Inc

David Otis, UST Class A Operator
David Otis, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------------------|--------------------------|-----------------------------|----------------|------------------|
| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 10/21/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 1861 | Spill Test Date | 06/05/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 06/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/05/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 06/05/2023 | Line Tightness Test Date | 06/05/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/05/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 10/21/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 1862 | Spill Test Date | 06/05/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 06/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 06/05/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 06/05/2023 | Line Tightness Test Date | 06/05/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/05/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Park County in the City of Gardiner

Location: TOWN STATION
401 Scott St W
Gardiner, MT 59030-0507 Park

System Facility ID:34-06531

Facility Code: 26030
Last Inspected On: 10/10/2023
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|------------------------|------------|
| Owner Operator Contact: | Gardiner Town Club Inc | 4068487322 |
| Operator Contact: | Wade Laubach | 4062230847 |

Owner/Operator: Gardiner Town Club Inc

Wade Laubach, UST Class A Operator
Wade Laubach, UST Class B Operator
Scott Kremer, UST Class B Global Operator
Wade Laubach, UST Class A Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| Tank Code | 01 | Tank Age | 40 | Tank Installed Date | 04/16/1984 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3189 | Spill Test Date | | Piping Installed Date | 11/12/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/12/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 01/04/2024 | Tank/Piping CP Test Date | 10/10/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 01/04/2024 | Line Tightness Test Date | 10/03/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/10/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 40 | Tank Installed Date | 04/16/1984 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3190 | Spill Test Date | 10/10/2023 | Piping Installed Date | 11/12/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/10/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 01/04/2024 | Tank/Piping CP Test Date | 10/10/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 01/04/2024 | Line Tightness Test Date | 10/03/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|-------------------|
| | | Overfill Test Date | 10/10/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 03 | Tank Age | 40 | Tank Installed Date | 04/16/1984 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3191 | Spill Test Date | 10/10/2023 | Piping Installed Date | 11/12/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/12/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 01/04/2024 | Tank/Piping CP Test Date | 10/10/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 01/04/2024 | Line Tightness Test Date | 10/03/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/10/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 40 | Tank Installed Date | 04/16/1984 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3192 | Spill Test Date | 10/10/2023 | Piping Installed Date | 11/12/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/12/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 01/04/2024 | Tank/Piping CP Test Date | 10/10/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 01/04/2024 | Line Tightness Test Date | 10/03/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/10/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Park County in the City of Livingston

Location: CASEY'S CORNER 4
2050 S Park
Livingston, MT 59047-9133 Park

System Facility ID:34-09906

Facility Code: 26096
Last Inspected On: 05/02/2022
Operating Permit Renewal Date: 07/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|--------------------------|------------|
| Owner Operator Contact: | Superpumper Inc | 7018521194 |
| Operator Contact: | Calvin Wilson;Nancy Coen | 7204212140 |

Owner/Operator: Superpumper Inc

Calvin Wilson, UST Class A Operator
Nancy Coen, UST Class A Operator
Nancy Coen, UST Class B Operator
Venus Banthem, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 05 | Tank Age | 26 | Tank Installed Date | 05/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 2033 | Spill Test Date | 04/16/2021 | Piping Installed Date | 02/20/2017 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 03/18/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/02/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 01/18/2023 | Line Tightness Test Date | 02/23/2016 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/18/2023 | | | ATG Type | Other/TLS-350 | | | | |
| Tank Code | 06 | Tank Age | 26 | Tank Installed Date | 05/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 2034 | Spill Test Date | 04/16/2021 | Piping Installed Date | 02/20/2017 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 03/18/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/02/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 01/18/2023 | Line Tightness Test Date | 02/23/2016 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/18/2023 | | | ATG Type | Other/ | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 07 | Tank Age | 26 | Tank Installed Date | 05/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 2035 | Spill Test Date | 03/18/2021 | Piping Installed Date | 02/20/2017 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 03/18/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/02/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 01/18/2023 | Line Tightness Test Date | 02/23/2016 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/18/2023 | | | ATG Type | Other/ | | | | |

Facility Summary in Park County in the City of Livingston

Location: CITY COUNTY COMPLEX
414 E Callender St
Livingston, MT 59047-2700 Park

System Facility ID:34-10573

Facility Code: 26105
Last Inspected On: 09/07/2022
Operating Permit Renewal Date: 10/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Park County Shop - City of Livingston

Operator Contact: Kelly Johnson4062224141

Owner/Operator: Park County Shop - City of Livingston

Kelly Johnson, UST Class A Operator
Kelly Johnson, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------------------|--------------------------|----------------------------|----------------|------------------|
| Tank Code | 02 | Tank Age | 29 | Tank Installed Date | 11/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1783 | Spill Test Date | 09/07/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 3000 | ATG Test Date | 09/07/2022 | Line Tightness Test Date | 09/28/2022 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.1 | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/07/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300 | | | | |

Facility Summary in Park County in the City of Livingston

Location: TJS GAS N CONVENIENCE
204 E Park St
Livingston, MT 59047-2713 Park

System Facility ID:34-13736

Facility Code: 26167
Last Inspected On: 05/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|-------------------------|----------------------------|------------|
| Owner Operator Contact: | TJs Gas N Convenience | 4062229720 |
| Operator Contact: | Becky Thomas;William Woods | 4062229720 |

Owner/Operator: TJs Gas N Convenience

Becky Thomas, UST Class A Operator
Becky Thomas, UST Class B Global Operator
William Woods, UST Class A Operator
William Woods, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 28 | Tank Installed Date | 05/01/1996 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3371 | Spill Test Date | 05/05/2023 | Piping Installed Date | 06/24/2014 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 01/22/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/05/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/05/2023 | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 02 | Tank Age | 28 | Tank Installed Date | 05/01/1996 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3372 | Spill Test Date | 05/05/2023 | Piping Installed Date | 06/24/2014 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 01/22/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/05/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/05/2023 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 2
716 E Park St
Livingston, MT 59047 Park

System Facility ID:34-08713

Facility Code: 26078
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 08/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Livingston 2 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Livingston 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 03 | Tank Age | 28 | Tank Installed Date | 09/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2575 | Spill Test Date | 08/02/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/13/2021 | Sump Tightness Test Date | 08/15/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/15/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 08/15/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/02/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 28 | Tank Installed Date | 09/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2576 | Spill Test Date | 05/13/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/13/2021 | Sump Tightness Test Date | 08/15/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/15/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 08/15/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| | | Overfill Test Date | 08/02/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 28 | Tank Installed Date | 09/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2577 | Spill Test Date | 08/02/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/13/2021 | Sump Tightness Test Date | 08/15/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/15/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 08/15/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/02/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 28 | Tank Installed Date | 09/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2578 | Spill Test Date | 08/02/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/13/2021 | Sump Tightness Test Date | 08/15/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/15/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 08/15/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/02/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 3
2200 Park St S
Livingston, MT 59047 Park

System Facility ID:34-13409

Facility Code: 26162
Last Inspected On: 08/16/2022
Operating Permit Renewal Date: 08/02/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Livingston 3 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Livingston 3 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---------------------------------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 30 | Tank Installed Date | 05/20/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2579 | Spill Test Date | 07/19/2021 | Piping Installed Date | 04/20/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 30 | Tank Installed Date | 05/20/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2580 | Spill Test Date | 05/12/2021 | Piping Installed Date | 04/20/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---------------------------------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 03 | Tank Age | 30 | Tank Installed Date | 05/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2581 | Spill Test Date | 07/19/2021 | Piping Installed Date | 04/20/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 30 | Tank Installed Date | 05/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2582 | Spill Test Date | 07/19/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 30 | Tank Installed Date | 05/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2583 | Spill Test Date | 07/19/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---------------------------------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Capacity | 12000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 23 | Tank Installed Date | 10/01/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4377 | Spill Test Date | 07/19/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 07 | Tank Age | 23 | Tank Installed Date | 10/01/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4378 | Spill Test Date | 07/19/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 08 | Tank Age | 23 | Tank Installed Date | 10/01/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4379 | Spill Test Date | 05/12/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|----------|----------|--------------------|------------|--------------------------|--|-------------------------------|---------------------------------------------------------------|--------------------------|--------------------------------------|----------------|----|
| Product | Gasoline | PLLD Test Date | 12/30/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/12/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Park County in the City of Livingston

Location: YELLOWSTONE TRAVEL PLAZA
1226 US Hwy 10 W
Livingston, MT 59047-9004 Park

System Facility ID:34-11200

Facility Code: 26137
Last Inspected On: 11/16/2022
Operating Permit Renewal Date: 03/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Yellowstone Travel Plaza

Operator Contact: Bailey Kostman;Gagandeep Chana;Yellowstone Travel Plaza 5099616186

Owner/Operator: Yellowstone Travel Plaza

Bailey Kostman, UST Class A Operator
Bailey Kostman, UST Class B Operator
Gagandeep Chana, UST Class A Operator
Gagandeep Chana, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 35 | Tank Installed Date | 01/01/1989 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2313 | Spill Test Date | 08/26/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/16/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/21/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/26/2022 | | | ATG Type | Incon/TS-1001 | | | | |
| Tank Code | 02 | Tank Age | 35 | Tank Installed Date | 01/01/1989 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2314 | Spill Test Date | 08/26/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/16/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 07/21/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/26/2022 | | | ATG Type | Incon/TS-1001 | | | | |
| Tank Code | 03 | Tank Age | 35 | Tank Installed Date | 01/01/1989 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tag Number | 2315 | Spill Test Date | 08/26/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/16/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 07/21/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/26/2022 | | | ATG Type | Incon/TS-1001 | | | | |
| Tank Code | 04 | Tank Age | 35 | Tank Installed Date | 01/01/1989 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2316 | Spill Test Date | 08/26/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/16/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 07/21/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/26/2022 | | | ATG Type | Incon/TS-1001 | | | | |

Facility Summary in Park County in the City of Livingston

Location: ZIP TRIP 47
101 Centennial Dr
Livingston, MT 59047-9155 Park

System Facility ID:34-11741

Facility Code: 26145
Last Inspected On: 05/21/2021
Operating Permit Renewal Date: 11/08/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | |
|-------------------------------------------------------------------------|----------------------------------|
| Owner Operator Contact: CHS Inc Spokane Valley | 5095357701 |
| Operator Contact: Ian Johnstone;Jim Alford;Nicholas Merritt;Sean Hurley | 4066330023;5095357701;5095367418 |

Owner/Operator: CHS Inc Spokane Valley

Darcy Ziegler, UST Class B Operator
Ian Johnstone, UST Class A Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Karina Serrano, UST Class B Global Operator
Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Global Operator
Nicholas Merritt, UST Class B Operator
Sean Hurley, UST Class A Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Tank Code | 01 | Tank Age | 34 | Tank Installed Date | 09/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 562 | Spill Test Date | 08/26/2021 | Piping Installed Date | 06/25/2018 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/25/2018 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 08/26/2020 | Tank/Piping CP Test Date | 09/25/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/04/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 08/26/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 34 | Tank Installed Date | 09/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 563 | Spill Test Date | 08/26/2021 | Piping Installed Date | 06/25/2018 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/25/2018 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------------------|--------------------------|------------------------------------|----------------|---------------|
| Product | Gasoline | PLLD Test Date | 08/26/2020 | Tank/Piping CP Test Date | 09/25/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/04/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 08/26/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 34 | Tank Installed Date | 09/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 564 | Spill Test Date | 08/26/2021 | Piping Installed Date | 06/25/2018 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/25/2018 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 08/26/2020 | Tank/Piping CP Test Date | 09/25/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 01/04/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 08/26/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Park County in the City of Wilsall

Location: PARK FARMERS COOP
114 S Elliot
Wilsall, MT 59086 Park

System Facility ID:34-06686

Facility Code: 26034
Last Inspected On: 04/20/2022
Operating Permit Renewal Date: 05/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Park Farmers Coop4065782543

Operator Contact: Don Scott

Owner/Operator: Park Farmers Coop

Don Scott, UST Class A Operator
Don Scott, UST Class B Operator
Donald Scott, UST Class B Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 13 | Tank Age | 31 | Tank Installed Date | 07/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1784 | Spill Test Date | 06/16/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/20/2022 | Tank/Piping CP Test Date | 04/26/2010 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/20/2022 | Line Tightness Test Date | 02/05/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 14 | Tank Age | 31 | Tank Installed Date | 07/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1785 | Spill Test Date | 06/16/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 04/20/2022 | Tank/Piping CP Test Date | 04/26/2010 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/20/2022 | Line Tightness Test Date | 02/06/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 15 | Tank Age | 31 | Tank Installed Date | 07/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1786 | Spill Test Date | 06/16/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/20/2022 | Tank/Piping CP Test Date | 04/26/2010 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 04/20/2022 | Line Tightness Test Date | 02/05/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 16 | Tank Age | 31 | Tank Installed Date | 07/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1787 | Spill Test Date | 06/16/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 04/20/2022 | Tank/Piping CP Test Date | 04/26/2010 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 04/20/2022 | Line Tightness Test Date | 02/07/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |