

Facility Summary in Petroleum County in the City of Winnett

Location: B and D SERVICE HWY 244  
203 N Broadway Ave  
Winnett, MT 59087 Petroleum

System Facility ID:56-13897

Facility Code: 30570  
Last Inspected On: 08/25/2021  
Operating Permit Renewal Date: 01/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: B and D Service;David Grantier4064295291

Operator Contact: Becky Grantier;David Grantier4064295291

Owner/Operator: B and D Service

Owner/Operator: David J Grantier

- Becky Grantier, UST Class A Operator
- Becky Grantier, UST Class B Operator
- David Grantier, UST Class A Operator
- David Grantier, UST Class B Operator

Tank Code	S5	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4001	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/25/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4002	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/25/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

	Overfill Test Date		ATG Type			
--	--------------------	--	----------	--	--	--

Facility Summary in Petroleum County in the City of Winnett

Location: WINNETT TIRE  
115 N Broadway  
Winnett, MT 59087 Petroleum

System Facility ID:35-00536

Facility Code: 26168  
Last Inspected On: 03/24/2022  
Operating Permit Renewal Date: 06/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: GS Oil Inc Roy

Operator Contact: Jolene Smith 4064642391

Owner/Operator: GS Oil Inc Roy

Jolene Smith, UST Class A Operator  
Jolene Smith, UST Class B Operator

Tank Code	S3	Tank Age	25	Tank Installed Date	09/27/1999	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4094	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/24/2022	Sump Tightness Test Date	10/24/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	03/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	25	Tank Installed Date	09/27/1999	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4095	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/24/2022	Sump Tightness Test Date	10/24/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	03/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	25	Tank Installed Date	09/27/1999	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	4096	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/24/2022	Sump Tightness Test Date	10/24/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	03/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	25	Tank Installed Date	09/27/1999	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4097	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/24/2022	Sump Tightness Test Date	10/24/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	03/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					