

**Facility Summary in Petroleum County in the City of Winnett**

**Location:** B and D SERVICE HWY 244  
203 N Broadway Ave  
Winnett, MT 59087 Petroleum

Legacy ID:56-13897

**Facility ID:** 30570  
**Last Inspected On:** 08/25/2021  
**Operating Permit Renewal Date:** 01/26/2025

**Owner Operator Contact:** B and D Service

**4064295291**

**Operator Contact:** Becky Grantier;David Grantier

**4064295291**

**Owner/Operator:** B and D Service

**Owner/Operator:** David J Grantier

Becky Grantier, UST Class A Operator  
Becky Grantier, UST Class B Operator  
David Grantier, UST Class A Operator  
David Grantier, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	22	04/01/1999	Unknown	Flexible Plastic	
<b>4001</b>	Yes	10/30/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S6	22	04/01/1999	Unknown	Flexible Plastic	
<b>4002</b>	Yes	10/30/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					No

**Facility Summary in Petroleum County in the City of Winnett**

**Location:** WINNETT TIRE  
 115 N Broadway  
 Winnett, MT 59087 Petroleum

Legacy ID:35-00536

**Facility ID:** 26168  
**Last Inspected On:** 01/07/2019  
**Operating Permit Renewal Date:** 06/17/2022

**Owner Operator Contact:** Gary Smith;GS Oil Inc Roy;GS Oil Inc Roy

**4064642221**

**Operator Contact:** Jolene Smith

**4064642391**

**Owner/Operator:** GS Oil Inc Roy

Jolene Smith, UST Class A Operator

Jolene Smith, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	22	09/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
<b>4094</b>	Yes	10/24/2016	Double-Walled	Double Walled	No
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
2,000					No
S4	22	09/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
<b>4095</b>	Yes	10/24/2016	Double-Walled	Double Walled	No
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
3,000					No
S5	22	09/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
<b>4096</b>	Yes	10/24/2016	Double-Walled	Double Walled	No
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No

3,000					No
S6	22	09/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4097	Yes	10/24/2016	Double-Walled	Double Walled	No
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
3,000					No