

Facility Summary in Phillips County in the City of Malta

Location: EQUITY COOP ASSOCIATION MALTA
428 S 1st St E
Malta, MT 59538 Phillips

Legacy ID:36-10706

Facility ID: 26305
Last Inspected On: 10/11/2019
Operating Permit Renewal Date: 10/30/2022

Owner Operator Contact: Equity Coop Association Malta;Larry Olson;Equity Coop Association Malta **4066542240**

Operator Contact: Angela Anderson;Dale Kaasa;Virgil Abrahamson

Owner/Operator: Equity Coop Association Malta

Angela Anderson, UST Class A Operator
Angela Anderson, UST Class B Operator
Dale Kaasa, UST Class A Operator
Dale Kaasa, UST Class B Operator
Virgil Abrahamson, UST Class A Operator
Virgil Abrahamson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S7	27	12/01/1994	Unknown	Fiberglass Reinforced Plastic	
5421	Yes	08/06/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Deferred	Continuous Interstitial Monitoring	No
3,200					No
S3	27	12/09/1994	Unknown	Fiberglass Reinforced Plastic	
860	Yes	08/06/2016		Double Walled	Yes
Currently in Use		07/20/2007	Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Gasoline			Deferred	Continuous Interstitial Monitoring	No
25,600					No

S4	27	12/09/1994	Unknown	Fiberglass Reinforced Plastic	
861	Yes	08/06/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Deferred	Continuous Interstitial Monitoring	No
17,000					No
S5	27	12/09/1994	Unknown	Fiberglass Reinforced Plastic	
862	Yes	08/06/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S6	27	12/09/1994	Unknown	Fiberglass Reinforced Plastic	
863	Yes	08/06/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Gasoline			Deferred	Continuous Interstitial Monitoring	No
9,900					No

Facility Summary in Phillips County in the City of Malta

Location: EZZIES BULK STORAGE
47259 US Hwy 2 E
Malta, MT 59538 Phillips

Legacy ID:60-15156

Facility ID: 30897
Last Inspected On: 11/13/2019
Operating Permit Renewal Date: 04/20/2023

Owner Operator Contact: Ezzies Wholesale Inc

Operator Contact: Clayton Jesson;David Skiff

4066542331

Owner/Operator: Ezzies Wholesale Inc

Clayton Jesson, UST Class A Operator
David Skiff, UST Class A Operator
David Skiff, UST Class B Global Operator
Derek Oshio, UST Class B Operator
Loren Johnson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5246	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
30,000			Incon/TS-5000		Yes
02	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5247	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Incon/TS-5000		Yes
03	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5248	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Incon/TS-5000		Yes
04	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5249	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No

10,000			Incon/TS-5000		Yes
05	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5250	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Incon/TS-5000		Yes
06	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5251	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Incon/TS-5000		Yes
07	11	09/27/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5252	No	10/06/2014	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Hazardous Substance			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
10,000			Incon/TS-5000		Yes
08	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5253	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Incon/TS-5000		Yes
09	11	09/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5254	No		Double-Walled	Double Walled	Yes

Currently in Use	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
30,000	Incon/TS-5000		Yes

Facility Summary in Phillips County in the City of Malta

Location: EZZIES WHOLESALE US 2 E
US Hwy 2 E
Malta, MT 59538 Phillips

Legacy ID:36-11372

Facility ID: 26310
Last Inspected On: 06/06/2019
Operating Permit Renewal Date: 09/15/2022

Owner Operator Contact: Ezzies Wholesale Inc

Operator Contact: David Skiff

4066542331

Owner/Operator: Ezzies Wholesale Inc

- David Skiff, UST Class A Operator
- David Skiff, UST Class B Global Operator
- David Skiff, UST Class B Operator
- Derek Oshio, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
----	----	------------	-------------------------------	-------------------------------	------------------

886	No			None	Yes
------------	----	--	--	------	-----

Currently in Use		07/23/2007	Electronic Line Leak Detector	Pressurized	
------------------	--	------------	-------------------------------	-------------	--

Diesel		03/23/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
--------	--	------------	----------------------------	-------------------	----

6,000		03/29/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
-------	--	------------	---	--	----

02	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
----	----	------------	-------------------------------	-------------------------------	------------------

887	No			None	Yes
------------	----	--	--	------	-----

Currently in Use		07/23/2007	Electronic Line Leak Detector	Pressurized	
------------------	--	------------	-------------------------------	-------------	--

Diesel		03/23/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
--------	--	------------	----------------------------	-------------------	----

6,000		03/29/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
888	No			Double Walled	Yes
Currently in Use		07/23/2007	Electronic Line Leak Detector	Pressurized	
Diesel		03/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000		03/29/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
889	No			None	Yes
Currently in Use		07/23/2007	Electronic Line Leak Detector	Pressurized	
Diesel		03/23/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		03/29/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
890	No			None	Yes
Currently in Use		07/23/2007	Electronic Line Leak Detector	Pressurized	
Gasoline		03/23/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		03/29/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
891	No			None	Yes
Currently in Use		07/23/2007	Electronic Line Leak Detector	Pressurized	
Gasoline		03/23/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		10/06/2006	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Phillips County in the City of Malta

Location: MALTA CONVENIENCE STORE
3 N 1st St E
Malta, MT 59538 Phillips

Legacy ID:36-02371

Facility ID: 26213
Last Inspected On: 05/24/2019
Operating Permit Renewal Date: 10/31/2022

Owner Operator Contact: Horizon Resources;Stanley Green;Greens Sales Inc 4066542631;4066542631;7015722172

Operator Contact: Chris Kinkelaar;Eric Ottinger;Novalene Nelson 4066541199

Owner/Operator: Horizon Resources

Chris Kinkelaar, UST Class A Operator
Chris Kinkelaar, UST Class B Operator
Eric Ottinger, UST Class A Operator
Eric Ottinger, UST Class B Operator
Novalene Nelson, UST Class A Operator
Novalene Nelson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	35	10/29/1986	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3287	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/27/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000			Veeder Root/TLS-300		No
03	35	10/29/1986	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3288	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/27/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000			Veeder Root/TLS-300		No
04	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3289	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Gasoline		09/22/2010	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Veeder Root/TLS-300		No
05	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3290	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		09/22/2010	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
5,000			Veeder Root/TLS-300		No

Facility Summary in Phillips County in the City of Malta

Location: PHILLIPS COUNTY MEDICAL CENTER
311 S 8th Ave E
Malta, MT 59538 Phillips

Legacy ID:56-14104

Facility ID: 30747
Last Inspected On: 06/06/2019
Operating Permit Renewal Date: 10/05/2022

Owner Operator Contact:

Operator Contact: Beu Winkel;Richard Ferrell;Thomas Miller **4063904452;4066832175**

Owner/Operator: Phillips County Medical Center

Beu Winkel, UST Class A Operator
Beu Winkel, UST Class B Operator
Richard Ferrell, UST Class A Operator
Richard Ferrell, UST Class B Operator
Thomas Miller, UST Class A Operator
Thomas Miller, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	17	03/02/2004	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4884	No	06/12/2013	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
1,000		06/21/2016	Gilbarco-Veeder Root/TLS-300		No
02	17	03/02/2004	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4885	No	06/12/2013	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
1,000		06/21/2016			No

Facility Summary in Phillips County in the City of Malta

Location: WESTSIDE SELF SERVICE INC
200 US Hwy 2
Malta, MT 59538 Phillips

Legacy ID:36-06668

Facility ID: 26274
Last Inspected On: 02/21/2019
Operating Permit Renewal Date: 07/09/2022

Owner Operator Contact: Claude Ereaux;Westside Self Service Inc;Robert Ereaux

4066547070;8008926874

Operator Contact: Byron Ereaux;Katie Smith

4066542144

Owner/Operator: Robert Ereaux

Owner/Operator: Robert N Ereaux

Byron Ereaux, UST Class A Operator

Byron Ereaux, UST Class B Operator

Katie Smith, UST Class A Operator

Katie Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	15	04/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5069	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		10/11/2006	Automatic Tank Gauging 0.1	ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco/EMC Basic		No
07	15	04/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5070	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		10/12/2006	Automatic Tank Gauging 0.1	ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco/EMC Basic		No
08	15	04/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

5071	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		10/13/2006	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco/EMC Basic		No
09	15	04/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5075	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		10/14/2006	Automatic Tank Gauging 0.1	ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No
10	15	04/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5076	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		10/20/2006	Automatic Tank Gauging 0.1	ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No
11	15	04/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5077	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		11/27/2006	Automatic Tank Gauging 0.1	ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No

Facility Summary in Phillips County in the City of Saco

Location: EZZIES WHOLESALE
100 Hwy 243
Saco, MT 59261 Phillips

Legacy ID:60-15270

Facility ID: 30982
Last Inspected On: 01/08/2019
Operating Permit Renewal Date: 07/05/2022

Owner Operator Contact: Ezzies Wholesale Inc

Operator Contact: David Skiff

4066542331

Owner/Operator: Ezzies Wholesale Inc

David Skiff, UST Class A Operator
 Loren Johnson, UST Class B Operator
 Nickole Cline, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	5	01/20/2016	Aboveground Tank	Flexible Plastic	
5626	Yes	01/15/2016		Double Walled	No
Currently in Use		01/20/2016	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000					Yes
S2	5	01/20/2016	Aboveground Tank	Flexible Plastic	
5627	Yes	01/15/2016		Double Walled	No
Currently in Use		01/20/2016	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
2,000					Yes
S3	5	01/20/2016	Aboveground Tank	Flexible Plastic	
5628	Yes	01/15/2016		Double Walled	No
Currently in Use		01/20/2016	Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
2,000					Yes

Facility Summary in Phillips County in the City of Whitewater

Location: Ezzie's Wholesale, Inc.
Main St
Whitewater, MT 59544 Phillips

Legacy ID:36-04082

Facility ID: 26227
Last Inspected On: 01/07/2021
Operating Permit Renewal Date: 02/11/2024

Owner Operator Contact: Ezzie's Wholesale, Inc.

4066542331

Operator Contact: David Skiff

4066542331

Owner/Operator: Ezzie's Wholesale, Inc.

David Skiff, UST Class A Operator
David Skiff, UST Class B Global Operator
David Skiff, UST Class B Operator
Loren Johnson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	23	10/13/1998	Unknown	Flexible Plastic	
3599	Yes	10/16/2017		Double Walled	Yes
Currently in Use		09/10/2007	Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
10,000					No
S6	23	10/13/1998	Unknown	Flexible Plastic	
3600	Yes	10/16/2017		Double Walled	Yes
Currently in Use		09/10/2007	Auto Dialer	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
15,000					No
S7	23	10/13/1998	Unknown	Flexible Plastic	
3601	Yes	10/16/2017		Double Walled	Yes

Currently in Use		09/10/2007	Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
9,000					No
S8	23	10/13/1998	Unknown	Flexible Plastic	
3602	Yes	10/16/2017		Double Walled	Yes
Currently in Use		09/10/2007	Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
9,000					No

Facility Summary in Phillips County in the City of Zortman

Location: ZORTMAN GARAGE and MOTEL
302 Main St
Zortman, MT 59546-0302 Phillips

Legacy ID:36-11549

Facility ID: 26314
Last Inspected On: 07/16/2019
Operating Permit Renewal Date: 11/27/2022

Owner Operator Contact: Zortman Garage and Motel

4066733160

Operator Contact: Candy Kalal;Deirdre Hanners

Owner/Operator: John Kalal

Owner/Operator: Zortman Garage and Motel

Candy Kalal, UST Class A Operator
Candy Kalal, UST Class B Operator
Deirdre Hanners, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	22	06/17/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4020	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		08/18/2010	Manual Interstitial Monitoring	Deferred	No
1,000					No
04	22	06/17/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4021	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		08/18/2010	Manual Interstitial Monitoring	Deferred	No
1,000					No