

Facility Summary in Pondera County in the City of Brady

Location: MOUNTAIN VIEW COOP BRADY
102 Railroad St N
Brady, MT 59416 Pondera

System Facility ID:37-04241

Facility Code: 26390
Last Inspected On: 05/27/2025
Operating Permit Renewal Date: 08/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle

ddouglas@mountainviewcoop.com

Operator Contact: David Douglas

ddouglas@mountainviewcoop.com

Owner/Operator: Mountain View Coop Black Eagle

ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator

ddouglas@mountainviewcoop.com

David Douglas, UST Class B Global Operator

ddouglas@mountainviewcoop.com

Jeremy Kulpas, UST Class B Global Operator

jkulpas@mountainviewcoop.com

Tank Code	S11	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2142	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/27/2025	Sump Tightness Test Date	05/27/2025	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date	06/21/2022	Line Tightness Test Date	03/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S12	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2143	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/27/2025	Sump Tightness Test Date	05/27/2025	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date	06/21/2022	Line Tightness Test Date	03/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S13	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	2144	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/27/2025	Sump Tightness Test Date	05/27/2025	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/21/2022	Line Tightness Test Date	03/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S14	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2145	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/27/2025	Sump Tightness Test Date	05/27/2025	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	06/21/2022	Line Tightness Test Date	03/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Pondera County in the City of Conrad

Location: MOUNTAIN VIEW COOP CONRAD
19 S Main St
Conrad, MT 59425-1828 Pondera

System Facility ID:37-01649

Facility Code: 26344
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 01/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle

ddouglas@mountainviewcoop.com

Operator Contact: Dave Douglas;Jeremy Kulpas

(406) 278-5524;(406) 750-6748

ddouglas@mountainviewcoop.com;jkulpas@mountainviewcoop.com

Owner/Operator: Mountain View Coop Black Eagle

ddouglas@mountainviewcoop.com

Dave Douglas, UST Class A Operator
Jeremy Kulpas, UST Class A Operator
Jeremy Kulpas, UST Class B Global Operator
Jeremy Kulpas, UST Class B Operator

ddouglas@mountainviewcoop.com
jkulpas@mountainviewcoop.com
jkulpas@mountainviewcoop.com
jkulpas@mountainviewcoop.com

Tank Code	13	Tank Age	6	Tank Installed Date	07/06/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5978	Spill Test Date	07/09/2020	Piping Installed Date	07/06/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/29/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/11/2023	Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2020			ATG Type					
Tank Code	14	Tank Age	6	Tank Installed Date	07/06/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5979	Spill Test Date	12/11/2023	Piping Installed Date	07/06/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/29/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/29/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/11/2023	Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2020			ATG Type					

Tank Code	15	Tank Age	6	Tank Installed Date	07/06/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5980	Spill Test Date	12/11/2023	Piping Installed Date	07/06/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/29/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/29/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	11000	ATG Test Date	12/11/2023	Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2020			ATG Type					
Tank Code	16	Tank Age	6	Tank Installed Date	07/06/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5981	Spill Test Date	12/11/2023	Piping Installed Date	07/06/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/29/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/29/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	9000	ATG Test Date	12/11/2023	Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2020			ATG Type					
Tank Code	17	Tank Age	6	Tank Installed Date	07/06/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5982	Spill Test Date	12/11/2023	Piping Installed Date	07/06/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/29/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/29/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/11/2023	Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2020			ATG Type					
Tank Code	18	Tank Age	6	Tank Installed Date	07/06/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5983	Spill Test Date	12/11/2023	Piping Installed Date	07/06/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/29/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/29/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	7000	ATG Test Date	12/11/2023	Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2020			ATG Type					
Tank Code	19	Tank Age	6	Tank Installed Date	07/06/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5984	Spill Test Date	12/11/2023	Piping Installed Date	07/06/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/29/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/29/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	12/11/2023	Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2020			ATG Type					

Facility Summary in Pondera County in the City of Conrad

Location: TOWN PUMP INC CONRAD
215 N Main St
Conrad, MT 59425-1628 Pondera

System Facility ID:37-08692

Facility Code: 26453
Last Inspected On: 03/21/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Conrad 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Conrad 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	43	Tank Installed Date	08/30/1983	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2584	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	09/22/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/21/2024	Line Tightness Test Date	07/28/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	43	Tank Installed Date	08/30/1983	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	2585	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	09/22/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/21/2024	Line Tightness Test Date	07/29/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	43	Tank Installed Date	08/30/1983	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2586	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	09/22/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/21/2024	Line Tightness Test Date	07/30/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	40	Tank Installed Date	08/30/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2587	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	09/22/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/21/2024	Line Tightness Test Date	08/01/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	38	Tank Installed Date	07/01/1988	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2588	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	12/03/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/21/2024	Line Tightness Test Date	10/26/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	27	Tank Installed Date	09/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4151	Spill Test Date	09/22/2023	Piping Installed Date	04/16/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	12/03/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/21/2024	Line Tightness Test Date	10/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	09	Tank Age	27	Tank Installed Date	09/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4152	Spill Test Date	09/22/2023	Piping Installed Date	04/16/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	12/03/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/21/2024	Line Tightness Test Date	10/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	12	Tank Installed Date	07/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5495	Spill Test Date	09/22/2023	Piping Installed Date	04/16/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	12	Tank Installed Date	07/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5496	Spill Test Date	09/22/2023	Piping Installed Date	04/16/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	20000	ATG Test Date	08/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	12	Tank Installed Date	07/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5497	Spill Test Date	09/22/2023	Piping Installed Date	04/16/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Pondera County in the City of Heart Butte

Location: HEART BUTTE SCHOOL DIST 1
School Bus Barn Rd
Heart Butte, MT 59448 Pondera

System Facility ID:37-09353

Facility Code: 26492
Last Inspected On: 07/11/2022
Operating Permit Renewal Date: 12/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 Heart Butte (406) 338-2200

Operator Contact: Dewey Skunk Cap dewys@heartbutte.k12.mt.us

Owner/Operator: School Dist 1 Heart Butte (406) 338-2200

Dewey Skunk Cap, UST Class A Operator
Nathan Ironheart, UST Class B Operator

dewys@heartbutte.k12.mt.us
nateironheart@gmail.com

Tank Code	03	Tank Age	40	Tank Installed Date	05/06/1986	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1901	Spill Test Date	03/04/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	40	Tank Installed Date	05/06/1986	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1902	Spill Test Date	03/04/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Pondera County in the City of Valier

Location: ONE STOP CENEX
518 Teton
Valier, MT 59486-0000 Pondera

System Facility ID:37-03112

Facility Code: 26371
Last Inspected On: 03/08/2026
Operating Permit Renewal Date: 12/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: One Stop LLC;Pardeep Kumar (406) 279-3600;(408) 449-9333 onestop@3rivers.net;pardeep.k51@yahoo.com

Operator Contact: Pardeep Kumar;Paul Johnson;Scott Curry (406) 505-0386;(406) 576-3365;(408) 449-9333 dstockton1223@gmail.com;onestop@3rivers.net;pardeep.k51@yahoo.com

Owner/Operator: One Stop LLC (406) 279-3600 onestop@3rivers.net

Owner/Operator: Pardeep Kumar (406) 279-3600 onestop@3rivers.net

Pardeep Kumar, UST Class A Operator	pardeep.k51@yahoo.com
Paul Johnson, UST Class A Operator	dstockton1223@gmail.com
Paul Johnson, UST Class B Global Operator	dstockton1223@gmail.com
Scott Curry, UST Class A Operator	onestop@3rivers.net
Scott Curry, UST Class B Global Operator	onestop@3rivers.net
Scott Curry, UST Class B Operator	onestop@3rivers.net

Tank Code	03	Tank Age	36	Tank Installed Date	03/21/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1878	Spill Test Date	06/12/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/07/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/07/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	07/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/12/2024			ATG Type					
Tank Code	04	Tank Age	36	Tank Installed Date	03/21/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1879	Spill Test Date	06/12/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/07/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/07/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	1000	ATG Test Date		Line Tightness Test Date	07/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/12/2024			ATG Type					
Tank Code	05	Tank Age	36	Tank Installed Date	03/21/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4445	Spill Test Date	06/12/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/07/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/07/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	07/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/12/2024			ATG Type					

Facility Summary in Pondera County in the City of Valier

Location: VALIER CARDLOCK
802 Teton
Valier, MT 59486 Pondera

System Facility ID:56-14043

Facility Code: 30698
Last Inspected On: 12/11/2023
Operating Permit Renewal Date: 03/25/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ben Taylor Inc

bti@3rivers.net

Operator Contact: Scott Curry

(406) 576-3365

onestop@3rivers.net

Owner/Operator: Ben Taylor Inc

bti@3rivers.net

Rita Swanson, UST Class B Operator
Scott Curry, UST Class A Operator
Scott Curry, UST Class B Global Operator
Scott Curry, UST Class B Operator

onestop@3rivers.net
onestop@3rivers.net
onestop@3rivers.net

Tank Code	S1	Tank Age	24	Tank Installed Date	08/19/2002	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4710	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/13/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/13/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	24	Tank Installed Date	08/19/2002	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4711	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/13/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/13/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S3	Tank Age	24	Tank Installed Date	08/19/2002	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4712	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/13/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date	11/13/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	24	Tank Installed Date	08/19/2002	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4713	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/13/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date	11/13/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					