

Facility Summary in Powder River County in the City of Biddle

Location: CROSS RANCH MERC
222 MT Hwy 59
Biddle, MT 59314 Powder River

Legacy ID:38-01493

Facility ID: 26537
Last Inspected On: 04/07/2020
Operating Permit Renewal Date: 08/10/2023

Owner Operator Contact: Nathan Rumph

Operator Contact: Connie Rumph

4064275447

Owner/Operator: Nathan Rumph

Connie Rumph, UST Class A Operator
Connie Rumph, UST Class B Global Operator
Connie Rumph, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	31	09/11/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
783	No			None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		05/23/2017	Automatic Tank Gauging 0.2	Deferred	No
2,000			EBW/Auto Stik II		No
08	31	09/11/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
784	No			None	Yes
Currently in Use			Not Required	Safe Suction	
Diesel		05/23/2017	Automatic Tank Gauging 0.2	Deferred	No
2,000			EBW/Auto Stik II		No

Facility Summary in Powder River County in the City of Broadus

Location: ALDERMAN OIL CO
601 S Park Ave
Broadus, MT 59317 Powder River

Legacy ID:38-03951

Facility ID: 26549
Last Inspected On: 04/08/2020
Operating Permit Renewal Date: 04/08/2023

Owner Operator Contact: Alderman Oil Co

Operator Contact: Gary Alderman;Theresa Alderman

4064362898

Owner/Operator: Alderman Oil Co

Owner/Operator: Gary Alderman

Gary Alderman, UST Class A Operator

Gary Alderman, UST Class B Operator

Raymond Rolfson, UST Class B Operator

Theresa Alderman, UST Class A Operator

Theresa Alderman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	28	05/10/1993	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
359	No			None	Yes
Currently in Use		04/15/2008	Not Required	Safe Suction	Galvanic
Diesel		05/23/2017	Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	28	05/10/1993	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
360	No			None	Yes
Currently in Use		04/15/2008	Not Required	Safe Suction	Galvanic
Diesel		05/23/2017	Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	28	05/10/1993	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
361	No			None	Yes

Currently in Use		04/15/2008	Not Required	Safe Suction	Galvanic
Diesel		05/23/2017	Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	23	09/30/1998	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
362	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/21/2011	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	23	09/30/1998	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
363	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/21/2011	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	23	09/30/1998	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
364	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/21/2011	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Powder River County in the City of Broadus

Location: COUNTY SHOP MAINTENANCE YARD
3 County Shop Rd
Broadus, MT 59317 Powder River

Legacy ID:38-00548

Facility ID: 26532
Last Inspected On: 04/07/2020
Operating Permit Renewal Date: 05/23/2023

Owner Operator Contact: Powder River County;Ray Traub;Powder River County Shops **4064362361**

Operator Contact: Teel Mullanix **4064362248**

Owner/Operator: Powder River County

Teel Mullanix, UST Class A Operator
 Teel Mullanix, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	30	06/17/1991	Cathodically Protected Steel	Steel	High Level Alarm
1807	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		05/23/2017	Automatic Tank Gauging 0.2	Deferred	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Powder River County in the City of Broadus

Location: THE CORNER STORE
 106 W Holt St
 Broadus, MT 59317 Powder River

Legacy ID:38-00126

Facility ID: 26529
Last Inspected On: 10/28/2020
Operating Permit Renewal Date: 11/06/2023

Owner Operator Contact: Dawn Brengle;Farmers Coop Assn Gillette;Milton Amsden

Operator Contact: Milton Amsden

Owner/Operator: Milton L Amsden

Milton L Amsden, UST Class A Operator
 Milton L Amsden, UST Class B Global Operator
 Milton L Amsden, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	29	12/04/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

933	No			Double Walled	Yes
Currently in Use		03/22/2013	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		01/25/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	29	12/04/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
934	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		01/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	29	12/04/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
935	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		05/20/2014	Automatic Tank Gauging 0.2	ELLD 0.1; ELLD 0.2	No
5,000		01/24/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	29	12/04/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
936	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		05/20/2014	Automatic Tank Gauging 0.2	ELLD 0.1	No
5,000		01/07/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No