

Facility Summary in Powder River County in the City of Biddle

Location: CROSS RANCH MERC
222 MT Hwy 59
Biddle, MT 59314 Powder River

System Facility ID:38-01493

Facility Code: 26537
Last Inspected On: 03/07/2023
Operating Permit Renewal Date: 08/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nathan Rumph

Operator Contact: Connie Rumph 4064275447

Owner/Operator: Nathan Rumph
Connie Rumph, UST Class A Operator
Connie Rumph, UST Class B Operator

Tank Code	07	Tank Age	34	Tank Installed Date	09/11/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	783	Spill Test Date	03/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	EBW/Auto Stik II				
Tank Code	08	Tank Age	34	Tank Installed Date	09/11/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	784	Spill Test Date	03/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	EBW/Auto Stik II				

Facility Summary in Powder River County in the City of Broadus

Location: ALDERMAN OIL CO
601 S Park Ave
Broadus, MT 59317 Powder River

System Facility ID:38-03951

Facility Code: 26549
Last Inspected On: 03/07/2023
Operating Permit Renewal Date: 04/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Alderman Oil Co;Gary Alderman4064362898

Operator Contact: Gary Alderman;Theresa Alderman

Owner/Operator: Alderman Oil Co

Owner/Operator: Gary Alderman

Gary Alderman, UST Class A Operator
Gary Alderman, UST Class B Operator
Raymond Rolfson, UST Class B Operator
Theresa Alderman, UST Class A Operator
Theresa Alderman, UST Class B Operator

Tank Code	04	Tank Age	31	Tank Installed Date	05/10/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	359	Spill Test Date	03/29/2023	Piping Installed Date	04/15/2008	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	31	Tank Installed Date	05/10/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	360	Spill Test Date	03/29/2023	Piping Installed Date	04/15/2008	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No

Capacity	2000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	31	Tank Installed Date	05/10/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	361	Spill Test Date	03/29/2023	Piping Installed Date	04/15/2008	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	26	Tank Installed Date	09/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	362	Spill Test Date	04/07/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	26	Tank Installed Date	09/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	363	Spill Test Date	03/07/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	09	Tank Age	26	Tank Installed Date	09/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	364	Spill Test Date	04/07/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Powder River County in the City of Broadus

Location: CORNER STORE
106 W Holt St
Broadus, MT 59317 Powder River

Facility Code: 26529
Last Inspected On: 11/06/2023
System Facility ID:38-00126
Operating Permit Renewal Date: 11/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Amsden, LLC4065804698

Operator Contact: Julie Riley4068533971

Owner/Operator: Amsden, LLC

Julie Riley, UST Class A Operator
Julie Riley, UST Class B Operator

Tank Code	06	Tank Age	32	Tank Installed Date	12/04/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	933	Spill Test Date	11/06/2023	Piping Installed Date	03/22/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/06/2023	Tank/Piping CP Test Date	11/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/06/2023	Line Tightness Test Date	10/10/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	32	Tank Installed Date	12/04/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	934	Spill Test Date	11/06/2023	Piping Installed Date	04/28/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/06/2023	Tank/Piping CP Test Date	11/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/06/2023	Line Tightness Test Date	09/25/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	08	Tank Age	32	Tank Installed Date	12/04/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	935	Spill Test Date	11/06/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/06/2023	Tank/Piping CP Test Date	11/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/06/2023	Line Tightness Test Date	09/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	32	Tank Installed Date	12/04/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	936	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	01/07/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<