

Facility Summary in Prairie County in the City of Terry

Location: 4 CORNERS
3 Ten Mile Rd
Terry, MT 59349 Prairie

Legacy ID:40-06798

Facility ID: 26798
Last Inspected On: 08/02/2021
Operating Permit Renewal Date: 08/03/2024

Owner Operator Contact: Chris Ueland;4-Corners Convenience LLC;Robert Waylon and Leann Lantis

4066352198;4066355814

Operator Contact: Leann Lantis

4066352198

Owner/Operator: Robert Waylon and Leann Lantis

Leann Lantis, UST Class A Operator

Leann Lantis, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
09	7	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5539	No	10/24/2014	Double-Walled	Double Walled	Yes
Currently in Use		10/29/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		05/31/2018	Incon/TS-550 EVO		Yes
10	7	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5540	No	10/24/2014	Double-Walled	Double Walled	Yes
Currently in Use		10/29/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000		05/31/2018	Incon/TS-550 EVO		Yes
11	7	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5541	No	10/24/2014	Double-Walled	Double Walled	Yes

Currently in Use	10/29/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000	05/31/2018	Incon/TS-550 EVO		Yes

Facility Summary in Prairie County in the City of Terry

Location: FARMERS UNION OIL CO TERRY
101 McDonald Ave
Terry, MT 59349 Prairie

Legacy ID:40-06797

Facility ID: 26797
Last Inspected On: 11/19/2019
Operating Permit Renewal Date: 03/14/2023

Owner Operator Contact: Cory Vorderbruggen;Farmers Union Oil Co
Circle;Farmers Union Oil Co Circle

4064853475;4064853475;4064853475

Operator Contact: Cory Vorderbruggen;Terry Wahl

4064853475

Owner/Operator: Farmers Union Oil Co Circle

Cory Vorderbruggen, UST Class A Operator
Dawnya Kirkpatrick, UST Class B Operator
Fritz Deines, UST Class B Global Operator
Terry Wahl, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	31	04/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
955	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/16/2016	Statistical Inventory Reconciliation	Deferred	No
1,000					No
07	31	04/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
956	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Gasoline		11/16/2016	Statistical Inventory Reconciliation	Deferred	No
1,000					No
08	31	04/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
957	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/16/2016	Statistical Inventory Reconciliation	Deferred	No
560					No

Facility Summary in Prairie County in the City of Terry

Location: MTD PETROLEUM SERVICE LLC
14 Ten Mile Rd
Terry, MT 59349 Prairie

Legacy ID:56-14149

Facility ID: 30785
Last Inspected On: 02/09/2021
Operating Permit Renewal Date: 02/24/2024

Owner Operator Contact: Cross Petroleum Services Glendive

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Cross Petroleum Services Glendive

Owner/Operator: Mark Underberg

Greg Cross, UST Class A Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator
Timothy Fife, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	16	05/05/2005	Concrete	Flexible Plastic	
4960	Yes			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000					No
S3	16	05/05/2005	Concrete	Flexible Plastic	
4961	Yes			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000					No
S4	16	05/05/2005	Concrete	Flexible Plastic	
4962	Yes			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000					No
S5	16	05/05/2005	Concrete	Flexible Plastic	
5039	Yes			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000					No
S1	16	05/05/2005	Concrete	Flexible Plastic	
5040	Yes			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000					No