

Facility Summary in Prairie County in the City of Terry

Location: 4 CORNERS
3 Ten Mile Rd
Terry, MT 59349 Prairie

System Facility ID:40-06798

Facility Code: 26798
Last Inspected On: 08/02/2021
Operating Permit Renewal Date: 08/03/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Robert Waylon and Leann Lantis4066355814

Operator Contact: Leann Lantis4066352198

Owner/Operator: Robert Waylon and Leann Lantis

Leann Lantis, UST Class A Operator
Leann Lantis, UST Class B Operator

Tank Code	09	Tank Age	10	Tank Installed Date	10/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5539	Spill Test Date	06/07/2021	Piping Installed Date	10/29/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/07/2021	Line Tightness Test Date	07/30/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/07/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	10	Tank Age	10	Tank Installed Date	10/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5540	Spill Test Date	06/07/2021	Piping Installed Date	10/29/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/07/2021	Line Tightness Test Date	07/30/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/07/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	11	Tank Age	10	Tank Installed Date	10/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	5541	Spill Test Date	06/07/2021	Piping Installed Date	10/29/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/07/2021	Line Tightness Test Date	07/30/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/07/2021			ATG Type	Incon/TS-550 EVO				

Facility Summary in Prairie County in the City of Terry

Location: FARMERS UNION OIL CO TERRY
101 McDonald Ave
Terry, MT 59349 Prairie

System Facility ID:40-06797

Facility Code: 26797
Last Inspected On: 11/21/2022
Operating Permit Renewal Date: 03/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Circle

Operator Contact: Dawnya Kirkpatrick 4069391559

Owner/Operator: Farmers Union Oil Co Circle

Dawnya Kirkpatrick, UST Class A Operator
Dawnya Kirkpatrick, UST Class B Operator
Fritz Deines, UST Class B Global Operator

Tank Code	06	Tank Age	34	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	955	Spill Test Date	11/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/21/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/21/2022			ATG Type					
Tank Code	07	Tank Age	34	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	956	Spill Test Date	11/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/21/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/21/2022			ATG Type					
Tank Code	08	Tank Age	34	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	957	Spill Test Date	11/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/21/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	560	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/21/2022			ATG Type					

Facility Summary in Prairie County in the City of Terry

Location: MTD PETROLEUM SERVICE LLC
14 Ten Mile Rd
Terry, MT 59349 Prairie

System Facility ID:56-14149

Facility Code: 30785
Last Inspected On: 09/26/2023
Operating Permit Renewal Date: 02/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Glendive;Mark Underberg

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife4066982967

Owner/Operator: Cross Petroleum Services Glendive

Owner/Operator: Mark Underberg

- Greg Cross, UST Class A Operator
- R J Serpe, UST Class A Operator
- R J Serpe, UST Class B Global Operator
- Ron Serpe, UST Class B Global Operator
- Timothy Fife, UST Class A Operator

Tank Code	S2	Tank Age	19	Tank Installed Date	05/05/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4960	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/26/2023	Line Tightness Test Date	02/23/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S3	Tank Age	19	Tank Installed Date	05/05/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4961	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/26/2023	Line Tightness Test Date	02/23/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	19	Tank Installed Date	05/05/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4962	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/26/2023	Line Tightness Test Date	02/23/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	19	Tank Installed Date	05/05/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5039	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/26/2023	Line Tightness Test Date	02/23/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S1	Tank Age	19	Tank Installed Date	05/05/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5040	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/26/2023	Line Tightness Test Date	02/23/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					