

Facility Summary in Prairie County in the City of Terry

Location: 4 CORNERS
3 Ten Mile Rd
Terry, MT 59349 Prairie

System Facility ID:40-06798

Facility Code: 26798
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 08/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Robert Waylon and Leann Lantis (406) 635-5814 lantis@midrivers.coms

Operator Contact: Leann Lantis (406) 635-2198 lantis@midrivers.com

Owner/Operator: Robert Waylon and Leann Lantis (406) 635-5814 lantis@midrivers.coms

Leann Lantis, UST Class A Operator
Leann Lantis, UST Class B Operator

lantis@midrivers.com
lantis@midrivers.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|--------------------------------|
| Tank Code | 09 | Tank Age | 12 | Tank Installed Date | 10/14/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5539 | Spill Test Date | 06/07/2021 | Piping Installed Date | 10/29/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 06/07/2021 | Line Tightness Test Date | 07/30/2021 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2021 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 10 | Tank Age | 12 | Tank Installed Date | 10/14/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5540 | Spill Test Date | 06/07/2021 | Piping Installed Date | 10/29/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 06/07/2021 | Line Tightness Test Date | 07/30/2021 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2021 | | | ATG Type | Incon/TS-550 EVO | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|---------------------------------|
| Tank Code | 11 | Tank Age | 12 | Tank Installed Date | 10/14/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve; High Level Alarm |
| Tag Number | 5541 | Spill Test Date | 06/07/2021 | Piping Installed Date | 10/29/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 06/07/2021 | Line Tightness Test Date | 07/30/2021 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2021 | | | ATG Type | Incon/TS-550 EVO | | | | |

Facility Summary in Prairie County in the City of Terry

Location: FARMERS UNION OIL CO TERRY
101 McDonald Ave
Terry, MT 59349 Prairie

System Facility ID:40-06797

Facility Code: 26797
Last Inspected On: 12/15/2025
Operating Permit Renewal Date: 03/14/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Circle

Operator Contact: Dawnya Kirkpatrick

(406) 939-1559

tfarmers@midrivers.com

Owner/Operator: Farmers Union Oil Co Circle

Dawnya Kirkpatrick, UST Class A Operator
Dawnya Kirkpatrick, UST Class B Operator
Fritz Deines, UST Class B Global Operator

tfarmers@midrivers.com
tfarmers@midrivers.com
frd92372@comcast.net

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 04/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 955 | Spill Test Date | 12/15/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 12/15/2025 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 1000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/15/2025 | | | ATG Type | | | | | |
| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 04/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 956 | Spill Test Date | 12/15/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 12/15/2025 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 1000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/15/2025 | | | ATG Type | | | | | |
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 04/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------|-----------------------|----------|
| Tag Number | 957 | Spill Test Date | 12/15/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 12/15/2025 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 560 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/15/2025 | | | ATG Type | | | | | |

Facility Summary in Prairie County in the City of Terry

Location: MTD PETROLEUM SERVICE LLC
14 Ten Mile Rd
Terry, MT 59349 Prairie

System Facility ID:56-14149

Facility Code: 30785
Last Inspected On: 09/26/2023
Operating Permit Renewal Date: 02/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Glendive;Mark Underberg

cross@midrivers.com;tfarmers@midrivers.com

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

(406) 698-2967

gcross@crosspetroleumservice.com;rlsrp@yahoo.com

Owner/Operator: Cross Petroleum Services Glendive

cross@midrivers.com

Owner/Operator: Mark Underberg

cross@midrivers.com

Greg Cross, UST Class A Operator

gcross@crosspetroleumservice.com

R J Serpe, UST Class A Operator

rlsrp@yahoo.com

R J Serpe, UST Class B Global Operator

rlsrp@yahoo.com

Ron Serpe, UST Class B Global Operator

rserpe@crossps.com

Timothy Fife, UST Class A Operator

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|------------------------------------|-----------------------|-----|
| Tank Code | S2 | Tank Age | 21 | Tank Installed Date | 05/05/2005 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 4960 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 08/25/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/26/2023 | Line Tightness Test Date | 02/23/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S3 | Tank Age | 21 | Tank Installed Date | 05/05/2005 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 4961 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 08/25/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/26/2023 | Line Tightness Test Date | 02/23/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|-----|
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S4 | Tank Age | 21 | Tank Installed Date | 05/05/2005 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 4962 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 08/25/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/26/2023 | Line Tightness Test Date | 02/23/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S5 | Tank Age | 21 | Tank Installed Date | 05/05/2005 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 5039 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 08/25/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/26/2023 | Line Tightness Test Date | 02/23/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S1 | Tank Age | 21 | Tank Installed Date | 05/05/2005 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 5040 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 08/25/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/26/2023 | Line Tightness Test Date | 02/23/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |