

Facility Summary in Ravalli County in the City of Corvallis

Location: THE MERC FRESH MARKET INC
1000 Main St
Corvallis, MT 59828-9749 Ravalli

System Facility ID:41-02402

Facility Code: 26862
Last Inspected On: 11/21/2024
Operating Permit Renewal Date: 02/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: The Merc Fresh Market Inc

mercfreshmarket@qwest.net

Operator Contact: Shelby LaForge

slaforge@mcleodpartnersinc.com

Owner/Operator: The Merc Fresh Market Inc

mercfreshmarket@qwest.net

Shelby LaForge, UST Class A Operator

slaforge@mcleodpartnersinc.com

Shelby LaForge, UST Class B Operator

slaforge@mcleodpartnersinc.com

Tank Code	04	Tank Age	31	Tank Installed Date	02/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	376	Spill Test Date	06/18/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/18/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/21/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/18/2024	Line Tightness Test Date	06/18/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	29	Tank Installed Date	08/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	377	Spill Test Date	06/18/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/18/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/18/2024	Line Tightness Test Date	06/18/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	29	Tank Installed Date	08/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	378	Spill Test Date	06/18/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/18/2024	Sump Tightness Test Date	06/15/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/18/2024	Line Tightness Test Date	06/18/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/18/2024			ATG Type	Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Darby

Location: DARBY LUMBER
3299 US Hwy 93
Darby, MT 59829 Ravalli

System Facility ID:41-00853

Facility Code: 26844
Last Inspected On: 11/02/2021
Operating Permit Renewal Date: 11/02/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: International Paper

tom.richardson@ipaper.com

Operator Contact: David Cosgriff

(406) 293-1011

david@aelibby.com

David Cosgriff, UST Class A Operator
David Cosgriff, UST Class B Global Operator

david@aelibby.com
david@aelibby.com

Tank Code	04	Tank Age	33	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	803	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/02/2021	Primary Tank Leak Detection	Inventory Reconciliation; Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	33	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	804	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/02/2021	Primary Tank Leak Detection	Manual Tank Gauging; Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Darby

Location: MR TS FOOD AND FUEL
101 S Main St
Darby, MT 59829 Ravalli

System Facility ID:41-00028

Facility Code: 26829
Last Inspected On: 02/15/2023
Operating Permit Renewal Date: 05/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Roller Darby Properties LLC

(509) 793-4164

jchana41@gmail.com

Operator Contact: Tohn Keagle

(509) 250-3093

keagletohn@gmail.com

Owner/Operator: Roller Darby Properties LLC

(509) 793-4164

jchana41@gmail.com

Jesse Goodwin, UST Class B Operator

Tohn Keagle, UST Class A Operator

Tohn Keagle, UST Class B Global Operator

keagletohn@gmail.com

keagletohn@gmail.com

Tank Code	06	Tank Age	30	Tank Installed Date	04/13/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3070	Spill Test Date	02/15/2023	Piping Installed Date	11/22/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/10/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/29/2023			ATG Type	Incon/TS-1000				
Tank Code	07	Tank Age	30	Tank Installed Date	04/13/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3071	Spill Test Date	02/15/2023	Piping Installed Date	11/22/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/10/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/29/2023			ATG Type	Incon/TS-1000				

Tank Code	08	Tank Age	9	Tank Installed Date	10/01/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5725	Spill Test Date	02/15/2023	Piping Installed Date	11/22/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/10/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/15/2023			ATG Type	Incon/TS-1001				
Tank Code	09	Tank Age	9	Tank Installed Date	10/01/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5726	Spill Test Date	02/15/2023	Piping Installed Date	11/22/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/10/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/15/2023			ATG Type	Incon/TS-1001				

Facility Summary in Ravalli County in the City of Darby

Location: OLES COUNTRY STORE 6
450 Hwy 93 S
Darby, MT 59829 Ravalli

System Facility ID:41-10908

Facility Code: 26979
Last Inspected On: 05/23/2024
Operating Permit Renewal Date: 05/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nathaniel Robbins;Town of Darby (406) 821-3753;(406) 821-3753 darbymontana@usa.net;darbymontana@usa.net

Operator Contact: Tammy Stuart;Town of Darby (406) 821-3753 darby-tammy@usa.net;darbymontana@usa.net

Owner/Operator: Nathaniel Robbins,Town of Darby (406) 821-3753 darbymontana@usa.net
Tammy Stuart, UST Class A Operator darbymontana@usa.net
Tammy Stuart, UST Class B Operator darbymontana@usa.net

Tank Code	06	Tank Age	30	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1441	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	30	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1442	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	08	Tank Age	30	Tank Installed Date	04/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1443	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Darby

Location: PEOPLES MARKET
801 N Main St
Darby, MT 59829 Ravalli

System Facility ID:56-14029

Facility Code: 30688
Last Inspected On: 08/08/2022
Operating Permit Renewal Date: 12/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Peoples Market (651) 261-3851

Operator Contact: Greg Bergren (406) 821-3612 peoplesharvest@gmail.com

Owner/Operator: Peoples Market (651) 261-3851

Greg Bergren, UST Class A Operator
Jesse Bergren, UST Class B Operator

peoplesharvest@gmail.com
peoplesharvest@gmail.com

Tank Code	S1	Tank Age	24	Tank Installed Date	08/20/2001	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4338	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	10/26/2021	Sump Tightness Test Date	11/20/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/26/2021	Line Tightness Test Date	10/26/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	24	Tank Installed Date	08/20/2001	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4339	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	10/26/2021	Sump Tightness Test Date	11/20/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/26/2021	Line Tightness Test Date	10/26/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	24	Tank Installed Date	08/20/2001	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	4340	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	10/26/2021	Sump Tightness Test Date	11/20/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/26/2021	Line Tightness Test Date	10/26/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	24	Tank Installed Date	08/20/2001	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4341	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	10/26/2021	Sump Tightness Test Date	11/20/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/26/2021	Line Tightness Test Date	10/26/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Florence

Location: DYNA MART LLP
5323 US Hwy 93
Florence, MT 59833-6830 Ravalli

System Facility ID:41-11356

Facility Code: 26989
Last Inspected On: 10/30/2024
Operating Permit Renewal Date: 10/30/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeremy and Betsy Milyard

milyardhomes@yahoo.com

Operator Contact: Shannon Tomicek;Timbre Case

(406) 949-3419

stomicek@yahoo.com;veritasconstruction1@gmail.com

Owner/Operator: Jeremy and Betsy Milyard

milyardhomes@yahoo.com

Shannon Tomicek, UST Class A Operator
Shannon Tomicek, UST Class B Operator
Timbre Case, UST Class A Operator
Timbre Case, UST Class B Operator

stomicek@yahoo.com
stomicek@yahoo.com
veritasconstruction1@gmail.com
veritasconstruction1@gmail.com

Tank Code	S1	Tank Age	45	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2331	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/20/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	45	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2332	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	10/20/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	45	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	

Tag Number	2333	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	10/20/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	45	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2334	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	10/20/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Florence

Location: TOWN PUMP INC FLORENCE
5495 US Hwy 93 N
Florence, MT 59833-6862 Ravalli

System Facility ID:41-12720

Facility Code: 27032
Last Inspected On: 05/04/2023
Operating Permit Renewal Date: 10/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Florence 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Florence 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com

Tank Code	01	Tank Age	33	Tank Installed Date	01/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2967	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	07/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	9000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	33	Tank Installed Date	01/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2968	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	07/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	3000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	33	Tank Installed Date	01/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2969	Spill Test Date	10/26/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	10/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	33	Tank Installed Date	01/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2970	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	07/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4192	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4193	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4194	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4195	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4196	Spill Test Date	10/18/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	07/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4197	Spill Test Date	07/26/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/28/2023	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/28/2023	Line Tightness Test Date	12/27/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Ravalli County in the City of Hamilton

Location: ANGLERS ROOST RV PARK AND CAMPGROUND
815 US Hwy 93 S
Hamilton, MT 59840-9746 Ravalli

System Facility ID:41-05798

Facility Code: 26904
Last Inspected On: 03/12/2021
Operating Permit Renewal Date: 03/12/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: RJ DEVELOPMENT GROUP, LLC

(406) 363-1268

RESMITH2011@RJ-DEVELOPMENT.NET

Operator Contact: John Cawley

anglersroost@cybernet1.com

John G Cawley, UST Class A Operator
John G Cawley, UST Class A Operator
John G Cawley, UST Class B Global Operator
John G Cawley, UST Class B Global Operator

anglersroost@cybernet1.com
anglersroost@cybernet1.com
anglersroost@cybernet1.com
anglersroost@cybernet1.com

Tank Code	01	Tank Age	41	Tank Installed Date	04/25/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3470	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/02/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	40	Tank Installed Date	04/04/1985	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3471	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/02/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Hamilton

Location: LONE PINE INC
504 US Hwy 93 S
Hamilton, MT 59840-8967 Ravalli

System Facility ID:56-13874

Facility Code: 30553
Last Inspected On: 09/28/2024
Operating Permit Renewal Date: 02/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: West Fork Holdings LLC

hawkes72@msn.com

Operator Contact: Brian Hawkes

(406) 363-6844

hawkes72@msn.com

Owner/Operator: West Fork Holdings LLC

hawkes72@msn.com

Brian R Hawkes, UST Class A Operator

hawkes72@msn.com

Brian R Hawkes, UST Class B Operator

hawkes72@msn.com

Tank Code	01	Tank Age	27	Tank Installed Date	07/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3513	Spill Test Date	09/22/2024	Piping Installed Date	10/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/22/2024	Line Tightness Test Date	05/14/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	27	Tank Installed Date	07/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3514	Spill Test Date	09/22/2024	Piping Installed Date	10/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/22/2024	Line Tightness Test Date	05/14/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	27	Tank Installed Date	07/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3515	Spill Test Date	09/22/2024	Piping Installed Date	10/20/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/22/2024	Line Tightness Test Date	05/16/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	8	Tank Installed Date	10/20/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5787	Spill Test Date	09/22/2024	Piping Installed Date	10/20/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	09/22/2024	Line Tightness Test Date	11/06/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	8	Tank Installed Date	10/20/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5788	Spill Test Date	09/22/2024	Piping Installed Date	10/20/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	09/22/2024	Line Tightness Test Date	05/17/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Ravalli County in the City of Hamilton

Location: MARCUS DALY MEMORIAL HOSPITAL
1200 Westwood Dr
Hamilton, MT 59840-2345 Ravalli

System Facility ID:41-12767

Facility Code: 27034
Last Inspected On: 01/31/2024
Operating Permit Renewal Date: 02/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Marcus Daly Memorial Hospital (406) 363-2211

Operator Contact: Brand McBride;Eric Etter (406) 375-4488;(406) 381-0873 brandmcbride@bitterroothealth.org

Owner/Operator: Marcus Daly Memorial Hospital (406) 363-2211

Brand McBride, UST Class A Operator
Brand McBride, UST Class B Operator
Daniel Healy, UST Class B Global Operator
Eric Etter, UST Class A Operator

brandmcbride@bitterroothealth.org
brandmcbride@bitterroothealth.org
daniel.healy@mdmh.org

Tank Code	S3	Tank Age	13	Tank Installed Date	08/01/2012	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5376	Spill Test Date		Piping Installed Date	06/08/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/31/2024	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	01/31/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Hamilton

Location: QUALITY USED CARS
400 N 1st St
Hamilton, MT 59840-2530 Ravalli

System Facility ID:41-13769

Facility Code: 27061
Last Inspected On: 09/27/2023
Operating Permit Renewal Date: 09/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Hull;Quality Investments (208) 756-2236

Operator Contact: Donald Harrison (406) 369-2291 donharrison403@gmail.com

Owner/Operator: David Hull

Owner/Operator: Quality Investments

Donald Harrison, UST Class A Operator
Donald Harrison, UST Class B Operator

donharrison403@gmail.com
donharrison403@gmail.com

Tank Code	01	Tank Age	28	Tank Installed Date	03/05/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3436	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	28	Tank Installed Date	03/05/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3437	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	28	Tank Installed Date	03/05/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	3438	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Hamilton

Location: RAVALLI COUNTY ROAD DEPT
244 Fairgrounds Rd
Hamilton, MT 59840 Ravalli

System Facility ID:41-06546

Facility Code: 26917
Last Inspected On: 02/04/2025
Operating Permit Renewal Date: 02/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ravalli County (406) 375-6500 gwiles@rc.mt.gov

Operator Contact: Jim Bryan dsenn@rc.mt.gov

Owner/Operator: Ravalli County (406) 375-6500 gwiles@rc.mt.gov

Jim Bryan, UST Class A Operator dsenn@rc.mt.gov
 Jim Bryan, UST Class A Operator dsenn@rc.mt.gov
 Jim Bryan, UST Class B Operator dsenn@rc.mt.gov
 Jim Bryan, UST Class B Operator dsenn@rc.mt.gov

Tank Code	05	Tank Age	34	Tank Installed Date	11/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1831	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/17/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1001				

Facility Summary in Ravalli County in the City of Hamilton

Location: RIVERSIDE CONOCO
1987 N 1st St
Hamilton, MT 59840-3116 Ravalli

System Facility ID:41-13588

Facility Code: 27056
Last Inspected On: 06/07/2023
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tsulkalu Holdings

sccghawkes@msn.com

Operator Contact: Stephen Hawkes

sccghawkes@msn.com

Owner/Operator: Tsulkalu Holdings

sccghawkes@msn.com

Stephen Hawkes, UST Class A Operator

sccghawkes@msn.com

Stephen Hawkes, UST Class B Operator

sccghawkes@msn.com

Tank Code	02	Tank Age	27	Tank Installed Date	06/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3262	Spill Test Date	04/25/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/07/2023	Line Tightness Test Date	08/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	27	Tank Installed Date	06/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3263	Spill Test Date	06/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/07/2023	Line Tightness Test Date	08/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	27	Tank Installed Date	06/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3264	Spill Test Date	04/25/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/07/2023	Line Tightness Test Date	08/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	20	Tank Installed Date	12/07/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5061	Spill Test Date	06/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/07/2023	Line Tightness Test Date	08/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	8	Tank Installed Date	04/01/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5745	Spill Test Date	06/07/2023	Piping Installed Date	05/19/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	06/07/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	---	--	--	--	--

Facility Summary in Ravalli County in the City of Hamilton

Location: TIMBOS BITTERROOT FUEL SERVICE INC
410 S 1st St
Hamilton, MT 59840-2809 Ravalli

System Facility ID:41-04846

Facility Code: 26891
Last Inspected On: 04/10/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Timbos Bitterroot Fuel Service Inc (406) 363-1933 Tim@StockdaleREG.com

Operator Contact: Tim McCrary;Timbos Bitterroot Fuel Service Inc (406) 363-1933 Timbo@TimbosFuelService.com;Tim@StockdaleREG.com

Owner/Operator: Timbos Bitterroot Fuel Service Inc (406) 363-1933 Tim@StockdaleREG.com
Tim McCrary, UST Class A Operator Tim@StockdaleREG.com
Tim McCrary, UST Class B Operator Timbo@TimbosFuelService.com

Tank Code	S4	Tank Age	32	Tank Installed Date	03/01/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	820	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/30/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/10/2024	Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7050	ATG Test Date		Line Tightness Test Date	04/10/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	32	Tank Installed Date	03/01/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	821	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/10/2024	Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2678	ATG Test Date		Line Tightness Test Date	06/08/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	32	Tank Installed Date	03/03/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	822	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes

Tank Status	Currently in Use	MLLD Test Date	05/30/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/10/2024	Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	04/10/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	32	Tank Installed Date	03/03/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	823	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/30/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/10/2024	Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	04/10/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Hamilton

Location: TOWN PUMP INC HAMILTON 1
1117 N 1st St
Hamilton, MT 59840-2103 Ravalli

System Facility ID:41-09670

Facility Code: 26952
Last Inspected On: 03/16/2023
Operating Permit Renewal Date: 10/18/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hamilton 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Hamilton 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com

Tank Code	01	Tank Age	38	Tank Installed Date	02/23/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2597	Spill Test Date	04/23/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/29/2021	Tank/Piping CP Test Date	07/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/16/2023	Line Tightness Test Date	01/05/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	38	Tank Installed Date	02/23/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2598	Spill Test Date	04/23/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/29/2021	Tank/Piping CP Test Date	07/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/16/2023	Line Tightness Test Date	01/05/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	38	Tank Installed Date	02/23/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2599	Spill Test Date	04/23/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/29/2021	Tank/Piping CP Test Date	07/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/16/2023	Line Tightness Test Date	01/05/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	38	Tank Installed Date	02/23/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2600	Spill Test Date	04/23/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/29/2021	Tank/Piping CP Test Date	07/26/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/16/2023	Line Tightness Test Date	01/05/2010	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4490	Spill Test Date	07/27/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/29/2021	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/16/2023	Line Tightness Test Date	01/05/2010	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4491	Spill Test Date	07/27/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	04/29/2021	Tank/Piping CP Test Date	01/06/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/16/2023	Line Tightness Test Date	01/05/2010	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Ravalli County in the City of Hamilton

Location: TOWN PUMP INC HAMILTON 2
932 S 1st St
Hamilton, MT 59840-3018 Ravalli

System Facility ID:41-00145

Facility Code: 26830
Last Inspected On: 03/16/2023
Operating Permit Renewal Date: 10/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hamilton 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Hamilton 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	0	Tank Installed Date		Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2593	Spill Test Date	07/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/03/2023	Line Tightness Test Date	08/18/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	41	Tank Installed Date	04/07/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2594	Spill Test Date	11/20/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/18/2023	Line Tightness Test Date	08/18/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	10/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	41	Tank Installed Date	04/07/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2595	Spill Test Date	07/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/03/2023	Line Tightness Test Date	08/18/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	41	Tank Installed Date	04/07/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2596	Spill Test Date	10/20/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/18/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/03/2023	Line Tightness Test Date	08/18/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Ravalli County in the City of Stevensville

Location: CJS DEN
324 Main St
Stevensville, MT 59870-2530 Ravalli

System Facility ID:41-11429

Facility Code: 26992
Last Inspected On: 07/25/2024
Operating Permit Renewal Date: 07/25/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cody Omlid (406) 239-9335

Operator Contact: Jon Vercruyssen (406) 239-9335 jonv.cjsden@gmail.com

Owner/Operator: Cody Omlid (406) 239-9335

Jon Vercruyssen, UST Class A Operator
Jon Vercruyssen, UST Class B Operator

jonv.cjsden@gmail.com
jonv.cjsden@gmail.com

Tank Code	05	Tank Age	35	Tank Installed Date	10/28/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2346	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	U.S. Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/25/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.1; Vapor Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	06	Tank Age	35	Tank Installed Date	10/28/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2347	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	U.S. Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/25/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.1; Vapor Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	35	Tank Installed Date	10/28/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	

Tag Number	2348	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	U.S. Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/25/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.1; Vapor Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing; Vapor Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Stevensville

Location: EASTSIDE COUNTRY STORE AND DELI
2693 Eastside Hwy
Stevensville, MT 59870-6954 Ravalli

System Facility ID:41-10286

Facility Code: 26962
Last Inspected On: 01/01/2024
Operating Permit Renewal Date: 02/10/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Eastside Country Store Inc

Operator Contact: Shane Cooke

maztech@aol.com

Shane Cooke, UST Class A Operator
Shane Cooke, UST Class B Operator

maztech@aol.com
maztech@aol.com

Tank Code	S3	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3614	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	02/07/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3615	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	02/07/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	02/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	3809	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	02/07/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	02/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Ravalli County in the City of Stevensville

Location: MOUNTAIN WEST CO OP STEVENSVILLE
115 Main St
Stevensville, MT 59870-2110 Ravalli

System Facility ID:41-10330

Facility Code: 26965
Last Inspected On: 05/19/2023
Operating Permit Renewal Date: 06/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Inver Grove Heights	(651) 355-6343	Kirsten.Tindall@chsinc.com
Operator Contact: Bob Westin;Dusty Smith;John Thompson;Michael Gourley;CHS Inc Inver Grove Heights;Will Dukart	(406) 370-3920;(651) 355-6343;(406) 541-6800;(406) 543-8383	chuck.thompson@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;Kirsten.Tindall@chsinc.com;will.dukart@chsinc.com

Owner/Operator: CHS Inc Inver Grove Heights	(651) 355-6343	Kirsten.Tindall@chsinc.com
Alicia Milner, UST Class B Operator		aliciahinton1982@icloud.com
Alicia Milner, UST Class B Operator		aliciahinton1982@icloud.com
Bob Westin, UST Class A Operator		
Bob Westin, UST Class B Global Operator		
Dusty Smith, UST Class A Operator		dusty.smith@chsinc.com
Dusty Smith, UST Class B Global Operator		dusty.smith@chsinc.com
John Thompson, UST Class A Operator		chuck.thompson@chsinc.com
John Thompson, UST Class A Operator		chuck.thompson@chsinc.com
John Thompson, UST Class B Global Operator		chuck.thompson@chsinc.com
John Thompson, UST Class B Global Operator		chuck.thompson@chsinc.com
John Thompson, UST Class B Operator		chuck.thompson@chsinc.com
John Thompson, UST Class B Operator		chuck.thompson@chsinc.com
Laura Tackes, UST Class B Operator		laura.tackes@chsinc.com
Laura Tackes, UST Class B Operator		laura.tackes@chsinc.com
Michael Gourley, UST Class A Operator		Kirsten.Tindall@chsinc.com
Will Dukart, UST Class A Operator		will.dukart@chsinc.com
Will Dukart, UST Class A Operator		will.dukart@chsinc.com
Will Dukart, UST Class B Global Operator		will.dukart@chsinc.com
Will Dukart, UST Class B Global Operator		will.dukart@chsinc.com

Tank Code	01	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	906	Spill Test Date	04/21/2023	Piping Installed Date	02/12/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/23/2023	Line Tightness Test Date	02/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	907	Spill Test Date	04/21/2023	Piping Installed Date	02/12/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/24/2023	Line Tightness Test Date	02/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	908	Spill Test Date	04/21/2023	Piping Installed Date	02/12/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/24/2023	Line Tightness Test Date	01/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	909	Spill Test Date	04/21/2023	Piping Installed Date	02/12/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	01/24/2023	Line Tightness Test Date	02/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	910	Spill Test Date	01/23/2023	Piping Installed Date	02/12/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/24/2023	Line Tightness Test Date	02/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	911	Spill Test Date	01/23/2023	Piping Installed Date	02/12/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/24/2023	Line Tightness Test Date	01/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	28	Tank Installed Date	12/29/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	912	Spill Test Date	01/23/2023	Piping Installed Date	02/12/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/07/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/24/2023	Line Tightness Test Date	01/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Ravalli County in the City of Stevensville

Location: OLES COUNTRY STORE 15
3912 US Hwy 93 N
Stevensville, MT 59870-6425 Ravalli

System Facility ID:41-13686

Facility Code: 27059
Last Inspected On: 09/19/2022
Operating Permit Renewal Date: 11/02/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ralls Inc (406) 777-1179

Operator Contact: Rob Ralls (406) 240-0797 stevioles@aol.com

Owner/Operator: Ralls Inc (406) 777-1179

Rob Ralls, UST Class A Operator
Rob Ralls, UST Class B Operator

stevioles@aol.com
stevioles@aol.com

Tank Code	01	Tank Age	29	Tank Installed Date	05/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3316	Spill Test Date	08/16/2022	Piping Installed Date	11/04/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/04/2022	Sump Tightness Test Date	09/19/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/04/2022	Line Tightness Test Date	06/28/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	02	Tank Age	29	Tank Installed Date	05/17/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3317	Spill Test Date	08/16/2022	Piping Installed Date	11/04/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/04/2022	Sump Tightness Test Date	09/19/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/04/2022	Line Tightness Test Date	06/28/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	03	Tank Age	29	Tank Installed Date	05/17/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	3318	Spill Test Date	08/16/2022	Piping Installed Date	09/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/04/2022	Sump Tightness Test Date	09/19/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	05/04/2022	Line Tightness Test Date	06/28/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Stevensville

Location: THREE MILE MERCANTILE
899 Three Mile Creek Rd
Stevensville, MT 59870-6126 Ravalli

System Facility ID:41-00170

Facility Code: 26831
Last Inspected On: 12/23/2023
Operating Permit Renewal Date: 12/24/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: B Wayne Enterprise LLC

atotalbs@yahoo.com

Operator Contact: Bill Smith;Russell Cleveland

(406) 777-5153

atotalbs@yahoo.com;racleveland@hotmail.com

Owner/Operator: B Wayne Enterprise LLC

atotalbs@yahoo.com

Bill Smith, UST Class A Operator

atotalbs@yahoo.com

Bill Smith, UST Class B Operator

atotalbs@yahoo.com

Russell Cleveland, UST Class A Operator

racleveland@hotmail.com

Russell Cleveland, UST Class B Global Operator

racleveland@hotmail.com

Russell Cleveland, UST Class B Operator

racleveland@hotmail.com

Tank Code	03	Tank Age	32	Tank Installed Date	03/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2115	Spill Test Date	12/23/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/23/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	08/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	04	Tank Age	32	Tank Installed Date	03/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2116	Spill Test Date	12/23/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/23/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	08/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	12/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	05	Tank Age	32	Tank Installed Date	03/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2117	Spill Test Date	12/23/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/23/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	08/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Sula

Location: CAMP SULA
7060 US Hwy 93 S
Sula, MT 59871-9600 Ravalli

System Facility ID:41-10411

Facility Code: 26969
Last Inspected On: 10/17/2022
Operating Permit Renewal Date: 10/29/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Camp Sula MT LLC (406) 821-3364 campsularesort@gmail.com

Operator Contact: Amie Wallace amiewallace@gmail.com

Owner/Operator: Camp Sula MT LLC (406) 821-3364 campsularesort@gmail.com

Amie Wallace, UST Class A Operator amiewallace@gmail.com
Amie Wallace, UST Class B Global Operator amiewallace@gmail.com

Tank Code	03	Tank Age	27	Tank Installed Date	03/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3485	Spill Test Date	03/14/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/17/2022	Sump Tightness Test Date	08/15/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/17/2022	Line Tightness Test Date	10/17/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/14/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	27	Tank Installed Date	03/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3486	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/17/2022	Sump Tightness Test Date	08/15/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/17/2022	Line Tightness Test Date	10/17/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/14/2023			ATG Type	Gilbarco/EMC Basic				

Tank Code	05	Tank Age	27	Tank Installed Date	03/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3487	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/17/2022	Sump Tightness Test Date	08/15/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/17/2022	Line Tightness Test Date	10/17/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/14/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Ravalli County in the City of Sula

Location: LOST TRAIL SKI AREA
 9485 US Hwy 93 S
 Sula, MT 59871-9611 Ravalli

System Facility ID:41-11692

Facility Code: 27002
Last Inspected On: 09/21/2023
Operating Permit Renewal Date: 10/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lost Trail Ski Area Inc (406) 360-9663 judy@losttrail.com

Operator Contact: Judy Grasser;Scott Grasser judy@losttrail.com;skilt@losttrail.com

Owner/Operator: Lost Trail Ski Area Inc (406) 360-9663 judy@losttrail.com
 Judy Grasser, UST Class A Operator judy@losttrail.com
 Judy Grasser, UST Class B Operator judy@losttrail.com
 Scott Grasser, UST Class A Operator skilt@losttrail.com
 Scott Grasser, UST Class B Operator skilt@losttrail.com

Tank Code	01	Tank Age	35	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	2351	Spill Test Date	09/21/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	09/21/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/21/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	33	Tank Installed Date	10/01/1992	Tank Material	Steel Clad	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	2352	Spill Test Date	09/21/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	09/21/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/21/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Victor

Location: BOWERS MARKET
2424 Meridian Rd
Victor, MT 59875 Ravalli

System Facility ID:00-32506

Facility Code: 32506
Last Inspected On: 02/02/2023
Operating Permit Renewal Date: 07/24/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bowers Market 3 LLC;Bridget Joyner;Bowers Market 3 LLC (406) 642-3421;(406) 642-3421;(406) 642-3421 bjoyner@mcleodpartnersinc.com;sbelford@mcleodpartnersinc.com;sbelford@mcleodpartnersinc.com

Operator Contact: Eric Belford;Bowers Market 3 LLC;Shelby LaForge (406) 691-0267;(406) 642-3421 eric.t.belford@gmail.com;sbelford@mcleodpartnersinc.com;slaforge@mcleodpartnersinc.com

Owner/Operator: Bowers Market 3 LLC (406) 642-3421 sbelford@mcleodpartnersinc.com

Owner/Operator: Bridget Joyner,Bowers Market 3 LLC (406) 642-3421 sbelford@mcleodpartnersinc.com

Eric Belford, UST Class A Operator
Eric Belford, UST Class B Operator
Shelby LaForge, UST Class A Operator
Shelby LaForge, UST Class B Operator

sbelford@mcleodpartnersinc.com
sbelford@mcleodpartnersinc.com
slaforge@mcleodpartnersinc.com
slaforge@mcleodpartnersinc.com

Tank Code	01	Tank Age	3	Tank Installed Date	11/13/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6124	Spill Test Date	11/02/2022	Piping Installed Date	11/13/2022	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	10/25/2022	Line Tightness Test Date	11/09/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/25/2022			ATG Type					
Tank Code	02	Tank Age	3	Tank Installed Date	11/13/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6125	Spill Test Date	11/02/2022	Piping Installed Date	11/13/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	5000	ATG Test Date	10/25/2022	Line Tightness Test Date	11/09/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/25/2022			ATG Type					

Tank Code	03	Tank Age	3	Tank Installed Date	11/13/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6126	Spill Test Date	11/02/2022	Piping Installed Date	11/13/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/25/2022	Line Tightness Test Date	11/09/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/25/2022			ATG Type					

Facility Summary in Ravalli County in the City of Victor

Location: TOWN PUMP OF WOODSIDE
915 US Hwy 93 N Suite 1
Victor, MT 59875 Ravalli

System Facility ID:60-15155

Facility Code: 30896
Last Inspected On: 12/13/2024
Operating Permit Renewal Date: 10/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Woodside 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Woodside 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	15	Tank Installed Date	09/09/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass	Overfill Types	Flapper Valve
Tag Number	5241	Spill Test Date	07/21/2022	Piping Installed Date	06/14/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/15/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	02/15/2023	Line Tightness Test Date	09/16/2010	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	15	Tank Installed Date	09/09/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass	Overfill Types	Flapper Valve
Tag Number	5242	Spill Test Date	12/06/2022	Piping Installed Date	06/14/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/15/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	02/15/2023	Line Tightness Test Date	09/16/2010	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	12/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	15	Tank Installed Date	09/09/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass	Overfill Types	Ball Float Valve
Tag Number	5243	Spill Test Date	07/21/2022	Piping Installed Date	06/14/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	02/15/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/15/2023	Line Tightness Test Date	09/16/2010	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	15	Tank Installed Date	09/09/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass	Overfill Types	Ball Float Valve
Tag Number	5244	Spill Test Date	07/21/2022	Piping Installed Date	06/14/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/15/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/15/2023	Line Tightness Test Date	09/16/2010	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	15	Tank Installed Date	09/09/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass	Overfill Types	Ball Float Valve
Tag Number	5245	Spill Test Date	07/21/2022	Piping Installed Date	06/14/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/15/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/15/2023	Line Tightness Test Date	09/16/2010	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	2	Tank Installed Date	05/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6155	Spill Test Date		Piping Installed Date	11/20/2023	Tank Construction		Piping Construction		AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	2	Tank Installed Date	11/20/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6156	Spill Test Date	04/02/2024	Piping Installed Date	11/20/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/24/2024	Line Tightness Test Date	07/19/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/02/2024			ATG Type					
Tank Code	08	Tank Age	2	Tank Installed Date	11/20/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6157	Spill Test Date	04/02/2024	Piping Installed Date	11/20/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	07/24/2024	Line Tightness Test Date	07/19/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/02/2024			ATG Type					
Tank Code	09	Tank Age	2	Tank Installed Date	11/20/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6158	Spill Test Date	04/02/2024	Piping Installed Date	11/20/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/24/2024	Line Tightness Test Date	07/19/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	04/02/2024			ATG Type					
Tank Code	10	Tank Age	2	Tank Installed Date	05/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6159	Spill Test Date	04/02/2024	Piping Installed Date	11/20/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	25000	ATG Test Date	07/24/2024	Line Tightness Test Date	07/19/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/02/2024			ATG Type					
Tank Code	11	Tank Age	2	Tank Installed Date	11/20/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6160	Spill Test Date	04/02/2024	Piping Installed Date	11/20/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/24/2024	Line Tightness Test Date	07/19/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/02/2024			ATG Type					
Tank Code	12	Tank Age	2	Tank Installed Date	11/20/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6161	Spill Test Date	04/02/2024	Piping Installed Date	11/20/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	07/24/2024	Line Tightness Test Date	07/19/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/02/2024			ATG Type					

Facility Summary in Ravalli County in the City of Victor

Location: VICTOR SINCLAIR
2381 US Hwy 93 N
Victor, MT 59875-9211 Ravalli

System Facility ID:41-13288

Facility Code: 27047
Last Inspected On: 04/04/2023
Operating Permit Renewal Date: 05/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MONTANA GAS N SHOP LLC (510) 714-5045 TONY@MONTANAGNS.COM

Operator Contact: Gurinderbir Muhar (408) 660-9884 gasnshop133@gmail.com

Owner/Operator: MONTANA GAS N SHOP LLC (510) 714-5045 TONY@MONTANAGNS.COM

Gurinderbir Muhar, UST Class A Operator
Gurinderbir Muhar, UST Class B Operator

gasnshop133@gmail.com
gasnshop133@gmail.com

Tank Code	01	Tank Age	32	Tank Installed Date	11/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3174	Spill Test Date	04/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/04/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/04/2023	Line Tightness Test Date	04/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	32	Tank Installed Date	11/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3175	Spill Test Date	04/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/04/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/04/2023	Line Tightness Test Date	04/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2023			ATG Type	Gilbarco/EMC Basic				

Tank Code	03	Tank Age	32	Tank Installed Date	11/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3176	Spill Test Date	07/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/04/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/04/2023	Line Tightness Test Date	04/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	32	Tank Installed Date	11/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3177	Spill Test Date	04/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/04/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/04/2023	Line Tightness Test Date	04/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2023			ATG Type	Gilbarco/EMC Basic				