

**Facility Summary in Ravalli County in the City of Corvallis**

**Location:** THE MERC FRESH MARKET INC  
1000 Main St  
Corvallis, MT 59828-9749 Ravalli

Legacy ID:41-02402

**Facility ID:** 26862  
**Last Inspected On:** 06/04/2019  
**Operating Permit Renewal Date:** 02/17/2022

**Owner Operator Contact:** The Merc Fresh Market Inc

**Operator Contact:** Jay Joyner

**Owner/Operator:** The Merc Fresh Market Inc

Jay Joyner, UST Class A Operator

Jay Joyner, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	27	02/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>376</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/20/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		08/20/2018	Veeder Root/TLS-300		No
05	25	08/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>377</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		08/20/2018	Veeder Root/TLS-300		No
06	25	08/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>378</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible

Diesel		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000	08/20/2018	Veeder Root/TLS-300		No

**Facility Summary in Ravalli County in the City of Darby**

**Location:** DARBY LUMBER  
3299 US Hwy 93  
Darby, MT 59829 Ravalli

Legacy ID:41-00853

**Facility ID:** 26844  
**Last Inspected On:** 11/02/2021  
**Operating Permit Renewal Date:** 01/09/2022

**Owner Operator Contact:** International Paper

**9014199000**

**Operator Contact:** David Cosgriff

**4062931011**

**Owner/Operator:** International Paper

David Cosgriff, UST Class A Operator  
David Cosgriff, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>803</b>	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		01/09/2019	Inventory Reconciliation; Tank Tightness Testing	MLLD Line Tightness Testing	No
3,000					No
05	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>804</b>	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		01/09/2019	Manual Tank Gauging; Tank Tightness Testing	MLLD Line Tightness Testing	No
1,000					No

**Facility Summary in Ravalli County in the City of Darby**

**Location:** MR TS FOOD AND FUEL  
101 S Main St  
Darby, MT 59829 Ravalli

Legacy ID:41-00028

**Facility ID:** 26829  
**Last Inspected On:** 04/16/2020  
**Operating Permit Renewal Date:** 05/16/2023

**Owner Operator Contact:** Jeryl George;J and G Properties LLC;Roller Darby Properties LLC

**4063635470;5097934164**

**Operator Contact:** Robert Flood

**4068211940**

**Owner/Operator:** Roller Darby Properties LLC

Raymond Flood, UST Class B Operator  
Robert Flood, UST Class A Operator  
Robert Flood, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	26	04/13/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3070</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Incon/TS-1000		Yes
07	26	04/13/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3071</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Incon/TS-1000		No
08	5	10/01/2016	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
<b>5725</b>	No	11/22/2016	Double-Walled	Double Walled	Yes
Currently in Use		11/22/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Incon/TS-1001		Yes
09	5	10/01/2016	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
<b>5726</b>	No	11/22/2016	Double-Walled	Double Walled	Yes
Currently in Use		11/22/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Incon/TS-1001		Yes

**Facility Summary in Ravalli County in the City of Darby**

**Location:** OLES COUNTRY STORE 6  
450 Hwy 93 S  
Darby, MT 59829 Ravalli

Legacy ID:41-10908

**Facility ID:** 26979  
**Last Inspected On:** 09/22/2021  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** Gary Louquet;JGL Distributing Inc

**4067287736**

**Operator Contact:** Franklin Tabish;Stanley Hendricksen

**4062395805**

**Owner/Operator:** Town of Darby

Franklin Tabish, UST Class A Operator  
Heather Stiles, UST Class B Operator  
Stanley Hendricksen, UST Class A Operator  
Stanley Hendricksen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
06	26	04/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1441</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	MLLD Line Tightness Testing	No
12,000					No
07	26	04/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1442	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	MLLD Line Tightness Testing	No
8,000					No
08	26	04/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1443	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	MLLD Line Tightness Testing	No
5,000					No

**Facility Summary in Ravalli County in the City of Darby**

**Location:** PEOPLES MARKET  
801 N Main St  
Darby, MT 59829 Ravalli

Legacy ID:56-14029

**Facility ID:** 30688  
**Last Inspected On:** 11/05/2019  
**Operating Permit Renewal Date:** 12/26/2022

**Owner Operator Contact:**

**Operator Contact:** Greg Bergren

**4068213612**

**Owner/Operator:** Peoples Market

Greg Bergren, UST Class A Operator  
Jesse Bergren, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	20	08/20/2001	Unknown	Flexible Plastic	High Level Alarm
<b>4338</b>	Yes	10/09/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000					No
S2	20	08/20/2001	Unknown	Flexible Plastic	High Level Alarm
<b>4339</b>	Yes	10/09/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000					No
S3	20	08/20/2001	Unknown	Flexible Plastic	High Level Alarm
<b>4340</b>	Yes	10/09/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000					No
S4	20	08/20/2001	Unknown	Flexible Plastic	High Level Alarm
<b>4341</b>	Yes	10/09/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No

5,000

No

**Facility Summary in Ravalli County in the City of Florence**

**Location:** DYNA MART LLP  
5323 US Hwy 93  
Florence, MT 59833-6830 Ravalli

Legacy ID:41-11356

**Facility ID:** 26989  
**Last Inspected On:** 04/26/2019  
**Operating Permit Renewal Date:** 05/20/2019

**Owner Operator Contact:** Jeremy and Betsy Milyard

**4065522257**

**Operator Contact:** Shannon Tomicek;Timbre Case

**4069493419**

**Owner/Operator:** Jeremy and Betsy Milyard

Shannon Tomicek, UST Class A Operator  
Shannon Tomicek, UST Class B Operator  
Timbre Case, UST Class A Operator  
Timbre Case, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	41	01/01/1980	Bare Steel	Fiberglass Reinforced Plastic	
<b>2331</b>	Yes			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
10,000		10/20/2010			No
S2	41	01/01/1980	Bare Steel	Fiberglass Reinforced Plastic	
<b>2332</b>	Yes			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
12,000		10/20/2010			No
S3	41	01/01/1980	Bare Steel	Fiberglass Reinforced Plastic	

<b>2333</b>	Yes			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
12,000		10/20/2010			No
S4	41	01/01/1980	Bare Steel	Fiberglass Reinforced Plastic	
<b>2334</b>	Yes			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
5,000		10/20/2010			No

**Facility Summary in Ravalli County in the City of Florence**

**Location:** TOWN PUMP INC FLORENCE  
5495 US Hwy 93 N  
Florence, MT 59833-6862 Ravalli

Legacy ID:41-12720

**Facility ID:** 27032  
**Last Inspected On:** 04/28/2021  
**Operating Permit Renewal Date:** 05/04/2024

**Owner Operator Contact:** Don Edmisten;Billings Holdings LLC

**4064976948**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Florence 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	29	01/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2967</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic



Gasoline		07/10/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	Yes
9,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
02	29	01/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2968</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/10/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
3,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
03	29	01/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2969</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/10/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
04	29	01/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2970</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/10/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
05	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4192</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
06	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4193</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
07	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4194</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
08	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4195</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
09	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4196</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No
10	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4197</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		12/27/2009	Gilbarco-Veeder Root/TLS-450		No

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** ANGLERS ROOST LLP  
815 US Hwy 93 S  
Hamilton, MT 59840-9746 Ravalli

Legacy ID:41-05798

**Facility ID:** 26904  
**Last Inspected On:** 03/12/2021  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** Anglers Roost LLP

<b>Operator Contact:</b> John Cawley	<b>4063631268</b>
--------------------------------------	-------------------

**Owner/Operator:** Anglers Roost LLP

John G Cawley, UST Class A Operator  
John G Cawley, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	04/25/1984	Bare Steel	Steel	Flapper Valve
<b>3470</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/05/2018	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No

10,000					No
02	36	04/04/1985	Bare Steel	Steel	Flapper Valve
<b>3471</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		04/05/2018	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
10,000					No

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** DAVISONS EXXON SERVICE  
410 S 1st St  
Hamilton, MT 59840-2809 Ravalli

Legacy ID:41-04846

**Facility ID:** 26891  
**Last Inspected On:** 08/03/2021  
**Operating Permit Renewal Date:** 08/06/2024

**Owner Operator Contact:** Bob Davison;Davisons Exxon Service;Davisons Exxon Service **4063631933**

**Operator Contact:** Jack Davison **4063636056**

**Owner/Operator:** Davisons Exxon Service

Jack Davison, UST Class A Operator

Jack Davison, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S4	28	03/01/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>820</b>	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		06/06/2018	Deferred	MLLD Line Tightness Testing	No
7,050		05/26/2018			No
S5	28	03/01/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>821</b>	Yes			None	Yes

Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		06/06/2018	Deferred	MLLD Line Tightness Testing	No
2,678		06/08/2015			No
S7	28	03/03/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>822</b>	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		06/06/2018	Deferred	MLLD Line Tightness Testing	No
5,000		05/26/2018			No
S8	28	03/03/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>823</b>	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		06/06/2018	Deferred	MLLD Line Tightness Testing	No
20,000		05/26/2018			No

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** LONE PINE INC  
504 US Hwy 93 S  
Hamilton, MT 59840-8967 Ravalli

Legacy ID:56-13874

**Facility ID:** 30553  
**Last Inspected On:** 06/04/2019  
**Operating Permit Renewal Date:** 02/17/2022

**Owner Operator Contact:** West Fork Holdings LLC

**4063750554**

**Operator Contact:** Brian Hawkes;Stephen Hawkes

**4063701612;4063750536**

**Owner/Operator:** West Fork Holdings LLC

Brian R Hawkes, UST Class A Operator  
Brian R Hawkes, UST Class B Operator  
Stephen Hawkes, UST Class A Operator  
Stephen Hawkes, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	23	07/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3513</b>	No	10/20/2017		Double Walled	Yes
Currently in Use		10/20/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	23	07/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3514</b>	No	10/20/2017		Double Walled	Yes
Currently in Use		10/20/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	23	07/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3515</b>	No	10/20/2017		Double Walled	Yes
Currently in Use		10/20/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	4	10/20/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
<b>5787</b>	No	10/20/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/20/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
05	4	10/20/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff

5788	No	10/20/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/20/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
12,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** MARCUS DALY MEMORIAL HOSPITAL  
1200 Westwood Dr  
Hamilton, MT 59840-2345 Ravalli

Legacy ID:41-12767

**Facility ID:** 27034  
**Last Inspected On:** 01/20/2021  
**Operating Permit Renewal Date:** 02/13/2024

**Owner Operator Contact:** Marcus Daly Memorial Hospital

**4063632211**

**Operator Contact:** Brand McBride;Eric Etter;Michael Heller

**4063754488**

**Owner/Operator:** Marcus Daly Memorial Hospital

- Brand McBride, UST Class A Operator
- Brand McBride, UST Class B Operator
- Daniel Healy, UST Class B Global Operator
- Eric Etter, UST Class A Operator
- Michael Heller, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	9	08/01/2012	Concrete	Flexible Plastic	
5376	Yes	03/24/2017		Double Walled	No
Currently in Use		06/08/2012	Continuous Interstitial Monitoring	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
2,000					No

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** QUALITY USED CARS  
 400 N 1st St  
 Hamilton, MT 59840-2530 Ravalli

Legacy ID:41-13769

**Facility ID:** 27061  
**Last Inspected On:** 12/05/2020  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** Quality Investments

**2087562236**

**Operator Contact:** Donald Harrison

**4063692291**

**Owner/Operator:** David Hull

**Owner/Operator:** Quality Investments

Donald Harrison, UST Class A Operator

Donald Harrison, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
01	24	03/05/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>3436</b>	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000					No
02	24	03/05/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>3437</b>	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
8,000					No
03	24	03/05/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>3438</b>	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	



-----  
 Diesel Automatic Tank Gauging 0.2 Continuous Interstitial Monitoring No  
 -----  
 4,000 No  
 -----

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** RAVALLI COUNTY ROAD DEPT  
 244 Fairgrounds Rd  
 Hamilton, MT 59840 Ravalli

Legacy ID:41-06546

**Facility ID:** 26917  
**Last Inspected On:** 04/08/2019  
**Operating Permit Renewal Date:** 08/05/2022

**Owner Operator Contact:** William Meisner;Ravalli County

**Operator Contact:** Jim Bryan

**Owner/Operator:** Ravalli County

Jim Bryan, UST Class A Operator  
 Jim Bryan, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	30	11/01/1991	Cathodically Protected Steel	Steel	Flapper Valve
1831	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		05/04/2016	Automatic Tank Gauging 0.2	Deferred	No
12,000			Incon/TS-1001		No

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** RIVERSIDE SINCLAIR  
 1987 N 1st St  
 Hamilton, MT 59840-3116 Ravalli

Legacy ID:41-13588

**Facility ID:** 27056  
**Last Inspected On:** 08/16/2020  
**Operating Permit Renewal Date:** 10/02/2023

**Owner Operator Contact:**

**Operator Contact:** Brian Hawkes;Stephen Hawkes

4063701612;4063750536

**Owner/Operator:** Riverside Sinclair LLC

Brian R Hawkes, UST Class A Operator  
 Brian R Hawkes, UST Class B Operator

Stephen Hawkes, UST Class A Operator

Stephen Hawkes, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	23	06/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3262</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		08/13/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	23	06/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3263</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		08/13/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	23	06/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3264</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000		08/13/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	16	12/07/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>5061</b>	No			Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		08/13/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	4	04/01/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5745</b>	No	05/01/2017	Double-Walled	Double Walled	Yes
Currently in Use		05/19/2017	Electronic Line Leak Detector	Not Listed	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** TOWN PUMP INC HAMILTON 1  
1117 N 1st St  
Hamilton, MT 59840-2103 Ravalli

Legacy ID: 41-09670

**Facility ID:** 26952  
**Last Inspected On:** 04/28/2021  
**Operating Permit Renewal Date:** 05/04/2024

**Owner Operator Contact:** Don Edmisten; Town Pump Inc Hamilton

**4064976948**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Hamilton 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	02/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2597</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/22/2016	Approved Remote Monitoring; Statistical Inventory Reconciliation	Approved Remote Monitoring; Statistical Inventory Reconciliation	No

12,000		01/05/2010	Gilbarco-Veeder Root/TLS-350		No
02	34	02/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2598</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/22/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		01/05/2010	Gilbarco-Veeder Root/TLS-350		No
03	34	02/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2599</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/22/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		01/05/2010	Gilbarco-Veeder Root/TLS-350		No
05	34	02/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2600</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/22/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000		01/05/2010	Gilbarco-Veeder Root/TLS-350		No
06	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4490</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		01/05/2010	Gilbarco-Veeder Root/TLS-350		No

07	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4491</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		01/06/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		01/05/2010	Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Ravalli County in the City of Hamilton**

**Location:** TOWN PUMP INC HAMILTON 2  
932 S 1st St  
Hamilton, MT 59840-3018 Ravalli

Legacy ID:41-00145

**Facility ID:** 26830  
**Last Inspected On:** 04/29/2021  
**Operating Permit Renewal Date:** 08/04/2024

**Owner Operator Contact:**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Hamilton 2 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	35	04/07/1986	Bare Steel	Steel	Flapper Valve
<b>2593</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/11/2018	Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000		12/13/2006	Gilbarco-Veeder Root/TLS-350		No
02	37	04/07/1984	Bare Steel	Steel	Flapper Valve

<b>2594</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/11/2018	Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000		12/13/2006	Gilbarco-Veeder Root/TLS-350		No
03	37	04/07/1984	Bare Steel	Steel	Flapper Valve
<b>2595</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/11/2018	Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000		12/14/2006	Gilbarco-Veeder Root/TLS-350		No
04	37	04/07/1984	Bare Steel	Steel	Flapper Valve
<b>2596</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/11/2018	Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000		12/14/2006	Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Ravalli County in the City of Stevensville**

**Location:** CJS DEN  
324 Main St  
Stevensville, MT 59870-2530 Ravalli

Legacy ID:41-11429

**Facility ID:** 26992  
**Last Inspected On:** 09/03/2021  
**Operating Permit Renewal Date:** 10/17/2021

**Owner Operator Contact:** Cody Omlid

**4067775605**

**Operator Contact:** Jon Vercruyssen

**4062399335**

**Owner/Operator:** Cody Omlid

Jon Vercruyssen, UST Class A Operator  
Jon Vercruyssen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	31	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic
<b>2346</b>	No		None	Yes
Temporarily Out of Use			U.S. Suction	
Gasoline	11/14/2018	Automatic Tank Gauging 0.1;Vapor Monitoring	MLLD Line Tightness Testing	No
6,000				No
06	31	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic
<b>2347</b>	No		None	Yes
Temporarily Out of Use			U.S. Suction	
Gasoline	11/14/2018	Automatic Tank Gauging 0.1;Vapor Monitoring	MLLD Line Tightness Testing	No
6,000				No
07	31	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic
<b>2348</b>	No		None	Yes
Temporarily Out of Use			U.S. Suction	
Gasoline	11/14/2018	Automatic Tank Gauging 0.1;Vapor Monitoring	MLLD Line Tightness Testing;Vapor Monitoring	No
2,000				No

**Facility Summary in Ravalli County in the City of Stevensville**

**Location:** EASTSIDE COUNTRY STORE and DELI  
2693 Eastside Hwy  
Stevensville, MT 59870-6954 Ravalli

Legacy ID:41-10286

**Facility ID:** 26962  
**Last Inspected On:** 08/24/2020  
**Operating Permit Renewal Date:** 09/25/2020

**Owner Operator Contact:** Eastside Country Store Inc

**4067775672**

**Operator Contact:** Clarence Rainforth;Julia Cooke

**4067775672**

**Owner/Operator:** Eastside Country Store Inc

Clarence Rainforth, UST Class A Operator

Clarence Rainforth, UST Class B Operator

Julia Cooke, UST Class A Operator  
 Julia Cooke, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
S3	23	12/01/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3614</b>	Yes	08/29/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
6,000					No
S4	23	12/01/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3615</b>	Yes	08/29/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
3,000					No
S5	23	12/01/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3809</b>	Yes	08/29/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
3,000					No

**Facility Summary in Ravalli County in the City of Stevensville**

**Location:** MOUNTAIN WEST CO OP STEVENSVILLE  
 115 Main St  
 Stevensville, MT 59870-2110 Ravalli

Legacy ID:41-10330

**Facility ID:** 26965  
**Last Inspected On:** 02/26/2020  
**Operating Permit Renewal Date:** 06/20/2023



Owner Operator Contact: Mark Lalum;Mountain West Cooperative

4065438383

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Will Dukart

4066651728;4067557427;4068808169

**Owner/Operator: CHS Inc Inver Grove Heights**

Alicia Milner, UST Class B Operator  
 Bob Westin, UST Class A Operator  
 Bob Westin, UST Class B Global Operator  
 Dusty Smith, UST Class A Operator  
 Dusty Smith, UST Class B Global Operator  
 John Thompson, UST Class A Operator  
 John Thompson, UST Class B Global Operator  
 John Thompson, UST Class B Operator  
 Laura Tackes, UST Class B Operator  
 Will Dukart, UST Class A Operator  
 Will Dukart, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	43	02/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>906</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		02/12/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		02/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	43	02/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>907</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		02/12/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

03	43	02/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>908</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		02/12/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	43	02/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>909</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		02/12/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	43	02/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>910</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		02/12/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		02/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	43	02/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>911</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		02/12/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		02/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	24	12/29/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>912</b>	No			Double Walled	Yes
Currently in Use		02/12/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	02/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Ravalli County in the City of Stevensville**

**Location:** OLES COUNTRY STORE 15  
3912 US Hwy 93 N  
Stevensville, MT 59870-6425 Ravalli

Legacy ID:41-13686

**Facility ID:** 27059  
**Last Inspected On:** 01/30/2020  
**Operating Permit Renewal Date:** 11/02/2022

**Owner Operator Contact:** Ralls Inc

**4067771179**

**Operator Contact:** Rob Ralls

**4062400797**

**Owner/Operator:** Ralls Inc

Rob Ralls, UST Class A Operator  
Rob Ralls, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	05/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3316</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		02/17/2017	Gilbarco-Veeder Root/TLS-300		No
02	25	05/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3317</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000		02/17/2017	Gilbarco-Veeder Root/TLS-300		No

03	25	05/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3318</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		09/01/2016	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
3,000		02/17/2017	Gilbarco-Veeder Root/TLS-300		No

**Facility Summary in Ravalli County in the City of Stevensville**

**Location:** THREE MILE MERCANTILE  
899 Three Mile Creek Rd  
Stevensville, MT 59870-6126 Ravalli

Legacy ID:41-00170

**Facility ID:** 26831  
**Last Inspected On:** 03/24/2021  
**Operating Permit Renewal Date:** 03/24/2024

**Owner Operator Contact:**

**Operator Contact:** Bill Smith;Russell Cleveland

**4063964151;4065442650**

**Owner/Operator:** B Wayne Enterprise LLC

- Bill Smith, UST Class A Operator
- Bill Smith, UST Class B Operator
- Russell Cleveland, UST Class A Operator
- Russell Cleveland, UST Class B Global Operator
- Russell Cleveland, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	28	03/01/1993	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
<b>2115</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/25/2018	Automatic Tank Gauging 0.2	Deferred	No
5,000			Gilbarco-Veeder Root/TLS-300		No

04	28	03/01/1993	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
<b>2116</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/25/2018	Automatic Tank Gauging 0.2	Deferred	No
5,000			Gilbarco-Veeder Root/TLS-300		No
05	28	03/01/1993	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
<b>2117</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/25/2018	Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco-Veeder Root/TLS-300		No

**Facility Summary in Ravalli County in the City of Sula**

**Location:** CAMP SULA  
7060 US Hwy 93 S  
Sula, MT 59871-9600 Ravalli

Legacy ID:41-10411

**Facility ID:** 26969  
**Last Inspected On:** 08/15/2019  
**Operating Permit Renewal Date:** 10/29/2022

**Owner Operator Contact:** Camp Sula LLC;John Kingsbury;Sula Store LLC **4063610338;4068211041;4068211041**

**Operator Contact:** John Kingsbury;Nancy Kingsbury;Rebecca Roberts;Scott Roberts **4063610338;4068211014;4068211041**

**Owner/Operator: Camp Sula LLC**

- John Kingsbury, UST Class A Operator
- John Kingsbury, UST Class B Global Operator
- Nancy Kingsbury, UST Class A Operator
- Nancy Kingsbury, UST Class B Global Operator
- Rebecca Roberts, UST Class A Operator
- Rebecca Roberts, UST Class B Operator
- Scott Roberts, UST Class A Operator
- Scott Roberts, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	03/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3485</b>	No	08/15/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco/EMC Basic		No
04	23	03/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3486</b>	No	08/15/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000			Gilbarco/EMC Basic		No
05	23	03/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3487</b>	No	08/15/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000			Gilbarco/EMC Basic		No

**Facility Summary in Ravalli County in the City of Sula**

**Location:** LOST TRAIL SKI AREA  
9485 US Hwy 93 S  
Sula, MT 59871-9611 Ravalli

Legacy ID:41-11692

**Facility ID:** 27002  
**Last Inspected On:** 09/22/2020  
**Operating Permit Renewal Date:** 10/03/2023

**Owner Operator Contact:** Lost Trail Ski Area Inc

**4068213742**

**Operator Contact:** Judy Grasser;Scott Grasser

**Owner/Operator:** Lost Trail Ski Area Inc

Judy Grasser, UST Class A Operator  
Judy Grasser, UST Class B Operator

Scott Grasser, UST Class A Operator  
 Scott Grasser, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	31	01/01/1990	Cathodically Protected Steel	No Piping	Flapper Valve
<b>2351</b>	No			None	Yes
Currently in Use			Not Required	Not Listed	Galvanic
Diesel		08/22/2017	Automatic Tank Gauging 0.2		No
8,000			Veeder Root/TLS-300		No
02	29	10/01/1992	Steel Clad	No Piping	Flapper Valve
<b>2352</b>	No			None	Yes
Currently in Use			Not Required	Not Listed	Non-corrodible
Diesel			Automatic Tank Gauging 0.2		No
8,000			Veeder Root/TLS-300		No

**Facility Summary in Ravalli County in the City of Victor**

**Location:** TOWN PUMP OF WOODSIDE  
 6 State Hwy 373  
 Victor, MT 59875 Ravalli

Legacy ID:60-15155

**Facility ID:** 30896  
**Last Inspected On:** 04/26/2021  
**Operating Permit Renewal Date:** 05/04/2024

**Owner Operator Contact:**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Woodside 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
 Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	11	09/09/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5241</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		06/14/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000		09/16/2010	Gilbarco-Veeder Root/TLS-350		Yes
02	11	09/09/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5242</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		06/14/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
10,000		09/16/2010	Gilbarco-Veeder Root/TLS-350		Yes
03	11	09/09/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5243</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		06/14/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		09/16/2010	Gilbarco-Veeder Root/TLS-350		Yes
04	11	09/09/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5244</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		06/14/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible



Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		09/16/2010	Gilbarco-Veeder Root/TLS-350		Yes
05	11	09/09/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
5245	No		Double-Walled	Double Walled	Yes
Currently in Use		06/14/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		09/16/2010	Gilbarco-Veeder Root/TLS-350		Yes

**Facility Summary in Ravalli County in the City of Victor**

**Location:** VICTOR SINCLAIR  
2381 US Hwy 93 N  
Victor, MT 59875-9211 Ravalli

Legacy ID:41-13288

**Facility ID:** 27047  
**Last Inspected On:** 12/30/2019  
**Operating Permit Renewal Date:** 05/06/2023

**Owner Operator Contact:**

<b>Operator Contact:</b> Shean Merwin;Teresa Clark;Troy Clark	<b>4063615473;4063692772</b>
---	------------------------------

**Owner/Operator:** GEQ Inc

- Barbara Oliver, UST Class B Global Operator
- Kevin Howe, UST Class B Operator
- Shean Merwin, UST Class A Operator
- Teresa Clark, UST Class A Operator
- Teresa Clark, UST Class B Operator
- Troy Clark, UST Class A Operator
- Troy Clark, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	28	11/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
----	----	------------	-------------------------------	-------------------------------	------------------

<b>3174</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		04/27/2018	Gilbarco/EMC Basic		No
02	28	11/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3175</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		04/17/2018	Gilbarco/EMC Basic		No
03	28	11/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3176</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		04/17/2018	Gilbarco/EMC Basic		No
04	28	11/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3177</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		04/17/2018	Gilbarco/EMC Basic		No