Location: HORIZON RESOURCES FAIRVIEW STORE 605 S Ellery Ave Fairview, MT 59221 Richland

System Facility ID:42-03363

Facility Code: 27175 Last Inspected On: 04/12/2023 Operating Permit Renewal Date: 07/24/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Horizon Resources

Operator Contact: Darcie Yadon

Owner/Operator: Horizon Resources

Darcie Yadon, UST Class A Operator

Darcie Yadon, UST Class B Operator

| Tank Code | 07 | Tank Age | 26 | Tank Installed Date | 12/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|----------------------------------|-----------------------------|--|----------------|---------------|
| Tag Number | 3722 | Spill Test Date | 12/14/2021 | Piping Installed Date | 01/24/2011 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/09/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 7800 | ATG Test Date | 11/22/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/12/2023 | | | ATG Type | Veeder Root/TLS- 450 | | | | |
| Tank Code | 08 | Tank Age | 26 | Tank Installed Date | 12/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3723 | Spill Test Date | 12/14/2021 | Piping Installed Date | 01/24/2011 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/09/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4200 | ATG Test Date | 11/22/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/12/2023 | | | ATG Type | Veeder Root/TLS- 450 | | | | |
| Tank Code | 09 | Tank Age | 26 | Tank Installed Date | 12/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |

Page [1] of [28]

| Tag Number | 3724 | Spill Test Date | 12/14/2021 | Piping Installed Date | 01/24/2011 | Tank Construction | | Piping Construction | Double Walled | AST | No |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|----------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/09/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5500 | ATG Test Date | 11/22/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/12/2023 | | | ATG Type | Veeder Root/TLS- 450 | | | | |
| Tank Code | 10 | Tank Age | 26 | Tank Installed Date | 12/01/1998 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3725 | Spill Test Date | 12/14/2021 | Piping Installed Date | 01/24/2011 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/09/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4500 | ATG Test Date | 11/22/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 04/12/2023 | | | АТG Туре | Veeder Root/TLS- 450 | | | | |
| Tank Code | 15 | Tank Age | 13 | Tank Installed Date | 01/02/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5274 | Spill Test Date | 12/14/2021 | Piping Installed Date | 01/24/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/22/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450 | | | | |
| Tank Code | 16 | Tank Age | 13 | Tank Installed Date | 01/02/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5275 | Spill Test Date | 12/14/2021 | Piping Installed Date | 01/24/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
|----------|--------|--------------------|------------|-----------------------------|--------------|--|-----------------------------|--|----------------|-----|
| Capacity | 10000 | ATG Test Date | 11/22/2022 | Line Tightness Test Date | | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/12/2023 | | ATG Type | Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450 | | | | |

Location: LOAF 'N JUG #714 516 S Ellery Ave Fairview, MT 59221 Richland

System Facility ID:42-03914

Facility Code: 27193 Last Inspected On: 07/20/2022 Operating Permit Renewal Date: 10/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| Owner Operat | tor Contact: Mini | i Mart Inc dba Loaf 'N | Jug Pueblo | | 5139641568 | | | | | | |
|--------------|-------------------|---|-------------------|-----------------------------|------------|----------------------------------|---|-----------------------------|--|----------------|--------------------------------------|
| Operat | tor Contact: The | odore Bezel;Mini Mar | t Inc dba Loaf 'N | I Jug Pueblo | 5139641568 | | | | | | |
| Owner/Ope | rator: Mini Ma | art Inc dba Loaf 'N | I Jug Pueblo | | | | | | | | |
| | Theodore B | Bezel, UST Class A Op Bezel, UST Class B Gl Bezel, UST Class B Op | obal Operator | | | | | | | | |
| Tank Code | 06 | Tank Age | 11 | Tank Installed Date | 03/01/2013 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5410 | Spill Test Date | 10/22/2020 | Piping Installed Date | 03/01/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/28/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 07/20/2022 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.1 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 10/22/2020 | | | АТС Туре | Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 11 | Tank Installed Date | 03/01/2013 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5411 | Spill Test Date | 10/22/2020 | Piping Installed Date | 03/01/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/28/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| Capacity | 10000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 07/20/2022 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.1 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
|-------------|------------------|--------------------|------------|-----------------------------|------------|----------------------------------|---|-----------------------------|--|----------------|--------------------------------------|
| | | Overfill Test Date | 10/22/2020 | | | АТG Туре | Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 11 | Tank Installed Date | 03/01/2013 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5412 | Spill Test Date | 10/22/2020 | Piping Installed Date | 03/01/2013 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | [| Sump Tightness Test Date | 08/28/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 07/20/2022 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.1 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 10/22/2020 | | | АТG Туре | Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC | | | | |

Location: NORTANA GRAIN CO Facility Code: 27067 100 1st Ave SW Last Inspected On: 10/26/2021 Lambert, MT 59243 Richland System Facility ID:42-00317 Operating Permit Renewal Date: 03/04/2025 Note: Inspection is due 90 days before the Operating Permit Renewal Date. Owner Operator Contact: Nortana Grain Co;Shane Keller 4064432580;4064784122 **Operator Contact:** Mike Arneson; Shane Keller 4064784122;4064893589 Owner/Operator: Nortana Grain Co **Owner/Operator:** Shane Keller Mike Arneson, UST Class A Operator Mike Arneson, UST Class B Operator Shane Keller, UST Class A Operator Shane Keller, UST Class B Operator S5 Tank Code Tank Installed Tank Age 15 03/06/2009 **Tank Material** Concrete **Piping Material** Flexible Plastic **Overfill Types** Date **Piping Installed** Tank Piping 5201 **Spill Test Date** 10/20/2008 **Double Walled** AST Yes Tag Number Construction Construction Date Catastrophic L.D Currently in Sump Tightness Mechanical Line MLLD Test Date 06/09/2021 **Piping Type** Tank Status Pressurized **CP Met Types** Test Date Type 3.0 Leak Detector Use Tank/Piping CP **Primary Tank Primary Pipe** MLLD Line Product Gasoline PLLD Test Date Vapor Recovery No Test Date Leak Detection Detection **Tightness Testing** Continuous Line Tightness Secondary Tank Secondary Pipe 21000 **ATG Test Date** 06/09/2021 Interstitial **Energy Act** No Capacity **Test Date** Leak Detection Detection Monitoring **Overfill Test Date** ATG Type S6 **Tank Code** Tank Installed Tank Age 15 03/06/2009 **Tank Material** Concrete **Piping Material** Flexible Plastic **Overfill Types** Date **Piping Installed** Tank Piping 5202 **Spill Test Date** 10/20/2008 **Double Walled** AST Yes **Tag Number** Construction Construction Date Catastrophic L.D Sump Tightness Mechanical Line Currently in **MLLD Test Date** 03/09/2022 **Piping Type Tank Status CP Met Types** Pressurized Test Date Type 3.0 Leak Detector Use Tank/Piping CP **Primary Tank Primary Pipe** MLLD Line Product Diesel **PLLD Test Date** Vapor Recovery No Leak Detection Test Date Detection **Tightness Testing** Continuous Line Tightness Secondary Tank Secondary Pipe 21000 06/09/2021 Capacity **ATG Test Date** Interstitial Energy Act No Leak Detection Test Date Detection Monitoring ATG Type **Overfill Test Date**

Report Created: 4/17/2024

| Tank Code | S7 | Tank Age | 15 | Tank Installed Date | 03/06/2009 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|----------------------------------|-----------------------------|--|----------------|-----|
| Гag Number | 5203 | Spill Test Date | | Piping Installed Date | 10/20/2008 | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Fank Status | Currently in Use | MLLD Test Date | 03/09/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 13000 | ATG Test Date | | Line Tightness Test Date | 06/09/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Fank Code | S8 | Tank Age | 15 | Tank Installed Date | 03/06/2009 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
| Гаg Number | 5204 | Spill Test Date | | Piping Installed Date | 10/20/2008 | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Fank Status | Currently in Use | MLLD Test Date | 03/09/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | | Line Tightness Test Date | 06/09/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | [|
| Fank Code | S9 | Tank Age | 15 | Tank Installed Date | 03/06/2009 | Tank Material | Concrete | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 5205 | Spill Test Date | | Piping Installed Date | 10/20/2008 | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | 03/09/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 21000 | ATG Test Date | | Line Tightness Test Date | 06/09/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | [|

Location: VALLEY FUEL SUPPLY Facility Code: 27187 MT Hwy 16 Last Inspected On: 09/26/2023 Savage, MT 59262 Richland System Facility ID:42-03815 Operating Permit Renewal Date: 03/14/2027 Note: Inspection is due 90 days before the Operating Permit Renewal Date. **Owner Operator Contact:** Gregory Cross 4066982967 Operator Contact: Gregory Cross:R J Serpe; Timothy Fife 4066982967 **Owner/Operator:** Greg Cross Greg Cross, UST Class A Operator R J Serpe, UST Class A Operator R J Serpe, UST Class B Global Operator Ron Serpe, UST Class B Global Operator Timothy Fife, UST Class A Operator Tank Code 03 **Tank Installed** Tank Age 26 08/25/1998 Tank Material Steel Clad **Piping Material** Flexible Plastic **Overfill Types** Flapper Valve Date **Piping Installed** Tank Piping **Tag Number** 780 **Spill Test Date** 02/01/2023 02/01/2023 Double-Walled **Double Walled** AST No Date Construction Construction Sump Tightness Currently in Catastrophic L.D Electronic Line **Piping Type Tank Status** MLLD Test Date 02/01/2023 Pressurized **CP Met Types** Non-corrodible Test Date Leak Detector Use Type 3.0 Continuous Tank/Piping CP Primary Tank Automatic Tank **Primary Pipe** Product Gasoline PLLD Test Date 08/09/2022 11/18/2008 No Interstitial Vapor Recovery Gauging 0.2 Test Date Leak Detection Detection Monitoring Line Tightness Secondary Tank Secondary Pipe Capacity 8000 **ATG Test Date** 09/26/2023 02/01/2023 **ELLD 0.2 Energy Act** No Test Date Leak Detection Detection Overfill Test Date 02/01/2023 ATG Type Other/ 04 Tank Code Tank Installed 26 08/01/1998 Tank Age **Tank Material** Steel Clad **Piping Material** Flexible Plastic **Overfill Types** Flapper Valve Date **Piping Installed** Tank Piping Tag Number 781 Spill Test Date 02/01/2023 02/01/2023 Double-Walled **Double Walled** AST No Construction Construction Date Currently in Sump Tightness Catastrophic L.D Electronic Line **MLLD Test Date** 02/01/2023 **Tank Status** Piping Type Pressurized **CP Met Types** Non-corrodible Use Test Date Type 3.0 Leak Detector Continuous Tank/Piping CP **Primary Tank** Automatic Tank **Primary Pipe** 11/18/2008 Gasoline PLLD Test Date 08/09/2022 Product Interstitial Vapor Recovery No Leak Detection Test Date Gauging 0.2 Detection Monitoring Secondary Pipe Line Tightness Secondary Tank 09/26/2023 4000 **ATG Test Date** 02/01/2023 **ELLD 0.2** Capacity Energy Act No Test Date Leak Detection Detection Overfill Test Date 02/01/2023 ATG Type Other/

| Tank Code | 05 | Tank Age | 26 | Tank Installed Date | 08/01/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|----------------------------------|-----------------------------|--|----------------|----------------|
| Tag Number | 782 | Spill Test Date | 02/01/2023 | Piping Installed Date | 02/01/2023 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 02/01/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | 11/18/2008 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 3000 | ATG Test Date | 09/26/2023 | Line Tightness Test Date | 02/01/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 02/01/2023 | | | ATG Type | Other/ | | | | |

Location: LOAF 'N JUG #712 706 S Central Ave Sidney, MT 59270-4939 Richland

System Facility ID:42-05084

Facility Code: 27233 Last Inspected On: 07/20/2022 Operating Permit Renewal Date: 10/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| Owner Operate | or Contact: Mini | i Mart Inc dba Loaf 'N | I Jug Pueblo | | 5139641568 | | | | | | |
|---------------|---------------------|--|-----------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|----------------------|
| Operate | | n Sumowski;Randal I Loaf 'N Jug Pueblo | Liebnow;Theodor | e Bezel;Mini Mart Inc | 5139641568 | | | | | | |
| Owner/Oper | ator: Mini Ma | art Inc dba Loaf 'I | N Jug Pueblo | | | | | | | | |
| | Carl Watkin | s, UST Class B Oper | ator | | | | | | | | |
| | Eileen Cam | pbell, UST Class B C | Operator | | | | | | | | |
| | Hiede Richa | ardson, UST Class B | Global Operator | | | | | | | | |
| | John Sumo | wski, UST Class A O | perator | | | | | | | | |
| | | onow, UST Class A C | | | | | | | | | |
| | | onow, UST Class B G | | | | | | | | | |
| | | er, UST Class B Ope | | | | | | | | | |
| | | er, UST Class B Glol | • | | | | | | | | |
| | | d, UST Class B Ope | | | | | | | | | |
| | | ezel, UST Class A O | • | | | | | | | | |
| | | ezel, UST Class B G ezel, UST Class B O | • | | | | | | | | |
| | | terman, UST Class B C | | | | | | | | | |
| | 2 | , UST Class B Globa | • | | | | | | | | |
| Tank Code | 01 | Tank Age | 48 | Tank Installed Date | 04/24/1976 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4586 | Spill Test Date | 10/21/2020 | Piping Installed Date | 12/22/2010 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/28/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 10/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 07/20/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | Overfill Test Date | 10/21/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|----------------------|
| Tank Code | 02 | Tank Age | 48 | Tank Installed Date | 04/24/1976 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4587 | Spill Test Date | 01/04/2023 | Piping Installed Date | 12/22/2010 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/28/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 10/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 07/20/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/21/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 48 | Tank Installed Date | 04/24/1976 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4588 | Spill Test Date | 10/21/2020 | Piping Installed Date | 12/22/2010 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/28/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 07/20/2022 | Tank/Piping CP Test Date | 10/21/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 07/20/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/21/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | | | |

| | INC 320 | WER YELLOWSTONE 0 W Holly St ney, MT 59270 Rich | | RIC ASSOCIATION | DN Facility Code: 27062 Last Inspected On: 04/14/2021 System Facility ID:42-00001 Operating Permit Renewal Date: 09/29/2024 Note: Inspection is due 90 days before the Operating Permit Renewal Date. | | | | | | | |
|--------------|---|---|-------------------|-----------------------------|---|----------------------------------|-----------------------------------|-----------------------------|----------------------------------|----------------|----------------|--|
| Owner Operat | or Contact: Low | er Yellowstone Rural | Electric Associat | tion Inc | 4064821602 | | | | | | | |
| Operat | or Contact: Bod | lrey Kindopp;Justin Ki | ng | | 4064881602 | | | | | | | |
| Owner/Oper | ator: Lower | Yellowstone Rura | I Electric Ass | ociation Inc | | | | | | | | |
| | Justin King, Justin King, Mike Eberli | dopp, UST Class A Op UST Class A Operato UST Class B Global ng, UST Class B Glob | or Operator | | | | | | | | | |
| Гank Code | 05 | Tank Age | 31 | Tank Installed Date | 10/01/1993 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve | |
| ag Number | 1558 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No | |
| ank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No | |
| apacity | 8000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No | |
| | | Overfill Test Date | | | | АТС Туре | | | | | | |
| ank Code | 06 | Tank Age | 31 | Tank Installed Date | 10/01/1993 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve | |
| ag Number | 1559 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No | |
| ank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No | |
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No | |
| | | Overfill Test Date | | | | ATG Type | | | | | | |

Location: METZ FUEL and SERVICE 625 S Central Ave Sidney, MT 59270-4936 Richland

System Facility ID:42-03224

Facility Code: 27172Last Inspected On: 09/25/2021Operating Permit Renewal Date: 09/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Metz Fuel Service Inc

Operator Contact: Jim Metz

4064801872

Owner/Operator: Metz Fuel Service Inc

Jim Metz, UST Class A Operator

Jim Metz, UST Class B Global Operator

| Tank Code | 10 | Tank Age | 33 | Tank Installed Date | 07/11/1991 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|-----------------------------------|-----------------------------|----------------------------------|----------------|----------------|
| Tag Number | 2110 | Spill Test Date | 12/15/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/25/2021 | | | ATG Type | | | | | |
| Tank Code | 11 | Tank Age | 33 | Tank Installed Date | 07/11/1991 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2111 | Spill Test Date | 12/15/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/25/2021 | | [| ATG Type | | | [| | [|
| Tank Code | 12 | Tank Age | 33 | Tank Installed Date | 07/11/1991 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2112 | Spill Test Date | 12/15/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| Tank Status | Currently in Use | MLLD Test Date | 03/11/2022 | Sump Tightness Test Date | 08/27/2016 | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mecha nical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|---|-----------------------------|--|----------------|----------------|
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 03/11/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/25/2021 | | | ATG Type | | | | | |
| Tank Code | 13 | Tank Age | 33 | Tank Installed Date | 07/11/1991 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2113 | Spill Test Date | 12/15/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/11/2022 | Sump Tightness Test Date | 08/27/2016 | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring;Mecha nical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 03/11/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/15/2021 | | | ATG Type | | | | | |

Location: MILLERS CORNER 2201 W Holly St Sidney, MT 59270 Richland

System Facility ID:56-14071

Facility Code: 30723Last Inspected On: 02/01/2023Operating Permit Renewal Date: 04/22/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Millers Corner LLC

Operator Contact: Gregory Miller; Nitin Patel

4062276755;4064334041

Owner/Operator: Millers Corner LLC

Gregory Miller, UST Class A Operator Gregory Miller, UST Class B Global Operator Nitin Patel, UST Class A Operator Nitin Patel, UST Class B Operator

| Tank Code | 01 | Tank Age | 21 | Tank Installed Date | 02/06/2003 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|----------------------------------|-----------------------------|--|----------------|---------------|
| Tag Number | 4797 | Spill Test Date | 06/09/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | [| Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 10/24/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/24/2022 | Line Tightness Test Date | 10/24/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/09/2021 | | | ATG Type | Incon/TS-550 | | | | [|
| Tank Code | 02 | Tank Age | 21 | Tank Installed Date | 02/06/2003 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4798 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | [| Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 10/24/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/24/2022 | Line Tightness Test Date | 10/24/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/09/2021 | | | ATG Type | Incon/TS-550 | | | | |

| Tank Code | 03 | Tank Age | 21 | Tank Installed Date | 02/06/2003 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
|-------------|------------------|---------------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|---------------|
| Tag Number | 4799 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 10/24/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 10/24/2022 | Line Tightness Test Date | 10/24/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/09/2021 | | | ATG Type | Incon/TS-550 | | | | |
| Tank Code | 04 | Tank Age | 12 | Tank Installed Date | 08/01/2012 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5387 | Spill Test Date | 08/30/2021 | Piping Installed Date | 08/16/2012 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/09/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 10/24/2022 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 10/24/2022 | Line Tightness Test Date | 10/24/2022 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 06/09/2021 | | | ATG Type | Incon/TS-550 | | | | |

Location: SIDNEY AIRPORT SERVICE 355 Airport Rd Sidney, MT 59270-0355 Richland

System Facility ID:42-04444

Facility Code: 27214 Last Inspected On: 12/14/2021 Operating Permit Renewal Date: 02/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sidney Airport Service

Operator Contact:

Owner/Operator: Sidney Airport Service

| Tank Code | 03 | Tank Age | 25 | Tank Installed Date | 04/01/1999 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|-----------------------------------|-----------------------------|----------------------------------|----------------|----------------|
| Tag Number | 3969 | Spill Test Date | 12/14/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Aviation Gas | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/14/2021 | | | ATG Type | [| | [| | |

Location: SIDNEY CARDTROL 901 3rd St NE Sidney, MT 59270 Richland

System Facility ID:42-02184

Facility Code: 27135 Last Inspected On: 07/20/2022 Operating Permit Renewal Date: 10/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Glendive

 Operator Contact:
 Gregory Cross;Larry Garman;R J Serpe;Timothy Fife
 4064334376;4066982967

Owner/Operator: Cross Petroleum Services Glendive

Greg Cross, UST Class A Operator Larry Garman, UST Class A Operator Larry Garman, UST Class B Global Operator R J Serpe, UST Class A Operator R J Serpe, UST Class B Global Operator Timothy Fife, UST Class A Operator

| Tank Code | 01 | Tank Age | 42 | Tank Installed Date | 04/17/1982 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|------------------|--------------------|------------|-----------------------------|------------|----------------------------------|----------------------------------|-----------------------------|----------------------------------|----------------|----------------------|
| Tag Number | 776 | Spill Test Date | 10/07/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/13/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 10/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/07/2021 | | | ATG Type | Incon/TS-1001 | | | | [|
| Fank Code | 02 | Tank Age | 42 | Tank Installed Date | 04/17/1982 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 777 | Spill Test Date | 03/30/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/13/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 10/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/07/2021 | | | ATG Type | Incon/TS-1001 | | | | |

| Tank Code | 03 | Tank Age | 42 | Tank Installed Date | 04/17/1982 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|------------------|--------------------|------------|-----------------------------|------------|----------------------------------|----------------------------------|-----------------------------|----------------------------------|----------------|----------------------|
| Tag Number | 778 | Spill Test Date | 10/07/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/13/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 10/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/07/2021 | | | ATG Type | Incon/TS-1001 | | | | |
| Tank Code | 04 | Tank Age | 42 | Tank Installed Date | 04/17/1982 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 779 | Spill Test Date | 10/07/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/13/2022 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | 07/20/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/20/2022 | Line Tightness Test Date | 10/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/07/2021 | | | ATG Type | Incon/TS-1001 | | | | |

Location: SIDNEY HEALTH CENTER 216 14th Ave SW Sidney, MT 59270-3519 Richland

System Facility ID:42-06159

Facility Code: 27255 Last Inspected On: 04/14/2021 Operating Permit Renewal Date: 09/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sidney Health Center Inc

4064822120

Operator Contact: Mark Delaney

Owner/Operator: Sidney Health Center Inc

Mark Delaney, UST Class A Operator Mark Delaney, UST Class B Operator Robert Jes, UST Class B Operator

| Tank Code | 02 | Tank Age | 27 | Tank Installed Date | 09/01/1997 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
|-------------|---------------------|--------------------|----|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|----------------|
| Tag Number | 700 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/13/2021 | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/19/2012 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | 03/18/2009 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Location: SUPERPUMPER 23 902 S Central Ave Sidney, MT 59270-5216 Richland

System Facility ID:42-09718

Facility Code: 27348 Last Inspected On: 10/04/2021 Operating Permit Renewal Date: 12/26/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| Owner Opera | tor Contact: Par | kland USA Corporatio | n | | 7018521194 | | | | | | |
|------------------------|-------------------|--|----------------|--|-----------------|--|---|---|---|--------------------------------|----------------------|
| Opera | tor Contact: Kris | stopher Wolla;Nancy C | Coen;Shane Far | stad;Steven Mack | 5702020945;7018 | 3520061;7204212140 | | | | | |
| Owner/Ope | erator: Parkla | nd USA Corporation | on | | | | | | | | |
| | Al Erickson | , UST Class B Operat | or | | | | | | | | |
| | Greg Schin | netz, UST Class B Glo | bal Operator | | | | | | | | |
| | Jessica Sh | affer, UST Class B Op | perator | | | | | | | | |
| | Kristopher | Wolla, UST Class A O | perator | | | | | | | | |
| | • | sky, UST Class B Ope | | | | | | | | | |
| | - | n, UST Class A Opera | | | | | | | | | |
| | - | n, UST Class B Opera | | | | | | | | | |
| | - | er, UST Class B Oper | | | | | | | | | |
| | | stad, UST Class A Ope | | | | | | | | | |
| | | stad, UST Class B Glo ck, UST Class A Opera | • | | | | | | | | |
| | | ck, UST Class A Open | | | | | | | | | |
| | | ey, UST Class B Oper | | | | | | | | | |
| Tank Code | 06 | | | Tank Installed | | | Fiberglass | | | o (111 T | |
| | | Tank Age | 9 | Date | 11/16/2015 | Tank Material | Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Positive Shutoff |
| Tag Number | 5595 | Spill Test Date | 07/09/2019 | Piping Installed Date | 11/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| | Currently in | | | Sump Tightness | | | | | | | |
| Tank Status | Use | MLLD Test Date | | Test Date | 07/09/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Tank Status Product | | MLLD Test Date | | | 07/09/2019 | | | Piping Type Primary Pipe Detection | Pressurized Continuous Interstitial Monitoring | CP Met Types Vapor Recovery | |
| | Use | | | Test Date Tank/Piping CP | 07/09/2019 | Type 3.0 Primary Tank | Leak Detector Continuous Interstitial | Primary Pipe | Continuous Interstitial | | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 07/09/2019 | Test Date Tank/Piping CP Test Date Line Tightness | 07/09/2019 | Type 3.0 Primary Tank Leak Detection Secondary Tank | Leak Detector Continuous Interstitial Monitoring Automatic Tank | Primary Pipe Detection Secondary Pipe | Continuous Interstitial Monitoring | Vapor Recovery | Non-corrodible No |

| Tag Number | 5596 | Spill Test Date | 07/09/2019 | Piping Installed Date | 11/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/09/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 07/09/2019 | | | АТG Туре | Incon/TS-550 EVO | | | | |
| Tank Code | 08 | Tank Age | 9 | Tank Installed Date | 11/16/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Positive Shutoff |
| Tag Number | 5597 | Spill Test Date | 07/09/2019 | Piping Installed Date | 11/16/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/09/2019 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | | Yes |
| | | Overfill Test Date | 07/09/2019 | | | ATG Type | Incon/TS-550 EVO | | | | |

| | 112 | ELEY OIL INC BULK 3 10th Ave SE ney, MT 59270-6393 | | | System Facility I | D:42-00183 O | Last | Facility Code: 27064 Inspected On: 10/26/2 Renewal Date: 02/18/2 | | | |
|--------------|---------------------|--|-------|-----------------------------|-------------------|----------------------------------|-----------------|--|--|----------------|-----|
| | | | | | | Note | Inspection is d | ue 90 days before the | Operating Permit R | enewal Date. | |
| Owner Operat | tor Contact: Nor | tana Grain Co | | | 4064432580 | | | | | | |
| Operat | tor Contact: Joh | n Sweley;Mike Arnes | on | | 4064822508;406 | 64893589 | | | | | |
| Owner/Ope | rator: Nortana | a Grain Co | | | | | | | | | |
| - | John Swele | y, UST Class A Oper | ator | | | | | | | | |
| | | ey, UST Class B Oper | | | | | | | | | |
| | Mike Arnes | on, UST Class A Ope | rator | | | | | | | | |
| | Mike Arnes | on, UST Class B Ope | rator | | | | | | | | |
| Tank Code | S4 | Tank Age | 26 | Tank Installed Date | 06/16/1998 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | |
| ſag Number | 2076 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| ank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2021 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 17000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | S5 | Tank Age | 26 | Tank Installed Date | 06/16/1998 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | |
| ag Number | 2077 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| ank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2021 | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 17000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Location: TOWN PUMP OF SIDNEY #3 12280 Hwy 200 Unit 1 Sidney, MT 59270 Richland

System Facility ID:60-15241

Facility Code: 30958 Last Inspected On: 02/07/2024 Operating Permit Renewal Date: 01/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sidney 3 Town Pump LLC

4064976700

Operator Contact: Trent Biggers

Owner/Operator: Sidney 3 Town Pump LLC

Brian Volbrecht, UST Class B Global Operator Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

| Tank Code | 01 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|---------------------|--------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|----------------|
| Tag Number | 5471 | Spill Test Date | | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/14/2014 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 08/09/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 09/10/2021 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5472 | Spill Test Date | 09/10/2021 | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/14/2014 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 08/09/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |

| | | Overfill Test Date | 09/10/2021 | | | АТG Туре | Gilbarco-Veeder Root/TLS-350 | | | | |
|-------------|------------------|--------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|--------------------------------------|
| Tank Code | 03 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 5473 | Spill Test Date | | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/14/2014 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 08/09/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | | | | АТG Туре | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 04 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5474 | Spill Test Date | 06/16/2023 | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/14/2014 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 30000 | ATG Test Date | 08/09/2022 | Line Tightness Test Date | 03/13/2019 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | | | | АТС Туре | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 05 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 5475 | Spill Test Date | | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/14/2014 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | 08/09/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | | | | АТС Туре | Gilbarco-Veeder Root/TLS-350 | | | | |

| Tank Code | 06 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
|-------------|------------------------|--------------------|------------|-----------------------------|------------|----------------------------------|--|-----------------------------|--|----------------|--------------------------------------|
| Tag Number | 5476 | Spill Test Date | | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/14/2014 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/09/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | | | | АТG Туре | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 07 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 5477 | Spill Test Date | | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/14/2014 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/09/2022 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 08/09/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 08 | Tank Age | 10 | Tank Installed Date | 03/01/2014 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 5478 | Spill Test Date | | Piping Installed Date | 03/24/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Pressurized | CP Met Types | |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring;Not Listed | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Not Listed | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

| Location: WESTERN CHOICE COOPERATIVE SIDNEY 1281 S Central Ave Sidney, MT 59270-5221 Richland | | | | Facility Code: 27176 Last Inspected On: 12/08/2021 Operating Permit Renewal Date: 02/11/2025 Note: Inspection is due 90 days before the Operating Permit Renewal Date. 7017646791 7015900693;7017646791;7017646791 | | | | | | | | |
|---|--------------------------|--|-------------|--|------------|----------------------------------|----------------------------------|-----------------------------|--|----------------|---------------|------------|
| Owner Operator Contact: Western Choice Cooperative Operator Contact: Jade Ziman;Western Choice Cooperative;Serena Ewer;Western Choice Cooperative | | | | | | | | | | | | |
| | | | | | | | | | | | | Owner/Oper |
| | Jade Ziman Serena Ewe | , UST Class A Opera , UST Class B Opera er, UST Class A Oper er, UST Class B Oper | tor ator | | | | | | | | | |
| Tank Code | 05 | Tank Age | 43 | Tank Installed Date | 06/25/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve | |
| Tag Number | 4046 | Spill Test Date | 06/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No | |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic | |
| Product | Diesel | PLLD Test Date | 11/23/2021 | Tank/Piping CP Test Date | 11/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No | |
| Capacity | 4000 | ATG Test Date | 11/23/2021 | Line Tightness Test Date | 04/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No | |
| | | Overfill Test Date | 06/14/2022 | | | ATG Type | Veeder Root/TLS- 450 | | | | | |
| Tank Code | 01 | Tank Age | 43 | Tank Installed Date | 06/25/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve | |
| Tag Number | 602 | Spill Test Date | 06/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No | |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic | |
| Product | Diesel | PLLD Test Date | 11/23/2021 | Tank/Piping CP Test Date | 11/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No | |
| Capacity | 20000 | ATG Test Date | 11/23/2021 | Line Tightness Test Date | | Secondary Tank Leak Detection | ····· | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No | |
| | | Overfill Test Date | 06/14/2022 | | | АТG Туре | Veeder Root/TLS- 450 | | | | | |

| Tank Code | 02 | Tank Age | 43 | Tank Installed Date | 06/25/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
|-------------|------------------|--------------------|------------|-----------------------------|------------|----------------------------------|----------------------------------|-----------------------------|--|----------------|---------------|
| Tag Number | 603 | Spill Test Date | 06/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 11/23/2021 | Tank/Piping CP Test Date | 11/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 11/23/2021 | Line Tightness Test Date | 04/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/14/2022 | | | ATG Type | Veeder Root/TLS- 450 | | | | |
| Tank Code | 03 | Tank Age | 43 | Tank Installed Date | 06/25/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 604 | Spill Test Date | 12/15/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 11/23/2021 | Tank/Piping CP Test Date | 11/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 11/23/2021 | Line Tightness Test Date | 04/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/14/2022 | | | АТС Туре | Veeder Root/TLS- 450 | | | | |
| Tank Code | 04 | Tank Age | 43 | Tank Installed Date | 06/25/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 605 | Spill Test Date | 06/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 11/23/2021 | Tank/Piping CP Test Date | 11/23/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 11/23/2021 | Line Tightness Test Date | 04/08/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/14/2022 | | | АТG Туре | Veeder Root/TLS- 450 | | | | |