

Facility Summary in Richland County in the City of Fairview

Location: HORIZON RESOURCES FAIRVIEW STORE
605 S Ellery Ave
Fairview, MT 59221 Richland

Legacy ID:42-03363

Facility ID: 27175
Last Inspected On: 05/20/2020
Operating Permit Renewal Date: 07/24/2023

Owner Operator Contact: Dixie McCampbell;McCampbell LLC;Horizon Resources;Jeffrey Watts;Farmers Union Oil Co Fairview

4064462504;4064462504;7015722171;7015722171;7015722172

Operator Contact: Darcie Yadon;Ronald Rolle

7015722172

Owner/Operator: Horizon Resources

Darcie Yadon, UST Class A Operator
Darcie Yadon, UST Class B Operator
Ronald Rolle, UST Class A Operator
Ronald Rolle, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	23	12/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3722	No			Double Walled	Yes
Currently in Use		01/24/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
7,800			Veeder Root/TLS-450		No
08	23	12/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3723	No			Double Walled	Yes
Currently in Use		01/24/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,200			Veeder Root/TLS-450		No
09	23	12/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

3724	No				Double Walled	Yes
Currently in Use		01/24/2011		Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/18/2015		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,500				Veeder Root/TLS-450		No
10	23	12/01/1998		Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3725	No				Double Walled	Yes
Currently in Use		01/24/2011		Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/18/2015		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,500				Veeder Root/TLS-450		No
15	10	01/02/2011		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5274	No				Double-Walled	Yes
Currently in Use		01/24/2011		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel				Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000				Gilbarco-Veeder Root/TLS-450; Veeder Root/TLS-450		Yes
16	10	01/02/2011		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5275	No				Double-Walled	Yes
Currently in Use		01/24/2011		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel				Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000				Gilbarco-Veeder Root/TLS-450; Veeder Root/TLS-450		Yes

Facility Summary in Richland County in the City of Fairview

Location: LOAF and JUG 714
516 S Ellery Ave
Fairview, MT 59221 Richland

Legacy ID:42-03914

Facility ID: 27193
Last Inspected On: 10/09/2019
Operating Permit Renewal Date: 10/04/2022

Owner Operator Contact: Deborah Markovich;Elena Lau;Mini Mart Inc dba Loaf 5139641568
 N Jug - Remittance;Elena Lau;Mini Mart Inc dba Loaf N
 Jug Hutchinson;Mini Mart Inc dba Loaf 'N Jug Pueblo

Operator Contact: Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

Theodore Bezel, UST Class A Operator
 Theodore Bezel, UST Class B Global Operator
 Theodore Bezel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	8	03/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5410	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
07	8	03/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5411	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
08	8	03/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5412	No		Double-Walled	Double Walled	Yes

Currently in Use	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Richland County in the City of Lambert

Location: NORTANA GRAIN CO
100 1st Ave SW
Lambert, MT 59243 Richland

Legacy ID:42-00317

Facility ID: 27067
Last Inspected On: 10/16/2018
Operating Permit Renewal Date: 03/04/2022

Owner Operator Contact: Lacey Mullin;Nortana Grain Co;Nortana Grain Co **4064432580**

Operator Contact: Mike Arneson;Shane Keller **4064784122;4064893589**

Owner/Operator: Nortana Grain Co

Owner/Operator: Shane Keller

Mike Arneson, UST Class A Operator
Mike Arneson, UST Class B Operator
Shane Keller, UST Class A Operator
Shane Keller, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	12	03/06/2009	Concrete	Flexible Plastic	
5201	Yes			Double Walled	Yes
Currently in Use		10/20/2008	Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
21,000		05/08/2018			No
S6	12	03/06/2009	Concrete	Flexible Plastic	

5202	Yes				Double Walled	Yes
Currently in Use		10/20/2008		Mechanical Line Leak Detector	Pressurized	
Diesel				Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
21,000		05/08/2018				No
S7	12	03/06/2009		Concrete	Flexible Plastic	
5203	Yes				Double Walled	Yes
Currently in Use		10/20/2008		Mechanical Line Leak Detector	Pressurized	
Diesel				Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
13,000		05/08/2018				No
S8	12	03/06/2009		Concrete	Flexible Plastic	
5204	Yes				Double Walled	Yes
Currently in Use		10/20/2008		Mechanical Line Leak Detector	Pressurized	
Diesel				Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
15,000		05/08/2018				No
S9	12	03/06/2009		Concrete	Flexible Plastic	
5205	Yes				Double Walled	Yes
Currently in Use		10/20/2008		Mechanical Line Leak Detector	Pressurized	
Diesel				Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
21,000		05/08/2018				No

Facility Summary in Richland County in the City of Savage

Location: VALLEY FUEL SUPPLY
 MT Hwy 16
 Savage, MT 59262 Richland

Legacy ID:42-03815

Facility ID: 27187
Last Inspected On: 03/04/2021
Operating Permit Renewal Date: 03/14/2024

Owner Operator Contact: Gregory Cross

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Greg Cross

Greg Cross, UST Class A Operator

R J Serpe, UST Class A Operator

R J Serpe, UST Class B Global Operator

Ron Serpe, UST Class B Global Operator

Timothy Fife, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	08/25/1998	Steel Clad	Flexible Plastic	Flapper Valve
780	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/18/2008	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		12/01/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	23	08/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
781	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/18/2008	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000		11/13/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	23	08/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
782	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	11/18/2008	Automatic Tank Gauging 0.2	ELLD 0.2	No
3,000	08/09/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Richland County in the City of Sidney

Location: LOAF 'N JUG #712
706 S Central Ave
Sidney, MT 59270-4939 Richland

Legacy ID:42-05084

Facility ID: 27233
Last Inspected On: 08/08/2019
Operating Permit Renewal Date: 10/04/2022

Owner Operator Contact: Mini Mart Inc dba Loaf 'N Jug Pueblo **5139641568**

Operator Contact: John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo **5139641568**

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

- Carl Watkins, UST Class B Operator
- Eileen Campbell, UST Class B Operator
- Hiede Richardson, UST Class B Global Operator
- John Sumowski, UST Class A Operator
- Randal Liebnow, UST Class A Operator
- Randal Liebnow, UST Class B Global Operator
- Richie Lesser, UST Class B Operator
- Scott Huether, UST Class B Global Operator
- Stevie Ulstad, UST Class B Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Operator
- Timothy Osterman, UST Class B Operator
- Toni Mullen, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	45	04/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4586	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		12/22/2010	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasohol/Ethanol		10/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	45	04/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4587	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		12/22/2010	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasohol/Ethanol		10/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	45	04/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4588	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		12/22/2010	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Richland County in the City of Sidney

Location: LOWER YELLOWSTONE RURAL ELECTRIC ASSOCIATION INC
3200 W Holly St
Sidney, MT 59270 Richland

Legacy ID:42-00001

Facility ID: 27062
Last Inspected On: 04/14/2021
Operating Permit Renewal Date: 09/29/2024

Owner Operator Contact: Lower Yellowstone Rural Electric Association Inc **4064821602**

Operator Contact: Bodrey Kindopp;Justin King **4064881602**

Owner/Operator: Lower Yellowstone Rural Electric Association Inc

Bodrey Kindopp, UST Class A Operator
Justin King, UST Class A Operator
Justin King, UST Class B Global Operator
Mike Eberling, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	28	10/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1558	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Not Listed	No
8,000					No
06	28	10/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1559	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Not Listed	No
4,000					No

Facility Summary in Richland County in the City of Sidney

Location: METZ FUEL and SERVICE
 625 S Central Ave
 Sidney, MT 59270-4936 Richland

Legacy ID:42-03224

Facility ID: 27172
Last Inspected On: 09/25/2021
Operating Permit Renewal Date: 09/29/2024

Owner Operator Contact: N/A ZZZ - TBL_OWN : 1025;Thogersen Oil Inc **4064332402**

Operator Contact: Jim Metz;Timothy Thogersen **4064332402**

Owner/Operator: Metz Fuel Service Inc

Jim Metz, UST Class A Operator
 Jim Metz, UST Class B Global Operator
 Timothy Thogersen, UST Class A Operator
 Timothy Thogersen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	30	07/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2110	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Deferred	No
4,000					No
11	30	07/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2111	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Deferred	No
8,000					No
12	30	07/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2112	No	08/27/2016	Double-Walled	Double Walled	Yes

Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Manual Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000					No
13	30	07/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2113	No	08/27/2016	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000					No

Facility Summary in Richland County in the City of Sidney

Location: MILLERS CORNER
2201 W Holly St
Sidney, MT 59270 Richland

Legacy ID:56-14071

Facility ID: 30723
Last Inspected On: 11/19/2019
Operating Permit Renewal Date: 04/14/2023

Owner Operator Contact: Millers Corner LLC

4064334041

Operator Contact: Gregory Miller;Nitin Patel

4064334041

Owner/Operator: Millers Corner LLC

Gregory Miller, UST Class A Operator
Gregory Miller, UST Class B Global Operator
Nitin Patel, UST Class A Operator
Nitin Patel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	18	02/06/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4797	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/29/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

12,000			Incon/TS-550		No
02	18	02/06/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4798	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/29/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000			Incon/TS-550		No
03	18	02/06/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4799	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/29/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Incon/TS-550		No
04	9	08/01/2012	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
5387	No		Double-Walled	Double Walled	Yes
Currently in Use		08/16/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/29/2017	Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
20,000			Incon/TS-550		Yes

Facility Summary in Richland County in the City of Sidney

Location: SIDNEY AIRPORT SERVICE
355 Airport Rd
Sidney, MT 59270-0355 Richland

Legacy ID:42-04444

Facility ID: 27214
Last Inspected On: 01/03/2019
Operating Permit Renewal Date: 02/12/2022

Owner Operator Contact: Sidney Airport Service **4064884031**

Operator Contact: Barry Holzworth **4068502024**

Owner/Operator: Sidney Airport Service

Barry Holzworth, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	22	04/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3969	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Other			Manual Interstitial Monitoring	Deferred	No
12,000					No

Facility Summary in Richland County in the City of Sidney

Location: SIDNEY CARDTROL
901 3rd St NE
Sidney, MT 59270 Richland

Legacy ID:42-02184

Facility ID: 27135
Last Inspected On: 10/22/2019
Operating Permit Renewal Date: 10/24/2022

Owner Operator Contact: Gregory Cross;Cross Petroleum Services Billings **4062525519**

Operator Contact: Gregory Cross;Larry Garman;R J Serpe;Timothy Fife **4064824376**

Owner/Operator: Cross Petroleum Services Glendive

Greg Cross, UST Class A Operator
Larry Garman, UST Class A Operator
Larry Garman, UST Class B Global Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
Timothy Fife, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	39	04/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
776	No			None	Yes
Currently in Use		05/18/2012	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/28/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Incon/TS-1001		No
02	39	04/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
777	No			None	Yes
Currently in Use		05/18/2012	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/28/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Incon/TS-1001		No
03	39	04/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
778	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/28/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Incon/TS-1001		No
04	39	04/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
779	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/28/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No

8,000

Incon/TS-1001

No

Facility Summary in Richland County in the City of Sidney

Location: SIDNEY HEALTH CENTER
216 14th Ave SW
Sidney, MT 59270-3519 Richland

Legacy ID:42-06159

Facility ID: 27255
Last Inspected On: 04/14/2021
Operating Permit Renewal Date: 09/14/2024

Owner Operator Contact: Sidney Health Center Inc

4064822120

Operator Contact: Mark Delaney

Owner/Operator: Sidney Health Center Inc

Mark Delaney, UST Class A Operator
Mark Delaney, UST Class B Operator
Robert Jes, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	24	09/01/1997	Steel Clad	Flexible Plastic	Flapper Valve
700	No	06/14/2018	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel		04/19/2012	Manual Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000		03/18/2009			No

Facility Summary in Richland County in the City of Sidney

Location: SUPERPUMPER #23 SIDNEY
902 S Central Ave
Sidney, MT 59270-5216 Richland

Legacy ID:42-09718

Facility ID: 27348
Last Inspected On: 10/04/2021
Operating Permit Renewal Date: 12/26/2024

Owner Operator Contact: Roger Pelzer;Superpumper Inc;Superpumper Inc

7018520061

Operator Contact: Kristopher Wolla;Shane Farstad;Steven Mack

5702020945;7018520061

Owner/Operator: Superpumper Inc

Al Erickson, UST Class B Operator
Greg Schimetz, UST Class B Global Operator
Jessica Shaffer, UST Class B Operator

Kristopher Wolla, UST Class A Operator
 Lory Polensky, UST Class B Operator
 Roger Pelzer, UST Class B Operator
 Shane Farstad, UST Class A Operator
 Shane Farstad, UST Class B Global Operator
 Steven Mack, UST Class A Operator
 Steven Mack, UST Class B Operator
 Susan Hurley, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	6	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5595	No	10/22/2015	Double-Walled	Double Walled	Yes
Currently in Use		11/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Incon/TS-550 EVO		Yes
07	6	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5596	No	10/22/2015	Double-Walled	Double Walled	Yes
Currently in Use		11/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Incon/TS-550 EVO		Yes
08	6	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5597	No	10/22/2015	Double-Walled	Double Walled	Yes
Currently in Use		11/16/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000	Incon/TS-550 EVO		Yes

Facility Summary in Richland County in the City of Sidney

Location: SWELEY OIL INC BULK PLANT
1123 10th Ave SE
Sidney, MT 59270-6393 Richland

Legacy ID:42-00183

Facility ID: 27064
Last Inspected On: 10/26/2021
Operating Permit Renewal Date: 02/18/2022

Owner Operator Contact: John Sweley;Sweley Oil Inc;Nortana Grain Co **4064432580;4064822508;4064432580**

Operator Contact: John Sweley;Mike Arneson **4064822508;4064893589**

Owner/Operator: Nortana Grain Co

John Sweley, UST Class A Operator
John Sweley, UST Class B Operator
Mike Arneson, UST Class A Operator
Mike Arneson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S4	23	06/16/1998	Bare Steel	Flexible Plastic	
2076	Yes	10/17/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
17,000					No
S5	23	06/16/1998	Bare Steel	Flexible Plastic	
2077	Yes	10/17/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No

17,000

No

Facility Summary in Richland County in the City of Sidney

Location: TOWN PUMP OF SIDNEY #3
12280 Hwy 200 Unit 1
Sidney, MT 59270 Richland

Legacy ID:60-15241

Facility ID: 30958
Last Inspected On: 09/11/2020
Operating Permit Renewal Date: 01/14/2024

Owner Operator Contact:

Operator Contact:

Owner/Operator: Sidney 3 Town Pump LLC

Brian Volbrecht, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5471	No	07/14/2014	Double-Walled	Double Walled	Yes
Currently in Use		03/24/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-350		Yes
02	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5472	No	07/14/2014	Double-Walled	Double Walled	Yes
Currently in Use		03/24/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-350		Yes

03	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
5473	No	07/14/2014	Double-Walled	Double Walled	Yes
Currently in Use		03/24/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-350		Yes
04	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5474	No	07/14/2014	Double-Walled	Double Walled	Yes
Currently in Use		03/24/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
30,000			Gilbarco-Veeder Root/TLS-350		Yes
05	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
5475	No	07/14/2014	Double-Walled	Double Walled	Yes
Currently in Use		03/24/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-350		Yes
06	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
5476	No	07/14/2014	Double-Walled	Double Walled	Yes
Currently in Use		03/24/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		Yes

07	7	03/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
5477	No	07/14/2014	Double-Walled	Double Walled	Yes
Currently in Use		03/24/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Richland County in the City of Sidney

Location: WESTERN CHOICE COOPERATIVE SIDNEY
1281 S Central Ave
Sidney, MT 59270-5221 Richland

Legacy ID:42-03364

Facility ID: 27176
Last Inspected On: 08/16/2018
Operating Permit Renewal Date: 02/11/2022

Owner Operator Contact: Western Choice Cooperative

7017646791

Operator Contact: David Corbin

Owner/Operator: Western Choice Cooperative

David Corbin, UST Class A Operator
David Corbin, UST Class B Operator
Sean Dodds, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	40	06/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4046	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/25/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Veeder Root/TLS-450		No
01	40	06/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

602	No			Double Walled	Yes
Currently in Use		08/12/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/25/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Veeder Root/TLS-450		No
02	40	06/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
603	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		08/25/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Veeder Root/TLS-450		No
03	40	06/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
604	No			Double Walled	Yes
Currently in Use		08/12/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/25/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Veeder Root/TLS-450		No
04	40	06/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
605	No			Double Walled	Yes
Currently in Use		08/12/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		08/25/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000			Veeder Root/TLS-450		No