

Facility Summary in Roosevelt County in the City of Bainville

Location: THE WELCOME STOP
209 N Clinton St
Bainville, MT 59212 Roosevelt

Legacy ID:43-13761

Facility ID: 27568
Last Inspected On: 02/12/2019
Operating Permit Renewal Date: 07/27/2022

Owner Operator Contact: Lafe Warren;Warrens Welcome Stop Inc Rosebud;Scot 4807171776
P;Welcome Stop Retail LLC Bainville;Welcome Stop
Retail LLC Scottsdale

Operator Contact: John Gilligan;Melissa Bonebrake

Owner/Operator: Welcome Stop Retail LLC Scottsdale

John Gilligan, UST Class A Operator
John Gilligan, UST Class B Global Operator
John Gilligan, UST Class B Operator
Melissa Bonebrake, UST Class A Operator
Melissa Bonebrake, UST Class B Operator
Rachelle Ryder, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	24	12/01/1997	Unknown	Fiberglass Reinforced Plastic	
3387	Yes	07/12/2012		Double Walled	Yes
Currently in Use		09/07/2011	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000					Yes
S4	24	12/01/1997	Unknown	Fiberglass Reinforced Plastic	
3388	Yes	07/12/2012		Double Walled	Yes
Currently in Use		09/07/2011	Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000					Yes

Facility Summary in Roosevelt County in the City of Brockton

Location: B and S QUICK STOP
 US Hwy 2 & 7th St
 Brockton, MT 59213-0248 Roosevelt

Legacy ID:43-02099

Facility ID: 27417
Last Inspected On: 11/18/2020
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact: Robert Nygard;Robert Nygard;Robert Nygard **4067863229**

Operator Contact: Ian Drum;Robert Nygard **4067863229**

Owner/Operator: Robert Nygard

Ian Drum, UST Class A Operator
 Ian Drum, UST Class B Operator
 Robert Nygard, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	26	06/12/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1828	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Not Listed	No
7,000					No
07	26	06/12/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1829	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Not Listed	No
5,000					No

Facility Summary in Roosevelt County in the City of Brockton

Location: CENEX HARVEST STATES BROCKTON ELEVATOR
 600 S Tracks Rd
 Brockton, MT 59213-0000 Roosevelt

Legacy ID:43-13651

Facility ID: 27567
Last Inspected On: 06/16/2021
Operating Permit Renewal Date: 10/02/2024

Owner Operator Contact: CHS Brockton;N/A ZZZ - TBL_OWN : 334;Farmers 4067863221
Elev Division Cenex Hsc

Operator Contact: David Corbin;Ron Shanks;Shari Cameron

Owner/Operator: CHS Brockton

David Corbin, UST Class A Operator
David Corbin, UST Class B Operator
Ron Shanks, UST Class A Operator
Ron Shanks, UST Class B Operator
Shari Cameron, UST Class A Operator
Shari Cameron, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	38	01/01/1983	Cathodically Protected Steel	No Piping	Flapper Valve
4317	No	10/09/2012		None	Yes
Currently in Use		08/13/2013	Not Required	Not Listed	Galvanic
Diesel		05/07/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	38	01/01/1983	Cathodically Protected Steel	No Piping	Flapper Valve
4318	No	10/09/2012		None	Yes
Currently in Use		08/13/2013	Not Required	Not Listed	Galvanic
Gasoline		05/07/2018	Automatic Tank Gauging 0.2	Deferred	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	22	08/01/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4319	No	10/09/2012		Double Walled	Yes

Currently in Use		08/13/2013	Not Required	Safe Suction	Galvanic
Diesel		05/07/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	22	08/01/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4320	No	10/09/2012		Double Walled	Yes
Currently in Use		08/13/2013	Not Required	Safe Suction	Galvanic
Diesel		05/07/2018	Automatic Tank Gauging 0.2	Deferred	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Roosevelt County in the City of Culbertson

Location: MILLER OIL
2006 US Hwy 2
Culbertson, MT 59218 Roosevelt

Legacy ID:60-15191

Facility ID: 30916
Last Inspected On: 04/16/2021
Operating Permit Renewal Date: 07/18/2024

Owner Operator Contact: Gordon Miller

Operator Contact: Kevin Miller;Matthew Miller

4067657730

Owner/Operator: Gordon Miller

Kevin Miller, UST Class A Operator
Kevin Miller, UST Class B Operator
Matthew Miller, UST Class A Operator
Matthew Miller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	10	09/01/2011	Unknown	Fiberglass	
5345	Yes	09/27/2011		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000		03/21/2018			Yes
S2	10	09/01/2011	Unknown	Fiberglass	
5346	Yes	09/27/2011		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000		03/21/2018			Yes

Facility Summary in Roosevelt County in the City of Culbertson

Location: MISSOURI RIVER LOGISTICS
 515 6th St E
 Culbertson, MT 59218-9301 Roosevelt

Legacy ID:43-03015

Facility ID: 27434
Last Inspected On: 11/20/2019
Operating Permit Renewal Date:

Owner Operator Contact:

Operator Contact:

Owner/Operator: Missouri River Logistics Frederick

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	43	05/05/1978	Cathodically Protected Steel	Steel	Flapper Valve
3732	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		11/16/2016	Not Listed	Deferred	No
6,000					No
02	43	05/05/1978	Cathodically Protected Steel	Steel	Flapper Valve
3733	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		11/16/2016	Not Listed	Deferred	No
6,000					No
03	43	05/05/1978	Cathodically Protected Steel	Steel	Flapper Valve
3734	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		11/16/2016	Not Listed	Deferred	No

6,000					No
04	43	05/05/1978	Cathodically Protected Steel	Steel	Flapper Valve
3735	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		11/16/2016	Not Listed	Deferred	No
6,000					No

Facility Summary in Roosevelt County in the City of Culbertson

Location: OELKERS SERVICE CENTER
4 6th St E
Culbertson, MT 59218-0272 Roosevelt

Legacy ID:43-00030

Facility ID: 27384
Last Inspected On: 06/02/2020
Operating Permit Renewal Date: 10/18/2023

Owner Operator Contact: Oelkers Inc;Ronald K Oelkers;Oelkers Inc

4067875315

Operator Contact: Ronald K Oelkers

4067875315

Owner/Operator: Oelkers Inc

Gordon Oelkers, UST Class B Operator
Ronald K Oelkers, UST Class A Operator
Ronald K Oelkers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	68	01/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1774	No			Double Walled	Yes
Currently in Use		05/21/2015	Not Required	Safe Suction	Impressed Current
Gasoline		08/28/2014	Automatic Tank Gauging 0.2	Deferred	No
3,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	68	01/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm

1775	No			Double Walled	Yes
Currently in Use		05/21/2015	Not Required	Safe Suction	Impressed Current
Diesel		08/28/2014	Automatic Tank Gauging 0.2	Deferred	No
3,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	68	01/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1776	No			Double Walled	Yes
Currently in Use		05/21/2015	Not Required	Safe Suction	Impressed Current
Diesel		08/28/2014	Automatic Tank Gauging 0.2	Deferred	No
3,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	68	01/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1777	No			Double Walled	Yes
Currently in Use		05/21/2015	Not Required	Safe Suction	Impressed Current
Gasoline		08/28/2014	Automatic Tank Gauging 0.2	Deferred	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Roosevelt County in the City of Culbertson

Location: TRIPLE M SINCLAIR
3 6th St W
Culbertson, MT 59218 Roosevelt

Legacy ID:43-07758

Facility ID: 27512
Last Inspected On: 12/12/2018
Operating Permit Renewal Date: 05/12/2022

Owner Operator Contact: Miller Oil Co Inc Culbertson

4067875230

Operator Contact: Kevin Miller;Matthew Miller

4067657730

Owner/Operator: Miller Oil Co Inc Culbertson

Kevin Miller, UST Class A Operator
Kevin Miller, UST Class B Operator
Matthew Miller, UST Class A Operator
Matthew Miller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	36	07/01/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3635	No	03/31/2015		Double Walled	Yes
Currently in Use		04/06/2015	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-450		No
02	36	07/01/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3636	No	03/31/2015		Double Walled	Yes
Currently in Use		04/06/2015	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-450		No
04	36	07/01/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3637	No	03/31/2015		Double Walled	Yes
Currently in Use		04/06/2015	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-450		No

Facility Summary in Roosevelt County in the City of Culbertson

Location: VAL AM STOP and GO LLC
110 6th St W
Culbertson, MT 59218 Roosevelt

Legacy ID:43-01991

Facility ID: 27412
Last Inspected On: 11/17/2020
Operating Permit Renewal Date: 02/11/2024

Owner Operator Contact: Douglas McCormick; Douglas McCormick and Tammie McCormick

Operator Contact: Shanonne Oelkers

7028021289

Owner/Operator: Shanonne Oelkers

Owner/Operator: Val Am Stop & Go LLC Culbertson

Alisha Maiolo, UST Class B Operator
 Austin Oelkers, UST Class B Operator
 Shanonne Oelkers, UST Class A Operator
 Shanonne Oelkers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
05	31	07/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3517	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Not Listed	No
6,000					No
06	31	07/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3518	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Not Listed	No
6,000					No

Facility Summary in Roosevelt County in the City of Froid

Location: AGLAND COOP FROID
 105 2nd Ave N
 Froid, MT 59226 Roosevelt

Legacy ID:43-04415

Facility ID: 27462
Last Inspected On: 06/18/2021
Operating Permit Renewal Date: 10/21/2024

Owner Operator Contact: Agland Coop Wolf Point

Operator Contact: Jeremy Breuer

4067662463

Owner/Operator: Agland Coop Wolf Point

Dan Kjelshus, UST Class B Operator
 Danny Mogen, UST Class B Operator
 Jeremy Breuer, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	31	10/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
958	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		09/28/2016	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	31	10/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
959	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/28/2016	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	31	10/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
960	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/28/2016	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	31	10/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
961	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Diesel	09/28/2016	Automatic Tank Gauging 0.2	Deferred	No
4,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Roosevelt County in the City of Poplar

Location: AGLAND COOP POPLAR
211 F St W
Poplar, MT 59255 Roosevelt

Legacy ID:43-10278

Facility ID: 27543
Last Inspected On: 06/16/2021
Operating Permit Renewal Date: 06/16/2024

Owner Operator Contact: Agland Coop Wolf Point; Gary Sadler; AgLand Co Op Poplar; Tom Dahl; Agland Coop Wolf Point **4067687255**

Operator Contact: David Parsley; Gary Sadler; Steven Long **4066531510; 4067687255**

Owner/Operator: Agland Coop Wolf Point

- Allen Richard, UST Class B Global Operator
- Allen Richard, UST Class B Operator
- David Parsley, UST Class A Operator
- David Parsley, UST Class B Operator
- Gary Sadler, UST Class A Operator
- Gary Sadler, UST Class B Operator
- Michael Pallvoda, UST Class B Operator
- Steven Long, UST Class A Operator
- Steven Long, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	10/27/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
993	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/25/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		03/21/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	37	10/27/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

994	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/25/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		03/21/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	37	10/27/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
995	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		08/25/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		03/21/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
996	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		08/25/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		03/21/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
997	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/25/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		03/21/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
998	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/25/2014	Automatic Tank Gauging 0.2	ELLD 0.2	No

10,000

03/21/2007

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Roosevelt County in the City of Poplar

Location: FORT PECK DETENTION CENTER
6256 Buffalo Dr
Poplar, MT 59255 Roosevelt

Legacy ID:60-15207

Facility ID: 30927
Last Inspected On: 01/13/2021
Operating Permit Renewal Date: 11/30/2023

Owner Operator Contact: Assiniboine and Sioux Tribes Poplar

4067682389

Operator Contact: David Lezard

Owner/Operator: Assiniboine and Sioux Tribes Poplar

David Lezard, UST Class A Operator
David Lezard, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	8	09/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5419	No	10/17/2017	Double-Walled	Double Walled	Yes
Currently in Use		05/02/2013	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
3,000			Gilbarco-Veeder Root/TLS-300		Yes

Facility Summary in Roosevelt County in the City of Poplar

Location: TJS QUICK STOP
302 F St W
Poplar, MT 59255 Roosevelt

Legacy ID:43-02100

Facility ID: 27418
Last Inspected On: 06/16/1999
Operating Permit Renewal Date:

Owner Operator Contact: Tom Atkinson

4067683371

Operator Contact:

Owner/Operator: Tom Atkinson

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	25	08/01/1996	Steel Clad	Flexible Plastic	Flapper Valve
5952	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
7,000					No
04	25	08/01/1996	Steel Clad	Flexible Plastic	Flapper Valve
5953	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
5,000					No

Facility Summary in Roosevelt County in the City of Poplar

Location: TRIBAL EXPRESS
US Hwy 2 E
Poplar, MT 59255 Roosevelt

Legacy ID:43-13620

Facility ID: 27566
Last Inspected On: 06/16/1999
Operating Permit Renewal Date:

Owner Operator Contact: Fort Peck Assiniboine and Sioux Tribes;Harry Three Stars;Fort Peck Assiniboine and Sioux Tribes **4067685155**

Operator Contact: Anita Trice **4066502409**

Owner/Operator: Fort Peck Assiniboine and Sioux Tribes

Anita Trice, UST Class A Operator
Anita Trice, UST Class B Global Operator
Diana Diserly, UST Class B Global Operator
Juanita Youngman, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
6,000					No

Facility Summary in Roosevelt County in the City of Wolf Point

Location: AGLAND COOP EAST
300 US Hwy 2
Wolf Point, MT 59201 Roosevelt

Legacy ID:43-10279

Facility ID: 27544
Last Inspected On: 06/16/2021
Operating Permit Renewal Date: 06/16/2024

Owner Operator Contact: Agland Coop Wolf Point;Dennis Vinger;Farmers Union Oil Co Wolf Point **4064853475;4066531510**

Operator Contact: David Parsley;Monica Turnburke;Nancy Sietsema **4066531510**

Owner/Operator: Agland Coop Wolf Point

- Allen Richard, UST Class B Global Operator
- Allen Richard, UST Class B Operator
- Bruce Unger, UST Class B Operator
- David Parsley, UST Class A Operator
- David Parsley, UST Class B Operator
- Michael Pallvoda, UST Class B Operator
- Monica Turnburke, UST Class A Operator
- Monica Turnburke, UST Class B Global Operator
- Nancy Sietsema, UST Class A Operator
- Nancy Sietsema, UST Class B Operator
- Steven Long, UST Class B Operator
- Weston Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1000	No			Double Walled	Yes
Currently in Use		09/23/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
30,000		09/01/2009	Veeder Root/TLS-450		No
11	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1001	No			Double Walled	Yes
Currently in Use		09/23/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		09/01/2009	Veeder Root/TLS-450		No
12	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1002	No			Double Walled	Yes
Currently in Use		09/23/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000		09/01/2009	Veeder Root/TLS-450		No
13	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1003	No			Double Walled	Yes
Currently in Use		09/23/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
14,000		09/01/2009	Veeder Root/TLS-450		No
14	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1004	No			Double Walled	Yes

Currently in Use		09/23/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000		09/01/2009	Veeder Root/TLS-450		No
15	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1005	No			Double Walled	Yes
Currently in Use		09/23/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000		09/01/2009	Veeder Root/TLS-450		No
09	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
999	No			Double Walled	Yes
Currently in Use		09/23/2011	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
30,000		09/01/2009	Veeder Root/TLS-450		No

Facility Summary in Roosevelt County in the City of Wolf Point

Location: AGLAND COOP WEST
603 US Hwy 2
Wolf Point, MT 59201 Roosevelt

Legacy ID:43-06866

Facility ID: 27498
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 06/15/2024

Owner Operator Contact: Agland Coop Wolf Point; Dennis Vinger; Farmers Union
Oil Co Wolf Point **4064853475; 4066531510**

Operator Contact: Nancy Sietsema

Owner/Operator: Agland Coop Wolf Point

Allen Richard, UST Class B Global Operator
Allen Richard, UST Class B Operator
Michael Pallvoda, UST Class B Operator
Nancy Sietsema, UST Class A Operator
Nancy Sietsema, UST Class B Operator
Steven Long, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
07	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4327	No		None	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized	Galvanic	
Gasoline	10/16/2013	Automatic Tank Gauging 0.2	ELLD 0.2	No	
12,000		Veeder Root/TLS-450		No	
09	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4328	No		None	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized	Galvanic	
Diesel	10/16/2013	Automatic Tank Gauging 0.2	ELLD 0.2	No	
12,000		Veeder Root/TLS-450		No	
11	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4329	No		None	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized	Galvanic	
Diesel, Dyed	10/16/2013	Automatic Tank Gauging 0.2	ELLD 0.2	No	
12,000		Veeder Root/TLS-450		No	
08	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
988	No		None	Yes	
Currently in Use		Electronic Line Leak Detector	Pressurized	Galvanic	
Gasoline	10/16/2013	Automatic Tank Gauging 0.2	ELLD 0.2	No	
12,000		Veeder Root/TLS-450		No	

10	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
990	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Veeder Root/TLS-450		No
12	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
992	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel, Dyed		10/16/2013	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Veeder Root/TLS-450		No

Facility Summary in Roosevelt County in the City of Wolf Point

Location: L M CLAYTON AIRPORT
 MT Hwy 13
 Wolf Point, MT 59201 Roosevelt

Legacy ID:43-00843

Facility ID: 27396
Last Inspected On: 10/29/2021
Operating Permit Renewal Date: 01/09/2025

Owner Operator Contact: City of Wolf Point

Operator Contact: Michelle Isle;Tom Romo

Owner/Operator: City of Wolf Point

Michelle Isle, UST Class A Operator
 Tom Romo, UST Class A Operator
 Tom Romo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	29	11/01/1992	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
648	No		Double-Walled	None	Yes

Currently in Use			Not Required	Safe Suction	Non-corrodible
Aviation Gas	02/20/2013		Manual Interstitial Monitoring	Deferred	No
8,000					No
07	29	11/01/1992	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
649	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)	02/20/2013		Manual Interstitial Monitoring	Deferred	No
4,000					No

Facility Summary in Roosevelt County in the City of Wolf Point

Location: TOWN PUMP INC WOLF POINT
401 Cascade St
Wolf Point, MT 59201-1339 Roosevelt

Legacy ID:43-08725

Facility ID: 27530
Last Inspected On: 07/01/2021
Operating Permit Renewal Date: 07/01/2024

Owner Operator Contact: Don Edmisten;E Z Supply Inc;E-Z Supply Inc

4064976700;4064976948

Operator Contact: Trent Biggers

Owner/Operator: E-Z Supply Inc

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	04/14/1985	Cathodically Protected Steel	Steel	Ball Float Valve;Flapper Valve
4774	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	06/19/2018		Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No

12,000		11/13/2009	Gilbarco-Veeder Root/TLS-350		No
02	36	04/14/1985	Cathodically Protected Steel	Steel	Ball Float Valve;Flapper Valve
4775	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/19/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		11/13/2009	Gilbarco-Veeder Root/TLS-350		No
03	36	04/14/1985	Cathodically Protected Steel	Steel	Ball Float Valve;Flapper Valve
4776	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/19/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		11/13/2009	Gilbarco-Veeder Root/TLS-350		No
04	35	04/14/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4777	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/19/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000		10/11/2006	Gilbarco-Veeder Root/TLS-350		No
05	35	04/14/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4778	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/19/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No

10,000		12/20/2006	Gilbarco-Veeder Root/TLS-350		No
06	19	06/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4779	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		12/21/2006	Gilbarco-Veeder Root/TLS-350		No