

Facility Summary in Rosebud County in the City of Ashland

Location: CHEYENNE DEPOT 2
2363 W US Hwy 212
Ashland, MT 59003 Rosebud

Legacy ID:44-13200

Facility ID: 27702
Last Inspected On: 05/14/2021
Operating Permit Renewal Date: 06/27/2024

Owner Operator Contact: Northern Cheyenne Development Corporation **4064776794**

Operator Contact: Curtis Elkshoulder **4064776767**

Owner/Operator: Northern Cheyenne Development Corporation

Curtis Elkshoulder, UST Class A Operator
Curtis Elkshoulder, UST Class B Global Operator
Curtis Elkshoulder, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	07/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4420	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/30/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		12/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	28	07/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4421	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/30/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		12/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	28	07/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4424	No			None	Yes

Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	11/30/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000	12/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Rosebud County in the City of Ashland

Location: ST LABRE INDIAN SCHOOL UST
1000 Tongue River Rd
Ashland, MT 59003 Rosebud

Legacy ID:44-00701

Facility ID: 27579
Last Inspected On: 06/18/2021
Operating Permit Renewal Date: 10/09/2024

Owner Operator Contact: St Labre Indian School

4067844500

Operator Contact: Dana Davis;Leney Mcnac

Owner/Operator: St Labre Indian School

- Dana Davis, UST Class A Operator
- Dana Davis, UST Class B Global Operator
- Dana Davis, UST Class B Operator
- Leney Mcnac, UST Class A Operator
- Leney Mcnac, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	28	12/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1957	No			None	Yes
Currently in Use		08/26/2011	Not Required	Safe Suction	Galvanic
Gasoline		09/21/2018	Automatic Tank Gauging 0.2	Deferred	No
15,000			Gilbarco/EMC Basic		No

Facility Summary in Rosebud County in the City of Ashland

Location: WESTERN PUMP
US Hwy 212
Ashland, MT 59003 Rosebud

Legacy ID:44-01892

Facility ID: 27599
Last Inspected On: 10/12/2020
Operating Permit Renewal Date: 12/31/2023

Owner Operator Contact: Cleatus Stevenson

4067842400

Owner/Operator: Cleatus Stevenson

James Stevenson, UST Class A Operator

James Stevenson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	02/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3098	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/04/2017	Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco-Veeder Root/		No
02	28	02/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3099	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/04/2017	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco-Veeder Root/		No
03	24	10/29/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3100	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/04/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/		No

Facility Summary in Rosebud County in the City of Colstrip

Location: COLSTRIP STEAM ELECTRIC STATION UNITS 3 and
4
601 Willow Ave
Colstrip, MT 59323 Rosebud

Legacy ID:44-06584

Facility ID: 27651
Last Inspected On: 12/22/2020
Operating Permit Renewal Date:

Owner Operator Contact:

Operator Contact:

Owner/Operator: Talen Montana LLC

William Neumiller, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S10-24	42	05/01/1979	Unknown	Steel	
2863	Yes			None	Yes
Temporarily Out of Use			Not Required	Pressurized	
Diesel		11/30/2017	Deferred	MLLD Line Tightness Testing	No
40,000					No
S10-23	42	05/01/1979	Unknown	Steel	
3703	Yes			None	Yes
Temporarily Out of Use			Not Required	Pressurized	
Diesel		11/30/2017	Deferred	MLLD Line Tightness Testing	No
500,000					No

Facility Summary in Rosebud County in the City of Colstrip

Location: COLSTRIP STEAM ELECTRIC STATION WILLOW
AVE
601 Willow Ave
Colstrip, MT 59323 Rosebud

Legacy ID:44-08921

Facility ID: 27669
Last Inspected On: 03/03/2017
Operating Permit Renewal Date: 08/22/2020

Owner Operator Contact: Cody Cole;Talen Montana LLC

4067485290;4067485002

Operator Contact: Brian Sullivan;Michael Holzwarth;Stephen Christian

4067485019;4067485038

Owner/Operator: Talen Montana LLC

Brian Sullivan, UST Class A Operator
 David Millegan, UST Class B Operator
 Michael Holzwarth, UST Class A Operator
 Stephen Christian, UST Class A Operator
 Stephen Christian, UST Class B Global Operator
 William Neumiller, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2864	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		03/30/2011	Manual Interstitial Monitoring	Deferred	No
10,000					No
02	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2865	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	
Diesel		03/30/2011	Manual Interstitial Monitoring	Deferred	No
10,000					No

Facility Summary in Rosebud County in the City of Colstrip

Location: TOWN PUMP INC COLSTRIP
 112 Willow Ave
 Colstrip, MT 59323 Rosebud

Legacy ID:44-08689

Facility ID: 27667
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/07/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Colstrip 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	46	04/12/1975	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4787	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000		06/02/2006	Gilbarco-Veeder Root/TLS-350		No
02	46	04/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4788	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		07/02/2006	Gilbarco-Veeder Root/TLS-350		No
03	46	04/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4789	No		Lined Interior/Impressed Current	None	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		07/02/2006	Gilbarco-Veeder Root/TLS-350		No
04	46	04/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

4790	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		10/14/2006	Gilbarco-Veeder Root/TLS-350		No
05	46	04/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4791	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/06/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000		10/14/2006	Gilbarco-Veeder Root/TLS-350		No
06	21	01/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4792	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		10/25/2006	Gilbarco-Veeder Root/TLS-350		No
07	21	01/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4793	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000		10/25/2006	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Rosebud County in the City of Forsyth

Location: FORSYTH WATERING HOLE
 1017 Front St
 Forsyth, MT 59327 Rosebud

Legacy ID:44-01244

Facility ID: 27590
Last Inspected On: 07/27/2021
Operating Permit Renewal Date: 12/13/2024

Owner Operator Contact: Otto Bendewald;Seven 11;RRR Properties LLC

4063462885;4063567644

Operator Contact: Cory Boyd;DeAnne Jonas;Mike Simpson

4063562885;4805886181

Owner/Operator: RRR Properties LLC

Cory Boyd, UST Class A Operator
 Cory Boyd, UST Class B Operator
 DeAnne Jonas, UST Class A Operator
 DeAnne Jonas, UST Class B Global Operator
 Mike Simpson, UST Class A Operator
 Mike Simpson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	29	02/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1393	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/15/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/08/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	29	02/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1394	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		08/15/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		12/08/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	29	02/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm

1395	No		None	Yes
Currently in Use			Mechanical Line Leak Detector Pressurized	
Diesel	08/15/2018		Automatic Tank Gauging 0.2 MLLD Line Tightness Testing	No
4,000	12/08/2017		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC	No

Facility Summary in Rosebud County in the City of Forsyth

Location: PRINCE INC FORSYTH
W Frontage Rd
Forsyth, MT 59327 Rosebud

Legacy ID:44-06209

Facility ID: 27646
Last Inspected On: 10/12/2020
Operating Permit Renewal Date: 02/12/2024

Owner Operator Contact: Prince Inc

4063562137

Operator Contact: Charlee Prince;Shelley Thompson;Steve Pulver

4063462137

Owner/Operator: Prince Inc

Charlee Prince, UST Class A Operator
Charlee Prince, UST Class B Global Operator
Shelley Thompson, UST Class A Operator
Shelley Thompson, UST Class B Operator
Steve Pulver, UST Class A Operator
Steve Pulver, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	23	10/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4532	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/18/2014	Automatic Tank Gauging 0.2	Not Listed	No
10,000		11/21/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	23	10/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4533	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/18/2014	Automatic Tank Gauging 0.2	Not Listed	No
5,000		11/21/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Rosebud County in the City of Forsyth

Location: ROSEBUD COUNTY ROAD DEPT
2975 US Hwy 10
Forsyth, MT 59327 Rosebud

Legacy ID:44-01288

Facility ID: 27592
Last Inspected On: 11/18/2020
Operating Permit Renewal Date: 01/14/2024

Owner Operator Contact: Rosebud County Road Dept

4063462261

Operator Contact: Dawne Buck;Pat Zent;Wayne Buck

4066983778

Owner/Operator: Rosebud County Road Dept

Dawne Buck, UST Class A Operator
Dawne Buck, UST Class B Operator
Pat Zent, UST Class A Operator
Pat Zent, UST Class B Operator
Wayne Buck, UST Class A Operator
Wayne Buck, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	30	04/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1858	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		11/08/2017	Continuous Interstitial Monitoring	Deferred	No
6,000			Gilbarco-Veeder Root/EMC Basic		No
06	30	04/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1859	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Diesel		11/08/2017	Continuous Interstitial Monitoring	Deferred	No
4,000			Gilbarco-Veeder Root/EMC Basic		No
07	30	04/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve

1860	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Diesel	11/08/2017		Continuous Interstitial Monitoring	Deferred	No
10,000			Gilbarco-Veeder Root/EMC Basic		No

Facility Summary in Rosebud County in the City of Forsyth

Location: ROSEBUD HEALTH CARE CENTER
383 N 17th Ave
Forsyth, MT 59327 Rosebud

Legacy ID:44-05262

Facility ID: 27633
Last Inspected On: 01/28/2019
Operating Permit Renewal Date: 04/20/2022

Owner Operator Contact: Rosebud Health Care Center

4063562161

Operator Contact: Chad Potts;Michael Jerhoff;Tim Davis

4063475222;4063512274;4063519095

Owner/Operator: Rosebud Health Care Center

- Chad Potts, UST Class A Operator
- Clint Boyer, UST Class B Operator
- Michael Jerhoff, UST Class A Operator
- Michael Jerhoff, UST Class B Global Operator
- Tim Davis, UST Class A Operator
- Tim Davis, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	30	09/01/1991	Cathodically Protected Steel	Steel	Flapper Valve
4343	No		Double-Walled	None	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		01/28/2019	Manual Interstitial Monitoring	3-Year Line Tightness Test	No
500		01/28/2019			No

Facility Summary in Rosebud County in the City of Forsyth

Location: TOWN PUMP INC FORSYTH
 974 Front St
 Forsyth, MT 59327 Rosebud

Legacy ID:44-09356

Facility ID: 27672
Last Inspected On: 12/26/2018
Operating Permit Renewal Date: 04/27/2022

Owner Operator Contact: Don Edmisten;Major Brands Dist Imports Inc

4064976948

Operator Contact: Daniel Sampson

Owner/Operator: Forsyth 1 Town Pump LLC

Daniel Sampson, UST Class A Operator
 Daniel Sampson, UST Class B Global Operator
 Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	19	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4736	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		12/03/2009			No
12	19	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4737	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/03/2009			No
14	19	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4738	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/03/2009			No
13	19	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4755	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		12/03/2009			No
15	19	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4756	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		12/03/2009			No
16	19	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4757	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/03/2009			No