

Facility Summary in Sanders County in the City of Heron

Location: THE HERON STORE AND CAFÉ
150 Railroad Ave
Heron, MT 59844-9596 Sanders

System Facility ID:45-10136

Facility Code: 27838
Last Inspected On: 10/02/2024
Operating Permit Renewal Date: 10/02/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Michael Kranzier (406) 847-1958 mayu.msrl@gmail.com

Operator Contact: Lisa Camara (208) 264-5606 cfgirl1111@outlook.com

Owner/Operator: Michael Kranzier (406) 847-1958 mayu.msrl@gmail.com
Lisa Camara, UST Class A Operator cfgirl1111@outlook.com
Lisa Camara, UST Class B Global Operator cfgirl1111@outlook.com

Tank Code	03	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3291	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection		Vapor Recovery	No
Capacity	1080	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3292	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection		Vapor Recovery	No
Capacity	1080	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Sanders County in the City of Hot Springs

Location: LONEPINE COUNTRY STORE
2534 MT Hwy 28
Hot Springs, MT 59845 Sanders

System Facility ID:45-12786

Facility Code: 27878
Last Inspected On: 04/01/2026
Operating Permit Renewal Date: 08/07/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lonepine General Store LLC (406) 741-2534 lonepinegeneralstore@yahoo.com

Operator Contact: Lindsey Colombo;Traci Salmi (406) 210-4029;(406) 471-2766 lonepinegeneralstore@yahoo.com

Owner/Operator: Lonepine General Store LLC (406) 741-2534 lonepinegeneralstore@yahoo.com

Lindsey Colombo, UST Class A Operator
Lindsey Colombo, UST Class B Operator
Traci Salmi, UST Class A Operator
Traci Salmi, UST Class B Operator

lonepinegeneralstore@yahoo.com
lonepinegeneralstore@yahoo.com
lonepinegeneralstore@yahoo.com
lonepinegeneralstore@yahoo.com

Tank Code	01	Tank Age	34	Tank Installed Date	06/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3536	Spill Test Date	04/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/09/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/09/2025	Line Tightness Test Date	04/09/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/09/2025			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	02	Tank Age	34	Tank Installed Date	06/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3537	Spill Test Date	04/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/09/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/09/2025	Line Tightness Test Date	04/09/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/09/2025			ATG Type	Gilbarco-Veeder Root/TLS-300				

Tank Code	03	Tank Age	34	Tank Installed Date	06/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3538	Spill Test Date	04/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/09/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	04/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/09/2025	Line Tightness Test Date	04/09/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/09/2025			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Sanders County in the City of Hot Springs

Location: ONE STOP 3 INC LOC 473
1893 MT Hwy 28
Hot Springs, MT 59845 Sanders

System Facility ID:45-12871

Facility Code: 27881
Last Inspected On: 04/10/2026
Operating Permit Renewal Date: 08/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: One Stop 3 Inc	(406) 279-3600	one-stop@outlook.com
Operator Contact: Carmen Carr;Danielle Chesley;Dianna Garcia;One Stop 3 Inc;Jan Montgomery;Jeffrey Jung;Manford Tempero;Pandora Fasciana;Sandra Brown	(406) 279-3600;(406) 741-3200;(406) 741-3210;(406) 885-1406	cornerstone@gmail.com;cornerstone59903@gmail.com;jeff1jung@gmail.com;mmtent@hotsprgs.net;mrs.dmgarcia91@gmail.com;one-stop@outlook.com;northwestnovelties@yahoo.com;pandoraf@gmail.com
Owner/Operator: One Stop 3 Inc	(406) 279-3600	one-stop@outlook.com

- | | |
|---|------------------------------|
| Carmen Carr, UST Class A Operator | cornerstone@gmail.com |
| Carmen Carr, UST Class B Operator | cornerstone@gmail.com |
| Danielle Chesley, UST Class A Operator | northwestnovelties@yahoo.com |
| Danielle Chesley, UST Class B Global Operator | northwestnovelties@yahoo.com |
| Dianna Garcia, UST Class A Operator | one-stop@outlook.com |
| Dianna Garcia, UST Class B Operator | one-stop@outlook.com |
| Jan Montgomery, UST Class A Operator | cornerstone59903@gmail.com |
| Jan Montgomery, UST Class B Operator | cornerstone59903@gmail.com |
| Jeffrey J Jung, UST Class A Operator | jeff1jung@gmail.com |
| Jeffrey J Jung, UST Class B Operator | jeff1jung@gmail.com |
| Jetta Aldridge, UST Class B Operator | almosta@hotsprgs.net |
| Manford Tempero, UST Class A Operator | mmtent@hotsprgs.net |
| Manford Tempero, UST Class B Operator | mmtent@hotsprgs.net |
| Pandora Fasciana, UST Class A Operator | pandoraf@gmail.com |
| Sandra Brown, UST Class A Operator | cornerstone59903@gmail.com |
| Sandra Brown, UST Class B Operator | cornerstone59903@gmail.com |

Tank Code	03	Tank Age	30	Tank Installed Date	05/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2984	Spill Test Date	04/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/14/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/14/2022	Line Tightness Test Date	12/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/25/2023			ATG Type	Incon/TS-1000				
Tank Code	04	Tank Age	30	Tank Installed Date	05/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2985	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/22/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	06/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				
Tank Code	05	Tank Age	30	Tank Installed Date	05/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2986	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/22/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	06/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				
Tank Code	06	Tank Age	30	Tank Installed Date	06/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2987	Spill Test Date	12/04/2019	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/22/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	06/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				

Facility Summary in Sanders County in the City of Noxon

Location: AITKENS QUIK STOP INC NOXON
1402 MT Hwy 200 W
Noxon, MT 59853-9750 Sanders

System Facility ID:56-13810

Facility Code: 30497
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 10/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Aitkens Quik Stop Inc

Operator Contact: Jeffrey Aitken;Travis Tammaro

(406) 396-4804

AITKEN@BLACKFOOT.NET;tammarot@gmail.com

Owner/Operator: Aitkens Quik Stop Inc

Jeffrey Aitken, UST Class A Operator
Jeffrey Aitken, UST Class B Operator
Travis Tammaro, UST Class A Operator
Travis Tammaro, UST Class B Global Operator

AITKEN@BLACKFOOT.NET
AITKEN@BLACKFOOT.NET
tammarot@gmail.com
tammarot@gmail.com

Tank Code	01	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4484	Spill Test Date	04/23/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/23/2025	Tank/Piping CP Test Date	04/23/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/23/2025	Line Tightness Test Date	05/10/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4485	Spill Test Date	04/23/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/23/2025	Tank/Piping CP Test Date	04/23/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/23/2025	Line Tightness Test Date	05/22/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4486	Spill Test Date	04/23/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/23/2025	Tank/Piping CP Test Date	04/23/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/23/2025	Line Tightness Test Date	09/20/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Sanders County in the City of Paradise

Location: PARADISE SCHOOL DIST 8
20 School House Hill Rd
Paradise, MT 59856 Sanders

System Facility ID:45-08864

Facility Code: 27812
Last Inspected On: 09/25/2020
Operating Permit Renewal Date: 10/17/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sanders County Commissioners (406) 827-6942 smaciel@co.sanders.mt.us

Operator Contact: David Colyer (406) 826-3679

Owner/Operator: Sanders County Commissioners (406) 827-6942 smaciel@co.sanders.mt.us

David Colyer, UST Class A Operator

David Colyer, UST Class B Operator

Tank Code	S2	Tank Age	28	Tank Installed Date	07/30/1998	Tank Material	Unknown	Piping Material	Copper	Overfill Types	
Tag Number	1782	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	PVC	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Sanders County in the City of Plains

Location: PLAINS TRAVEL PLAZA
100 E Railroad Ave
Plains, MT 59859 Sanders

System Facility ID:45-01147

Facility Code: 27721
Last Inspected On: 03/21/2025
Operating Permit Renewal Date: 06/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Plains Properties LLC

(509) 883-6629

tindic15@gmail.com

Operator Contact:

Owner/Operator: Plains Properties LLC

(509) 883-6629

tindic15@gmail.com

Tank Code	07	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3594	Spill Test Date	03/21/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/21/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2025			ATG Type	Gilbarco/EMC				
Tank Code	08	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3595	Spill Test Date	03/21/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	03/21/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2025			ATG Type	Gilbarco/EMC				
Tank Code	09	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3596	Spill Test Date	03/21/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	03/21/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2025			ATG Type	Gilbarco/EMC				
Tank Code	10	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3597	Spill Test Date	04/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/29/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/29/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	11	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3598	Spill Test Date	09/29/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/29/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/29/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Sanders County in the City of Plains

Location: TOWN PUMP OF PLAINS
325 E Railroad Ave
Plains, MT 59859 Sanders

System Facility ID:45-03803

Facility Code: 27764
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 09/28/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Plains 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Plains 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Operator

Trentb@townpump.com

Tank Code	07	Tank Age	0	Tank Installed Date		Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4510	Spill Test Date	07/15/2025	Piping Installed Date	11/15/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/27/2023	Tank/Piping CP Test Date	08/11/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	27	Tank Installed Date	02/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4511	Spill Test Date	07/15/2025	Piping Installed Date	11/15/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/27/2023	Tank/Piping CP Test Date	08/11/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	09	Tank Age	27	Tank Installed Date	02/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4512	Spill Test Date	08/11/2022	Piping Installed Date	11/15/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/27/2023	Tank/Piping CP Test Date	08/11/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	8	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5810	Spill Test Date	08/11/2022	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/27/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	8	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5811	Spill Test Date	08/11/2022	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/27/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	12	Tank Age	8	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5812	Spill Test Date	08/11/2022	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/27/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	18000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	13	Tank Age	8	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5813	Spill Test Date	08/11/2022	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/27/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Sanders County in the City of Thompson Falls

Location: EAST END FUEL INC
5236 MT Hwy 200
Thompson Falls, MT 59873-9417 Sanders

System Facility ID:45-13460

Facility Code: 27893
Last Inspected On: 09/21/2023
Operating Permit Renewal Date: 10/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: East End Fuel Inc. (406) 546-8430 eastendfuel71@gmail.com

Operator Contact: Bobbie Rasmussen;Bridget Knerr;East End Fuel Inc.;John Hoy;East End Fuel Inc.;Kimberly Pardee;East End Fuel Inc. (406) 210-0872;(406) 490-4245;(406) 546-8430;(406) 529-8406;(406) 546-8430;(406) 546-8430;(406) 546-8430 eastendfuel71@gmail.com;eastendfuel71@gmail.com;menmychillins3@gmail.com;pardeekim12@gmail.com;eastendfuel71@gmail.com;thenaturalhand@yahoo.com;eastendfuel71@gmail.com

Owner/Operator: East End Fuel Inc. (406) 546-8430 eastendfuel71@gmail.com

Bobbie Rasmussen, UST Class A Operator menmychillins3@gmail.com
 Bobbie Rasmussen, UST Class B Operator eastendfuel71@gmail.com
 Bridget Knerr, UST Class A Operator eastendfuel71@gmail.com
 John Hoy, UST Class A Operator eastendfuel71@gmail.com
 Kimberly Pardee, UST Class A Operator eastendfuel71@gmail.com
 Kimberly Pardee, UST Class B Operator eastendfuel71@gmail.com
 Walter Klein, UST Class B Operator eastendfuel71@gmail.com

Tank Code	01	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2150	Spill Test Date	05/22/2023	Piping Installed Date	05/19/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/22/2023			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	02	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2151	Spill Test Date	05/22/2023	Piping Installed Date	05/19/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/22/2023			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	03	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2152	Spill Test Date	05/22/2023	Piping Installed Date	05/19/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/22/2023			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	04	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2153	Spill Test Date	05/22/2023	Piping Installed Date	05/19/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/22/2023			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	05	Tank Age	3	Tank Installed Date	05/19/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6121	Spill Test Date	05/22/2023	Piping Installed Date	05/19/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes

Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/22/2023			ATG Type					
Tank Code	06	Tank Age	3	Tank Installed Date	05/19/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6122	Spill Test Date	05/22/2023	Piping Installed Date	05/19/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/22/2023			ATG Type					
Tank Code	07	Tank Age	3	Tank Installed Date	05/19/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6123	Spill Test Date	05/22/2023	Piping Installed Date	05/19/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline, E10	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/22/2023			ATG Type					

Facility Summary in Sanders County in the City of Thompson Falls

Location: ELEMENTARY SCHOOL
315 S Columbia St
Thompson Falls, MT 59873 Sanders

System Facility ID:45-08537

Facility Code: 27806
Last Inspected On: 03/09/2026
Operating Permit Renewal Date: 03/09/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 2 Thompson Falls (406) 827-3323

Operator Contact: Joshua Schmidt;School Dist 2 Thompson Falls (406) 827-3323 jschmidt@tfalls.org

Owner/Operator: School Dist 2 Thompson Falls (406) 827-3323

Joshua Schmidt, UST Class A Operator
Joshua Schmidt, UST Class B Operator

jschmidt@tfalls.org
jschmidt@tfalls.org

Tank Code	S3	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1887	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	03/09/2026	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Sanders County in the City of Thompson Falls

Location: MOODYS MARKET HARVEST FOODS
5254 MT Hwy 200
Thompson Falls, MT 59873-0880 Sanders

System Facility ID:56-14114

Facility Code: 30755
Last Inspected On: 01/16/2025
Operating Permit Renewal Date: 03/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gregory Hurtz (406) 883-1500 harvest@blackfoot.net

Operator Contact: Donald Lake;Michelle Mayfield;Richard Fargher (406) 721-3719 jimval422@gmail.com;lake72c@gmail.com;Wiggs1sm@gmail.com

Owner/Operator: Gregory Hurtz (406) 883-1500 harvest@blackfoot.net
 Donald Lake, UST Class A Operator lake72c@gmail.com
 Donald Lake, UST Class B Operator lake72c@gmail.com
 Michelle Mayfield, UST Class A Operator Wiggs1sm@gmail.com
 Michelle Mayfield, UST Class B Operator Wiggs1sm@gmail.com
 Richard Fargher, UST Class A Operator jimval422@gmail.com
 Richard Fargher, UST Class B Operator jimval422@gmail.com

Tank Code	01	Tank Age	23	Tank Installed Date	11/04/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4868	Spill Test Date	01/16/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/16/2025	Sump Tightness Test Date	01/16/2025	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/16/2025	Line Tightness Test Date	05/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/16/2025			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	23	Tank Installed Date	11/04/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4869	Spill Test Date	01/16/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/16/2025	Sump Tightness Test Date	01/16/2025	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	5000	ATG Test Date	01/16/2025	Line Tightness Test Date	05/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/16/2025			ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	23	Tank Installed Date	11/04/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4870	Spill Test Date	01/16/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/16/2025	Sump Tightness Test Date	01/16/2025	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/16/2025	Line Tightness Test Date	05/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/16/2025			ATG Type	Veeder Root/TLS-300				

Facility Summary in Sanders County in the City of Thompson Falls

Location: THOMPSON FALLS FEED AND FUEL LLC
1201 Main St
Thompson Falls, MT 59873 Sanders

System Facility ID:45-02633

Facility Code: 27741
Last Inspected On: 10/31/2023
Operating Permit Renewal Date: 12/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Thompson Falls Feed and Fuel LLC

Operator Contact: Carole Jensen

(406) 827-4325

feedfuel2426@yahoo.com

Owner/Operator: Thompson Falls Feed and Fuel LLC

Carole Jensen, UST Class A Operator
Carole Jensen, UST Class B Operator

feedfuel2426@yahoo.com
feedfuel2426@yahoo.com

Tank Code	01	Tank Age	38	Tank Installed Date	04/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3203	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/13/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/13/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	38	Tank Installed Date	04/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3204	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/13/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/13/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	38	Tank Installed Date	04/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3205	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	11/13/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/13/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	38	Tank Installed Date	04/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3206	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/13/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/13/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Sanders County in the City of Thompson Falls

Location: TOWN PUMP INC THOMPSON FALLS
1301 W Main St
Thompson Falls, MT 59873 Sanders

System Facility ID:45-08720

Facility Code: 27808
Last Inspected On: 12/04/2025
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Thompson Falls 1 Town Pump LLC;Town Pump Inc Thompson Falls (406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Thompson Falls 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Owner/Operator: Town Pump Inc Thompson Falls

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	08	Tank Age	27	Tank Installed Date	10/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4115	Spill Test Date	08/26/2025	Piping Installed Date	07/17/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	08/26/2025	Tank/Piping CP Test Date	12/01/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/26/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	27	Tank Installed Date	10/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4116	Spill Test Date	08/26/2025	Piping Installed Date	08/26/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/26/2025	Tank/Piping CP Test Date	12/01/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	5000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/26/2025			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	22	Tank Installed Date	08/18/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4932	Spill Test Date	08/26/2025	Piping Installed Date	08/26/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/26/2025	Tank/Piping CP Test Date	12/01/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/26/2025			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	14	Tank Age	1	Tank Installed Date	08/26/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6244	Spill Test Date	08/26/2025	Piping Installed Date	08/26/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/26/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/26/2025			ATG Type					
Tank Code	15	Tank Age	1	Tank Installed Date	08/26/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6245	Spill Test Date	08/26/2025	Piping Installed Date	08/26/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/26/2025			ATG Type					

Tank Code	11	Tank Age	1	Tank Installed Date	08/26/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6267	Spill Test Date	08/26/2025	Piping Installed Date	08/26/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/26/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/26/2025			ATG Type					
Tank Code	12	Tank Age	1	Tank Installed Date	08/26/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6268	Spill Test Date	08/26/2025	Piping Installed Date	08/26/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/26/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/26/2025			ATG Type					
Tank Code	13	Tank Age	1	Tank Installed Date	08/26/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6269	Spill Test Date	08/26/2025	Piping Installed Date	08/26/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/26/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	08/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/26/2025			ATG Type					

Facility Summary in Sanders County in the City of Trout Creek

Location: TROUT CREEK LOCAL STORE INC
2954 MT Hwy 200
Trout Creek, MT 59874-9564 Sanders

System Facility ID:45-10228

Facility Code: 27844
Last Inspected On: 03/11/2026
Operating Permit Renewal Date: 08/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: The Local Store Inc (208) 610-5396 troutcreekstore@gmail.com

Operator Contact: John Fitchett;Michele Tammaro (208) 610-5396 tclsinc@gmail.com;troutcreekstore@gmail.com

Owner/Operator: The Local Store Inc (208) 610-5396 troutcreekstore@gmail.com
 John Fitchett, UST Class A Operator troutcreekstore@gmail.com
 John Fitchett, UST Class B Operator troutcreekstore@gmail.com
 Michele Tammaro, UST Class A Operator tclsinc@gmail.com
 Michele Tammaro, UST Class B Operator tclsinc@gmail.com

Tank Code	03	Tank Age	37	Tank Installed Date	12/04/1989	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1607	Spill Test Date	03/30/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/28/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	03/30/2023	Line Tightness Test Date	06/28/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	04	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1608	Spill Test Date	03/30/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	03/30/2023	Line Tightness Test Date	03/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	S5	Tank Age	37	Tank Installed Date	12/01/1989	Tank Material	Not Listed	Piping Material	Steel	Overfill Types	
Tag Number	5682	Spill Test Date	03/30/2023	Piping Installed Date	12/01/1989	Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/30/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/30/2023	Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	03/30/2023	Line Tightness Test Date	03/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/30/2023			ATG Type					

Facility Summary in Sanders County in the City of Trout Creek

Location: TROUT CREEK QUIK STOP
2950 MT Hwy 200
Trout Creek, MT 59874 Sanders

System Facility ID:56-14146

Facility Code: 30782
Last Inspected On: 12/09/2025
Operating Permit Renewal Date: 04/28/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: TC Quick Stop Inc (406) 396-4804 tammarot@gmail.com

Operator Contact: Tanner Tammaro;Tiffany Yee (406) 396-4949 tanner.tammaro@gmail.com

Owner/Operator: TC Quick Stop Inc (406) 396-4804 tammarot@gmail.com

Cayla Emerson, UST Class B Operator tclsinc@gmail.com
Tanner Tammaro, UST Class A Operator tanner.tammaro@gmail.com
Tanner Tammaro, UST Class B Operator tanner.tammaro@gmail.com
Tiffany Yee, UST Class A Operator
Tiffany Yee, UST Class B Global Operator

Tank Code	01	Tank Age	21	Tank Installed Date	04/21/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4946	Spill Test Date	12/09/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/09/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	21	Tank Installed Date	04/21/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4947	Spill Test Date	12/09/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/09/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	21	Tank Installed Date	04/21/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4948	Spill Test Date	12/09/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/09/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	21	Tank Installed Date	04/21/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4949	Spill Test Date	12/09/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/09/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/09/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Sanders County in the City of Trout Creek

Location: TROUT CREEK SCHOOL DIST 6
4 School Ln
Trout Creek, MT 59874 Sanders

System Facility ID:45-07647

Facility Code: 27802
Last Inspected On: 01/27/2026
Operating Permit Renewal Date: 04/08/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 6 Trout Creek (406) 827-3629

Operator Contact: Corbin Imlay;All Tank Compliance (406) 998-4813;(406) 998-4696 corbin@alltankcompliance.com;abbra@alltankcompliance.com

Owner/Operator: School Dist 6 Trout Creek (406) 827-3629

Corbin Imlay, UST Class A Operator
Corbin Imlay, UST Class B Operator

abbra@alltankcompliance.com
abbra@alltankcompliance.com

Tank Code	S2	Tank Age	33	Tank Installed Date	08/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	2146	Spill Test Date	01/27/2026	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	10/04/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/27/2026			ATG Type					