

**Facility Summary in Sanders County in the City of Heron**

**Location:** THE HERON STORE AND CAFÉ  
150 Railroad Ave  
Heron, MT 59844-9596 Sanders

Legacy ID:45-10136

**Facility ID:** 27838  
**Last Inspected On:** 01/15/2019  
**Operating Permit Renewal Date:** 01/15/2022

**Owner Operator Contact:** Lisa Camara

**4068473663**

**Operator Contact:** Lisa Camara

**4068473663**

**Owner/Operator:** Lisa Camara

Lisa Camara, UST Class A Operator

Lisa Camara, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	26	06/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>3291</b>	No		Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	
Diesel			Not Listed	Deferred	No
1,080					No
04	26	06/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>3292</b>	No		Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	
Gasoline			Not Listed	Deferred	No
1,080					No

**Facility Summary in Sanders County in the City of Hot Springs**

**Location:** CORNERSTONE CONVENIENCE LLC  
1893 MT Hwy 28  
Hot Springs, MT 59845 Sanders

Legacy ID:45-12871

**Facility ID:** 27881  
**Last Inspected On:** 06/26/2020  
**Operating Permit Renewal Date:** 08/13/2023

**Owner Operator Contact:** Cornerstone Convenience LLC

**4067413200**

**Operator Contact:** Carmen Carr;Danielle Chesley;Jan Montgomery;Jeffrey Jung;Manford Tempero;Pandora Fasciana;Sandra Brown

**4067413200;4067413215;4068851406**

**Owner/Operator:** Cornerstone Convenience LLC

**Owner/Operator:** Jeffrey J Jung

Carmen Carr, UST Class A Operator  
 Carmen Carr, UST Class B Operator  
 Danielle Chesley, UST Class A Operator  
 Danielle Chesley, UST Class B Global Operator  
 Jan Montgomery, UST Class A Operator  
 Jan Montgomery, UST Class B Operator  
 Jeffrey J Jung, UST Class A Operator  
 Jeffrey J Jung, UST Class B Operator  
 Jetta Aldridge, UST Class B Operator  
 Manford Tempero, UST Class A Operator  
 Manford Tempero, UST Class B Operator  
 Pandora Fasciana, UST Class A Operator  
 Sandra Brown, UST Class A Operator  
 Sandra Brown, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	25	05/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2984</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		06/01/2017	Incon/TS-1000		No
04	25	05/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2985</b>	No			None	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		06/01/2017	Incon/TS-1000		No
05	25	05/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2986</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		06/01/2017	Incon/TS-1000		No
06	25	06/01/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2987</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		06/01/2017	Incon/TS-1000		No

**Facility Summary in Sanders County in the City of Hot Springs**

**Location:** LONEPINE COUNTRY STORE  
2532 MT Hwy 28  
Hot Springs, MT 59845 Sanders

Legacy ID:45-12786

**Facility ID:** 27878  
**Last Inspected On:** 04/04/2019  
**Operating Permit Renewal Date:** 08/07/2022

**Owner Operator Contact:** Lonepine General Store LLC

**4067412534**

**Operator Contact:** Lindsey Herron;Rae Herman;Traci Salmi

**4062539240;4064712766;4067413454**

**Owner/Operator:** Lonepine General Store LLC

- Lindsey Herron, UST Class A Operator
- Lindsey Herron, UST Class B Operator
- Rae Herman, UST Class A Operator
- Rae Herman, UST Class B Operator
- Traci Salmi, UST Class A Operator
- Traci Salmi, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	29	06/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3536</b>	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic	
Gasoline	04/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
8,000	04/15/2016	Gilbarco-Veeder Root/TLS-300		No	
02	29	06/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3537</b>	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic	
Diesel	04/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
6,000	04/15/2016	Gilbarco-Veeder Root/TLS-300		No	
03	29	06/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3538</b>	No		None	Yes	
Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic	
Diesel	04/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
8,000	04/15/2016	Gilbarco-Veeder Root/TLS-300		No	

**Facility Summary in Sanders County in the City of Noxon**

**Location:** AITKENS QUIK STOP INC NOXON  
1402 MT Hwy 200 W  
Noxon, MT 59853-9750 Sanders

Legacy ID:56-13810

**Facility ID:** 30497  
**Last Inspected On:** 10/14/2019  
**Operating Permit Renewal Date:** 10/17/2022

**Owner Operator Contact:** Aitkens Quik Stop Inc

**4068479191**

**Operator Contact:** Jeffrey Aitken

**4068474080**

**Owner/Operator:** Aitkens Quik Stop Inc

Jeffrey Aitken, UST Class A Operator  
Jeffrey Aitken, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	10/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4484</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/08/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		10/20/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	24	10/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4485</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/08/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		11/06/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	24	10/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4486</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/08/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		09/11/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Sanders County in the City of Paradise**

**Location:** PARADISE SCHOOL DIST 8  
20 School House Hill Rd  
Paradise, MT 59856 Sanders

Legacy ID:45-08864

**Facility ID:** 27812  
**Last Inspected On:** 09/25/2020  
**Operating Permit Renewal Date:** 10/17/2023

**Owner Operator Contact:** Sanders County Commissioners

**Operator Contact:** Dan Kelly;David Colyer

**Owner/Operator:** Sanders County Commissioners

Dan Kelly, UST Class A Operator  
Dan Kelly, UST Class B Operator  
David Colyer, UST Class A Operator  
David Colyer, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	23	07/30/1998	Unknown	Copper	
1782	Yes	08/07/2017		PVC	No
Currently in Use			Auto Dialer	U.S. Suction	
Heating Oil			Deferred	Continuous Interstitial Monitoring	No
1,000					No

**Facility Summary in Sanders County in the City of Plains**

**Location:** COLYER OIL CO E RAILROAD  
100 E Railroad Ave  
Plains, MT 59859 Sanders

Legacy ID:45-01147

**Facility ID:** 27721  
**Last Inspected On:** 03/11/2019  
**Operating Permit Renewal Date:** 06/30/2022

**Owner Operator Contact:** Colyer Oil Co;David Colyer;Colyer Oil Co

**4068263961**

**Operator Contact:** David Colyer

**Owner/Operator:** Colyer Oil Co

**Owner/Operator:** David Colyer

David Colyer, UST Class A Operator  
David Colyer, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

07	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3594</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No
08	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3595</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
S9	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3596</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Heating Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No
10	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3597</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
11	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3598</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Gasoline	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000	Gilbarco/EMC Basic		No

**Facility Summary in Sanders County in the City of Plains**

**Location:** TOWN PUMP OF PLAINS  
325 E Railroad Ave  
Plains, MT 59859 Sanders

Legacy ID:45-03803

**Facility ID:** 27764  
**Last Inspected On:** 07/02/2021  
**Operating Permit Renewal Date:** 07/21/2024

**Owner Operator Contact:** Van Dorathy;Plains Service Center Inc

**4068265969;4068265969**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Plains 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	22	02/01/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4510</b>	No	06/20/2018		Double Walled	Yes
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
08	22	02/01/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4511</b>	No	06/20/2018		Double Walled	Yes
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No

6,000			Gilbarco-Veeder Root/TLS-450		No
09	22	02/01/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4512</b>	No	06/20/2018		Double Walled	Yes
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		No
10	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5810</b>	No	06/20/2018	Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-450		Yes
11	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5811</b>	No	06/20/2018	Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		Yes
12	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5812</b>	No	06/20/2018	Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No

18,000			Gilbarco-Veeder Root/TLS-450		Yes
13	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5813</b>	No	06/20/2018	Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		Yes

**Facility Summary in Sanders County in the City of Thompson Falls**

**Location:** ELEMENTARY SCHOOL  
315 S Columbia St  
Thompson Falls, MT 59873 Sanders

Legacy ID:45-08537

**Facility ID:** 27806  
**Last Inspected On:** 12/29/2020  
**Operating Permit Renewal Date:** 01/21/2024

**Owner Operator Contact:** N/A ZZZ - TBL\_OWN : 926;School Dist 2 Thompson Falls;School Dist 2 Thompson Falls

**Operator Contact:** Mike Bates

**Owner/Operator:** School Dist 2 Thompson Falls

Mike Bates, UST Class A Operator  
Mike Bates, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	29	08/01/1992	Cathodically Protected Steel	Steel	Flapper Valve
<b>1887</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		11/30/2017	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
10,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Sanders County in the City of Thompson Falls**

**Location:** MOODYS MARKET HARVEST FOODS  
 5254 MT Hwy 200  
 Thompson Falls, MT 59873-0880 Sanders

Legacy ID:56-14114

**Facility ID:** 30755  
**Last Inspected On:** 09/19/2018  
**Operating Permit Renewal Date:** 03/02/2022

**Owner Operator Contact:** Gregory Hurtz

**4068274321**

**Operator Contact:** Richard Fargher

**4067213719**

**Owner/Operator:** Gregory Hurtz

Richard Fargher, UST Class A Operator  
 Richard Fargher, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	18	11/04/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4868</b>	No	06/29/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Veeder Root/TLS-300		No
02	18	11/04/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4869</b>	No	06/29/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
5,000			Veeder Root/TLS-300		No
03	18	11/04/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4870</b>	No	06/29/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	

Diesel	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
8,000	Veeder Root/TLS-300		No

**Facility Summary in Sanders County in the City of Thompson Falls**

**Location:** RONS EXPRESS PAY  
5236 MT Hwy 200  
Thompson Falls, MT 59873-9417 Sanders

Legacy ID:45-13460

**Facility ID:** 27893  
**Last Inspected On:** 10/19/2020  
**Operating Permit Renewal Date:** 10/17/2023

**Owner Operator Contact:** Turk Inc

**4068274653**

**Operator Contact:** Ronald Turk

**4068274653**

**Owner/Operator:** Turk Inc

Ronald Turk, UST Class A Operator  
Ronald Turk, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	05/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2150</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Deferred	No
10,000			Incon/TS-1000		No
02	27	05/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2151</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
10,000			Incon/TS-1000		No
03	27	05/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve

<b>2152</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
4,000			Incon/TS-1000		No
04	27	05/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2153</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Deferred	No
4,000			Incon/TS-1000		No

**Facility Summary in Sanders County in the City of Thompson Falls**

**Location:** THOMPSON FALLS FEED AND FUEL LLC  
1201 Main St  
Thompson Falls, MT 59873 Sanders

Legacy ID:45-02633

**Facility ID:** 27741  
**Last Inspected On:** 11/17/2020  
**Operating Permit Renewal Date:** 12/02/2023

**Owner Operator Contact:** Mark Waters;Thompson Falls Feed and Fuel LLC **4068274325**

**Operator Contact:** Anna Wood;Carole Jensen;Kayla Hoar **4068274325**

**Owner/Operator:** Thompson Falls Feed and Fuel LLC

- Anna Wood, UST Class A Operator
- Anna Wood, UST Class B Operator
- Carole Jensen, UST Class A Operator
- Carole Jensen, UST Class B Operator
- Kayla Hoar, UST Class A Operator
- Kayla Hoar, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	33	04/01/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

<b>3203</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/17/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		10/17/2017	Veeder Root/TLS-300		No
02	33	04/01/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3204</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/17/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		10/17/2017	Veeder Root/TLS-300		No
03	33	04/01/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3205</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/17/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		10/17/2017	Veeder Root/TLS-300		No
04	33	04/01/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3206</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/17/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		10/17/2017	Veeder Root/TLS-300		No

**Facility Summary in Sanders County in the City of Thompson Falls**

**Location:** THOMPSON FALLS UNLOADING TERMINAL  
5315 MT Hwy 200  
Thompson Falls, MT 59873-9417 Sanders

Legacy ID:45-13726

**Facility ID:** 27900  
**Last Inspected On:** 06/20/2001  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** Conoco Inc Billings

**Operator Contact:**

**Owner/Operator:** Conoco Inc Billings

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	25	01/01/1996	Unknown	Steel	
	Yes			None	Yes
Currently in Use			Not Required	Gravity Feed	
Mixture			Deferred	Deferred;MLLD Line Tightness Testing	No
2,000					No

**Facility Summary in Sanders County in the City of Thompson Falls**

**Location:** TOWN PUMP INC THOMPSON FALLS  
1301 W Main St  
Thompson Falls, MT 59873 Sanders

Legacy ID:45-08720

**Facility ID:** 27808  
**Last Inspected On:** 07/01/2021  
**Operating Permit Renewal Date:** 07/21/2024

**Owner Operator Contact:** Don Edmisten;Town Pump Inc Thompson Falls;Town Pump Inc Thompson Falls **4064976700;4064976948;4064976700**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Thompson Falls 1 Town Pump LLC

**Owner/Operator:** Town Pump Inc Thompson Falls

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	41	04/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2614</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/05/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
05	31	04/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2615</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/01/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
06	31	04/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2616</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/01/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
07	31	04/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2617</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		12/01/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
08	22	10/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4115</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/01/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
09	22	10/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4116</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/01/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
10	17	08/18/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4932</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/01/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Sanders County in the City of Trout Creek**

**Location:** HENRYS HIDEAWAY  
4091 MT Hwy 200  
Trout Creek, MT 59874-9505 Sanders

Legacy ID:45-13738

**Facility ID:** 27901  
**Last Inspected On:** 12/12/2018  
**Operating Permit Renewal Date:**

**Owner Operator Contact:**

Operator Contact:

Owner/Operator: Mary Kendziorski

Owner/Operator: Stanley Kendziorski

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4568</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		02/05/2014	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		12/19/2007	Gilbarco/EMC Basic		No
02	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4569</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		02/05/2014	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		12/19/2007	Gilbarco/EMC Basic		No
03	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4570</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		02/05/2014	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		12/19/2007	Gilbarco/EMC Basic		No

04	25	08/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4571</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		02/05/2014	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		12/19/2007	Gilbarco/EMC Basic		No

**Facility Summary in Sanders County in the City of Trout Creek**

**Location:** TROUT CREEK LOCAL STORE INC  
2954 MT Hwy 200  
Trout Creek, MT 59874-9564 Sanders

Legacy ID:45-10228

**Facility ID:** 27844  
**Last Inspected On:** 07/02/2020  
**Operating Permit Renewal Date:** 08/07/2023

**Owner Operator Contact:**

**Operator Contact:** Michele Tammaro

**Owner/Operator:** The Local Store Inc

Michele Tammaro, UST Class A Operator  
Michele Tammaro, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	32	12/04/1989	Cathodically Protected Steel	Steel	Flapper Valve
<b>1607</b>	No		Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		03/17/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
3,000		03/23/2017	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
04	23	12/01/1998	Cathodically Protected Steel	Steel	Flapper Valve
<b>1608</b>	No		Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Gasoline		03/17/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
3,000		03/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
S5	32	12/01/1989	Not Listed	Steel	
<b>5682</b>	Yes			None	No
Currently in Use		12/01/1989	Mechanical Line Leak Detector	Pressurized	
Diesel		03/17/2015	Deferred	MLLD Line Tightness Testing	No
3,000		03/23/2017			No

**Facility Summary in Sanders County in the City of Trout Creek**

**Location:** TROUT CREEK QUIK STOP  
2950 MT Hwy 200  
Trout Creek, MT 59874 Sanders

Legacy ID:56-14146

**Facility ID:** 30782  
**Last Inspected On:** 11/11/2019  
**Operating Permit Renewal Date:** 04/28/2023

**Owner Operator Contact:**

**Operator Contact:** Tanner Tammaro;Tiffany Yee

**4063964949**

**Owner/Operator:** Tammaro Family LLC

Tanner Tammaro, UST Class A Operator  
Tanner Tammaro, UST Class B Operator  
Tiffany Yee, UST Class A Operator  
Tiffany Yee, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	16	04/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4946</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No

02	16	04/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4947</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco/EMC Basic		No
03	16	04/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4948</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco/EMC Basic		No
04	16	04/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4949</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000			Gilbarco/EMC Basic		No

**Facility Summary in Sanders County in the City of Trout Creek**

**Location:** TROUT CREEK SCHOOL DIST 6  
4 School Ln  
Trout Creek, MT 59874 Sanders

Legacy ID:45-07647

**Facility ID:** 27802  
**Last Inspected On:** 01/30/2020  
**Operating Permit Renewal Date:** 04/08/2023

**Owner Operator Contact:** Michael Linderman;School Dist 6 Trout Creek;School Dist 6 Trout Creek **4068273629**

**Operator Contact:** Craig Barrus;Mary Smith;Richard Sorenson **4068273629**

**Owner/Operator:** School Dist 6 Trout Creek

- Craig Barrus, UST Class A Operator
- Craig Barrus, UST Class B Operator
- Mary Smith, UST Class A Operator
- Richard Sorenson, UST Class A Operator
- Richard Sorenson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	28	08/01/1993	Cathodically Protected Steel	Copper	Flapper Valve
2146	No	01/19/2017	Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		02/03/2017	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Manual Interstitial Monitoring	No
1,000			Gilbarco-Veeder Root/TLS-350		No