

Facility Summary in Sheridan County in the City of Medicine Lake

Location: LAKE PIT STOP
729 Main St
Medicine Lake, MT 59247 Sheridan

Legacy ID:46-01127

Facility ID: 27958
Last Inspected On: 10/28/2021
Operating Permit Renewal Date: 03/30/2022

Owner Operator Contact: R Herman;Herman Oil Co

7015722478

Operator Contact: Chanel Johnson;James BoBo;Robert Herman

4064805957;7015722478

Owner/Operator: Lake Pit Stop LLC

Chanel Johnson, UST Class A Operator
Chanel Johnson, UST Class B Operator
James BoBo, UST Class A Operator
James BoBo, UST Class B Operator
Robert Herman, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S6	24	10/01/1997	Unknown	Flexible Plastic	
2323	Yes	10/16/2018		Double Walled	Yes
Currently in Use		06/03/2013	Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
15,000		04/24/2015			No
S7	24	10/01/1997	Unknown	Flexible Plastic	
2324	Yes	10/16/2018		Double Walled	Yes
Currently in Use		06/03/2013	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000		04/24/2015			No
S8	24	10/01/1997	Unknown	Flexible Plastic	

2325	Yes	10/16/2018		Double Walled	Yes
Currently in Use		06/03/2013	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000		04/24/2015			No
S9	24	10/01/1997	Unknown	Flexible Plastic	
2326	Yes	10/16/2018		Double Walled	Yes
Currently in Use		06/03/2013	Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
8,000		04/24/2015			No

Facility Summary in Sheridan County in the City of Medicine Lake

Location: MEDICINE LAKE SCHOOL DIST 7
1 Young St
Medicine Lake, MT 59247 Sheridan

Legacy ID:46-01122

Facility ID: 27957
Last Inspected On: 05/23/2019
Operating Permit Renewal Date: 06/03/2022

Owner Operator Contact: School Dist 7 Medicine Lake

4067892211

Operator Contact: James Simoneau;Mike Olson

Owner/Operator: School Dist 7 Medicine Lake

J Lail, UST Class B Operator
James Simoneau, UST Class A Operator
James Simoneau, UST Class B Operator
Mike Olson, UST Class A Operator
Mike Olson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	30	08/01/1991	Steel Clad	Flexible Plastic	Flapper Valve
1603	No	03/01/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Heating Oil		01/16/2014	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
10,066			OPW / EMCO/EECO 1500		No

Facility Summary in Sheridan County in the City of Plentywood

Location: AUTO TECH SERVICES
327 W 1st Ave
Plentywood, MT 59254-1802 Sheridan

Legacy ID:46-01524

Facility ID: 27977
Last Inspected On: 05/02/2019
Operating Permit Renewal Date: 06/08/2022

Owner Operator Contact: Farmers Union Oil Co Plentywood;Raymond Forster;Raymond J Forster

4067651180

Operator Contact: James Kibbe;L Kibbe

4067651180

Owner/Operator: Farmers Union Oil Co Plentywood

James Kibbe, UST Class A Operator
James Kibbe, UST Class B Global Operator

L James Kibbe, UST Class A Operator
 L James Kibbe, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
08	32	12/10/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1114	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/18/2015	Automatic Tank Gauging 0.2	Deferred	No
4,000			Veeder Root/TLS-450		No
09	32	12/10/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1115	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/18/2015	Automatic Tank Gauging 0.2	Deferred	No
4,000			Veeder Root/TLS-450		No
10	32	12/10/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1116	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/18/2015	Automatic Tank Gauging 0.2	Deferred	No
10,000			Veeder Root/TLS-450		No

Facility Summary in Sheridan County in the City of Plentywood

Location: FARMERS UNION OIL CO PLENTYWOOD
 301 W 1st Ave
 Plentywood, MT 59254-1802 Sheridan

Legacy ID:46-06801

Facility ID: 28147
Last Inspected On: 08/04/2021
Operating Permit Renewal Date: 08/23/2024

Owner Operator Contact: Farmers Union Oil Co Plentywood;Jeffrey Schaefer;Farmers Union Oil Co Plentywood

Operator Contact: L Kibbe

Owner/Operator: Farmers Union Oil Co Plentywood

L James Kibbe, UST Class A Operator

L James Kibbe, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
09	25	06/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1038	No	06/13/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/15/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		07/28/2016	Veeder Root/TLS-450		No
10	25	06/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1039	No	06/13/2015		Double Walled	Yes
Currently in Use		05/20/2009	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/15/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		07/28/2016	Veeder Root/TLS-450		No
11	25	06/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1040	No	06/13/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/15/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		07/28/2016	Veeder Root/TLS-450		No

12	25	06/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1041	No	06/13/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/15/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		03/24/2016	Veeder Root/TLS-450		No
13	25	06/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1042	No	06/13/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/15/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		07/28/2016	Veeder Root/TLS-450		No
14	25	06/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1043	No	06/13/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/15/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		03/24/2016	Veeder Root/TLS-450		No
15	25	06/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1044	No	06/13/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/15/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		03/24/2016	Veeder Root/TLS-450		No

Facility Summary in Sheridan County in the City of Plentywood

Location: KUM AND GO STORE 808
211 W 1st Ave
Plentywood, MT 59254-1830 Sheridan

Legacy ID:46-05200

Facility ID: 28101
Last Inspected On: 04/08/2020
Operating Permit Renewal Date: 09/10/2023

Owner Operator Contact: Krause Gentle Corp

5152260128

Operator Contact: Amanda Schumacher;Anthony Alred;Christopher Bergman;Kevin Kautzman;Mike Simpson;Wayne Lundquist

4805886181;7013401435;7013918114;7016094711;7632293142;9522003139

Owner/Operator: Krause Gentle Corp

Aeon Long, UST Class B Global Operator
 Amanda Schumacher, UST Class A Operator
 Amanda Schumacher, UST Class B Global Operator
 Anthony Alred, UST Class A Operator
 Anthony Alred, UST Class B Global Operator
 Christopher Bergman, UST Class A Operator
 Kevin Kautzman, UST Class A Operator
 Kevin Kautzman, UST Class B Global Operator
 Mike Simpson, UST Class A Operator
 Wayne Lundquist, UST Class A Operator
 Wayne Lundquist, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	39	12/01/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1498	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		06/26/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/28/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000		08/28/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	33	01/01/1988	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
1500	No			Double Walled	Yes
Currently in Use		06/26/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/28/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		08/28/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

04	33	01/01/1988	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
4358	No			Double Walled	Yes
Currently in Use		06/26/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/28/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		08/28/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Sheridan County in the City of Plentywood

Location: MILLER OIL CO INC E RAILROAD AVE
416 W Railroad Ave
Plentywood, MT 59254 Sheridan

Legacy ID:46-08609

Facility ID: 28240
Last Inspected On: 10/28/2021
Operating Permit Renewal Date: 03/04/2022

Owner Operator Contact: Miller Oil Co Inc Culbertson

4067875230

Operator Contact: Kevin Miller;Matthew Miller

4067657730

Owner/Operator: Miller Oil Co Inc Culbertson

Kevin Miller, UST Class A Operator
Kevin Miller, UST Class B Operator
Matthew Miller, UST Class A Operator
Matthew Miller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	54	04/08/1967	Bare Steel	Fiberglass Reinforced Plastic	
1617	Yes	06/18/2015		Double Walled	Yes
Currently in Use		03/23/2009	Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
12,048		08/05/2009			No
S2	60	04/07/1961	Bare Steel	Fiberglass Reinforced Plastic	

1618	Yes	06/18/2015		Double Walled	No
Currently in Use		03/23/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/08/2006	Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
5,327		08/05/2009			No
S3	54	04/08/1967	Bare Steel	Fiberglass Reinforced Plastic	
1619	Yes	06/18/2015		Double Walled	Yes
Currently in Use		03/23/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/08/2006	Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
14,848		08/05/2009			No
S4	53	04/07/1968	Bare Steel	Fiberglass Reinforced Plastic	
1620	Yes	06/18/2015		Double Walled	Yes
Currently in Use		03/23/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/08/2006	Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
14,773		08/05/2009			No

Facility Summary in Sheridan County in the City of Plentywood

Location: MONTANA PIONEER MANOR INC
605 Sheridan St
Plentywood, MT 59254-1715 Sheridan

Legacy ID:46-10679

Facility ID: 28282
Last Inspected On: 01/23/2019
Operating Permit Renewal Date: 06/04/2022

Owner Operator Contact: Montana Pioneer Manor Inc

4067651362

Operator Contact: Charles Archer;Diane Archer;Ervin Steltzer

4067651362;4067652148

Owner/Operator: Montana Pioneer Manor Inc

Charles Archer, UST Class A Operator
Charles Archer, UST Class B Operator
Diane Archer, UST Class A Operator
Diane Archer, UST Class B Operator
Ervin Steltzer, UST Class A Operator
Ervin Steltzer, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	25	05/01/1996	Steel Clad	Flexible Plastic	Flapper Valve
1673	No	01/23/2019	Double-Walled	Double Walled	Yes
Currently in Use			Not Required	U.S. Suction	
Heating Oil			Manual Interstitial Monitoring	Manual Interstitial Monitoring	No
10,000					No

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN COUNTY
100 W Laurel Ave
Plentywood, MT 59254-1647 Sheridan

Legacy ID:46-06278

Facility ID: 28126
Last Inspected On: 02/10/2020
Operating Permit Renewal Date: 06/18/2023

Owner Operator Contact: Sheridan County Sanitarian

4067652310

Operator Contact: Arthur Kurk;Austin Tommerup;D. A. Michels;Gary Bartnes;Jerry Hendrickson;Monica Vines;Ricky Lagerquist

4064892017;4067652310;4067657046;4067657702;4069393719

Owner/Operator: Sheridan County Sanitarian

Arthur Kurk, UST Class A Operator
 Austin Tommerup, UST Class A Operator
 D. A. Michels, UST Class A Operator
 Gary Bartnes, UST Class A Operator
 Gary Bartnes, UST Class B Global Operator
 Jerry Hendrickson, UST Class A Operator
 Jody Lowe, UST Class B Operator
 Monica Vines, UST Class A Operator
 Ricky Lagerquist, UST Class A Operator
 Ryan Mitchell, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	26	09/01/1995	Steel Clad	Flexible Plastic	Flapper Valve
1911	No	11/16/2016	Double-Walled	Double Walled	Yes
Temporarily Out of Use			Auto Dialer	U.S. Suction	Non-corrodible
Heating Oil		01/05/2011	Manual Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
10,000		11/16/2016			No

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN COUNTY SHOP
 MT Hwy 16 E
 Plentywood, MT 59254 Sheridan

Legacy ID:46-06279

Facility ID: 28127
Last Inspected On: 11/21/2019
Operating Permit Renewal Date: 02/19/2023

Owner Operator Contact: Sheridan County Sanitarian **4067652310**

Operator Contact: Arthur Kurk;Austin Tommerup

Owner/Operator: Sheridan County Sanitarian

Arthur Kurk, UST Class A Operator
 Austin Tommerup, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
05	31	01/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1912	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		01/05/2011	Manual Interstitial Monitoring	Deferred	No
10,000					No
06	31	01/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1913	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		01/05/2011	Manual Interstitial Monitoring	Deferred	No
10,150					No
07	31	01/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1914	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		01/05/2011	Manual Interstitial Monitoring	Deferred	No
10,150					No
08	31	01/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Positive Shutoff
1915	No		Double-Walled	None	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Oil, Waste		01/05/2011	Manual Interstitial Monitoring	3-Year Line Tightness Test	No
1,002		11/16/2016			No

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN MEMORIAL HOSPITAL
440 W Laurel Ave
Plentywood, MT 59254-1526 Sheridan

Legacy ID:46-00795

Facility ID: 27939
Last Inspected On: 05/23/2019
Operating Permit Renewal Date: 06/03/2022

Owner Operator Contact: Sheridan Memorial Hospital

Operator Contact: Mark Brensdal;Murvin Anderson

4067652646;4067653700

Owner/Operator: Sheridan Memorial Hospital

Athena Gardenier, UST Class B Global Operator
Athena Gardenier, UST Class B Operator
Mark Brensdal, UST Class A Operator
Murvin Anderson, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	23	10/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
1918	No	11/22/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Heating Oil			Manual Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000		11/22/2016			No

Facility Summary in Sheridan County in the City of Plentywood

Location: WELCOME STOP PLENTYWOOD, LLC
203 Raymond Rd
Plentywood, MT 59254-1545 Sheridan

Legacy ID:46-12667

Facility ID: 28312
Last Inspected On: 08/26/2021
Operating Permit Renewal Date: 11/13/2024

Owner Operator Contact: John Gilligan

Operator Contact: John Gilligan;Lance Chandler

4067652983

Owner/Operator: John Gilligan

John Gilligan, UST Class A Operator
John Gilligan, UST Class B Global Operator
John Gilligan, UST Class B Operator
Lance Chandler, UST Class A Operator
Lance Chandler, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	30	07/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2954	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Not Listed	No
10,000					No
02	30	07/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
2955	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Not Listed	No
10,000					No

Facility Summary in Sheridan County in the City of Reserve

Location: J & R SERVICE
101 Main St
Reserve, MT 59258 Sheridan

Legacy ID:46-02103

Facility ID: 28008
Last Inspected On: 04/24/2019
Operating Permit Renewal Date: 08/10/2022

Owner Operator Contact: J and R Services; Jack Schmidt

4062865276

Operator Contact: Jeff Brensda

4062865276

Owner/Operator: J and R Services

Jeff Brensda, UST Class A Operator
Jeff Brensda, UST Class B Global Operator
Jeff Brensda, UST Class B Operator
Ryan Brensda, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
05	21	07/27/2000	Steel Clad	Flexible Plastic	Flapper Valve
4213	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Deferred	No
2,000					No
03	30	05/21/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4733	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Manual Interstitial Monitoring	Deferred	No
2,000					No