

**Facility Summary in Stillwater County in the City of Absarokee**

**Location:** ROCKIN J  
2993 MT Hwy 78  
Absarokee, MT 59001 Stillwater

Legacy ID:56-13932

**Facility ID:** 30602  
**Last Inspected On:** 03/16/2020  
**Operating Permit Renewal Date:** 07/15/2023

**Owner Operator Contact:** Automatic Car Wash Inc

**Operator Contact:** Julie Lindgren

**4064463123**

**Owner/Operator:** Automatic Car Wash Inc

Julie Lindgren, UST Class A Operator

Julie Lindgren, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	22	05/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
<b>4038</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
2,000		01/19/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	22	05/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
<b>4039</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		07/12/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	22	05/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
<b>4040</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		11/22/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	22	05/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
<b>4041</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		11/24/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	22	05/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
<b>4042</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		11/30/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Stillwater County in the City of Columbus**

**Location:** FARMERS UNION TRADING CO  
101 S Pratten St  
Columbus, MT 59019-0509 Stillwater

Legacy ID:48-03409

**Facility ID:** 28554  
**Last Inspected On:** 07/25/2019  
**Operating Permit Renewal Date:** 10/31/2022

**Owner Operator Contact:** Farmers Union Trading Co Columbus;Jenny Calovis;Farmers Union Trading Co Columbus

**4067800660;4067800660;4067800660**

**Operator Contact:** Jennifer Calovis

**4067800660**

**Owner/Operator:** Farmers Union Trading Co Columbus

Clarence McCade, UST Class B Operator  
Jennifer Calovis, UST Class A Operator  
Jennifer Calovis, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

10	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>1033</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/29/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,500		06/22/2007	Gilbarco/EMC Basic		No
11	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>1034</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		07/29/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
2,500		05/24/2007	Gilbarco/EMC Basic		No
12	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>1035</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		07/29/2016	Automatic Tank Gauging 0.2	Deferred	No
2,500			Gilbarco/EMC Basic		No
14	23	07/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>1037</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/29/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		06/17/2007	Gilbarco/EMC Basic		No
13	23	07/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>4731</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Diesel	07/29/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000	07/01/2007	Gilbarco/EMC Basic		No

**Facility Summary in Stillwater County in the City of Columbus**

**Location:** GITS CONOCO  
740 E Pike Ave  
Columbus, MT 59019 Stillwater

Legacy ID:48-07859

**Facility ID:** 28599  
**Last Inspected On:** 07/25/2019  
**Operating Permit Renewal Date:** 10/26/2022

**Owner Operator Contact:** Gits Inc;N/A ZZZ - TBL\_OWN : 416;Gits Conoco Gary Woltermann **4063224111**

**Operator Contact:** Gary Woltermann;Tracy Gernant **4063224111;4063225026**

**Owner/Operator:** Gits Inc

Gary Woltermann, UST Class A Operator  
Gary Woltermann, UST Class B Global Operator  
Tracy Gernant, UST Class A Operator  
Tracy Gernant, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	42	05/08/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3209</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		07/15/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	42	05/08/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3210</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

10,000

07/15/2010

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

**Facility Summary in Stillwater County in the City of Columbus**

**Location:** TOWN PUMP INC COLUMBUS UST  
602 E 8th Ave N  
Columbus, MT 59019 Stillwater

Legacy ID:48-08691

**Facility ID:** 28607  
**Last Inspected On:** 08/10/2021  
**Operating Permit Renewal Date:** 11/18/2024

**Owner Operator Contact:** Don Edmisten;Town and Country Supply and Management

**4064976948;4064976700**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Columbus 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
03	37	05/01/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2646</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/01/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		No
06	37	09/01/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2647</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/01/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
07	33	12/29/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

<b>2648</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/01/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
08	33	11/01/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2649</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/01/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
09	33	11/01/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2650</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/01/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
10	33	11/01/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2651</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/01/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
11	22	06/25/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4064</b>	No		Double-Walled	Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-450		No
12	22	06/25/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4065</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		No
13	22	06/25/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4066</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		No
14	17	12/30/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4933</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-450		No
15	8	10/01/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
<b>5437</b>	No		Double-Walled	None	Yes

Currently in Use	08/25/2013		Pressurized	
DEF (Not Regulated)		Not Listed	Not Listed	No
10,000				Yes
16	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5968</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
8,000				Yes
17	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
<b>5969</b>	No			No
Currently in Use			Pressurized	
DEF (Not Regulated)				No
10,000				No

**Facility Summary in Stillwater County in the City of Fishtail**

**Location:** FISHTAIL BASIN RANCH  
633 Fiddler Creek Rd  
Fishtail, MT 59028-8021 Stillwater

Legacy ID:56-13917

**Facility ID:** 30587  
**Last Inspected On:** 11/10/2020  
**Operating Permit Renewal Date:** 01/28/2024

**Owner Operator Contact:** Francis Abbott

**6103539700**

**Operator Contact:** Francis Abbott

**6103539700**

**Owner/Operator:** Francis Abbott

**Owner/Operator:** Francis H Abbott Jr

Francis Abbott, UST Class A Operator

Francis Abbott, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types



Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
S1	22	03/01/1999	Steel Clad	Flexible Plastic	Flapper Valve
4400	No	12/15/2017	Double-Walled	Double Walled	Yes
Currently in Use		Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible	
Heating Oil	12/13/2011	Manual Interstitial Monitoring	Continuous Interstitial Monitoring; Manual Interstitial Monitoring	No	
4,000				No	

**Facility Summary in Stillwater County in the City of Fishtail**

**Location:** FISHTAIL GENERAL STORE  
35 W Main St  
Fishtail, MT 59028-0040 Stillwater

Legacy ID:48-03599

**Facility ID:** 28556  
**Last Inspected On:** 10/13/2021  
**Operating Permit Renewal Date:** 03/07/2025

**Owner Operator Contact:** Bill Martin; Bill Martin and Katy Martin; Fishtail General Store **4063284260**

**Operator Contact:** Katy Martin

**Owner/Operator:** Fishtail General Store

Katy Martin, UST Class A Operator  
Katy Martin, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	28	05/01/1993	Steel Clad	Flexible Plastic	High Level Alarm
1086	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		09/25/2015	Automatic Tank Gauging 0.2	Deferred	No
1,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

03	28	05/01/1993	Steel Clad	Flexible Plastic	High Level Alarm
<b>1087</b>	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		09/25/2015	Automatic Tank Gauging 0.2	Deferred	No
1,002			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Stillwater County in the City of Fishtail**

**Location:** NYE TRADING POST  
1997 Nye Rd  
Fishtail, MT 59028 Stillwater

Legacy ID:48-09647

**Facility ID:** 28616  
**Last Inspected On:** 10/13/2021  
**Operating Permit Renewal Date:** 03/05/2022

**Owner Operator Contact:**

<b>Operator Contact:</b> Heath Benson	<b>7203833694</b>
---------------------------------------	-------------------

**Owner/Operator:** Chance Kukowski

**Owner/Operator:** Nye MT LLC

Heath Benson, UST Class A Operator  
Heath Benson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
03	28	10/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>1296</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/17/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000			Veeder Root/TLS-300		No
04	28	10/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>1297</b>	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		09/17/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000			Veeder Root/TLS-300		No

**Facility Summary in Stillwater County in the City of Fishtail**

**Location:** TIPPET RISE COTTONWOOD SITE  
96 S Grove Creek Rd  
Fishtail, MT 59028 Stillwater

Legacy ID:60-15267

**Facility ID:** 30980  
**Last Inspected On:** 09/14/2020  
**Operating Permit Renewal Date:** 10/16/2023

Owner Operator Contact: Tippet Rise Cottonwood Site

4062559287

Operator Contact: Carl Mayer;Christopher Castillo;Dan Luttschwager;Joshua Boyce

2076206273;4063287820;4066207404;4068600947

**Owner/Operator:** Tippet Rise Cottonwood Site

Carl Mayer, UST Class A Operator  
Carl Mayer, UST Class B Global Operator  
Christopher Castillo, UST Class A Operator  
Christopher Castillo, UST Class B Operator  
Dan Luttschwager, UST Class A Operator  
Joshua Boyce, UST Class A Operator  
Joshua Boyce, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	5	10/07/2016	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5618	No	10/07/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/07/2016	Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
1,000			Gilbarco-Veeder Root/TLS-300		Yes

**Facility Summary in Stillwater County in the City of Park City**

Location: KWIK STOP INC  
1 N Clark St  
Park City, MT 59063 Stillwater

Legacy ID:48-06610

Facility ID: 28591  
Last Inspected On: 10/07/2021  
Operating Permit Renewal Date: 03/17/2022

Owner Operator Contact: Margaret Keating;Margaret Keating;Marge Keating

4066332730

Operator Contact: Margaret Keating

4066332730

**Owner/Operator:** Margaret Keating

Margaret Keating, UST Class A Operator  
Margaret Keating, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	24	05/05/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>1507</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/28/2018	Automatic Tank Gauging 0.2	Deferred	No
8,000			Veeder Root/TLS-300		No
04	24	05/05/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>1508</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/28/2018	Automatic Tank Gauging 0.2	Deferred	No
4,000			Veeder Root/TLS-300		No

**Facility Summary in Stillwater County in the City of Park City**

**Location:** ZIP TRIP 50  
Exit 426 & I-90  
Park City, MT 59063 Stillwater

Legacy ID:48-08910

**Facility ID:** 28609  
**Last Inspected On:** 09/24/2020  
**Operating Permit Renewal Date:** 10/21/2023

**Owner Operator Contact:** Jim Alford;CHS Inc - Spokane;Tim Lakers;Kum and Go L C **5095367418**

**Operator Contact:** Jim Alford;Pete Nussbaum **5095367418**

**Owner/Operator:** CHS Inc Spokane Valley

Darcy Ziegler, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator  
Pete Nussbaum, UST Class A Operator  
Pete Nussbaum, UST Class B Global Operator  
Robert Hays, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
18	0		Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5954</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
20,000					Yes
19	0		Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>5955</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
10,000					Yes
20	0		Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5957</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
15,000					Yes
21	0		Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5958</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
15,000				Yes
22	0	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5959</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000				Yes
23	0	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5960</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel, Dyed		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000				Yes
24	0	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5961</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
30,000				Yes

**Facility Summary in Stillwater County in the City of Reed Point**

**Location:** REEDPOINT DOMESTIC WELLS LUST TRUST INV  
4 Division St  
Reed Point, MT 59069 Stillwater

Legacy ID:

**Facility ID:** 17106  
**Last Inspected On:**  
**Operating Permit Renewal Date:**

**Owner Operator Contact:**

**Operator Contact:**

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	35	12/10/1986	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3305</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		04/03/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		03/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Stillwater County in the City of Reed Point**

**Location:** VALLEY FARMERS SUPPLY SURE STOP  
4 N Division St  
Reed Point, MT 59069 Stillwater

Legacy ID:48-01521

**Facility ID:** 28529  
**Last Inspected On:** 03/31/2020  
**Operating Permit Renewal Date:** 09/04/2023

**Owner Operator Contact:** Elskeline Pratton;Reedpoint Sinclair

**4063262319;4063262226**

**Operator Contact:** Elisha Lewis;Ralph Lewis;Scott Black;Steven Shelton

**4063200055;4063225214;4069673100**

**Owner/Operator:** Julie L Pratton

**Owner/Operator:** Valley Farmers Supply

- Elisha Lewis, UST Class A Operator
- Elisha Lewis, UST Class B Global Operator
- Ralph Lewis, UST Class A Operator
- Scott Black, UST Class A Operator
- Scott Black, UST Class B Global Operator
- Steven Shelton, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act



01	35	12/10/1986	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3303</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/03/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		03/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	35	12/10/1986	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3304</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/03/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		03/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	35	12/10/1986	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3305</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		04/03/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		03/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No