

Facility Summary in Stillwater County in the City of Absarokee

Location: ROCKIN J
2993 MT Hwy 78
Absarokee, MT 59001 Stillwater

System Facility ID:56-13932

Facility Code: 30602
Last Inspected On: 08/21/2023
Operating Permit Renewal Date: 11/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Automatic Car Wash Inc;Gene Carlson;Automatic Car Wash Inc (406) 248-2558;(406) 248-2558;(406) 248-2558 donsscarwashmt@gmail.com;donsscarwashmt@gmail.com;donscarwashmt@gmail.com

Operator Contact: Eric Carlson;Gene Carlson;Automatic Car Wash Inc (406) 248-2558;(406) 248-2558;(406) 894-2373 donsscarwashmt@gmail.com;donsscarwashmt@gmail.com;donsxp
ress24@outlook.com

Owner/Operator: Automatic Car Wash Inc (406) 248-2558 donsscarwashmt@gmail.com

Owner/Operator: Gene Carlson, Automatic Car Wash Inc (406) 248-2558 donsscarwashmt@gmail.com

Eric Carlson, UST Class A Operator donsxp
ress24@outlook.com
Eric Carlson, UST Class B Operator donsxp
ress24@outlook.com
Gene Carlson, UST Class A Operator donsca
rwashmt@gmail.com
Gene Carlson, UST Class B Operator donsca
rwashmt@gmail.com

Tank Code	01	Tank Age	27	Tank Installed Date	05/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4038	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	05/08/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	27	Tank Installed Date	05/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4039	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	4000	ATG Test Date		Line Tightness Test Date	12/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	27	Tank Installed Date	05/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4040	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/25/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	27	Tank Installed Date	05/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4041	Spill Test Date	05/20/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	11/25/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	27	Tank Installed Date	05/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4042	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/25/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	3	Tank Installed Date	05/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve; High Level Alarm
Tag Number	6151	Spill Test Date	05/02/2023	Piping Installed Date	05/02/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/08/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	05/02/2023			ATG Type					

Facility Summary in Stillwater County in the City of Columbus

Location: FARMERS UNION TRADING CO
101 S Pratten St
Columbus, MT 59019-0509 Stillwater

System Facility ID:48-03409

Facility Code: 28554
Last Inspected On: 07/09/2025
Operating Permit Renewal Date: 10/31/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Trading Co Columbus

(406) 322-5214

manager@farmersuniontrading.com

Operator Contact:

Owner/Operator: Farmers Union Trading Co Columbus

(406) 322-5214

manager@farmersuniontrading.com

Clarence McCade, UST Class B Operator

Tank Code	10	Tank Age	34	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1033	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	07/09/2025	Tank/Piping CP Test Date	07/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5500	ATG Test Date	07/09/2025	Line Tightness Test Date	07/10/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	11	Tank Age	34	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1034	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	07/09/2025	Tank/Piping CP Test Date	07/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2500	ATG Test Date	07/09/2025	Line Tightness Test Date	01/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	12	Tank Age	34	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1035	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2500	ATG Test Date	07/09/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	14	Tank Age	28	Tank Installed Date	07/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1037	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	07/09/2025	Tank/Piping CP Test Date	07/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/09/2025	Line Tightness Test Date	01/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	13	Tank Age	28	Tank Installed Date	07/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4731	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	07/09/2025	Tank/Piping CP Test Date	07/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/09/2025	Line Tightness Test Date	04/10/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Stillwater County in the City of Columbus

Location: GITS CONOCO
740 E Pike Ave
Columbus, MT 59019 Stillwater

System Facility ID:48-07859

Facility Code: 28599
Last Inspected On: 07/09/2025
Operating Permit Renewal Date: 10/26/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gits Inc (406) 322-4111

Operator Contact: Gary Woltermann;Tracy Gernant (406) 322-4111;(406) 322-5026 warheart@q.com

Owner/Operator: Gits Inc (406) 322-4111

Gary Woltermann, UST Class A Operator
Gary Woltermann, UST Class B Global Operator
Tracy Gernant, UST Class A Operator
Tracy Gernant, UST Class B Global Operator

warheart@q.com
warheart@q.com

Tank Code	01	Tank Age	47	Tank Installed Date	05/08/1979	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3209	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/09/2025	Tank/Piping CP Test Date	07/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/09/2025	Line Tightness Test Date	07/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	47	Tank Installed Date	05/08/1979	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3210	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/09/2025	Tank/Piping CP Test Date	07/09/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	07/09/2025	Line Tightness Test Date	07/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Facility Summary in Stillwater County in the City of Columbus

Location: TOWN PUMP INC COLUMBUS
605 East 8th Avenue
Columbus, MT 59019 Stillwater

System Facility ID:00-32595

Facility Code: 32595
Last Inspected On:
Operating Permit Renewal Date: 09/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Trent Biggers;COLUMBUS TOWN PUMP LLC (406) 457-6700 Trentb@townpump.com

Operator Contact: Trent Biggers;COLUMBUS TOWN PUMP LLC (406) 457-6700 Trentb@townpump.com

Owner/Operator: Trent Biggers,COLUMBUS TOWN PUMP LLC (406) 457-6700 Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Code	01	Tank Age	0	Tank Installed Date	01/01/2026	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	6306	Spill Test Date	02/12/2026	Piping Installed Date	01/01/2026	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/11/2026	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	20000	ATG Test Date	01/28/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/28/2026			ATG Type					
Tank Code	02	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6307	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6308	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6309	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6310	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	06	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6311	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6312	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	08	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6313	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	09	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6314	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	10	Tank Age	1	Tank Installed Date	08/30/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6315	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Stillwater County in the City of Columbus

Location: TOWN PUMP INC COLUMBUS UST
602 E 8th Ave N
Columbus, MT 59019 Stillwater

System Facility ID:48-08691

Facility Code: 28607
Last Inspected On: 03/05/2024
Operating Permit Renewal Date: 07/21/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Columbus 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Columbus 1 Town Pump LLC (406) 497-6700 environmental@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	03	Tank Age	42	Tank Installed Date	05/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2646	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date	08/18/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	42	Tank Installed Date	09/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2647	Spill Test Date	07/03/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date	08/18/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	07	Tank Age	38	Tank Installed Date	12/29/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2648	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date	08/18/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	38	Tank Installed Date	11/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2649	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date	08/18/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	38	Tank Installed Date	11/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2650	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date	08/18/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	38	Tank Installed Date	11/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2651	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Diesel	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date	08/18/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	27	Tank Installed Date	06/25/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4064	Spill Test Date	08/18/2023	Piping Installed Date	06/16/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	12	Tank Age	27	Tank Installed Date	06/25/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4065	Spill Test Date	08/18/2023	Piping Installed Date	06/16/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	13	Tank Age	27	Tank Installed Date	06/25/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4066	Spill Test Date	08/18/2023	Piping Installed Date	06/16/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	14	Tank Age	22	Tank Installed Date	12/30/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4933	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	15	Tank Age	13	Tank Installed Date	10/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5437	Spill Test Date		Piping Installed Date	08/25/2013	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	16	Tank Age	6	Tank Installed Date	06/16/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5968	Spill Test Date	08/18/2023	Piping Installed Date	06/16/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	03/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/18/2023			ATG Type					
Tank Code	17	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5969	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Stillwater County in the City of Fishtail

Location: FISHTAIL BASIN RANCH
633 Fiddler Creek Rd
Fishtail, MT 59028-8021 Stillwater

System Facility ID:56-13917

Facility Code: 30587
Last Inspected On: 12/13/2023
Operating Permit Renewal Date: 01/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Francis Abbott;Francis Abbott Jr (610) 353-9700

Operator Contact: Francis Abbott (610) 353-9700

Owner/Operator: Francis Abbott (610) 353-9700

Owner/Operator: Francis H Abbott Jr (610) 353-9700

Francis Abbott, UST Class A Operator
Francis Abbott, UST Class B Operator

Tank Code	S1	Tank Age	27	Tank Installed Date	03/01/1999	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4400	Spill Test Date	11/02/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	12/13/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	11/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/13/2023			ATG Type					

Facility Summary in Stillwater County in the City of Fishtail

Location: FISHTAIL GENERAL STORE
35 W Main St
Fishtail, MT 59028-0040 Stillwater

System Facility ID:48-03599

Facility Code: 28556
Last Inspected On: 10/24/2024
Operating Permit Renewal Date: 03/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fishtail General Store

fishtailstore@montana.net

Operator Contact: Katy Martin

Owner/Operator: Fishtail General Store

fishtailstore@montana.net

Katy Martin, UST Class A Operator

Katy Martin, UST Class B Operator

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1993	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1086	Spill Test Date	10/18/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/25/2015	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	10/18/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	33	Tank Installed Date	05/01/1993	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1087	Spill Test Date	10/18/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/25/2015	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1002	ATG Test Date	10/18/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Stillwater County in the City of Fishtail

Location: NYE TRADING POST
1997 Nye Rd
Fishtail, MT 59028 Stillwater

System Facility ID:48-09647

Facility Code: 28616
Last Inspected On: 11/11/2024
Operating Permit Renewal Date: 03/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Chance Kukowski;Nye MT LLC (406) 328-6262;(720) 383-3694 hbenson4469@yahoo.com;tandil@live.com

Operator Contact: Heath Benson (720) 383-3694 hbenson4469@yahoo.com

Owner/Operator: Chance Kukowski (406) 328-6262 tandil@live.com
Owner/Operator: Nye MT LLC (406) 328-6262 tandil@live.com
 Heath Benson, UST Class A Operator hbenson4469@yahoo.com
 Heath Benson, UST Class B Global Operator hbenson4469@yahoo.com

Tank Code	03	Tank Age	33	Tank Installed Date	10/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1296	Spill Test Date	11/11/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/11/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/11/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	33	Tank Installed Date	10/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1297	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/11/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Stillwater County in the City of Fishtail

Location: TIPPET RISE COTTONWOOD SITE
96 S Grove Creek Rd
Fishtail, MT 59028 Stillwater

System Facility ID:60-15267

Facility Code: 30980
Last Inspected On: 06/12/2023
Operating Permit Renewal Date: 10/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tippet Rise Cottonwood Site (406) 255-9287 rcoppock@crowleyfleck.com

Operator Contact: Dan Luttschwager (406) 860-0947

Owner/Operator: Tippet Rise Cottonwood Site (406) 255-9287 rcoppock@crowleyfleck.com

Dan Luttschwager, UST Class A Operator

Tank Code	01	Tank Age	10	Tank Installed Date	10/07/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5618	Spill Test Date	05/30/2023	Piping Installed Date	10/07/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/30/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	05/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	05/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Stillwater County in the City of Park City

Location: KWIK STOP INC
1 N Clark St
Park City, MT 59063 Stillwater

System Facility ID:48-06610

Facility Code: 28591
Last Inspected On: 03/14/2025
Operating Permit Renewal Date: 03/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Margaret Keating (406) 633-2730 whoawhat@aol.com

Operator Contact: Margaret Keating (406) 633-2730 whoawhat@aol.com

Owner/Operator: Margaret Keating (406) 633-2730 whoawhat@aol.com
Margaret Keating, UST Class A Operator whoawhat@aol.com
Margaret Keating, UST Class B Operator whoawhat@aol.com

Tank Code	03	Tank Age	29	Tank Installed Date	05/05/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1507	Spill Test Date	02/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/14/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	11/11/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/14/2025			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	29	Tank Installed Date	05/05/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1508	Spill Test Date	02/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/14/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	02/14/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/14/2025			ATG Type	Veeder Root/TLS-300				

Facility Summary in Stillwater County in the City of Park City

Location: ZIP TRIP 50
EXIT 426 AND I-90
Park City, MT 59063 Stillwater

System Facility ID:48-08910

Facility Code: 28609
Last Inspected On: 02/24/2026
Operating Permit Renewal Date: 10/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Hannah Smith, UST Class B Operator hannah.smith3@chsinc.com
 Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com

Tank Code	17	Tank Age	11	Tank Installed Date	06/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5599	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	18	Tank Age	7	Tank Installed Date	10/25/2019	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5954	Spill Test Date	08/26/2021	Piping Installed Date	10/25/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	08/26/2021			ATG Type					
Tank Code	19	Tank Age	7	Tank Installed Date	10/25/2019	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5955	Spill Test Date	08/26/2021	Piping Installed Date	10/25/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/26/2021			ATG Type					
Tank Code	20	Tank Age	7	Tank Installed Date	10/25/2019	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5957	Spill Test Date	08/26/2021	Piping Installed Date	10/25/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/26/2021			ATG Type					
Tank Code	21	Tank Age	7	Tank Installed Date	10/25/2019	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5958	Spill Test Date	08/26/2021	Piping Installed Date	10/25/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/26/2021			ATG Type					
Tank Code	22	Tank Age	7	Tank Installed Date	10/25/2019	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5959	Spill Test Date	08/26/2021	Piping Installed Date	10/25/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/26/2021			ATG Type					
Tank Code	23	Tank Age	7	Tank Installed Date	10/25/2019	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5960	Spill Test Date	08/26/2021	Piping Installed Date	10/25/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/26/2021			ATG Type					
Tank Code	24	Tank Age	7	Tank Installed Date	10/25/2019	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5961	Spill Test Date	08/26/2021	Piping Installed Date	10/25/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/26/2021			ATG Type					

Facility Summary in Stillwater County in the City of Reed Point

Location: VALLEY FARMERS SUPPLY SURE STOP
8 Divison St
Reed Point, MT 59069 Stillwater

System Facility ID:48-01521

Facility Code: 28529
Last Inspected On: 05/08/2023
Operating Permit Renewal Date: 09/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Julie Pratton;Valley Farmers Supply

sblack@vfarmers.com

Operator Contact: Elisha Lewis;Scott Black

(406) 322-5214;(406) 967-3100

cenex@imt.net;sblack@vfarmers.com

Owner/Operator: Julie L Pratton

Owner/Operator: Valley Farmers Supply

Elisha Lewis, UST Class A Operator

cenex@imt.net

Elisha Lewis, UST Class B Global Operator

cenex@imt.net

Scott Black, UST Class A Operator

sblack@vfarmers.com

Scott Black, UST Class B Global Operator

sblack@vfarmers.com

Stephanie Joy, UST Class B Operator

sblack@vfarmers.com

Tank Code	01	Tank Age	40	Tank Installed Date	12/10/1986	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3303	Spill Test Date	05/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	11/04/2022	Tank/Piping CP Test Date	11/04/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/04/2022	Line Tightness Test Date	03/21/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	40	Tank Installed Date	12/10/1986	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3304	Spill Test Date	05/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	11/04/2022	Tank/Piping CP Test Date	11/04/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/04/2022	Line Tightness Test Date	03/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	11/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	40	Tank Installed Date	12/10/1986	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3305	Spill Test Date	03/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	11/04/2022	Tank/Piping CP Test Date	03/31/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	03/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				