

**Facility Summary in Sweet Grass County in the City of Big Timber**

**Location:** THE FORT  
228 Big Timber Loop  
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-02680

**Facility Code:** 28652  
**Last Inspected On:** 06/22/2023  
**Operating Permit Renewal Date:** 09/21/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** J Diamond L Inc;Jeffrey Cowell (406) 932-5992

**Operator Contact:** Justin Cowell (406) 932-5992 justincowell@fortmt.com

**Owner/Operator:** J Diamond L Inc (406) 932-5992

**Owner/Operator:** Jeffrey L Cowell (406) 932-5992

Jeremy Frisk, UST Class B Operator  
Justin Cowell, UST Class A Operator

sports@fortmt.com  
justincowell@fortmt.com

<b>Tank Code</b>	04	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	08/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	3229	<b>Spill Test Date</b>	02/17/2022	<b>Piping Installed Date</b>	06/25/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	06/22/2023	<b>Tank/Piping CP Test Date</b>	06/22/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/22/2023	<b>Line Tightness Test Date</b>	02/19/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/13/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	08/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3230	<b>Spill Test Date</b>	02/17/2022	<b>Piping Installed Date</b>	06/25/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	08/17/2022	<b>Tank/Piping CP Test Date</b>	09/19/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/17/2022	<b>Line Tightness Test Date</b>	02/19/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	02/17/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	08/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	3231	<b>Spill Test Date</b>	07/13/2023	<b>Piping Installed Date</b>	06/25/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/17/2022	<b>Tank/Piping CP Test Date</b>	09/19/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	08/17/2022	<b>Line Tightness Test Date</b>	02/19/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/13/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	21	<b>Tank Installed Date</b>	10/31/2005	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	5052	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/25/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/17/2022	<b>Tank/Piping CP Test Date</b>	09/19/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	08/17/2022	<b>Line Tightness Test Date</b>	02/19/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Sweet Grass County in the City of Big Timber**

**Location:** TOWN PUMP BIG TIMBER 2  
20 A Big Timber Loop Rd  
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-09311

**Facility Code:** 28709  
**Last Inspected On:** 03/18/2025  
**Operating Permit Renewal Date:** 08/23/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Big Timber 2 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Big Timber 2 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	05	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	04/30/2003	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4828	<b>Spill Test Date</b>	10/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	06	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	04/30/2003	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4829	<b>Spill Test Date</b>	10/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				

<b>Tank Code</b>	07	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	04/30/2003	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4830	<b>Spill Test Date</b>	07/08/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	08	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	04/30/2003	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4831	<b>Spill Test Date</b>	07/08/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	09	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	02/24/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6050	<b>Spill Test Date</b>	10/17/2024	<b>Piping Installed Date</b>	02/24/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	10	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	02/24/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6051	<b>Spill Test Date</b>	02/15/2022	<b>Piping Installed Date</b>	02/24/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	11	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	02/24/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6052	<b>Spill Test Date</b>	10/17/2024	<b>Piping Installed Date</b>	02/24/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	18000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	12	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	02/24/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6053	<b>Spill Test Date</b>	07/08/2024	<b>Piping Installed Date</b>	02/24/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	02/21/2022			<b>ATG Type</b>					
<b>Tank Code</b>	13	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	04/05/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6054	<b>Spill Test Date</b>	07/08/2024	<b>Piping Installed Date</b>	04/05/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/31/2025			<b>ATG Type</b>					

<b>Tank Code</b>	14	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	04/05/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6055	<b>Spill Test Date</b>	07/08/2024	<b>Piping Installed Date</b>	04/05/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	15	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	04/05/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6056	<b>Spill Test Date</b>	07/08/2024	<b>Piping Installed Date</b>	04/05/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/18/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/18/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	16	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	04/05/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6057	<b>Spill Test Date</b>	02/21/2022	<b>Piping Installed Date</b>	04/05/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/06/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Sweet Grass County in the City of Big Timber**

**Location:** TOWN PUMP INC BIG TIMBER 1ST AVE  
510 W 1st Ave  
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-13756

**Facility Code:** 28726  
**Last Inspected On:** 04/29/2025  
**Operating Permit Renewal Date:** 10/19/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Big Timber 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Big Timber 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	08/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2652	<b>Spill Test Date</b>	11/06/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/29/2025	<b>Sump Tightness Test Date</b>	06/27/2024	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>	09/01/2015	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/27/2024			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2653	<b>Spill Test Date</b>	11/06/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/29/2025	<b>Sump Tightness Test Date</b>	06/27/2024	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>	09/01/2015	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/27/2024			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				

<b>Tank Code</b>	03	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2654	<b>Spill Test Date</b>	11/06/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/29/2025	<b>Sump Tightness Test Date</b>	06/27/2024	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>	09/01/2015	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/27/2024			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2655	<b>Spill Test Date</b>	06/27/2024	<b>Piping Installed Date</b>	10/29/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/27/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/01/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/27/2024			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	05	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2656	<b>Spill Test Date</b>	06/27/2024	<b>Piping Installed Date</b>	10/29/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/27/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/01/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/27/2024			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	06	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	05/01/2002	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4649	<b>Spill Test Date</b>	06/27/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/29/2025	<b>Sump Tightness Test Date</b>	06/27/2024	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>	09/01/2015	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/27/2024			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	07	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	05/01/2002	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4650	<b>Spill Test Date</b>	11/06/2024	<b>Piping Installed Date</b>	10/29/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/29/2025	<b>Sump Tightness Test Date</b>	06/27/2024	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>	09/01/2015	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/06/2024			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				