

Facility Summary in Sweet Grass County in the City of Big Timber

Location: BIG TIMBER 2 TOWN PUMP LLC
 20 A Big Timber Loop Rd
 Big Timber, MT 59011 Sweet Grass

Legacy ID:49-09311

Facility ID: 28709
Last Inspected On: 06/09/2021
Operating Permit Renewal Date: 11/08/2024

Owner Operator Contact: Lawrence Hilton

Operator Contact: Trent Biggers

Owner/Operator: Big Timber 2 Town Pump LLC

Trent Biggers, UST Class A Operator
 Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	18	04/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4828	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
06	18	04/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4829	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		No
07	18	04/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4830	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
08	18	04/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4831	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		No

Facility Summary in Sweet Grass County in the City of Big Timber

Location: THE FORT
228 Big Timber Loop
Big Timber, MT 59011 Sweet Grass

Legacy ID:49-02680

Facility ID: 28652
Last Inspected On: 09/19/2020
Operating Permit Renewal Date: 09/21/2023

Owner Operator Contact: J Diamond L Inc

4069325992

Operator Contact: Justin Cowell

4069325992

Owner/Operator: J Diamond L Inc

Owner/Operator: Jeffrey L Cowell

Jeremy Frisk, UST Class B Operator
Justin Cowell, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	25	08/01/1996	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve

3229	No			Double Walled	Yes
Currently in Use		06/25/2010	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/12/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		12/11/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	25	08/01/1996	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3230	No			Double Walled	Yes
Currently in Use		06/25/2010	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/12/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000		12/05/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	25	08/01/1996	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3231	No			Double Walled	Yes
Currently in Use		06/25/2010	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/12/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		12/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	16	10/31/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve; Flapper Valve
5052	No			Double Walled	Yes
Currently in Use		06/25/2010	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/12/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
20,000		12/07/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Sweet Grass County in the City of Big Timber

Location: TOWN PUMP INC BIG TIMBER 1ST AVE
510 W 1st Ave
Big Timber, MT 59011 Sweet Grass

Legacy ID: 49-13756

Facility ID: 28726
Last Inspected On: 07/18/2021
Operating Permit Renewal Date: 12/05/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Big Timber 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	08/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2652	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		09/01/2015	Gilbarco-Veeder Root/TLS-350		No
02	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2653	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		09/01/2015	Gilbarco-Veeder Root/TLS-350		No
03	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2654	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No

12,000		09/01/2015	Gilbarco-Veeder Root/TLS-350		No
04	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2655	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
05	25	10/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2656	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
06	19	05/01/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4649	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		09/01/2015	Gilbarco-Veeder Root/TLS-350		No
07	19	05/01/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4650	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No

5,000

09/01/2015

Gilbarco-Veeder Root/TLS-350

No
