

Facility Summary in Teton County in the City of

Location: MALMSTROM AFB F 8
US Hwy 287 Rural Location
, MT Teton

System Facility ID:50-09037

Facility Code: 28881
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	307	Spill Test Date		Piping Installed Date	09/18/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: BREEN OIL CARD LOCK S
505 S Main St
Choteau, MT 59422 Teton

System Facility ID:56-14147

Facility Code: 30783
Last Inspected On: 06/23/2022
Operating Permit Renewal Date: 10/15/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: K B Leasing	4064662575
Operator Contact: Jerold Breen;Jesse Jenkins;Liam Breen	4064462575;4064662575;4065908788

Owner/Operator: K B Leasing

Jerold Breen, UST Class A Operator
Jerold Breen, UST Class B Operator
Jesse Jenkins, UST Class A Operator
Liam Breen, UST Class A Operator
Liam Breen, UST Class B Global Operator
Liam Breen, UST Class B Operator

Tank Code	S1	Tank Age	19	Tank Installed Date	01/14/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4950	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	S2	Tank Age	19	Tank Installed Date	01/14/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4951	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	3000	ATG Test Date	06/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	S3	Tank Age	19	Tank Installed Date	01/14/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4952	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	06/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	S4	Tank Age	19	Tank Installed Date	01/14/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4953	Spill Test Date		Piping Installed Date	05/10/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	06/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	S5	Tank Age	19	Tank Installed Date	01/14/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4954	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	S6	Tank Age	19	Tank Installed Date	01/14/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	4955	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	06/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Teton County in the City of Choteau

Location: DESHS TIRE AND AUTO LLC
401 Main Ave S
Choteau, MT 59422 Teton

System Facility ID:50-07565

Facility Code: 28865
Last Inspected On: 04/29/2021
Operating Permit Renewal Date: 04/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Roy and Pandora Deshner 4064662066

Operator Contact: Roy Deshner 4064662066

Owner/Operator: Roy and Pandora Deshner

Roy Deshner, UST Class A Operator
Roy Deshner, UST Class B Global Operator

Tank Code	05	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1487	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1488	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Teton County in the City of Choteau

Location: MAIN STREET EXPRESS LLP
222 Main Ave N
Choteau, MT 59422 Teton

System Facility ID:56-13816

Facility Code: 30503
Last Inspected On: 11/03/2022
Operating Permit Renewal Date: 11/21/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Main Street Express LLP 4064665863

Operator Contact: Jerold Breen;Liam Breen 4064462575;4064662575

Owner/Operator: Main Street Express LLP

- Jerold Breen, UST Class A Operator
- Jerold Breen, UST Class B Operator
- Liam Breen, UST Class A Operator
- Liam Breen, UST Class B Global Operator
- Liam Breen, UST Class B Operator
- Rhonda Brewster, UST Class B Operator

Tank Code	01	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	488	Spill Test Date	11/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/01/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	489	Spill Test Date	11/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	11/01/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	490	Spill Test Date	11/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/01/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 10
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09039

Facility Code: 28883
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	309	Spill Test Date		Piping Installed Date	06/19/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/24/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 11
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09040

Facility Code: 28884
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	310	Spill Test Date		Piping Installed Date	06/19/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/24/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 2
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09031

Facility Code: 28878
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ	4067316188
Operator Contact: Candace Ellsworth;Curtis Hester;William Smith	4067316239;4067317128

Owner/Operator: 341 CES CEANQ	
Candace Ellsworth, UST Class A Operator	
Candace Ellsworth, UST Class B Global Operator	
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	
William Smith, UST Class B Global Operator	

Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	304	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/24/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 3
US Hwy 287
Choteau, MT 59422 Teton

System Facility ID:50-09032

Facility Code: 28879
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ	4067316188
Operator Contact: Candace Ellsworth;Curtis Hester;William Smith	4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	305	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 9
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09038

Facility Code: 28882
Last Inspected On: 06/08/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	308	Spill Test Date		Piping Installed Date	09/11/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/24/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB H 10
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09061

Facility Code: 28889
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	33	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	315	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/02/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB H 11
Road 221
Choteau, MT 59422 Teton

System Facility ID:50-09062

Facility Code: 28890
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	33	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	316	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/20/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/25/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MOUNTAIN VIEW CO-OP 158
215 Main Ave S
Choteau, MT 59422 Teton

System Facility ID:50-03593

Facility Code: 28795
Last Inspected On: 09/26/2022
Operating Permit Renewal Date: 10/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop

Operator Contact: Timothy Kelly

Owner/Operator: Mountain View Coop

Timothy Kelly, UST Class A Operator
Timothy Kelly, UST Class B Operator

Tank Code	S6	Tank Age	28	Tank Installed Date	05/15/1996	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1469	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/24/2022	Sump Tightness Test Date	10/16/2013	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/23/2023	Line Tightness Test Date	05/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	28	Tank Installed Date	08/15/1996	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1470	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/24/2022	Sump Tightness Test Date	10/16/2013	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/23/2023	Line Tightness Test Date	05/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	21	Tank Installed Date	11/26/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	4929	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/24/2022	Sump Tightness Test Date	10/16/2013	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/23/2023	Line Tightness Test Date	05/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	21	Tank Installed Date	11/26/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4930	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/24/2022	Sump Tightness Test Date	10/16/2013	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/23/2023	Line Tightness Test Date	05/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Teton County in the City of Dutton

Location: DUTTON SCHOOL DIST 28
101 2nd St NE
Dutton, MT 59433-9670 Teton

System Facility ID:50-03600

Facility Code: 28797
Last Inspected On: 08/15/2023
Operating Permit Renewal Date: 08/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 28C Dutton Brady4064763201

Operator Contact: Jeremy Locke;School Dist 28C Dutton Brady4064763201

Owner/Operator: School Dist 28C Dutton Brady

Jeremy Locke, UST Class A Operator
Jeremy Locke, UST Class B Operator

Tank Code	S2	Tank Age	35	Tank Installed Date	08/21/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	842	Spill Test Date	08/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/15/2023	Line Tightness Test Date	09/29/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/15/2023			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB H 2
Road 221
Dutton, MT 59433 Teton

Facility Code: 28886
Last Inspected On: 06/07/2021
System Facility ID:50-09053
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ	4067316188
Operator Contact: Candace Ellsworth;Curtis Hester;William Smith	4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	35	Tank Installed Date	05/21/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	312	Spill Test Date		Piping Installed Date	06/30/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/20/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/25/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB J 1
I-15
Dutton, MT 59433 Teton

Facility Code: 28891
Last Inspected On: 06/07/2021
System Facility ID:50-09074
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ
Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

Tank Code	01	Tank Age	62	Tank Installed Date	06/02/1962	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	317	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/17/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/26/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB J 11
I-15
Dutton, MT 59433 Teton

Facility Code: 28894
Last Inspected On: 06/07/2021
System Facility ID:50-09084
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	320	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/17/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/26/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/26/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB J 2
Road 379
Dutton, MT 59433 Teton

Facility Code: 28892
Last Inspected On: 04/06/2021
System Facility ID:50-09075
Operating Permit Renewal Date: 05/25/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	318	Spill Test Date		Piping Installed Date	01/04/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Dutton

Location: MOUNTAIN VIEW CO OP
210 N Grain Ave
Dutton, MT 59433 Teton

System Facility ID:60-15071

Facility Code: 30842
Last Inspected On: 04/21/2023
Operating Permit Renewal Date: 05/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle

Operator Contact: Judy Statham;Pat Trainor;William (Ralph) Floyd4064016025;4064532435;8008233276

Owner/Operator: Mountain View Coop Black Eagle

Judy Statham, UST Class A Operator
Pat Trainor, UST Class A Operator
Pat Trainor, UST Class B Global Operator
William (Ralph) Floyd, UST Class A Operator
William (Ralph) Floyd, UST Class B Operator

Tank Code	01	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5111	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/19/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	02	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5112	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	03	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5113	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	04	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5114	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	05	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5115	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	06	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5116	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	07	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5117	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	40000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	08	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5118	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	06/19/2020	Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	40000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	09	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5119	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	40000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	10	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5120	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	40000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Veeder Root/TLS-350				
Tank Code	11	Tank Age	17	Tank Installed Date	11/07/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	5121	Spill Test Date	05/29/2019	Piping Installed Date	01/24/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/19/2020	Sump Tightness Test Date	10/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Electronic Line Leak Detector;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	40000	ATG Test Date		Line Tightness Test Date	06/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/10/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Teton County in the City of Dutton

Location: MOUNTAIN VIEW COOP DUTTON
110 Main St W
Dutton, MT 59433-9686 Teton

System Facility ID:50-03701

Facility Code: 28798
Last Inspected On: 08/17/2022
Operating Permit Renewal Date: 09/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle

Operator Contact: David Douglas

Owner/Operator: Mountain View Coop Black Eagle

David Douglas, UST Class A Operator
David Douglas, UST Class B Global Operator
Thomas DeMars, UST Class B Operator

Tank Code	07	Tank Age	25	Tank Installed Date	08/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4108	Spill Test Date	08/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/28/2022	Sump Tightness Test Date	07/28/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/12/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/12/2022	Line Tightness Test Date	03/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	34	Tank Installed Date	04/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4688	Spill Test Date	08/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/28/2022	Sump Tightness Test Date	07/28/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	07/12/2022	Line Tightness Test Date	03/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	08/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	34	Tank Installed Date	04/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4689	Spill Test Date	08/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/28/2022	Sump Tightness Test Date	07/28/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	07/12/2022	Line Tightness Test Date	03/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	34	Tank Installed Date	04/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4690	Spill Test Date	08/16/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/28/2022	Sump Tightness Test Date	07/28/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	07/12/2022	Line Tightness Test Date	03/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Teton County in the City of Fairfield

Location: GREENFIELDS IRRIGATION DISTRICT UST
105 Central Ave W
Fairfield, MT 59436 Teton

System Facility ID:50-07428

Facility Code: 28858
Last Inspected On: 03/14/2023
Operating Permit Renewal Date: 08/05/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Greenfields Irrigation District4064672533

Operator Contact: Eric Mayer4065903254

Owner/Operator: Greenfields Irrigation District

Eric Mayer, UST Class A Operator

Eric Mayer, UST Class B Operator

Tank Code	03	Tank Age	32	Tank Installed Date	10/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1241	Spill Test Date	03/01/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	03/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/01/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	04	Tank Age	32	Tank Installed Date	10/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1242	Spill Test Date	03/01/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	03/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/01/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Teton County in the City of Fairfield

Location: MALMSTROM AFB F 4
Road 408
Fairfield, MT 59436 Teton

Facility Code: 28880
Last Inspected On: 06/08/2021
System Facility ID:50-09033
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ
Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	306	Spill Test Date		Piping Installed Date	11/16/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/02/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Fairfield

Location: MALMSTROM AFB H 1
US Hwy 89
Fairfield, MT 59436 Teton

System Facility ID:50-09052

Facility Code: 28885
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	07	Tank Age	18	Tank Installed Date	09/28/2006	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5086	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/19/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/31/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Teton County in the City of Fairfield

Location: MALMSTROM AFB H 9
Road 408
Fairfield, MT 59436 Teton

System Facility ID:50-09060

Facility Code: 28888
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/30/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ 4067316188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith 4067316239;4067317128

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	02	Tank Age	33	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	314	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/19/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Fairfield

Location: MOUNTAIN VIEW COOP FAIRFIELD
219 Central Ave
Fairfield, MT 59436 Teton

System Facility ID:50-03596

Facility Code: 28796
Last Inspected On: 07/26/2022
Operating Permit Renewal Date: 09/27/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle

Operator Contact: Dave Douglas 4067506748

Owner/Operator: Mountain View Coop Black Eagle

Dave Douglas, UST Class A Operator
Nathan Pitcher, UST Class B Global Operator

Tank Code	10	Tank Age	32	Tank Installed Date	12/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1235	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/05/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	32	Tank Installed Date	12/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1236	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/05/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	32	Tank Installed Date	12/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1237	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/05/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	26	Tank Installed Date	08/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1238	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/05/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	14	Tank Age	26	Tank Installed Date	08/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1239	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/05/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	15	Tank Age	26	Tank Installed Date	08/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1240	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/05/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Fairfield

Location: MOUNTAIN VIEW COOP THE STORE
305 Central Ave
Fairfield, MT 59436 Teton

System Facility ID:50-11700

Facility Code: 28945
Last Inspected On: 09/13/2023
Operating Permit Renewal Date: 09/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle

Operator Contact: Charla Merja;David Douglas;Denna Lekan 4065901235

Owner/Operator: Mountain View Coop Black Eagle

- Charla Merja, UST Class A Operator
- Charla Merja, UST Class B Operator
- David Douglas, UST Class A Operator
- David Douglas, UST Class B Global Operator
- Denna Lekan, UST Class A Operator
- Denna Lekan, UST Class B Operator
- Nathan Pitcher, UST Class B Global Operator

Tank Code	01	Tank Age	34	Tank Installed Date	07/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2354	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	34	Tank Installed Date	07/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2355	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	20000	ATG Test Date		Line Tightness Test Date	05/01/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	34	Tank Installed Date	07/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2356	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	04/17/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				