

Facility Summary in Toole County in the City of Galata

Location: FRASER OIL INC GALATA  
30342 US Hwy 2 & Galata Rd  
Galata, MT 59444 Toole

System Facility ID:51-02311

Facility Code: 29035  
Last Inspected On: 11/16/2023  
Operating Permit Renewal Date: 03/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fraser Oil Inc4062923833

Operator Contact: Cory Fraser

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator  
Cory Fraser, UST Class B Operator

Tank Code	03	Tank Age	32	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1126	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/03/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	32	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1127	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/29/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Shelby

Location: BTI CONOCO  
Hwy 2  
Shelby, MT 59474 Toole

System Facility ID:51-08629

Facility Code: 29119  
Last Inspected On: 07/28/2023  
Operating Permit Renewal Date: 11/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ben Taylor Inc;Pat Simons;Simons Petroleum Inc;Unclaimed 4064342431

Operator Contact: Scott Curry;Simons Petroleum Inc 5108629 4065763365

Owner/Operator: Ben Taylor Inc

Owner/Operator: Pat Simons

Owner/Operator: Simons Petroleum Inc

Owner/Operator: Unclaimed

Scott Curry, UST Class A Operator  
Scott Curry, UST Class B Operator

Tank Code	09	Tank Age	19	Tank Installed Date	05/27/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5012	Spill Test Date	07/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	19	Tank Installed Date	05/27/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5013	Spill Test Date	07/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	5000	ATG Test Date	07/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	19	Tank Installed Date	05/27/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5014	Spill Test Date	07/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	19	Tank Installed Date	05/27/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5015	Spill Test Date	07/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Shelby

Location: H AND R INC 6  
101 E Main St  
Shelby, MT 59474-2127 Toole

System Facility ID:51-06113

Facility Code: 29092  
Last Inspected On: 11/15/2023  
Operating Permit Renewal Date: 01/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Singh Inc4068682062

Operator Contact: Harinder Singh;Singh Inc4068682062;4068682062

Owner/Operator: Singh Inc

Frank Kruse, UST Class B Operator  
Harinder Singh, UST Class A Operator

Tank Code	06	Tank Age	35	Tank Installed Date	08/16/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	426	Spill Test Date	07/13/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/12/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	35	Tank Installed Date	08/16/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	427	Spill Test Date	07/13/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/12/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	08	Tank Age	35	Tank Installed Date	08/16/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	428	Spill Test Date	12/08/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/12/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	35	Tank Installed Date	08/16/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	429	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/12/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Toole County in the City of Shelby

Location: NOONS FOOD STORE  
602 W Roosevelt Hwy 2  
Shelby, MT 59474 Toole

System Facility ID:51-00104

Facility Code: 28986  
Last Inspected On: 03/30/2022  
Operating Permit Renewal Date: 04/18/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MCP INC4064345882

Operator Contact: Manjit Maan2096478034

Owner/Operator: MCP INC

Manjit Maan, UST Class A Operator  
Manjit Maan, UST Class B Operator

Tank Code	02	Tank Age	52	Tank Installed Date	02/18/1972	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3557	Spill Test Date	03/30/2022	Piping Installed Date	09/21/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	11/03/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/30/2022	Line Tightness Test Date	11/02/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	52	Tank Installed Date	02/18/1972	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4382	Spill Test Date	03/30/2022	Piping Installed Date	09/21/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	11/03/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/30/2022	Line Tightness Test Date	10/31/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	52	Tank Installed Date	02/18/1972	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	4383	Spill Test Date	05/02/2023	Piping Installed Date	09/21/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	11/03/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/30/2022	Line Tightness Test Date	11/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Shelby

Location: TOWN PUMP INC SHELBY  
1350 W Roosevelt Hwy  
Shelby, MT 59474 Toole

System Facility ID:51-09749

Facility Code: 29136  
Last Inspected On: 12/17/2021  
Operating Permit Renewal Date: 04/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Shelby 1 Town Pump LLC	4064976700
Operator Contact: Trent Biggers	

Owner/Operator: Shelby 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	36	Tank Installed Date	09/07/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2657	Spill Test Date	01/25/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	36	Tank Installed Date	09/07/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2658	Spill Test Date	07/27/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No



		Overfill Test Date	04/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	36	Tank Installed Date	09/07/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2659	Spill Test Date	07/27/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2663	Spill Test Date	07/27/2021	Piping Installed Date	10/22/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/27/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date	04/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	25	Tank Installed Date	07/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4248	Spill Test Date	07/27/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/27/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	36	Tank Installed Date	09/07/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4291	Spill Test Date	07/27/2021	Piping Installed Date	10/22/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date	04/01/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	36	Tank Installed Date	09/07/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4292	Spill Test Date	07/27/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4293	Spill Test Date	01/25/2022	Piping Installed Date	10/22/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/27/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	09	Tank Age	23	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4413	Spill Test Date	01/25/2022	Piping Installed Date	10/22/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2022	Sump Tightness Test Date	03/03/2020	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/27/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/27/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	12	Tank Installed Date	09/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5416	Spill Test Date		Piping Installed Date	10/02/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/18/2012	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Automatic Tank Gauging 0.2	Primary Pipe Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	0	Tank Installed Date		Tank Material	Other	Piping Material	Steel	Overfill Types	
Tag Number	5862	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	150	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	12	Tank Age	0	Tank Installed Date		Tank Material	Other	Piping Material	Steel	Overfill Types	
Tag Number	5874	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product		PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	150	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	13	Tank Age	0	Tank Installed Date		Tank Material	Other	Piping Material	Steel	Overfill Types	
Tag Number	5890	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	150	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Toole County in the City of Sunburst

Location: TAYLORS BULK PLANT  
55 Railroad Ave  
Sunburst, MT 59482 Toole

System Facility ID:51-02025

Facility Code: 29031  
Last Inspected On: 04/08/2022  
Operating Permit Renewal Date: 06/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ben Taylor Inc

Operator Contact: Scott Curry

Owner/Operator: Ben Taylor Inc

Brian Robertson, UST Class B Operator  
Dan Gliko, UST Class B Operator  
Scott Curry, UST Class A Operator

Tank Code	S6	Tank Age	25	Tank Installed Date	08/31/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4137	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date	04/08/2022	Sump Tightness Test Date	04/20/2016	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	04/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	25	Tank Installed Date	08/31/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4138	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date	04/08/2022	Sump Tightness Test Date	04/20/2016	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	20000	ATG Test Date		Line Tightness Test Date	04/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	25	Tank Installed Date	08/31/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4139	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date	04/08/2022	Sump Tightness Test Date	04/20/2016	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	04/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	25	Tank Installed Date	08/31/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4140	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date	04/08/2022	Sump Tightness Test Date	04/20/2016	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	04/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S10	Tank Age	25	Tank Installed Date	08/31/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4161	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date	04/08/2022	Sump Tightness Test Date	04/20/2016	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1500	ATG Test Date		Line Tightness Test Date	04/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

	Overfill Test Date		ATG Type			
--	--------------------	--	----------	--	--	--

Facility Summary in Toole County in the City of Sweet Grass

Location: DUTY FREE AMERICAS  
60 3rd Ave  
Sweet Grass, MT 59484-0249 Toole

System Facility ID:51-01377

Facility Code: 29016  
Last Inspected On: 08/03/2023  
Operating Permit Renewal Date: 09/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Duty Free America's Hollywood 9549867700

Operator Contact: Chad Underdal

Owner/Operator: Duty Free America's Hollywood

Chad Underdal, UST Class A Operator  
Chad Underdal, UST Class B Operator  
Kelsey Burley, UST Class B Operator

Tank Code	03	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	871	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/17/2023	Tank/Piping CP Test Date	10/10/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	872	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/17/2023	Tank/Piping CP Test Date	10/10/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Facility Summary in Toole County in the City of Sweet Grass

Location: SHORYA ENTERPRISES  
510 2nd St  
Sweet Grass, MT 59484 Toole

System Facility ID:51-12405

Facility Code: 29154  
Last Inspected On: 03/27/2021  
Operating Permit Renewal Date: 03/27/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sunita Toora4084499333

Operator Contact: Cody Young;William Cooper4063352905;4069953058

Owner/Operator: Sunita Toora

Cody Young, UST Class A Operator  
Cody Young, UST Class B Operator  
William Cooper, UST Class A Operator  
William Cooper, UST Class B Operator

Tank Code	01	Tank Age	33	Tank Installed Date	06/25/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2718	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	03/27/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/27/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	33	Tank Installed Date	06/25/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2719	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	03/27/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/27/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				