

Facility Summary in Toole County in the City of Galata

Location: FRASER OIL INC GALATA
30342 US Hwy 2 & Galata Rd
Galata, MT 59444 Toole

Legacy ID:51-02311

Facility ID: 29035
Last Inspected On: 11/03/2020
Operating Permit Renewal Date: 03/17/2024

Owner Operator Contact: Fraser Oil Inc

Operator Contact: Cory Fraser

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1126	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/23/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000		12/11/2008	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	29	10/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1127	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/23/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000		12/11/2008	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Toole County in the City of Shelby

Location: H and R #3
602 W Roosevelt Hwy
Shelby, MT 59474 Toole

Legacy ID:51-00104

Facility ID: 28986
Last Inspected On: 04/25/2019
Operating Permit Renewal Date: 09/29/2022

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula

4065420384

Owner/Operator: Singh Inc

Frank Kruse, UST Class B Global Operator

Frank Kruse, UST Class B Operator

Harinder Singh, UST Class A Operator

Joe Ackerman, UST Class B Operator

Rajinder Singh, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	49	02/18/1972	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
3557	No			None	Yes
Currently in Use		09/21/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/09/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		07/30/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
01	49	02/18/1972	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
4382	No			None	Yes
Currently in Use		09/21/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/09/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		07/30/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	49	02/18/1972	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
4383	No			None	Yes
Currently in Use		09/21/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/09/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

10,000

07/30/2014

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Toole County in the City of Shelby

Location: MAIN STREET EXXON
101 E Main St
Shelby, MT 59474-2127 Toole

Legacy ID:51-06113

Facility ID: 29092
Last Inspected On: 01/05/2021
Operating Permit Renewal Date: 01/08/2024

Owner Operator Contact: Ben Taylor Inc

4064345076

Operator Contact: Scott Curry

Owner/Operator: Ben Taylor Inc

Casey Nickol, UST Class B Operator
Scott Curry, UST Class A Operator
Thomas Loch, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	32	08/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
426	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/15/2017	Continuous Interstitial Monitoring	ELLD 0.2	No
8,000			Gilbarco-Veeder Root/ILS-250		No
07	32	08/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
427	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/15/2017	Continuous Interstitial Monitoring	ELLD 0.2	No
4,000			Gilbarco-Veeder Root/ILS-250		No
08	32	08/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve

428	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/15/2017	Continuous Interstitial Monitoring	ELLD 0.2	No
4,000			Gilbarco-Veeder Root/ILS-250		No
09	32	08/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
429	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/15/2017	Continuous Interstitial Monitoring	ELLD 0.2	No
4,000			Gilbarco-Veeder Root/ILS-250		No

Facility Summary in Toole County in the City of Shelby

Location: SIMONS PETROLEUM INC 5108629
530 W Roosevelt Hwy
Shelby, MT 59474-1810 Toole

Legacy ID:51-08629

Facility ID: 29119
Last Inspected On: 09/30/2020
Operating Permit Renewal Date: 11/27/2023

Owner Operator Contact: Simons Petroleum Inc

Operator Contact: Scott Curry;Simons Petroleum Inc 5108629

Owner/Operator: Simons Petroleum Inc

Scott Curry, UST Class A Operator
Scott Curry, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
09	16	05/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5012	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	16	05/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5013	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	16	05/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5014	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	16	05/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5015	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Toole County in the City of Shelby

Location: TOWN PUMP INC SHELBY
1350 W Roosevelt Hwy
Shelby, MT 59474 Toole

Legacy ID:51-09749

Facility ID: 29136
Last Inspected On: 02/21/2019
Operating Permit Renewal Date: 04/01/2022

Owner Operator Contact: Don Edmisten;Travel Plaza of Montana Inc;Town Pump Inc Shelby **4064976948**

Operator Contact: Daniel Sampson

Owner/Operator: Shelby 1 Town Pump LLC

Daniel Sampson, UST Class A Operator
Daniel Sampson, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	33	09/07/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2657	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/29/2019	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-350		No
02	33	09/07/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2658	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		01/29/2019	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
03	33	09/07/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve;Positive Shutoff
2659	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/29/2019	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
07	29	08/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

2663	No			Double Walled	Yes
Currently in Use		10/22/2012	Not Required	Safe Suction	
Diesel		11/27/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
08	22	07/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4248	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		11/27/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
04	33	09/07/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4291	No			Double Walled	Yes
Currently in Use		10/22/2012	Mechanical Line Leak Detector	Pressurized	
Diesel		01/29/2019	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
05	33	09/07/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4292	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		01/29/2019	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
06	29	08/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4293	No			Double Walled	Yes
Currently in Use		10/22/2012	Not Required	Safe Suction	
Diesel		11/27/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
09	20	10/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4413	No		Double-Walled	Double Walled	Yes
Currently in Use		10/22/2012	Mechanical Line Leak Detector	Pressurized	
Diesel		11/27/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Toole County in the City of Sunburst

Location: TAYLORS BULK PLANT
55 Railroad Ave
Sunburst, MT 59482 Toole

Legacy ID:51-02025

Facility ID: 29031
Last Inspected On: 01/07/2019
Operating Permit Renewal Date: 06/22/2022

Owner Operator Contact: Ben Taylor Inc;Ben Taylor;Ben Taylor Inc

4064345076

Operator Contact: Scott Curry

Owner/Operator: Ben Taylor Inc

Brian Robertson, UST Class B Operator
Dan Gliko, UST Class B Operator
Scott Curry, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

S6	22	08/31/1999	Unknown	Flexible Plastic	
4137	Yes	04/20/2016		Double Walled	Yes

Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S7	22	08/31/1999	Unknown	Flexible Plastic	
4138	Yes	04/20/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
20,000					No
S8	22	08/31/1999	Unknown	Flexible Plastic	
4139	Yes	04/20/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
20,000					No
S9	22	08/31/1999	Unknown	Flexible Plastic	
4140	Yes	04/20/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
20,000					No
S10	22	08/31/1999	Unknown	Flexible Plastic	
4161	Yes	04/20/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	

Diesel
Deferred
Continuous Interstitial Monitoring
No
1,500
No

Facility Summary in Toole County in the City of Sweet Grass

Location: DUTY FREE AMERICA'S
60 3rd Ave
Sweet Grass, MT 59484-0249 Toole

Legacy ID:51-01377

Facility ID: 29016
Last Inspected On: 08/13/2020
Operating Permit Renewal Date: 09/06/2023

Owner Operator Contact: N/A ZZZ - TBL_OWN : 325;Exports Inc

Operator Contact: Lori Schoendaller

Owner/Operator: Duty Free America's Hollywood

Jeff Nanini, UST Class B Operator
Lori Schoendaller, UST Class A Operator
Lori Schoendaller, UST Class B Operator
Peggy Rossmiller, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
871	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/10/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
872	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/10/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Toole County in the City of Sweet Grass

Location: MARS GAS and GROCERY
510 2nd St
Sweet Grass, MT 59484 Toole

Legacy ID:51-12405

Facility ID: 29154
Last Inspected On: 03/27/2021
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: Paper Dollar Bar Inc

4063352905

Operator Contact: Cody Young

4063352905

Owner/Operator: Paper Dollar Bar Inc

Cody Young, UST Class A Operator

Cody Young, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	30	06/25/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2718	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		03/23/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	30	06/25/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2719	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		03/23/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No