

## Facility Summary in Treasure County in the City of Hysham

**Location:** FRIENDLY CORNER  
718 Elliot Ave  
Hysham, MT 59038 Treasure

System Facility ID:52-06316

**Facility Code:** 29186  
**Last Inspected On:** 06/26/2024  
**Operating Permit Renewal Date:** 09/29/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Cross Petroleum Services Billings (406) 252-5519

**Operator Contact:** Gregory Cross;R J Serpe;Timothy Fife (406) 698-2967 gcross@crosspetroleumservice.com;rlsrp@yahoo.com

**Owner/Operator:** Cross Petroleum Services Billings (406) 252-5519

Greg Cross, UST Class A Operator  
R J Serpe, UST Class A Operator  
R J Serpe, UST Class B Global Operator  
Shelli Thrower, UST Class B Operator  
Timothy Fife, UST Class A Operator

gcross@crosspetroleumservice.com  
rlsrp@yahoo.com  
rlsrp@yahoo.com  
seves74@hotmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	47	<b>Tank Installed Date</b>	08/01/1979	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1405	<b>Spill Test Date</b>	06/26/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/26/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/26/2024	<b>Line Tightness Test Date</b>	03/24/2012	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/19/2024			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	02	<b>Tank Age</b>	47	<b>Tank Installed Date</b>	08/01/1979	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1406	<b>Spill Test Date</b>	06/26/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/26/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No

<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/26/2024	<b>Line Tightness Test Date</b>	04/01/2012	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/19/2024			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	03	<b>Tank Age</b>	47	<b>Tank Installed Date</b>	08/01/1979	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1407	<b>Spill Test Date</b>	06/26/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/26/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>	06/26/2024	<b>Line Tightness Test Date</b>	04/05/2012	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/19/2024			<b>ATG Type</b>	Incon/TS-550 EVO				

### Facility Summary in Treasure County in the City of Hysham

**Location:** VALLEY FARMERS SUPPLY HYSHAM  
121 Elliot Ave  
Hysham, MT 59038 Treasure

System Facility ID:52-01905

**Facility Code:** 29169  
**Last Inspected On:** 10/26/2023  
**Operating Permit Renewal Date:** 02/27/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Valley Farmers Supply

sblack@vfarmers.com

**Operator Contact:** Scott Black

(406) 967-3100

sblack@vfarmers.com

**Owner/Operator:** Valley Farmers Supply

sblack@vfarmers.com

Earl Mitchell, UST Class B Operator  
Scott Black, UST Class A Operator  
Scott Black, UST Class B Global Operator  
Shawn Hedges, UST Class B Operator  
Sheryl Warren, UST Class B Operator

emitchell@vfarmers.com  
sblack@vfarmers.com  
sblack@vfarmers.com

<b>Tank Code</b>	03	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3144	<b>Spill Test Date</b>	10/26/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/26/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	10/26/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/26/2023			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	04	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3145	<b>Spill Test Date</b>	10/26/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/26/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	10/26/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/26/2023			<b>ATG Type</b>	Veeder Root/TLS-300				