

Facility Summary in Treasure County in the City of Hysham

Location: FARMERS UNION OIL CO HYSHAM
121 Elliot Ave
Hysham, MT 59038 Treasure

Legacy ID:52-01905

Facility ID: 29169
Last Inspected On: 11/16/2020
Operating Permit Renewal Date: 02/27/2024

Owner Operator Contact: Farmers Union Oil Co Worden;Farmers Union Oil Company;Tri County Coop **4063425221;4069673100**

Operator Contact: Scott Black **4069673100**

Owner/Operator: Farmers Union Oil Co Worden

- Earl Mitchell, UST Class B Operator
- Scott Black, UST Class A Operator
- Scott Black, UST Class B Global Operator
- Shawn Hedges, UST Class B Operator
- Sheryl Warren, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	07/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3144	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/08/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000			Veeder Root/TLS-300		No
04	31	07/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3145	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/08/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000			Veeder Root/TLS-300		No

Facility Summary in Treasure County in the City of Hysham

Location: FRIENDLY CORNER
 718 Elliot Ave
 Hysham, MT 59038 Treasure

Legacy ID:52-06316

Facility ID: 29186
Last Inspected On: 07/02/2021
Operating Permit Renewal Date: 09/29/2024

Owner Operator Contact: Cross Petroleum Services Billings

4062525519

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Cross Petroleum Services Billings

Greg Cross, UST Class A Operator
 R J Serpe, UST Class A Operator
 R J Serpe, UST Class B Global Operator
 Shelli Thrower, UST Class B Operator
 Timothy Fife, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	42	08/01/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1405	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/12/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		03/24/2012	Incon/TS-550 EVO		No
02	42	08/01/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1406	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		04/12/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		04/01/2012	Incon/TS-550 EVO		No
03	42	08/01/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1407	No		Lined Interior/Impressed Current	None	Yes

Currently in Use		Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	04/12/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
3,000	04/05/2012	Incon/TS-550 EVO		No
