

Facility Summary in Treasure County in the City of Hysham

Location: FRIENDLY CORNER  
718 Elliot Ave  
Hysham, MT 59038 Treasure

System Facility ID:52-06316

Facility Code: 29186  
Last Inspected On: 07/02/2021  
Operating Permit Renewal Date: 09/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Billings 4062525519

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife 4066982967

Owner/Operator: Cross Petroleum Services Billings

Greg Cross, UST Class A Operator  
R J Serpe, UST Class A Operator  
R J Serpe, UST Class B Global Operator  
Shelli Thrower, UST Class B Operator  
Timothy Fife, UST Class A Operator

|             |                  |                    |            |                          |            |                               |                                  |                          |                               |                |                   |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-------------------------------|----------------|-------------------|
| Tank Code   | 01               | Tank Age           | 45         | Tank Installed Date      | 08/01/1979 | Tank Material                 | Bare Steel                       | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm  |
| Tag Number  | 1405             | Spill Test Date    | 07/02/2021 | Piping Installed Date    |            | Tank Construction             | Lined Interior/Impressed Current | Piping Construction      | None                          | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector    | Piping Type              | Pressurized                   | CP Met Types   | Impressed Current |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date | 11/07/2023 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2       | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No                |
| Capacity    | 10000            | ATG Test Date      | 08/09/2022 | Line Tightness Test Date | 03/24/2012 | Secondary Tank Leak Detection |                                  | Secondary Pipe Detection |                               | Energy Act     | No                |
|             |                  | Overfill Test Date | 07/02/2021 |                          |            | ATG Type                      | Incon/TS-550 EVO                 |                          |                               |                |                   |
| Tank Code   | 02               | Tank Age           | 45         | Tank Installed Date      | 08/01/1979 | Tank Material                 | Bare Steel                       | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm  |
| Tag Number  | 1406             | Spill Test Date    | 07/02/2021 | Piping Installed Date    |            | Tank Construction             | Lined Interior/Impressed Current | Piping Construction      | None                          | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector    | Piping Type              | Pressurized                   | CP Met Types   | Impressed Current |
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date | 11/07/2023 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2       | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No                |
| Capacity    | 10000            | ATG Test Date      | 08/09/2022 | Line Tightness Test Date | 04/01/2012 | Secondary Tank Leak Detection |                                  | Secondary Pipe Detection |                               | Energy Act     | No                |

|             |                  |                    |            |                          |            |                               |                                  |                          |                               |                |                   |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|-------------------------------|----------------|-------------------|
|             |                  | Overfill Test Date | 07/02/2021 |                          |            | ATG Type                      | Incon/TS-550 EVO                 |                          |                               |                |                   |
| Tank Code   | 03               | Tank Age           | 45         | Tank Installed Date      | 08/01/1979 | Tank Material                 | Bare Steel                       | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm  |
| Tag Number  | 1407             | Spill Test Date    | 07/02/2021 | Piping Installed Date    |            | Tank Construction             | Lined Interior/Impressed Current | Piping Construction      | None                          | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector    | Piping Type              | Pressurized                   | CP Met Types   | Impressed Current |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date | 09/10/2020 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2       | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No                |
| Capacity    | 3000             | ATG Test Date      | 11/07/2023 | Line Tightness Test Date | 04/05/2012 | Secondary Tank Leak Detection |                                  | Secondary Pipe Detection |                               | Energy Act     | No                |
|             |                  | Overfill Test Date | 07/02/2021 |                          |            | ATG Type                      | Incon/TS-550 EVO                 |                          |                               |                |                   |

Facility Summary in Treasure County in the City of Hysham

Location: VALLEY FARMERS SUPPLY HYSHAM  
121 Elliot Ave  
Hysham, MT 59038 Treasure

System Facility ID:52-01905

Facility Code: 29169  
Last Inspected On: 10/26/2023  
Operating Permit Renewal Date: 02/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Valley Farmers Supply

Operator Contact: Scott Black4069673100

Owner/Operator: Valley Farmers Supply

Earl Mitchell, UST Class B Operator  
Scott Black, UST Class A Operator  
Scott Black, UST Class B Global Operator  
Shawn Hedges, UST Class B Operator  
Sheryl Warren, UST Class B Operator

|             |                  |                    |            |                          |            |                               |                              |                          |                               |                |               |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tank Code   | 03               | Tank Age           | 34         | Tank Installed Date      | 07/01/1990 | Tank Material                 | Cathodically Protected Steel | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number  | 3144             | Spill Test Date    | 10/26/2023 | Piping Installed Date    |            | Tank Construction             |                              | Piping Construction      | None                          | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                 | Piping Type              | Safe Suction                  | CP Met Types   | Galvanic      |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date | 10/26/2023 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   |                               | Vapor Recovery | No            |
| Capacity    | 1000             | ATG Test Date      | 10/26/2023 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                              | Secondary Pipe Detection |                               | Energy Act     | No            |
|             |                  | Overfill Test Date | 10/26/2023 |                          |            | ATG Type                      | Veeder Root/TLS-300          |                          |                               |                |               |
| Tank Code   | 04               | Tank Age           | 34         | Tank Installed Date      | 07/01/1990 | Tank Material                 | Cathodically Protected Steel | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number  | 3145             | Spill Test Date    | 10/26/2023 | Piping Installed Date    |            | Tank Construction             |                              | Piping Construction      | None                          | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                 | Piping Type              | Safe Suction                  | CP Met Types   | Galvanic      |
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date | 10/26/2023 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   |                               | Vapor Recovery | No            |
| Capacity    | 1000             | ATG Test Date      | 10/26/2023 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                              | Secondary Pipe Detection |                               | Energy Act     | No            |
|             |                  | Overfill Test Date | 10/26/2023 |                          |            | ATG Type                      | Veeder Root/TLS-300          |                          |                               |                |               |