

Facility Summary in Valley County in the City of Fort Peck

Location: ROCK CREEK MARINA
652 S Rock Creek Rd
Fort Peck, MT 59223-7001 Valley

Legacy ID:29-11049

Facility ID: 24936
Last Inspected On: 09/03/2021
Operating Permit Renewal Date: 11/11/2021

Owner Operator Contact: Rock Creek Marina Inc **4064852560**

Operator Contact: Monty LeTexier;William Hinrichs **4064650241**

Owner/Operator: Rock Creek Marina Inc

Monty LeTexier, UST Class A Operator
Monty LeTexier, UST Class B Operator
William Hinrichs, UST Class A Operator
William Hinrichs, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	30	05/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1846	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/15/2018	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco/EMC Basic		No

Facility Summary in Valley County in the City of Fort Peck

Location: US ARMY CORPS OF ENGINEERS FORT PECK
Judith Rd
Fort Peck, MT 59223 Valley

Legacy ID:53-04612

Facility ID: 29268
Last Inspected On: 04/19/2021
Operating Permit Renewal Date: 08/28/2024

Owner Operator Contact: US Army Corps of Engineers Fort Peck **4065263411**

Operator Contact: Mary Nyquist;Seth Reedy;Thomas Grant **4065263411;4065263431**

Owner/Operator: US Army Corps of Engineers Fort Peck

Mary Nyquist, UST Class A Operator
Mary Nyquist, UST Class B Operator
Seth Reedy, UST Class A Operator

Seth Reedy, UST Class B Global Operator
 Seth Reedy, UST Class B Operator
 Thomas Grant, UST Class A Operator
 Thomas Grant, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	31	06/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2154	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/10/2018	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
9,000		04/10/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	31	06/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2155	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		04/10/2018	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
2,500		04/10/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	31	06/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2156	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		04/10/2018	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No

2,500

04/10/2018

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Valley County in the City of Frazer

Location: NAKODA TRAILSTOP
Main St & 2nd St
Frazer, MT 59225 Valley

Legacy ID:56-13890

Facility ID: 30564
Last Inspected On: 06/17/1999
Operating Permit Renewal Date:

Owner Operator Contact:

Operator Contact: Anita Trice

4066502409

Owner/Operator: Fort Peck Assiniboine and Sioux Tribes

Anita Trice, UST Class A Operator
Anita Trice, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	24	12/01/1997	Steel Clad	Flexible Plastic	Flapper Valve
	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	
Gasoline			Automatic Tank Gauging 0.1;Manual Interstitial Monitoring;Tank Tightness Testing	Continuous Interstitial Monitoring	No
2,000					No

Facility Summary in Valley County in the City of Glasgow

Location: AGLAND COOP GLASGOW
54197 US Hwy 2
Glasgow, MT 59230-1803 Valley

Legacy ID:53-03160

Facility ID: 29245
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 07/11/2024

Owner Operator Contact: Agland Coop Wolf Point;Donavon Boos;Grain Growers Oil Co **4064872741**

Operator Contact: Kory Hentges

4062284641

Owner/Operator: Agland Coop Wolf Point

Allen Richard, UST Class B Global Operator
Allen Richard, UST Class B Operator

Kory Hentges, UST Class A Operator
 Kory Hentges, UST Class B Operator
 Michael Pallvoda, UST Class B Operator
 Steven Long, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	30	05/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
1574	No	10/26/2012		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/27/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	30	05/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
1575	No	10/26/2012		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/27/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	30	05/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
1576	No	10/26/2012		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/27/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	30	05/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm

1577	No	10/26/2012		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/27/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	30	05/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve; High Level Alarm
1578	No	10/26/2012		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Safe Suction	Galvanic
Diesel		09/27/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
2,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	9	10/01/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve; High Level Alarm
5391	No	10/26/2012	Double-Walled	Double Walled	Yes
Currently in Use		08/31/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000		10/26/2012	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Valley County in the City of Glasgow

Location: EZZIE'S MIDTOWN
204 1st Ave N
Glasgow, MT 59230-1820 Valley

Legacy ID: 53-05709

Facility ID: 29276
Last Inspected On: 11/21/2019
Operating Permit Renewal Date: 04/04/2023

Owner Operator Contact: Andy Anderson; Anderson Oil Co Inc

Operator Contact: Brandon Hoerster; David Skiff; Jody Faul

4062282313; 4062282713; 4066542331

Owner/Operator: Ezzies Wholesale Inc

Owner/Operator: Jody Faul

Brandon Hoerster, UST Class A Operator
David Skiff, UST Class A Operator
Jennifer Fischer, UST Class B Operator
Jody Faul, UST Class A Operator
Jody Faul, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	21	06/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4201	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350		No
06	21	06/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4202	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES WHOLESALE GLASGOW
1330 US Hwy 2 W
Glasgow, MT 59230 Valley

Legacy ID:53-10475

Facility ID: 29361
Last Inspected On: 01/27/2021
Operating Permit Renewal Date: 03/24/2024

Owner Operator Contact: Ezzies Wholesale Inc; Steve Fossum

Operator Contact: Brandon Hoerster; David Skiff

4062282713; 4066542331

Owner/Operator: Ezzies Wholesale Inc

- Brandon Hoerster, UST Class A Operator
- Brandon Hoerster, UST Class B Global Operator
- Brandon Hoerster, UST Class B Operator
- David Skiff, UST Class A Operator
- David Skiff, UST Class B Global Operator
- David Skiff, UST Class B Operator
- Jarid Jensen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	19	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4758	No			Double Walled	Yes
Currently in Use		08/15/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		11/27/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
08	19	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4759	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000		06/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	19	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4760	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000		06/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	19	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4761	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

8,000		06/28/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	19	11/21/2002	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
4762	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
12	19	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4763	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000		10/10/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
13	19	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4764	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
14	19	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4765	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
30,000		06/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Valley County in the City of Glasgow

Location: FRANCES MAHON DEACONESS HOSPITAL
621 3rd St S
Glasgow, MT 59230-2604 Valley

Legacy ID:53-05192

Facility ID: 29273
Last Inspected On: 07/27/2020
Operating Permit Renewal Date: 11/06/2023

Owner Operator Contact: Frances Mahon Deaconess Hospital

4062284351

Operator Contact: David Nixdorf

Owner/Operator: Frances Mahon Deaconess Hospital

David Nixdorf, UST Class A Operator
Jeff Damboise, UST Class B Operator
Paul Sallee, UST Class B Operator
Walter Adams, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	26	10/01/1995	Steel Clad	Flexible Plastic	Flapper Valve
1118	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel		05/22/2013	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
4,000		07/06/2017	Veeder Root/TLS-300		No
04	26	10/01/1995	Steel Clad	Flexible Plastic	Flapper Valve
1119	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel		05/22/2013	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
2,000		07/06/2017	Veeder Root/TLS-300		No

Facility Summary in Valley County in the City of Glasgow

Location: GLASGOW INTERNATIONAL AIRPORT
89 Airport Rd
Glasgow, MT 59230-2843 Valley

Legacy ID:53-03271

Facility ID: 29250
Last Inspected On: 07/14/2021
Operating Permit Renewal Date:

Owner Operator Contact: Dave Reinhardt;N/A ZZZ - TBL_OWN : 1084;Valley County Airport Commission;Valley County Airport Commission

4062288221

Operator Contact: Lucas Locke;Manfreda Donovan;Robert Lipscomb

4062302257;4062637010;4062932067

Owner/Operator: Dave Reinhardt

Owner/Operator: Valley County Airport Commission

Lucas Locke, UST Class A Operator

Lucas Locke, UST Class B Operator

Manfreda Donovan, UST Class A Operator

Manfreda Donovan, UST Class B Operator

Robert Lipscomb, UST Class A Operator

Robert Lipscomb, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	41	01/01/1980	Cathodically Protected Steel	Steel	High Level Alarm
2726	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Impressed Current
Aviation Gas		10/15/2018	Statistical Inventory Reconciliation	Not Listed	No
12,000		08/09/2006			No
02	40	04/07/1981	Cathodically Protected Steel	No Piping	High Level Alarm
2727	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Not Listed	Impressed Current
Jet Fuel (Jet-A, Jet-A1, JP5)		10/15/2018	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
12,000		08/09/2006			No

Facility Summary in Valley County in the City of Glasgow

Location: HOLIDAY STATIONSTORE 281
108 1st Ave N
Glasgow, MT 59230 Valley

Legacy ID:53-09712

Facility ID: 29324
Last Inspected On: 05/18/2020
Operating Permit Renewal Date: 10/01/2023

Owner Operator Contact: Camie Pederson;Rocky Mountain Oil LLC - Env Director

9528308899

Operator Contact: Chuck Nyberg;Dean Townsend

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
Chuck Nyberg, UST Class A Operator
Dean Townsend, UST Class A Operator
Dylan Imbrescia, UST Class B Operator
Greg Brewer, UST Class B Global Operator
Jon Garcia, UST Class B Operator
Travis Struckman, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	32	08/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4431	No			Double Walled	Yes
Currently in Use		08/12/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/03/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
01	35	03/01/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4432	No			Double Walled	Yes
Currently in Use		08/12/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/03/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

03	33	04/15/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4433	No			Double Walled	Yes
Currently in Use		08/12/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		04/03/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Valley County in the City of Glasgow

Location: LAKERIDGE LODGING and BAIT SHOP
5990 MT Hwy 24 S
Glasgow, MT 59230-8822 Valley

Legacy ID:53-08383

Facility ID: 29312
Last Inspected On: 01/08/2019
Operating Permit Renewal Date: 05/04/2022

Owner Operator Contact: Gene Moore;Gene Moore;Team Lakeridge LLC **4065263597**

Operator Contact: Carrie Mindt;Gene Moore **4065263597**

Owner/Operator: Carrie Mindt

Owner/Operator: Team Lakeridge LLC

Carrie Mindt, UST Class A Operator
Carrie Mindt, UST Class B Global Operator
Carrie Mindt, UST Class B Operator
Gene Moore, UST Class A Operator
Gene Moore, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	24	05/15/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1509	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		01/21/2013	Manual Interstitial Monitoring	Deferred	No
4,000					No
06	24	05/15/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1510	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		01/21/2013	Manual Interstitial Monitoring	Deferred	No
2,000					No

Facility Summary in Valley County in the City of Glasgow

Location: TRAILSIDE GENERAL STORE GLASGOW
54271 Hwy 2 E
Glasgow, MT 59230 Valley

Legacy ID:53-07787

Facility ID: 29299
Last Inspected On: 12/15/2020
Operating Permit Renewal Date:

Owner Operator Contact: Wayne Waarvik

4062289528

Operator Contact: Wayne Waarvik

4062289528

Owner/Operator: Wayne Waarvik

Wayne Waarvik, UST Class A Operator
Wayne Waarvik, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	30	09/09/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
3873	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Diesel		01/23/2018	Inventory Reconciliation; Tank Tightness Testing	MLLD Line Tightness Testing	No
10,000					No
04	30	09/09/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
3874	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		01/23/2018	Inventory Reconciliation; Tank Tightness Testing	MLLD Line Tightness Testing	No
10,000					No

Facility Summary in Valley County in the City of Hinsdale

Location: RAIDERS QUICK STOP
842 1st Ave N
Hinsdale, MT 59241 Valley

Legacy ID:60-15298

Facility ID: 31002
Last Inspected On: 07/22/2020
Operating Permit Renewal Date: 10/11/2023

Owner Operator Contact: Ezzies Wholesale Inc

Owner/Operator: Ezzies Wholesale Inc

David Skiff, UST Class A Operator

Nickole Cline, UST Class B Global Operator

Nickole Cline, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	4	04/10/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5716	No	11/11/2016	Double-Walled	Double Walled	Yes
Currently in Use		04/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
2,000		07/05/2017	Incon/TS-550 EVO		Yes
02	4	04/10/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5717	No	11/11/2016	Double-Walled	Double Walled	Yes
Currently in Use		04/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
5,000		07/05/2017	Incon/TS-550 EVO		Yes
03	4	04/10/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5718	No	11/11/2016	Double-Walled	Double Walled	Yes
Currently in Use		04/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes

2,000		07/05/2017	Incon/TS-550 EVO		Yes
04	4	04/10/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5727	No	11/11/2016	Double-Walled	Double Walled	No
Currently in Use		04/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
2,500		07/05/2017	Incon/TS-550 EVO		Yes

Facility Summary in Valley County in the City of Nashua

Location: AGLAND COOP NASHUA
810 Front St
Nashua, MT 59248 Valley

Legacy ID:53-10461

Facility ID: 29360
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 08/07/2024

Owner Operator Contact: Agland Coop Wolf Point

Operator Contact: James Merideth

Owner/Operator: Agland Coop Wolf Point

- Allen Richard, UST Class B Global Operator
- Allen Richard, UST Class B Operator
- James Merideth, UST Class A Operator
- James Merideth, UST Class B Global Operator
- Michael Pallvoda, UST Class B Operator
- Steven Long, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	31	03/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
937	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/17/2017	Automatic Tank Gauging 0.2	Deferred	No

2,000			Gilbarco/EMC Basic		No
06	31	03/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
938	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/17/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco/EMC Basic		No
07	31	03/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
939	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/17/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco/EMC Basic		No
08	31	03/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
940	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/17/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco/EMC Basic		No

Facility Summary in Valley County in the City of Opheim

Location: PRO COOP OPHEIM
45 S Main
Opheim, MT 59250 Valley

Legacy ID:53-07814

Facility ID: 29300
Last Inspected On: 11/19/2020
Operating Permit Renewal Date: 02/12/2024

Owner Operator Contact: Pro Coop Opheim

4067623231

Operator Contact: Jason Nasby;Myron Redfield;Timothy Stenglein

4067623231

Owner/Operator: Pro Coop Opheim

Jason Nasby, UST Class A Operator
Jason Nasby, UST Class B Operator
Myron Redfield, UST Class A Operator
Myron Redfield, UST Class B Operator

Timothy Stenglein, UST Class A Operator

Timothy Stenglein, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	28	08/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1820	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/17/2017	Manual Interstitial Monitoring	Deferred	No
2,300					No
05	28	08/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1821	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasohol/Ethanol		10/17/2017	Manual Interstitial Monitoring	Deferred	No
3,700					No
06	28	08/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1822	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/17/2017	Manual Interstitial Monitoring	Deferred	No
2,300					No
07	28	08/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1823	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Diesel	10/17/2017	Manual Interstitial Monitoring	Deferred	No
3,700				No

Facility Summary in Valley County in the City of Saint Marie

Location: MT AVIATION RESEARCH BLDG CO BLDG 649A
 Address Unavailable (DEQ_GEO_LOC_INFO : 44095) Legacy ID:53-12774
 Saint Marie, MT 59231 Valley

Facility ID: 29550
Last Inspected On: 05/11/2021
Operating Permit Renewal Date: 10/19/2024

Owner Operator Contact: Montana Aviation Research Co **4065243777**

Operator Contact: Brad Juntunen;Brian Mix;Darcel Wesen;Kenny Bryan;Kevin Wersal;Lynn Blatter;Michael Myrick;Preston Murch **4062289584;4062631362;4062634591;4062636931;4065243777**

Owner/Operator: Montana Aviation Research Co

- Brad Juntunen, UST Class A Operator
- Brad Juntunen, UST Class B Operator
- Brian Mix, UST Class A Operator
- Brian Mix, UST Class B Operator
- Darcel Wesen, UST Class A Operator
- Darcel Wesen, UST Class B Operator
- Kenny Bryan, UST Class A Operator
- Kenny Bryan, UST Class B Global Operator
- Kenny Bryan, UST Class B Operator
- Kevin Wersal, UST Class A Operator
- Kevin Wersal, UST Class B Operator
- Lynn Blatter, UST Class A Operator
- Lynn Blatter, UST Class B Global Operator
- Michael Myrick, UST Class A Operator
- Michael Myrick, UST Class B Operator
- Preston Murch, UST Class A Operator
- Preston Murch, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

S4	27	01/01/1994	Bare Steel	Fiberglass Reinforced Plastic
----	----	------------	------------	-------------------------------

2975	Yes			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
50,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
S5	27	01/01/1994	Bare Steel	Fiberglass Reinforced Plastic	
2976	Yes			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
50,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No