

Facility Summary in Valley County in the City of Fort Peck

Location: ROCK CREEK MARINA
652 S Rock Creek Rd
Fort Peck, MT 59223-7001 Valley

System Facility ID:29-11049

Facility Code: 24936
Last Inspected On: 07/20/2022
Operating Permit Renewal Date: 10/08/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rock Creek Marina Inc4064852560

Operator Contact: Monty LeTexier;William Hinrichs4064650241

Owner/Operator: Rock Creek Marina Inc

Monty LeTexier, UST Class A Operator
Monty LeTexier, UST Class B Operator
William Hinrichs, UST Class A Operator
William Hinrichs, UST Class B Operator

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1846	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/09/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2021			ATG Type	Gilbarco/TLS-300				

Facility Summary in Valley County in the City of Fort Peck

Location: US ARMY CORPS OF ENGINEERS FORT PECK
Judith Rd
Fort Peck, MT 59223 Valley

System Facility ID:53-04612

Facility Code: 29268
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 08/28/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	US Army Corps of Engineers Fort Peck	4065263411
Operator Contact:	Mary Nyquist;Seth Reedy;Thomas Grant	4065263411;4065263431

Owner/Operator: US Army Corps of Engineers Fort Peck

Mary Nyquist, UST Class A Operator
Mary Nyquist, UST Class B Operator
Seth Reedy, UST Class A Operator
Seth Reedy, UST Class B Global Operator
Seth Reedy, UST Class B Operator
Thomas Grant, UST Class A Operator
Thomas Grant, UST Class B Operator

Tank Code	08	Tank Age	34	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2154	Spill Test Date	04/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/19/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/19/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	9000	ATG Test Date		Line Tightness Test Date	04/19/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	34	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2155	Spill Test Date	04/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	04/19/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/19/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date	04/19/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	34	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2156	Spill Test Date	04/19/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/19/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/19/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date	04/19/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: AGLAND COOP GLASGOW
54197 US Hwy 2
Glasgow, MT 59230-1803 Valley

System Facility ID:53-03160

Facility Code: 29245
Last Inspected On: 02/26/2024
Operating Permit Renewal Date: 07/11/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Agland Coop Wolf Point

Operator Contact: Kory Hentges4062284641

Owner/Operator: Agland Coop Wolf Point

- Allen Richard, UST Class B Global Operator
- Allen Richard, UST Class B Operator
- Kory Hentges, UST Class A Operator
- Kory Hentges, UST Class B Operator
- Michael Pallvoda, UST Class B Operator
- Steven Long, UST Class B Operator

Tank Code	05	Tank Age	33	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1574	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	33	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1575	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Gasoline	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	33	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1576	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	33	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1577	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	33	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1578	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	2000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	12	Tank Installed Date	10/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5391	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/17/2023	Line Tightness Test Date	10/26/2012	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: CIRCLE K STORE 2746281
108 1st Ave N
Glasgow, MT 59230 Valley

System Facility ID:53-09712

Facility Code: 29324
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 10/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Rocky Mountain Oil LLC	6027288000
Operator Contact:	Chuck Nyberg;Dean Townsend	9528308722

Owner/Operator: Rocky Mountain Oil LLC

Brad Lee, UST Class B Global Operator
Chuck Nyberg, UST Class A Operator
Dean Townsend, UST Class A Operator
Dylan Imbrescia, UST Class B Operator
Greg Brewer, UST Class B Global Operator
Jon Garcia, UST Class B Operator
Travis Struckman, UST Class B Global Operator

Tank Code	04	Tank Age	35	Tank Installed Date	08/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4431	Spill Test Date	04/19/2022	Piping Installed Date	08/12/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/10/2020	Tank/Piping CP Test Date	03/10/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	38	Tank Installed Date	03/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4432	Spill Test Date	04/10/2023	Piping Installed Date	08/12/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLLD Test Date	04/10/2023	Tank/Piping CP Test Date	04/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/10/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	36	Tank Installed Date	04/15/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4433	Spill Test Date		Piping Installed Date	08/12/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/10/2020	Tank/Piping CP Test Date	03/10/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES MIDTOWN
204 1st Ave N
Glasgow, MT 59230-1820 Valley

System Facility ID:53-05709

Facility Code: 29276
Last Inspected On: 10/25/2022
Operating Permit Renewal Date: 04/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc4066542331

Operator Contact: Brandon Hoerster;Joe Brookie;Ezzies Wholesale Inc4062282713;4066542331;4066542331

Owner/Operator: Ezzies Wholesale Inc

Brandon Hoerster, UST Class A Operator
Brandon Hoerster, UST Class B Operator
Joe Brookie, UST Class A Operator

Tank Code	05	Tank Age	24	Tank Installed Date	06/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4201	Spill Test Date	10/25/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/13/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	24	Tank Installed Date	06/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4202	Spill Test Date	10/25/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/13/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES WHOLESALE GLASGOW
1330 US Hwy 2 W
Glasgow, MT 59230 Valley

System Facility ID:53-10475

Facility Code: 29361
Last Inspected On: 12/14/2023
Operating Permit Renewal Date: 03/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc4066542331

Operator Contact: Brandon Hoerster;Joe Brookie;Ezzies Wholesale Inc4062282713;4066542331;4066542331

Owner/Operator: Ezzies Wholesale Inc

Brandon Hoerster, UST Class A Operator
Brandon Hoerster, UST Class B Global Operator
Brandon Hoerster, UST Class B Operator
Jarid Jensen, UST Class B Operator
Joe Brookie, UST Class A Operator

Tank Code	07	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4758	Spill Test Date	11/20/2023	Piping Installed Date	08/15/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4759	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4760	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4761	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	4762	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	4763	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4764	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/20/2023	Line Tightness Test Date	12/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	22	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4765	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: FRANCES MAHON DEACONESS HOSPITAL

621 3rd St S

Glasgow, MT 59230-2604 Valley

Facility Code: 29273

Last Inspected On: 05/17/2023

Operating Permit Renewal Date: 11/06/2026

System Facility ID:53-05192

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Frances Mahon Deaconess Hospital4062284351

Operator Contact: David Nixdorf

Owner/Operator: Frances Mahon Deaconess Hospital

David Nixdorf, UST Class A Operator

Jeff Damboise, UST Class B Operator

Paul Sallee, UST Class B Operator

Tank Code	03	Tank Age	29	Tank Installed Date	10/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1118	Spill Test Date	05/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/22/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/17/2023	Line Tightness Test Date	07/22/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/29/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	29	Tank Installed Date	10/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1119	Spill Test Date	05/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/22/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2000	ATG Test Date	05/17/2023	Line Tightness Test Date	05/17/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/29/2023			ATG Type	Veeder Root/TLS-300				
--	--	--------------------	------------	--	--	----------	---------------------	--	--	--	--

Facility Summary in Valley County in the City of Glasgow

Location: GLASGOW INTERNATIONAL AIRPORT
89 Airport Rd
Glasgow, MT 59230-2843 Valley

System Facility ID:53-03271

Facility Code: 29250
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 07/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dave Reinhardt;Valley County Airport Commission4062262719

Operator Contact: Lucas Locke;Manfreda Donovan;Robert Lipscomb4062302257;4062637010;4062932067

Owner/Operator: Dave Reinhardt
Owner/Operator: Valley County Airport Commission
Lucas Locke, UST Class A Operator
Lucas Locke, UST Class B Operator
Manfreda Donovan, UST Class A Operator
Manfreda Donovan, UST Class B Operator
Robert Lipscomb, UST Class A Operator
Robert Lipscomb, UST Class B Operator

Tank Code	01	Tank Age	44	Tank Installed Date	01/01/1980	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2726	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	07/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	08/09/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	43	Tank Installed Date	04/07/1981	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	2727	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current

Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	07/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	08/09/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Valley County in the City of Glasgow

Location: LAKERIDGE LODGING AND BAIT SHOP
5990 MT Hwy 24 S
Glasgow, MT 59230-8822 Valley

System Facility ID:53-08383

Facility Code: 29312
Last Inspected On: 12/06/2021
Operating Permit Renewal Date: 05/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Carrie Mindt;Team Lakeridge LLC	4065263597
Operator Contact:	Carrie Mindt;Gene Moore	4065263597

Owner/Operator: Carrie Mindt
Owner/Operator: Team Lakeridge LLC

Carrie Mindt, UST Class A Operator
Carrie Mindt, UST Class B Global Operator
Carrie Mindt, UST Class B Operator
Gene Moore, UST Class A Operator
Gene Moore, UST Class B Operator

Tank Code	05	Tank Age	27	Tank Installed Date	05/15/1997	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1509	Spill Test Date	12/06/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/21/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/06/2021			ATG Type					
Tank Code	06	Tank Age	27	Tank Installed Date	05/15/1997	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1510	Spill Test Date	12/06/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/21/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/06/2021			ATG Type					

Facility Summary in Valley County in the City of Glasgow

Location: TRAILSIDE GENERAL STORE GLASGOW
54271 Hwy 2 E
Glasgow, MT 59230 Valley

System Facility ID:53-07787

Facility Code: 29299
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 07/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wayne Waarvik4062289528

Operator Contact: Wayne Waarvik4062289528

Owner/Operator: Wayne Waarvik

Wayne Waarvik, UST Class A Operator
Wayne Waarvik, UST Class B Global Operator

Tank Code	03	Tank Age	33	Tank Installed Date	09/09/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	3873	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/25/2023	Primary Tank Leak Detection	Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	33	Tank Installed Date	09/09/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	3874	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/25/2023	Primary Tank Leak Detection	Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Valley County in the City of Hinsdale

Location: RAIDERS QUICK STOP
842 1st Ave N
Hinsdale, MT 59241 Valley

System Facility ID:60-15298

Facility Code: 31002
Last Inspected On: 04/10/2023
Operating Permit Renewal Date: 10/11/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc				4066542331			
Operator Contact: Joe Brookie;Ezzies Wholesale Inc				4066542331;4066542331			

Owner/Operator: Ezzies Wholesale Inc

Joe Brookie, UST Class A Operator
Nena Malmend, UST Class B Operator

Tank Code	01	Tank Age	7	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5716	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	7	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5717	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	5000	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				
Tank Code	03	Tank Age	7	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	5718	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	2000	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				
Tank Code	04	Tank Age	7	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5727	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				

Facility Summary in Valley County in the City of Nashua

Location: AGLAND COOP NASHUA
810 Front St
Nashua, MT 59248 Valley

System Facility ID:53-10461

Facility Code: 29360
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 08/07/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Agland Coop Wolf Point

Operator Contact: James Merideth

Owner/Operator: Agland Coop Wolf Point

- Allen Richard, UST Class B Global Operator
- Allen Richard, UST Class B Operator
- James Merideth, UST Class A Operator
- James Merideth, UST Class B Global Operator
- Michael Pallvoda, UST Class B Operator
- Steven Long, UST Class B Operator

Tank Code	05	Tank Age	34	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	937	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	34	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	938	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	07	Tank Age	34	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	939	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	08	Tank Age	34	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	940	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Valley County in the City of Opheim

Location: PRO COOP OPHEIM
45 S Main
Opheim, MT 59250 Valley

System Facility ID:53-07814

Facility Code: 29300
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 02/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Pro Coop Opheim

Operator Contact: Jason Nasby;Myron Redfield;Timothy Stenglein 4067623231

Owner/Operator: Pro Coop Opheim

Jason Nasby, UST Class A Operator
Jason Nasby, UST Class B Operator
Myron Redfield, UST Class A Operator
Myron Redfield, UST Class B Operator
Timothy Stenglein, UST Class A Operator
Timothy Stenglein, UST Class B Operator

Tank Code	04	Tank Age	31	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1820	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2300	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					
Tank Code	05	Tank Age	31	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1821	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasohol/Ethanol	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3700	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					

Tank Code	06	Tank Age	31	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1822	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2300	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					
Tank Code	07	Tank Age	31	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1823	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3700	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					

Facility Summary in Valley County in the City of Saint Marie

Location: MT AVIATION RESEARCH BLDG CO BLDG 649A
Address Unavailable (DEQ_GEO_LOC_INFO : 44095)
Saint Marie, MT 59231 Valley

System Facility ID:53-12774

Facility Code: 29550
Last Inspected On: 05/11/2021
Operating Permit Renewal Date: 10/19/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Aviation Research Co4065243777

Operator Contact: Brad Juntunen;Brian Mix;Darcel Wesen;Kenny Bryan;Kevin Wersal;Lynn Blatter;Michael Myrick;Preston Murch4062141991;4062289584;4062631362;4062634591;4062636931

Owner/Operator: Montana Aviation Research Co

- Brad Juntunen, UST Class A Operator
- Brad Juntunen, UST Class B Operator
- Brian Mix, UST Class A Operator
- Brian Mix, UST Class B Operator
- Darcel Wesen, UST Class A Operator
- Darcel Wesen, UST Class B Operator
- Kenny Bryan, UST Class A Operator
- Kenny Bryan, UST Class B Global Operator
- Kenny Bryan, UST Class B Operator
- Kevin Wersal, UST Class A Operator
- Kevin Wersal, UST Class B Operator
- Lynn Blatter, UST Class A Operator
- Lynn Blatter, UST Class B Global Operator
- Michael Myrick, UST Class A Operator
- Michael Myrick, UST Class B Operator
- Preston Murch, UST Class A Operator
- Preston Murch, UST Class B Operator

Tank Code	S4	Tank Age	30	Tank Installed Date	01/01/1994	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2975	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	50000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S5	Tank Age	30	Tank Installed Date	01/01/1994	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2976	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	50000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				