

Facility Summary in Valley County in the City of Fort Peck

Location: ROCK CREEK MARINA
652 S Rock Creek Rd
Fort Peck, MT 59223-7001 Valley

System Facility ID:29-11049

Facility Code: 24936
Last Inspected On: 05/22/2025
Operating Permit Renewal Date: 10/08/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rock Creek Marina LLC

(406) 245-2560

rockcreekmarina2023@gmail.com

Operator Contact: David Frank

rockcreekmarina2023@gmail.com

Owner/Operator: Rock Creek Marina LLC

(406) 245-2560

rockcreekmarina2023@gmail.com

David Frank, UST Class A Operator

rockcreekmarina2023@gmail.com

David Frank, UST Class B Operator

rockcreekmarina2023@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 02 | Tank Age | 35 | Tank Installed Date | 05/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1846 | Spill Test Date | 05/24/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/24/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 05/22/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/24/2024 | | | ATG Type | Gilbarco/TLS-300 | | | | |

Facility Summary in Valley County in the City of Fort Peck

Location: US ARMY CORPS OF ENGINEERS FORT PECK
Judith Rd
Fort Peck, MT 59223 Valley

System Facility ID: 53-04612

Facility Code: 29268
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 08/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: US Army Corps of Engineers Fort Peck

(406) 526-3411

Operator Contact: Mary Nyquist; Thomas Grant

(406) 526-3411; (406) 526-3431

mary.b.nyquist@usace.army.mil; thomas.d.grant@usace.army.mil

Owner/Operator: US Army Corps of Engineers Fort Peck

(406) 526-3411

Mary Nyquist, UST Class A Operator

mary.b.nyquist@usace.army.mil

Mary Nyquist, UST Class B Operator

mary.b.nyquist@usace.army.mil

Seth Reedy, UST Class B Operator

seth.a.reedy@usace.army.mil

Thomas Grant, UST Class A Operator

thomas.d.grant@usace.army.mil

Thomas Grant, UST Class B Operator

thomas.d.grant@usace.army.mil

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 06/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2154 | Spill Test Date | 04/03/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/03/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer; Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/03/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 9000 | ATG Test Date | 04/03/2024 | Line Tightness Test Date | 04/03/2024 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 36 | Tank Installed Date | 06/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2155 | Spill Test Date | 04/03/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/03/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer; Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/03/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Capacity | 2500 | ATG Test Date | 04/03/2024 | Line Tightness Test Date | 04/03/2024 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 10 | Tank Age | 36 | Tank Installed Date | 06/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 2156 | Spill Test Date | 04/03/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/03/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer;Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/03/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 2500 | ATG Test Date | 04/03/2024 | Line Tightness Test Date | 04/03/2024 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Valley County in the City of Frazer

Location: TRIBAL EXPRESS II
207 Main Ave
Frazer, MT 59225 Valley

System Facility ID: 56-13890

Facility Code: 30564
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 03/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fort Peck Assiniboine and Sioux Tribes

Operator Contact: Lynette Adams

(406) 650-7774

tribalexpress@yahoo.com

Owner/Operator: Fort Peck Assiniboine and Sioux Tribes

Lynette Adams, UST Class A Operator

tribalexpress@yahoo.com

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------|---------------------------------|------------------|-----------------------|---------------|
| Tank Code | 01 | Tank Age | 29 | Tank Installed Date | 12/01/1997 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6214 | Spill Test Date | 03/12/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | Deferred | Vapor Recovery | No |
| Capacity | 1000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/12/2025 | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 29 | Tank Installed Date | 12/01/1997 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6215 | Spill Test Date | 03/12/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | Deferred | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/12/2025 | | | ATG Type | | | | | |

Facility Summary in Valley County in the City of Glasgow

Location: AGLAND COOP GLASGOW
54197 US Hwy 2
Glasgow, MT 59230-1803 Valley

System Facility ID: 53-03160

Facility Code: 29245
Last Inspected On: 02/26/2024
Operating Permit Renewal Date: 07/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|---|----------------|-------------------------------|
| Owner Operator Contact: Agland Coop Wolf Point | (406) 653-1221 | dave.williams@agland-coop.com |
|---|----------------|-------------------------------|

| | | |
|---------------------------------------|----------------|------------------------------|
| Operator Contact: Kory Hentges | (406) 228-4641 | kory.hentges@agland-coop.com |
|---------------------------------------|----------------|------------------------------|

| | | |
|---|----------------|-------------------------------|
| Owner/Operator: Agland Coop Wolf Point | (406) 653-1221 | dave.williams@agland-coop.com |
|---|----------------|-------------------------------|

Allen Richard, UST Class B Global Operator
Allen Richard, UST Class B Operator
Kory Hentges, UST Class A Operator
Kory Hentges, UST Class B Operator
Michael Pallvoda, UST Class B Operator
Steven Long, UST Class B Operator

allen.richard@agland-coop.com
allen.richard@agland-coop.com
kory.hentges@agland-coop.com
kory.hentges@agland-coop.com
fuoilwp@nemont.net

| Tank Code | 05 | Tank Age | 35 | Tank Installed Date | 05/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|--------------------------------|
| Tag Number | 1574 | Spill Test Date | 02/26/2024 | Piping Installed Date | 08/31/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 02/26/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 05/17/2023 | Tank/Piping CP Test Date | 02/26/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 02/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 35 | Tank Installed Date | 05/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1575 | Spill Test Date | 02/26/2024 | Piping Installed Date | 08/31/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|--------------------------------|
| Product | Gasoline | PLL D Test Date | 05/17/2023 | Tank/Piping CP Test Date | 02/26/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overflow Test Date | 02/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 35 | Tank Installed Date | 05/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overflow Types | Flapper Valve;High Level Alarm |
| Tag Number | 1576 | Spill Test Date | 02/26/2024 | Piping Installed Date | 08/31/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLL D Test Date | 05/17/2023 | Tank/Piping CP Test Date | 02/26/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overflow Test Date | 02/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 35 | Tank Installed Date | 05/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overflow Types | Flapper Valve;High Level Alarm |
| Tag Number | 1577 | Spill Test Date | 02/26/2024 | Piping Installed Date | 08/31/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLL D Test Date | 05/17/2023 | Tank/Piping CP Test Date | 02/26/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overflow Test Date | 02/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 35 | Tank Installed Date | 05/01/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overflow Types | Flapper Valve;High Level Alarm |
| Tag Number | 1578 | Spill Test Date | 02/26/2024 | Piping Installed Date | 08/31/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLL D Test Date | 05/17/2023 | Tank/Piping CP Test Date | 02/26/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|--------------------------------|
| Capacity | 2000 | ATG Test Date | 05/17/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 02/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 10 | Tank Age | 14 | Tank Installed Date | 10/01/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5391 | Spill Test Date | 02/26/2024 | Piping Installed Date | 08/31/2012 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/17/2023 | Tank/Piping CP Test Date | 02/26/2024 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 05/17/2023 | Line Tightness Test Date | 10/26/2012 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 02/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Valley County in the City of Glasgow

Location: CIRCLE K STORE 2746281
108 1st Ave N
Glasgow, MT 59230 Valley

System Facility ID:53-09712

Facility Code: 29324
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 10/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|---|----------------|--------------------|
| Owner Operator Contact: Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
|---|----------------|--------------------|

| | | |
|---|----------------|------------------------------------|
| Operator Contact: Chuck Nyberg;Dean Townsend | (952) 830-8722 | dean.townsend@holidaycompanies.com |
|---|----------------|------------------------------------|

| | | |
|---|----------------|--------------------|
| Owner/Operator: Rocky Mountain Oil LLC | (602) 728-8000 | NT-ESS@Circlek.com |
|---|----------------|--------------------|

Brad Lee, UST Class B Global Operator
Chuck Nyberg, UST Class A Operator
Dean Townsend, UST Class A Operator
Dylan Imbrescia, UST Class B Operator
Greg Brewer, UST Class B Global Operator
Jon Garcia, UST Class B Operator
Travis Struckman, UST Class B Global Operator

brad.lee@holidaycompanies.com
dean.townsend@holidaycompanies.com
dimbrescia2715@gmail.com
greg.brewer@holidaycompanies.com
jon.p.garcia89@gmail.com
travis.struckman@holidaycompanies.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|--------------------------------|
| Tank Code | 04 | Tank Age | 37 | Tank Installed Date | 08/01/1989 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4431 | Spill Test Date | 04/19/2022 | Piping Installed Date | 08/12/2008 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 03/10/2020 | Tank/Piping CP Test Date | 03/10/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 01 | Tank Age | 40 | Tank Installed Date | 03/01/1986 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 4432 | Spill Test Date | 04/10/2023 | Piping Installed Date | 08/12/2008 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-------------------|
| Product | Gasoline | PLLD Test Date | 04/10/2023 | Tank/Piping CP Test Date | 04/10/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/10/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/10/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 38 | Tank Installed Date | 04/15/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4433 | Spill Test Date | | Piping Installed Date | 08/12/2008 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 03/10/2020 | Tank/Piping CP Test Date | 03/10/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/20/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES MIDTOWN
204 1st Ave N
Glasgow, MT 59230-1820 Valley

System Facility ID: 53-05709

Facility Code: 29276
Last Inspected On: 12/16/2025
Operating Permit Renewal Date: 04/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc (406) 228-2713;(406) 654-2331 brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Brandon Hoerster, UST Class A Operator
Brandon Hoerster, UST Class B Operator
Conor Moran, UST Class A Operator

| Tank Code | 05 | Tank Age | 26 | Tank Installed Date | 06/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
|-------------|------------------|--------------------|------------|--------------------------|---|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tag Number | 4201 | Spill Test Date | 10/25/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 07/13/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/13/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 06 | Tank Age | 26 | Tank Installed Date | 06/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4202 | Spill Test Date | 10/25/2022 | Piping Installed Date | <th>Tank Construction</th> <td></td> <th>Piping Construction</th> <td>Double Walled</td> <td>AST</td> <td>No</td> | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | <th>Catastrophic L.D Type 3.0</th> <td>Electronic Line Leak Detector</td> <th>Piping Type</th> <td>Pressurized</td> <th>CP Met Types</th> <td>Non-corrodible</td> | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | <th>Primary Tank Leak Detection</th> <td>Automatic Tank Gauging 0.2</td> <th>Primary Pipe Detection</th> <td>ELLD 0.2</td> <th>Vapor Recovery</th> <td>No</td> | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/13/2022 | Line Tightness Test Date | <th>Secondary Tank Leak Detection</th> <td></td> <th>Secondary Pipe Detection</th> <td>Continuous Interstitial Monitoring</td> <th>Energy Act</th> <td>No</td> | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/13/2022 | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | | |

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES WHOLESALE GLASGOW
1330 US Hwy 2 W
Glasgow, MT 59230 Valley

System Facility ID: 53-10475

Facility Code: 29361
Last Inspected On: 12/14/2023
Operating Permit Renewal Date: 03/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc (406) 228-2713;(406) 654-2331 brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Brandon Hoerster, UST Class A Operator
Brandon Hoerster, UST Class B Global Operator
Brandon Hoerster, UST Class B Operator
Conor Moran, UST Class A Operator
Jarid Jensen, UST Class B Operator

brandon@ezzies.com
brandon@ezzies.com
brandon@ezzies.com
bill@ezzies.com
jpjensen@hotmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 07 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4758 | Spill Test Date | 11/20/2023 | Piping Installed Date | 08/15/2012 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/20/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 11/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4759 | Spill Test Date | 11/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/20/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 11/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4760 | Spill Test Date | 11/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/20/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 11/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 10 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4761 | Spill Test Date | 11/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/20/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 11/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 11 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | No Piping | Overfill Types | High Level Alarm |
| Tag Number | 4762 | Spill Test Date | 11/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 02/27/2025 | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/20/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 11/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 12 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tag Number | 4763 | Spill Test Date | 11/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 02/27/2025 | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/20/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 11/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 13 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4764 | Spill Test Date | 11/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 12/05/2023 | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 11/05/2020 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 12/05/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 14 | Tank Age | 24 | Tank Installed Date | 11/21/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4765 | Spill Test Date | 11/20/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/20/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 11/20/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 11/20/2023 | Line Tightness Test Date | 11/20/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/20/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Valley County in the City of Glasgow

Location: FRANCES MAHON DEACONESS HOSPITAL
621 3rd St S
Glasgow, MT 59230-2604 Valley

System Facility ID: 53-05192

Facility Code: 29273
Last Inspected On: 05/17/2023
Operating Permit Renewal Date: 11/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Frances Mahon Deaconess Hospital (406) 228-4351

Operator Contact: David Nixdorf

Owner/Operator: Frances Mahon Deaconess Hospital (406) 228-4351

David Nixdorf, UST Class A Operator

Jeff Damboise, UST Class B Operator

Paul Sallee, UST Class B Operator

jeff.damboise@fmdh.org

dolby2070@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 03 | Tank Age | 31 | Tank Installed Date | 10/01/1995 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1118 | Spill Test Date | 05/17/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/22/2013 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 07/10/2024 | Line Tightness Test Date | 07/22/2020 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/10/2024 | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 04 | Tank Age | 31 | Tank Installed Date | 10/01/1995 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 1119 | Spill Test Date | 05/17/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/22/2013 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 07/10/2024 | Line Tightness Test Date | 05/17/2023 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | |
|--|---------------------------|------------|--|-----------------|---------------------|--|--|
| | Overfill Test Date | 07/10/2024 | | ATG Type | Veeder Root/TLS-300 | | |
|--|---------------------------|------------|--|-----------------|---------------------|--|--|

Facility Summary in Valley County in the City of Glasgow

Location: GLASGOW INTERNATIONAL AIRPORT
89 Airport Rd
Glasgow, MT 59230-2843 Valley

System Facility ID: 53-03271

Facility Code: 29250
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 04/04/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dave Reinhardt; Valley County Airport Commission

(406) 226-2719

airport@valleycountymt.gov

Operator Contact: Lucas Locke; Manfreda Donovan; Robert Lipscomb

(406) 230-2257; (406) 263-7010; (406) 293-2067

airport@valleycountymt.gov; irpilot@nemont.net; sevencarpileup1970@gmail.com

Owner/Operator: Dave Reinhardt

Owner/Operator: Valley County Airport Commission

Lucas Locke, UST Class A Operator

airport@valleycountymt.gov

Lucas Locke, UST Class B Operator

airport@valleycountymt.gov

Manfreda Donovan, UST Class A Operator

sevencarpileup1970@gmail.com

Manfreda Donovan, UST Class B Operator

sevencarpileup1970@gmail.com

Robert Lipscomb, UST Class A Operator

irpilot@nemont.net

Robert Lipscomb, UST Class B Operator

irpilot@nemont.net

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|----|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|-------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 46 | Tank Installed Date | 01/01/1980 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 2726 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Aviation Gas | PLLD Test Date | | Tank/Piping CP Test Date | 04/04/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 08/09/2006 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 45 | Tank Installed Date | 04/07/1981 | Tank Material | Cathodically Protected Steel | Piping Material | No Piping | Overfill Types | High Level Alarm |
| Tag Number | 2727 | Spill Test Date | | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Not Listed | CP Met Types | Impressed Current |

| | | | | | | | | | | |
|----------|-------------------------------|--------------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----|
| Product | Jet Fuel (Jet-A, Jet-A1, JP5) | PLL D Test Date | Tank/Piping CP Test Date | 04/04/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | Line Tightness Test Date | 08/09/2006 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | ATG Type | | | | | |

Facility Summary in Valley County in the City of Glasgow

Location: LAKERIDGE LODGING AND BAIT SHOP
5990 MT Hwy 24 S
Glasgow, MT 59230-8822 Valley

System Facility ID: 53-08383

Facility Code: 29312
Last Inspected On: 11/26/2024
Operating Permit Renewal Date: 05/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Carrie Mindt; Team Lakeridge LLC (406) 526-3597 lakeridgefortpeck@gmail.com;lakeridgefortpek@gmail.com

Operator Contact: Carrie Mindt (406) 526-3597 lakeridgefortpeck@gmail.com

Owner/Operator: Carrie Mindt (406) 526-3597 lakeridgefortpeck@gmail.com

Owner/Operator: Team Lakeridge LLC (406) 526-3597 lakeridgefortpeck@gmail.com

Carrie Mindt, UST Class A Operator lakeridgefortpeck@gmail.com

Carrie Mindt, UST Class B Global Operator lakeridgefortpeck@gmail.com

Carrie Mindt, UST Class B Operator lakeridgefortpeck@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Code | 05 | Tank Age | 29 | Tank Installed Date | 05/15/1997 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1509 | Spill Test Date | 04/16/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 01/21/2013 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/16/2025 | | | ATG Type | | | | | |
| Tank Code | 06 | Tank Age | 29 | Tank Installed Date | 05/15/1997 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1510 | Spill Test Date | 11/25/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 01/21/2013 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/25/2024 | | | ATG Type | | | | | |

Facility Summary in Valley County in the City of Hinsdale

Location: RAIDERS QUICK STOP
842 1st Ave N
Hinsdale, MT 59241 Valley

System Facility ID: 60-15298

Facility Code: 31002
Last Inspected On: 04/10/2023
Operating Permit Renewal Date: 10/11/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc (406) 228-2713;(406) 654-2331 brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Brandon Hoerster, UST Class A Operator
Conor Moran, UST Class A Operator
Nena Malmend, UST Class B Operator

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | 01 | Tank Age | 9 | Tank Installed Date | 04/10/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5716 | Spill Test Date | 07/22/2020 | Piping Installed Date | 04/12/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | 07/05/2017 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 07/22/2020 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 02 | Tank Age | 9 | Tank Installed Date | 04/10/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5717 | Spill Test Date | 07/22/2020 | Piping Installed Date | 04/12/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | 07/05/2017 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 07/22/2020 | | | ATG Type | Incon/TS-550 EVO | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 03 | Tank Age | 9 | Tank Installed Date | 04/10/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5718 | Spill Test Date | 07/22/2020 | Piping Installed Date | 04/12/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | 07/05/2017 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 07/22/2020 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 04 | Tank Age | 9 | Tank Installed Date | 04/10/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5727 | Spill Test Date | 07/22/2020 | Piping Installed Date | 04/12/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2500 | ATG Test Date | | Line Tightness Test Date | 07/05/2017 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 07/22/2020 | | | ATG Type | Incon/TS-550 EVO | | | | |

Facility Summary in Valley County in the City of Opheim

Location: PRO COOP OPHEIM
45 S Main
Opheim, MT 59250 Valley

System Facility ID: 53-07814

Facility Code: 29300
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 02/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Pro Coop Opheim

Operator Contact: Jason Nasby; Myron Redfield; Timothy Stenglein

(406) 762-3231

jnasby@procoopag.com; mtstenglein@yahoo.com

Owner/Operator: Pro Coop Opheim

Jason Nasby, UST Class A Operator

jnasby@procoopag.com

Jason Nasby, UST Class B Operator

jnasby@procoopag.com

Myron Redfield, UST Class A Operator

mtstenglein@yahoo.com

Myron Redfield, UST Class B Operator

mtstenglein@yahoo.com

Timothy Stenglein, UST Class A Operator

mtstenglein@yahoo.com

Timothy Stenglein, UST Class B Operator

| Tank Code | 04 | Tank Age | 33 | Tank Installed Date | 08/01/1993 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tag Number | 1820 | Spill Test Date | 11/09/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/19/2020 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2300 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/09/2023 | | | ATG Type | | | | | |
| Tank Code | 05 | Tank Age | 33 | Tank Installed Date | 08/01/1993 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1821 | Spill Test Date | 11/09/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasohol/Ethanol | PLLD Test Date | | Tank/Piping CP Test Date | 11/19/2020 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 3700 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/09/2023 | | | ATG Type | | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tank Code | 06 | Tank Age | 33 | Tank Installed Date | 08/01/1993 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1822 | Spill Test Date | 11/09/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/19/2020 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2300 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/09/2023 | | | ATG Type | | | | | |
| Tank Code | 07 | Tank Age | 33 | Tank Installed Date | 08/01/1993 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1823 | Spill Test Date | 11/09/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/19/2020 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 3700 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/09/2023 | | | ATG Type | | | | | |

Facility Summary in Valley County in the City of Saint Marie

Location: MT AVIATION RESEARCH BLDG CO BLDG 649A
 Address Unavailable (DEQ_GEO_LOC_INFO : 44095)
 Saint Marie, MT 59231 Valley

System Facility ID: 53-12774

Facility Code: 29550
Last Inspected On: 07/19/2024
Operating Permit Renewal Date: 10/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Aviation Research Co

(406) 524-3777

Operator Contact: Brad Juntunen; Brian Mix; Darcel Wesen; Kenny Bryan; Kevin Wersal; Lynn Blatter; Michael Myrick; Preston Murch (406) 214-1991; (406) 228-9584; (406) 263-1362; (406) 263-4591; (406) 263-6931 darcel.d.wesen@boeing.com; marco787@nemont.net; marcomaintenanc916@gmail.com; mm2000chevy@yahoo.com; shirleyblatter@yahoo.com; wersal5@hotmail.com

Owner/Operator: Montana Aviation Research Co

(406) 524-3777

| | |
|---|------------------------------|
| Brad Juntunen, UST Class A Operator | marco787@nemont.net |
| Brad Juntunen, UST Class B Operator | marco787@nemont.net |
| Brian Mix, UST Class A Operator | marco787@nemont.net |
| Brian Mix, UST Class B Operator | marco787@nemont.net |
| Darcel Wesen, UST Class A Operator | darcel.d.wesen@boeing.com |
| Darcel Wesen, UST Class B Operator | darcel.d.wesen@boeing.com |
| Kenny Bryan, UST Class A Operator | marcomaintenanc916@gmail.com |
| Kenny Bryan, UST Class B Global Operator | marcomaintenanc916@gmail.com |
| Kenny Bryan, UST Class B Operator | marcomaintenanc916@gmail.com |
| Kevin Wersal, UST Class A Operator | wersal5@hotmail.com |
| Kevin Wersal, UST Class B Operator | wersal5@hotmail.com |
| Lynn Blatter, UST Class A Operator | shirleyblatter@yahoo.com |
| Lynn Blatter, UST Class B Global Operator | shirleyblatter@yahoo.com |
| Michael Myrick, UST Class A Operator | mm2000chevy@yahoo.com |
| Michael Myrick, UST Class B Operator | mm2000chevy@yahoo.com |
| Preston Murch, UST Class A Operator | marco787@nemont.net |
| Preston Murch, UST Class B Operator | marco787@nemont.net |

| | | | | | | | | | | |
|--------------------|-------------------------------|------------------------|----|---------------------------------|------------|------------------------------------|------------------------------------|-------------------------------|------------------------------------|-----------------------|
| Tank Code | S4 | Tank Age | 32 | Tank Installed Date | 01/01/1994 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 2975 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types |
| Product | Jet Fuel (Jet-A, Jet-A1, JP5) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |

| | | | | | | | | | | | |
|-------------|-------------------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|-----|
| Capacity | 50000 | ATG Test Date | 07/19/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | S5 | Tank Age | 32 | Tank Installed Date | 01/01/1994 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | |
| Tag Number | 2976 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | |
| Product | Jet Fuel (Jet-A, Jet-A1, JP5) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 50000 | ATG Test Date | 07/19/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |